Open Head Deluge Systems. FAC: 8999

CATCODE: 880212
OPR: AFCEC/COS
OCR: N/A

1.1. **Description.** This system, presently installed in many older, pre-1978, large hangar facilities, is not authorized for use in new construction except as permitted in UFC 3-600-01. The sprinklers on this type of system are all open.

1.2. **Requirements Determination.** See UFC 3-600-01, *Fire Protection Engineering for Facilities*.

1.3. **Scope Determination.** See UFC 3-600-01.

1.4. **Dimensions.** See UFC 3-600-01.

1.5. **Design Considerations.** See UFC 3-600-01.