



1. EXTERIOR SHEATHING
2. AIR AND VAPOR BARRIER MEMBRANE, WRAP INTO OPENING
3. MASTIC AT LEADING EDGE OF OVERLAP OF MEMBRANE OR ELASTOMERIC FLASHING
4. RIGID INSULATION (WITHOUT VOIDS)
8. SELF-ADHERING MEMBRANE FLASHING, 3" MINIMUM OVERLAP AT MEMBRANE JOINTS (VERIFY COMPATIBILITY WITH AIR & VAPOR BARRIERS)
10. LINE OF METAL FLASHING END DAM (DASHED)
13. SEALANT AND BACKER ROD
14. THERMAL BREAK
15. HEEL BEAD OF SEALANT TO PROVIDE AIR TIGHTNESS (SNAP-IN GLAZING BEAD LEAKS AIR) CONTINUOUS AT ALL FOUR SIDES OF GLASS
16. HIGH PERFORMANCE INSULATING GLASS UNIT (TRIPLE GLAZED INSULATED UNIT WILL IMPROVE ENERGY PERFORMANCE)
17. SPRAY POLYURETHANE FOAM TO IMPROVE THERMAL PERFORMANCE
18. MINERAL WOOL
19. SEALANT AND BACKER ROD
21. WINDOW FASTENER (SIZE AND SPACING AS REQUIRED)
22. BLOCKING AS REQUIRED
25. SPRAY POLYURETHANE FOAM (PREFERRED), OR RIGID INSULATION
26. STOOL
27. METAL SILL PAN FLASHING WITH END CAPS
28. HOODED WEEP FOR GLAZING CAVITY
29. CONTINUOUS BUTYL TAPE
32. METAL PANEL CLADDING SYSTEM
33. INSULATION RETAINER
34. ALUMINUM WINDOW
35. STUD CAVITY (NO INSULATION)

G WINDOW SILL WITH FIN AT METAL PANEL
 GENERIC CONDITION
 (NOTE: REQUIRES OPENING WITH NO DIFFERENTIAL MOVEMENT AROUND OPENING)