

\*\*\*\*\*  
USACE / NAVFAC / AFCEC UFGS-10 21 23.16 (August 2024)

Preparing Activity: NAVFAC

-----  
Superseding  
UFGS-10 21 23.16 (April 2006)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated January 2025

\*\*\*\*\*

SECTION TABLE OF CONTENTS

DIVISION 10 - SPECIALTIES

SECTION 10 21 23.16

CUBICLE TRACK AND HARDWARE

08/24

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 DRAWING REQUIREMENTS
- 1.4 DELIVERY AND STORAGE
- 1.5 QUALITY CONTROL

PART 2 PRODUCTS

- 2.1 CUBICLE TRACK SYSTEM
  - 2.1.1 Cubicle Track
  - 2.1.2 Shower Curtain Track
  - 2.1.3 Intravenous Track
  - 2.1.4 Extruded Aluminum Tracks
- 2.2 CARRIER UNIT
- 2.3 END STOP AND PULL-OUT
- 2.4 SUPPORT DEVICES
- 2.5 PARTS LIST
- 2.6 FASTENERS
- 2.7 FINISH

PART 3 EXECUTION

- 3.1 INSTALLATION
  - 3.1.1 Installation Details

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEC UFGS-10 21 23.16 (August 2024)

Preparing Activity: NAVFAC

-----  
Superseding  
UFGS-10 21 23.16 (April 2006)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated January 2025

\*\*\*\*\*

SECTION 10 21 23.16

CUBICLE TRACK AND HARDWARE  
08/24

\*\*\*\*\*

NOTE: This guide specification covers the requirements for the provision and installation of hospital cubicle tracks.

Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

\*\*\*\*\*

\*\*\*\*\*

NOTE: Cubicle tracks may be mounted directly to ceiling or suspended from hangers. Hanger option should be chosen when ceiling heights are over **2700 mm 9 feet** to reduce curtain length. Use I-beam section where accumulation of dirt on track (which would impede carrier movement) would be a problem.

On the drawings, show:

1. Ceiling height
2. Anchorage system
3. Anchorage spacing and locations
4. If both heavy and light duty tracks are used,

indicate locations of each.

\*\*\*\*\*

PART 1 GENERAL

1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ALUMINUM ASSOCIATION (AA)

AA DAF45 (2003; Reaffirmed 2009) Designation System for Aluminum Finishes

ASTM INTERNATIONAL (ASTM)

ASTM B221 (2021) Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes

ASTM B221M (2021) Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric)

ASTM B456 (2017; R 2022) Standard Specification for Electrodeposited Coatings of Copper Plus Nickel Plus Chromium and Nickel Plus Chromium

1.2 SUBMITTALS

\*\*\*\*\*

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals

required for the project. The Guide Specification technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G". Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item if the submittal is sufficiently important or complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy and Air Force projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

\*\*\*\*\*

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are for Contractor Quality Control approval. Submittals not having a "G" or "S" classification are for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Cubicle Track Layout

SD-03 Product Data

Product Data; G

SD-04 Samples

Product Samples; G

SD-07 Certificates

Parts List

SD-08 Manufacturer's Instructions

Cubicle Track Installation

SD-10 Operation and Maintenance Data

Cubicle Track System, Data Package 1; ; G, [\_\_\_\_\_]

### 1.3 DRAWING REQUIREMENTS

Submit cubicle track layout drawings. Include[ ceiling, surface-mounted installation details,][ suspended track installation details,][ number of carriers][, and][ overlay drawing showing other trades installation within area]. Prepare drawings using field verified information and dimensions.

### 1.4 DELIVERY AND STORAGE

Deliver cubicle tracks to site in unopened containers clearly labeled with manufacturer's name and contents. Store in safe, dry, and clean location. Do not open containers until contents are to be installed.

### 1.5 QUALITY CONTROL

Allow smooth, rapid, and complete screening with no gaps at corners or ends of track. Provide tracks of a standard 2400 by 2400 mm 8 by 8 foot cubicle with no joints. Form corner bends in a single continuous piece on a 300 mm 12 inch radius to exactly 90 degrees. Provide track lengths to 4800 mm 16 feet with no joints.

## PART 2 PRODUCTS

### 2.1 CUBICLE TRACK SYSTEM

\*\*\*\*\*  
**NOTE: Heavy duty track can be mounted either on ceilings directly or from hangers. The hanger option should be chosen when ceiling heights are over 2700 mm 9 feet to reduce curtain length.**  
\*\*\*\*\*

\*\*\*\*\*  
**NOTE: If required, consider integration of related equipment that may be hung from tracks such as intravenous support assemblies, shower curtains, welding curtains, and similar materials.**  
\*\*\*\*\*

[ Heavy-duty type,[ ceiling surface mounted][ hanger mounted]. Provide tracks with a minimum 450 mm 18 inches radius. Submit product samples of track (254 mm10 inches), carriers, and hardware.

][Intravenous Track type,[ ceiling surface mounted][ hanger mounted]. Provide tracks with a minimum 450 mm 18 inches radius. Submit product samples of track (254 mm10 inches), carriers, and hardware.

][Shower Curtain track type,[ ceiling surface mounted][ hanger mounted]. Provide tracks with a minimum 450 mm 18 inches radius. Submit product samples of track (254 mm10 inches), carriers, and hardware.

#### ]2.1.1 Cubicle Track

Channel Track (Surface Mounted Type) channel shaped with smooth inside raceway for curtain carriers[, curved track sections and curved connectors,] and all components and accessories required for a working installation.

Tubular Track (Suspended Type) seamless tubing 25 mm 1 inch minimum outside diameter[ slotted for interior carriers][, curved track sections and curved connectors,] and all components and accessories required for a working installation.

#### 2.1.2 Shower Curtain Track

Corrosion resistant surface mounted track system and glider hooks at 10 count per meter 40 inches[, curved track sections and curved connectors,] and all components and accessories required for a working installation.

#### 2.1.3 Intravenous Track

Include track, carrier assembly, bottle holding pendant, curved track sections and curved connectors, and all components and accessories required for a working installation.

#### 2.1.4 Extruded Aluminum Tracks

\*\*\*\*\*  
**NOTE: Use I-beam section where accumulation of dirt on track (which would impede carrier movement) would be a problem. I-beam types of track generally use the one piece.**  
\*\*\*\*\*

ASTM B221M ASTM B221 and ASTM B456; alloy 6063-TS, channel shape minimum 32 mm wide by 29 mm deep, 1.25 mm 1-1/4 inch wide by 1-1/8 inch deep, 0.050 inch minimum wall thickness. Inside raceway to be smooth for interior carriers and must be able to receive a double coated wheel carrier with hook. Finish as designated for aluminum finishes in AA DAF45.

### 2.2 CARRIER UNIT

Silent type with double canted wheel carrier. Provide wheels with nylon on stainless steel[ chrome plated brass][ chromium plated steel][ stainless steel] hooks with swivel to support the curtain. Provide carriers that are removable only through access aperture or through end-cap that provides room for insertion or removal of carrier. Provide 2.2 carriers for every 300 mm foot of track length, plus one additional carrier. Provide a safety loading unit at one end of the channel track consisting of a section of channel track equipped with a hinge and end latch to permit lowering for installation of or removal of curtains from hooks without the use of a step-ladder and without removing carriers from track. Rivet moveable end of safety loading unit to be riveted to the hinge. Latching end of safety loading unit with a double locking fail-proof locking device for safety. Safety loading unit to be 1200 mm 4 feet in length of an 2400 mm 8 foot ceiling installation so latch end lowers to 1200 mm 4 feet from floor, for installation or removal of curtain without the use of a step-ladder. Increase length of safety loading unit to be increased according to ceiling height. Provide a key wand for every 20 units.

### 2.3 END STOP AND PULL-OUT

Fabricate from aluminum or nylon with an anodized finish matching the track finish. Provide[ non-removable][ removable (with carrier hook)] end stops as indicated.

## 2.4 SUPPORT DEVICES

[ Provide hardware and brackets intended for the support of cubicle tracks[ to ceiling grids][ through to support framing above drywall or plaster ceilings] indicated.

]Provide 05 50 13 MISCELLANEOUS METAL FABRICATIONS support system(s) designed to support cubicle tracks and brackets intended for the support of cubicle tracks from the structure above.

## ]2.5 PARTS LIST

Provide complete product data and detailed parts list for replaceable and compatible hardware and fittings and items such as hooks and gliding carriers.

## 2.6 FASTENERS

Stainless steel.

## 2.7 FINISH

Satin, clear anodized.

## PART 3 EXECUTION

### 3.1 INSTALLATION

Verify dimensions prior to installation. Install cubicle track after painting and finishing operations are complete. Provide labor and all materials indicated, specified or necessary for a complete finished installation. Install track plumb, level and true, and securely anchored to the ceiling to form a neat, rigid installation. Remove damaged or defective components and replace with new components.

#### 3.1.1 Installation Details

\*\*\*\*\*

NOTE: The types of ceilings to which the cubicle tracks or hangers will be fastened will differ. Therefore, in addition to showing the location of cubicle tracks on the drawings, the type of fastener or fasteners permitted for securing the tracks or hangers to the particular ceiling type for this project must be shown. Indicate intended support on the drawings, such as metal framing, lay in tile ceiling grids, or concrete structure.

\*\*\*\*\*

\*\*\*\*\*

NOTE: Generally, use hangers when room heights are 2700 mm 9 feet or more. Where hangers are used, indicate them on the drawings. Locate them:

1. At offsets or bends of 45 degrees or more.
2. At rises in track.
3. At 900 mm 3 feet on center, maximum, on straight

cubicle tracks over 2400 mm 8 feet long.

4. At termination of track if not at wall or other attachable vertical surface.

\*\*\*\*\*

Install heavy-duty cubicle tracks[ ceiling surface mounted][ suspended from hangers]. Install cubicle tracks where indicated. Install carrier units at 150 mm 6 inches on center maximum. Install end cap at each end of the track and pull-out at the end where curtains are stacked to permit insertion and removal of carrier units. Securely fasten end stops to prevent their being forced out by striking weight of carrier units.

-- End of Section --