

\*\*\*\*\*  
USACE / NAVFAC / AFCESA / NASA UFGS-26 29 02.00 10 (November 2008)  
-----  
Preparing Activity: USACE (CW) Superseding  
UFGS-26 29 02 00 10 (April 2006)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2009

\*\*\*\*\*

SECTION TABLE OF CONTENTS

DIVISION 26 - ELECTRICAL

SECTION 26 29 02.00 10

ELECTRIC MOTORS, 3-PHASE VERTICAL SYNCHRONOUS TYPE

11/08

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SYSTEM DESCRIPTION
- 1.3 SUBMITTALS
- 1.4 QUALITY ASSURANCE
  - 1.4.1 Corrosion Prevention and Finish Painting
    - 1.4.1.1 Corrosion-Resisting Materials
    - 1.4.1.2 Corrosion-Resisting Treatments
    - 1.4.1.3 Frames
    - 1.4.1.4 Cores
    - 1.4.1.5 Shafts
    - 1.4.1.6 Finish Painting
    - 1.4.1.7 Fastenings and Fittings
  - 1.4.2 Government Study
- 1.5 DELIVERY, STORAGE, AND HANDLING
  - 1.5.1 Impact Recorder
  - 1.5.2 Long Term Storage
- 1.6 EXTRA MATERIALS

PART 2 PRODUCTS

- 2.1 NAMEPLATES
- 2.2 GUARDS AND PROTECTIVE ENCLOSURES
- 2.3 MOTORS
  - 2.3.1 Rating
  - 2.3.2 Operating Characteristics
    - 2.3.2.1 Torques
    - 2.3.2.2 Locked-Rotor Current
    - 2.3.2.3 Starting Capability
    - 2.3.2.4 Balance
    - 2.3.2.5 Noise
    - 2.3.2.6 Overspeed Option
    - 2.3.2.7 [Antireverse Device
    - 2.3.2.8 [Power Factor and Efficiency
  - 2.3.3 Frames and Brackets

- 2.3.3.1 Stator Frame
- 2.3.3.2 Supporting Brackets
- 2.3.3.3 Eyebolts
- 2.3.3.4 Platforms and Stairways
- 2.3.4 Insulation Against Stray Currents
- 2.3.5 Motor Cooling
- 2.3.6 Stator
  - 2.3.6.1 Stator Core
  - 2.3.6.2 Stator Coils
  - 2.3.6.3 Insulated Stator Windings
  - 2.3.6.4 Temperature Detectors
  - 2.3.6.5 Grounding
- 2.3.7 Rotor
  - 2.3.7.1 Field Windings
  - 2.3.7.2 Starting Windings
- 2.3.8 Exciter
- 2.3.9 Shaft
- 2.3.10 Bearings
  - 2.3.10.1 Thrust Bearings
  - 2.3.10.2 Guide Bearings
  - 2.3.10.3 Lubrication
  - 2.3.10.4 Housing
  - 2.3.10.5 Cooling
  - 2.3.10.6 Temperature Detectors
- 2.4 INSTRUMENTS AND GAUGES
  - 2.4.1 Thermometers
  - 2.4.2 Temperature Relay
  - 2.4.3 Oil-Level Gauge
- 2.5 PIPING
- 2.6 WINDING SPACE HEATERS
  - 2.6.1 Construction
  - 2.6.2 Element
  - 2.6.3 Sheath
  - 2.6.4 Insulation
  - 2.6.5 Terminals
- 2.7 MAIN LEADS AND TERMINAL BOX
  - 2.7.1 Stator Terminals
  - 2.7.2 Stator Terminal Box
- 2.8 SURGE PROTECTION
  - 2.8.1 Surge Capacitors
  - 2.8.2 Surge Arresters
  - 2.8.3 Space Heater
- 2.9 CURRENT TRANSFORMERS
- 2.10 ACCESSORY WIRING AND BOXES
  - 2.10.1 Wiring
  - 2.10.2 Terminal Blocks
- 2.11 JACKING PROVISIONS
- 2.12 SPECIAL TOOLS AND EQUIPMENT
- 2.13 SET-DOWN FIXTURES
- 2.14 FACTORY TESTS
  - 2.14.1 Witness Test
  - 2.14.2 Complete Test
  - 2.14.3 Check Tests
  - 2.14.4 Stator Winding Coil Tests
  - 2.14.5 Space Heater Tests

PART 3 EXECUTION (Not Applicable)

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEA / NASA UFGS-26 29 02.00 10 (November 2008)  
-----  
Preparing Activity: USACE (CW) Superseding  
UFGS-26 29 02 00 10 (April 2006)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2009

\*\*\*\*\*

SECTION 26 29 02.00 10

ELECTRIC MOTORS, 3-PHASE VERTICAL SYNCHRONOUS TYPE  
11/08

\*\*\*\*\*

NOTE: This guide specification covers the requirements for the procurement of three-phase vertical synchronous motors, 1500 horsepower and above, for driving storm-water pumps for local flood-control pumping stations.

Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

\*\*\*\*\*

PART 1 GENERAL

\*\*\*\*\*

NOTE: This Section covers motors with special features of construction which are considered necessary to provide maximum insurance against failures where the motors are to be operated only for short periods of time, at infrequent intervals, and at locations where the average relative humidity of the air is high. Where operating characteristics or features of motor construction are different from those normally specified, this specification shall be modified accordingly. The designer shall also consider unusual service conditions such as direct exposure to the sun, vermin infestation, or high

altitude.

In adapting this specification to any project, the form and phraseology will be changed as necessary to properly specify the work contemplated. When deviations from this specification are considered, necessary prior approval from HQUSACE will be obtained.

Instructions for Section 22 10 00.00 10 VERTICAL PUMPS, AXIAL-FLOW AND MIXED-FLOW IMPELLER-TYPE, specify that Section 4 of Part IV, Technical Provisions, be reserved for insertion of the technical provisions of this guide specification.

The following should be included in section "L" of standard form 36, Information to Bidders.

"It is preferred that the field poles be secured to the rotor structure by means of dovetails, but an alternate method of construction will be acceptable, provided that evidence of its adequacy, satisfactory to the Contracting Officer, is submitted with the bid."

The designer should consider prequalifying the bidders based on past experience with this type and size of motor. Criteria for qualifying should be included in section "L" of standard form 36.

\*\*\*\*\*

## 1.1 REFERENCES

\*\*\*\*\*

**NOTE:** This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

- ASTM A 123/A 123M (2008) Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products
- ASTM A 153/A 153M (2005) Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware
- ASTM B 344 (2001) Standard Specification for Drawn or Rolled Nickel-Chromium and Nickel-Chromium-Iron Alloys for Electrical Heating Elements

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

- IEEE C37.96 (2000; R 2006) AC Motor Protection
- IEEE C57.13 (2008) Standard Requirements for Instrument Transformers
- IEEE Std 115 (1995; R 2002) Test Procedures for Synchronous Machines: Part I: Acceptance and Performance Testing; Part II: Test Procedures and Parameter Determination for Dynamic Analysis
- IEEE Std 43 (2000; R 2006) Testing Insulation Resistance of Rotating Machinery

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

- NEMA ICS 4 (2005) Industrial Control and Systems: Terminal Blocks
- NEMA MG 1 (2007; Errata 2008) Standard for Motors and Generators

1.2 SYSTEM DESCRIPTION

a. The work under this section includes furnishing all labor, equipment, and material and performing all operations required to design, manufacture, assemble, factory test, prepare for shipment and storage, and to deliver the vertical synchronous motors required to drive the flood-control pumps specified under Section 22 10 00.00 10 VERTICAL PUMPS, AXIAL-FLOW AND MIXED-FLOW IMPELLER-TYPE. Supply these motors complete with all accessories, spare parts, tools, and manufacturer's data and instructions as specified herein.

\*\*\*\*\*  
**NOTE: Include contract specification number where service conditions are described.**  
 \*\*\*\*\*

b. Insulation for the stator, rotor field, and exciter windings shall be full class "F" insulation as defined in NEMA MG 1 paragraph 1.66 and as described herein. The insulation system shall be a combination of

materials and processes which provides high resistance to moisture, fungus, and other contaminants as experienced by a motor in the service conditions specified herein.

c. The insulation system shall also be of a type designed and constructed to withstand severe humidity conditions and to function properly after long periods of idleness without first drying out. All windings and connections shall be of the sealed type as defined in **NEMA MG 1** paragraph 1.27.2. **Insulated windings**, unless otherwise approved, shall be completely assembled in the motor core before impregnating with the insulating compound. The compound shall consist of 100 percent solid resin. Impregnation of the windings with the insulating compound shall be by vacuum impregnation method followed by baking. Repeat the procedure as often as necessary to fill in and seal over the interstices of the winding, but in no case shall the number of dips and bakes be less than two dips and bakes when the vacuum method of impregnation is used.

d. Process insulation to ground on the coil. Slot tubes or cells are not acceptable. The insulation shall be of adequate thickness and breakdown strength throughout the length of the coil. Use mica in the slot portion of adequate thickness to withstand the dielectric tests specified in paragraph **FACTORY TESTS**.

1.3 SUBMITTALS

\*\*\*\*\*

**NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.**

**A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.**

**For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.**

**Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.**

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for [Contractor Quality Control approval.] [information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Motors[; G][; G, [\_\_\_\_\_]]

[Six] [\_\_\_\_\_] copies of equipment foundation dimensions; outline drawings for motor and rotor set-down fixture and jacking provisions with weights, nameplate data, and details showing method of mounting and anchoring the motor. Contracting Officer's approval shall be obtained in writing prior to the commencement of manufacture of motors.

SD-03 Product Data

Insulated Windings[; G][; G, [\_\_\_\_\_]]

A detailed description of and specification for the manufacturing process, the materials and the insulating compound used in insulating the windings for approval before manufacture of the motors is commenced. If, in the opinion of the Contracting Officer, the insulation proposed is not of the quality specified and if the methods of manufacture are not considered to be in accordance with best modern practice, the motors will not be accepted.

Witness Test[; G][; G, [\_\_\_\_\_]]

[Six] [\_\_\_\_\_] copies of motor design (characteristic) curves or tabulated data indicating the efficiency, current, and kilowatt input at rated voltage and 110 and 90 percent rated voltage, all plotted or tabulated against torque or percent load as abscissas. Where values are given in percentages all base values will be indicated.

\*\*\*\*\*  
**NOTE: Use final sentence only when the pump and motor are furnished under the same procurement.**  
\*\*\*\*\*

[Six] [\_\_\_\_\_] copies of the motor torque curves plotted for the following values of voltage at the motor terminals: [rated and 90 percent of rated voltage] [the output of a closed-transition autotransformer type reduced-voltage starter supplied at rated and 90 percent of rated motor voltage and connected on its [80] [65] percent tap]. [The pump torque curve shall be plotted for starting, accelerating, and synchronizing against maximum head. Furnish computations to demonstrate that the motor will pull into synchronism under all of the foregoing conditions.]

Motors[; G][; G, [\_\_\_\_\_]]

[Six] [\_\_\_\_\_] copies of complete descriptive specification for

each type and size motor furnished, with necessary cuts, photographs, and drawings to clearly indicate the construction of the motor, specifications for the materials and treatments used to prevent corrosion of parts, and of bearing construction. A complete listing of motor performance data in the form provided in NEMA MG 1 paragraph 21.50. Include with the submittal all information required for the selection of protective and control equipment and for operational settings. Information such as, but not limited to, normal and maximum operating temperatures for windings and bearings, V-curves, field control and protective equipment to be mounted on the motor controller cubicle, locked-rotor current, permissible locked-rotor time, starting times for each type of start as indicated above, and subtransient, transient, and synchronous reactance. If duplicate equipment has not been manufactured previously, calculations or tests shall be made as necessary and confirmed as required by paragraph FACTORY TESTS. Contracting Officer's approval shall be obtained in writing prior to the commencement of manufacture of motors.

#### Government Study

[Six] [\_\_\_\_\_] copies of the specified data.

#### Spare Parts

A complete list of renewal parts for the motor. The list shall accompany the instruction manuals.

#### Antireverse Device[; G][; G, [\_\_\_\_\_]]

The design of the antireverse device for approval by the Contracting Officer.

#### SD-06 Test Reports

##### Factory Tests[; G][; G, [\_\_\_\_\_]]

[Six] [\_\_\_\_\_] copies of test reports recording all data, calculations, and curves for each motor used.

#### SD-07 Certificates

##### Power Factor and Efficiency

[Six] [\_\_\_\_\_] copies of certification guaranteeing value of power factor and efficiency for full load, 3/4 full load, and 1/2 full load.

##### Factory Tests Complete Test Check Tests

[Six] [\_\_\_\_\_] certified copies of the results of a "Complete Test" for duplicate equipment of the respective rating and type will be accepted in lieu of the "Complete Test" specified for equipment of the respective rating and type. No substitute will be accepted for the "Check Test".

#### SD-10 Operation and Maintenance Data

## Manufacturer's Data and Instructions [\_\_\_\_\_]

[Six] [\_\_\_\_\_] copies of printed and bound instructions manual for the proper installation, erection, inspection, and maintenance of the machines furnished under this contract not later than the date the equipment is shipped from the manufacturer's plant. Manuals shall include complete installation, maintenance, and service instructions for the motors, lube oil system, thrust bearings (including cooling water requirements), and other accessories. The instructions shall include a cross-sectional drawing indicating the major component parts of the motor and procedure for disassembly. The description in the manual for the motor shall be coordinated with the installation erection instructions specified in Section 22 10 00.00 10 VERTICAL PUMPS, AXIAL-FLOW AND MIXED-FLOW IMPELLER-TYPE for the pump and integrated with same for a complete motor and pump assembly.

### 1.4 QUALITY ASSURANCE

#### 1.4.1 Corrosion Prevention and Finish Painting

The equipment provided under these specifications will be subjected to severe moisture conditions and shall be designed to render it resistant to corrosion from such exposure. The general requirements to be followed to mitigate corrosion are specified below. Any additional special treatment or requirement considered necessary for any individual items is specified under the respective item. However, other corrosion-resisting treatments that are the equivalent of those specified herein may, with the approval of the Contracting Officer, be used.

##### 1.4.1.1 Corrosion-Resisting Materials

Corrosion-resisting steel, copper, brass, bronze, copper-nickel, and nickel-copper alloys are acceptable corrosion-resisting materials.

##### 1.4.1.2 Corrosion-Resisting Treatments

Hot-dip galvanizing shall be in accordance with ASTM A 123/A 123M or ASTM A 153/A 153M as applicable. Other corrosion-resisting treatments may be used if approved by the Contracting Officer.

##### 1.4.1.3 Frames

Motor frames, end bells, covers, conduit boxes, and any other parts, if of steel, and if they will be coated during the process of insulating the windings, shall be cleaned of rust, grease, millscale, and dirt, and then treated and rinsed in accordance with manufacturers' standard process. If any of the above-listed parts are not coated during the process of insulating the windings then, in addition to the above, give them two coats of primer and then two coats of manufacturers' standard moisture-resistant coating, processed as required.

##### 1.4.1.4 Cores

The assembled motor core shall be thoroughly cleaned and then immediately primed by applying a minimum of two coats of a moisture-resisting and oil-resisting insulating compound. Air gap surfaces shall be given a minimum of one coat.

1.4.1.5 Shafts

Exposed surfaces of motor shafts shall be cleaned of rust, grease, and dirt and, except for bearing surfaces, given one coat of a zinc molybdate or equivalent primer and two coats of a moisture-proof coating, each cured as required. Shafts of a corrosion-resisting steel may be used in lieu of the above-mentioned treatment.

1.4.1.6 Finish Painting

\*\*\*\*\*  
**NOTE: If severely moist conditions exist, a separate paint system should be specified using Section 09 97 02 PAINTING: HYDRAULIC STRUCTURES, system 21, epoxy finish or equivalent. When such painting is specified, care must be taken to specify a paint that will adhere to and not be injurious to the protective painting provided under these specifications.**  
\*\*\*\*\*

Finish painting of all equipment in accordance with the standard practice or recommendation of the manufacturer, as approved by the Contracting Officer.

1.4.1.7 Fastenings and Fittings

Where practicable, all screws, bolts, nuts, pins, studs, springs, washers, and other similar fittings shall be of corrosion-resisting material or shall be treated in an approved manner to render them resistant to corrosion.

1.4.2 Government Study

\*\*\*\*\*  
**NOTE: Item d. may be used only when the pump and motor are furnished under the same procurement.**  
\*\*\*\*\*

Supply to the Government, for completion of its Motor Torque and Accelerating Time Studies (MTATS), the following data:

- a. Complete equivalent circuit data referred to the stator with friction, windage, and stray load losses.
- b. Current, power factor, and torque versus speed (0-100 percent, inclusive, in 1 percent increments up to 95 percent and 0.1 percent increments above 95 percent) and load (0-125 percent, inclusive, in 25 percent increments) as a function of line voltage (from 80 percent to 110 percent, inclusive, in 5 percent increments), for rated and 90 percent of rated voltage at starter. Only tabulated data will be required.
- c. Load inertia, Wk<sup>2</sup> of motor rotating parts, pound-foot<sup>2</sup>.
- [d. Load inertia, Wk<sup>2</sup> of pump rotating parts (wet), pound-foot<sup>2</sup>.]

1.5 DELIVERY, STORAGE, AND HANDLING

Ship each motor in the vertical position with the rotor blocked inside the stator to prevent damage to the bearings. Securely mount the motor on a skid or pallet of ample size. All small parts or elements shall be boxed. Perform the skid mounting and boxing in a manner which will prevent damage or distortion to the motor during loading, shipment, unloading, indoor storage, and subsequent handling. Provide weatherproof covers as necessary to protect the motor during shipment. Any eyebolts, special slings, strongbacks, or other devices used in loading the equipment at the manufacturer's plant shall be furnished for unloading and handling at the destination and shall become the property of the Government.

1.5.1 Impact Recorder

Ship each motor with a three-way temporary impact recorder to measure magnitude and direction of longitudinal (Y), lateral (X), and vertical (Z) impacts suffered during shipment. If the recorder indicates impacts equal to or greater than those determined by the Contractor prior to shipment for any of the three directions specified herein, inspect and test motor to determine extent of damage, if any, and repair or replace any damaged equipment.

1.5.2 Long Term Storage

\*\*\*\*\*  
**NOTE: The designer will include this paragraph only when there is no available Government storage. The designer should also investigate storage to be used by the installation Contractor and the possibility of making this a requirement under the installation contract.**  
\*\*\*\*\*

Store all equipment provided under this contract for [\_\_\_\_\_] [days] [months] at no cost to the Government. The storage site shall be subject to the approval of the Contracting Officer and shall meet the manufacturer's recommendations for indoor storage. The equipment will be subject to periodic inspection by the Government to ensure that proper storage conditions are maintained.

1.6 EXTRA MATERIALS

The following spare parts shall be furnished for each type and rating in addition to the assembled motors:

- a. Two complete stator coils but not less than the number of coils to span one coil pitch with necessary wedges and material for installation for one motor.
- b. Two complete field coils, including necessary materials for installation.
- c. One complete exciter field coil, including necessary materials for installation.
- d. One complete set of bearing parts for pump motors. Each set to include:

- (1) Stationary thrust bearing plate.
- (2) Rotating thrust bearing plate.
- (3) Upper guide bearing lining.
- (4) Lower guide bearing lining.
- (5) Two sets of oil rings for pump motors.
- [(6) One complete set of parts necessary for replacement of antireverse device.]

## PART 2 PRODUCTS

### 2.1 NAMEPLATES

Nameplate data shall include rated voltage, rated full-load amperes, rated horsepower, service factor, number of phases, RPM at rated load, frequency, code letter, locked-rotor amperes, duty rating, insulation system designation, and maximum ambient design temperature. Each motor shall have a nameplate listing motor characteristics in accordance with NEMA MG 1 paragraph 21.61. A separate starting information nameplate shall be furnished as specified in paragraph OPERATING CHARACTERISTICS. A starting information nameplate setting forth the starting capabilities shall be provided on each motor in accordance with NEMA MG 1 paragraph 21.43.3. This nameplate shall also include the minimum time at standstill and the minimum running time prior to an additional start.

### 2.2 GUARDS AND PROTECTIVE ENCLOSURES

All moving, energized, or other parts where accidental contact might be hazardous to personnel shall be equipped with adequate guards, rails, or other suitable enclosures to prevent accidental contact. All lubrication fittings shall be piped to convenient locations where they can be serviced from regularly utilized access ways without removal of the guards or enclosures.

### 2.3 MOTORS

\*\*\*\*\*  
**NOTE: For weak source (high thevenin source impedance), the electric utility should be contacted to determine starting restrictions, maximum inrush, or voltage dip limits. This is especially critical for motors over 100 hp. The designer must then perform a motor torque and accelerating time study (MTATS) to evaluate the motor starting torque and voltage dip requirement. The selection of a reduced voltage starter will be based on the electric utility requirements and the motor pump arrangement.**  
 \*\*\*\*\*

The motors to be supplied under these specifications shall be of the vertical [solid] [hollow] shaft type as required by the pump manufacturer, with direct-connected brushless exciter, designed for full voltage starting, of drip-proof construction, [complete with antireversing ratchet or backstop device], and shall conform to the applicable requirements of NEMA MG 1, except as hereinafter specified.

2.3.1 Rating

\*\*\*\*\*

**NOTE:** The local electric utility should be consulted for the expected average and maximum values of percentage voltage unbalance, as defined in NEMA MG 1 paragraph 21.81.2, that will be present at the pumping station. If either value exceeds 1 percent as recommended in NEMA MG 1 paragraph 21.81, the utility should be requested to furnish their plans to improve the voltage unbalance. If they are unable to do so, then the motor should be derated where the voltage unbalance exceeds 1-2 percent. Voltage unbalance should never exceed 5 percent. Motor manufacturers should be consulted for voltage unbalance limits whenever motors have specified limits on locked-rotor currents, particularly the 500 percent limit.

\*\*\*\*\*

Each motor shall be wound for three-phase, 60 Hz, alternating current, and for the respective operating voltage listed below:

PLANT	PUMP	PUMP SERVICE	MOTOR OPERATING VOLTAGE
[_____]	[_____]	[_____]	[_____]
[_____]	[_____]	[_____]	[_____]

Design the motor for operation in a 40 degrees C 104 degrees F ambient temperature, and all temperature risers shall be above this ambient temperature. The rated horsepower of the motor shall be not less than 110 percent of the determined maximum load requirement of the pump. [Supply voltage unbalance will be [\_\_\_\_\_] percent. The motor rated horsepower will be further derated according to NEMA MG 1 paragraph 21.81 for a voltage unbalance above [1.5 percent] [2 percent].] Motors shall have a power factor and service factor of 1.0. The temperature rise above the ambient temperature for continuous rated full load conditions and for the class of insulation specified shall not exceed the values given in NEMA MG 1 paragraph 21.40.

2.3.2 Operating Characteristics

2.3.2.1 Torques

\*\*\*\*\*

**NOTE:** This guide specification identifies closed transition autotransformer-type reduced voltage starters. These starters provide the most flexibility during installation, when exact load and line characteristics are not determined, since both input voltage and inrush current may be adjusted. This specification is not meant to limit the selection of reduced voltage starter to only autotransformer type. The use of wye-delta type starter may be appropriate in certain situations. The reduced starter cost must be weighed against the increase cost in motor designs; however each design should be evaluated for the most suitable type

**starter. All reduced voltage starters will reduce the motor starting torque, so the designer should evaluate the load characteristics to ensure that motor torque will be sufficient under all starting conditions. If reduced-kVA starters are required, EM 1110-2-3105 should be consulted for further guidance.**

\*\*\*\*\*

Starting and accelerating torque shall be sufficient to start the pump and accelerate it against all torques experienced in passing to the pull-in speed under maximum head conditions and with rated excitation current and a terminal voltage equal to [90 percent of rated value] [the output of a closed-transition autotransformer type reduced-voltage starter supplied at 90 percent of rated voltage and connected on its [80] [65] percent tap]. The pull-in torque shall exceed that required by the pump under maximum head conditions but shall not be less than 100 percent of motor full-load torque, with a terminal voltage equal to 90 percent of rated value. Pull-out torque shall not be less than 150 percent of motor full-load torque for one minute minimum and with a terminal voltage equal to 90 percent of rated value.

#### 2.3.2.2 Locked-Rotor Current

\*\*\*\*\*

**NOTE: The objective of this specification is to limit the locked-rotor current to a value sufficiently low to permit full-voltage starting. The motor horsepower rating is to be a minimum of 110 percent of the maximum pump load at a service factor of 1.0. Manufacturer's standard is to limit locked-rotor current to 600 percent of full load current. However, local utilities may have additional limitations on inrush currents and should be consulted. Motor design will permit some reduction in inrush current in which case 500 percent should be used. If this is not sufficient, reduced-voltage starting should be used. The inrush current limit should be specified whenever possible.**

\*\*\*\*\*

The locked-rotor current shall not exceed [600] [500] percent of rated nameplate full load running current. [The locked-rotor current shall not exceed [\_\_\_\_\_] amperes at 90 percent of rated voltage during any point in the starting cycle under worst case starting conditions. For autotransformer reduced voltage starting, the above criteria shall apply to primary side and at any prescribed tap.]

#### 2.3.2.3 Starting Capability

Each motor, when operating at rated voltage and frequency and on the basis of the connected pump load inertia, Wk<sup>2</sup>, and the speed-torque characteristics of the maximum load during starting conditions as furnished by the pump manufacturer, shall be capable of making the starts required in [NEMA MG 1](#) paragraph 21.43.

#### 2.3.2.4 Balance

The balance for each motor when measured in accordance with [NEMA MG 1](#)

paragraph 20.53 shall not exceed the values specified in NEMA MG 1 paragraph 21.54. Each motor's characteristics shall be such that the maximum vibration requirements of Section 22 10 00.00 10 VERTICAL PUMPS, AXIAL-FLOW AND MIXED-FLOW IMPELLER-TYPE are met.

#### 2.3.2.5 Noise

\*\*\*\*\*  
**NOTE: The Department of Defense considers hazardous noise exposure of personnel as equivalent to 85 dB or greater: A-weighted sound pressure level for eight hours in any one 24-hour period. On the assumption that pumping plant operating personnel may be exposed to noise levels approaching or exceeding that defined by the DOD as hazardous, the motor noise limit should be specified not to exceed 85 dBA. The additional cost of providing motors meeting this requirement should be investigated and weighed against an alternate of providing a room to isolate these personnel from the noise exposure.**  
\*\*\*\*\*

All motors shall operate at a noise level less than 85 decibels A-weighted mean sound pressure level (dBA). Noise shall be determined in accordance with NEMA MG 1 paragraph 21.53.

#### 2.3.2.6 Overspeed Option

\*\*\*\*\*  
**NOTE: NEMA MG 1 paragraphs 12.48 and 21.45 specify that overspeeds are for emergencies lasting no longer than one minute. Using this option will increase costs due to requirements well beyond standard limits. Designer must do a cost analysis before selection of this option.**  
\*\*\*\*\*

Design each motor to withstand indefinitely, without injury, the maximum overspeed to which the motor will be subjected when the pump to which it is connected is acting as hydraulic turbine under the maximum head with the pump discharge pipe open.

#### 2.3.2.7 [Antireverse Device

Install a self-actuated backstop device or antireversing ratchet, to prevent reverse rotation of the pump due to loss of power or failure of the electric prime mover, as an integral part of the motor. Submit the design of the device for approval such that its action is without intentional delay or excessive backlash. It shall have sufficient capacity to prevent reverse rotation with a back flow through the pump due to a [\_\_\_\_]-foot differential head. The device shall be precision machined and be complete with support housing and oil collector as required. An oil reservoir, independent of the one used for the thrust bearing, complete with oil-level gauge and 120-volt ac rated high and low level contacts shall be provided for the backstop device. The lubricant for the antireverse device shall contain a corrosion inhibitor, whose type and grade shall be shown on a special nameplate attached to the frame of the motor adjacent to the lubricating filling device.]

2.3.2.8 [Power Factor and Efficiency]

\*\*\*\*\*  
**NOTE: List power factor and efficiency for each size only if high efficiency motors are required. Generally manufacturers' standards will be used.**  
\*\*\*\*\*

The power factor and efficiency at full load, 3/4 full load, and 1/2 full load shall be not less than [\_\_\_\_], [\_\_\_\_], [\_\_\_\_] and [\_\_\_\_], [\_\_\_\_], [\_\_\_\_], respectively. Motors will be rejected if factory tests specified in paragraph FACTORY TESTS do not demonstrate that these values will be met or exceeded.]

2.3.3 Frames and Brackets

Frames and end brackets shall be of cast iron, cast steel, or welded steel. The mounting ring, unless otherwise approved, shall be built integral with the frame or lower end bracket. Coordinate the motor installation with the mounting arrangement specified in Section 22 10 00.00 10 VERTICAL PUMPS: AXIAL-FLOW AND MIXED-FLOW IMPELLER-TYPE, paragraph BASE PLATE AND SUPPORTS. Furnish all equipment and materials required to mount the motor, such as a base or pedestal, sole plates, and bolts or dowels. Install sufficient bolts and dowels to prevent any possible movement of the motor assembly when the motor is subjected to stresses resulting from the most severe short-circuit conditions. Treatment against corrosion shall be as specified in paragraph GENERAL REQUIREMENTS.

2.3.3.1 Stator Frame

The stator frame shall be rigid and sufficiently strong to support the weight of the upper bearing bracket load, the weight of the stator core and windings, and to sustain the operating torques without perceptible distortion.

2.3.3.2 Supporting Brackets

The upper bracket supporting the thrust bearing and upper guide bearings shall have sufficient strength and rigidity to support the weight of the entire rotating element of the motor, together with the pump impeller and shaft, and the unbalanced hydraulic thrust of the pump impeller. The lower bracket supporting the lower guide bearing shall preferably be so designed and constructed that the entire rotor can be lifted out as a unit without disturbing the bearing alignment. If it is not feasible to construct the rotor so that it can be lifted out as a unit, then the lower bracket shall be supported on separate base plates or structure and shall be designed so that it can be removed through the stator. The maximum deflection of the thrust bearing support system at any point shall not exceed the limits set by the pump manufacturer to maintain proper clearances for any operating condition.

2.3.3.3 Eyebolts

Provide eyebolts, lugs, or other approved means for assembling, dismantling, and removing the motors from above, utilizing the overhead pumping station building crane. Furnish with the motor all lifting devices for use in conjunction with the building crane.

#### 2.3.3.4 Platforms and Stairways

Furnish each motor with a platform and stairway complete with railing. An easily removed section of railing shall be provided so that the rotor shaft does not have to be hoisted above the railing when the rotor is removed. The platform shall also provide maintenance access as required by the motor furnished. Locate the stairway [\_\_\_\_\_] degrees [counter-] clockwise from the discharge elbow of the pump, when looking down on the motor/pump assembly.

#### 2.3.4 Insulation Against Stray Currents

The motor shall be adequately insulated against stray currents which may be set up by the field of the motor and which might cause injury to the motor or pump bearings. This insulation shall be arranged to break the possible path of such currents in not less than two places in series.

#### 2.3.5 Motor Cooling

Provide the motor with an open-type system of ventilation, taking cooling air from above the operating floor level and discharging the heated air into the operating room through upper openings in the stator frame. The circulation of air shall be induced by means of the fan action of the rotor. No openings to the air space below the operating level are to be used in the motor design for ventilation or other uses that are not reasonably airtight.

#### 2.3.6 Stator

##### 2.3.6.1 Stator Core

The cores shall be built up of separately punched thin laminations of low-hysteresis loss, nonaging, annealed, electrical silicon steel; assembled under heavy pressure; and clamped in such a manner as to ensure that the assembled core is tight at the top of the teeth of the laminated core. Laminations shall be properly insulated from each other. Only laminations free from burrs shall be used, and care shall be taken to remove all burrs or projecting laminations from the slots of the assembled cores. Cores shall be keyed, dovetailed, or otherwise secured to the shaft or frame in an approved manner. Treatment against corrosion shall be as specified in paragraph GENERAL REQUIREMENTS.

##### 2.3.6.2 Stator Coils

The coils shall be thoroughly insulated and treated with a moisture and fungus-resisting compound in such a way that air will be excluded and the insulation will be protected from the absorption of moisture. Provide additional insulation for those portions of each coil which are within the slots. The coils shall fit the slots accurately and they shall be form wound and interchangeable. The end turns shall be so designed and supported that they will not be distorted under the most severe short-circuit conditions to which the motor may be subjected.

##### 2.3.6.3 Insulated Stator Windings

The stator windings shall be insulated as specified in paragraph GENERAL REQUIREMENTS. Coils shall be of such uniformity that the stator windings of all similarly rated motors will be alike, in shape and size, and interchangeable. The stator winding and end turn connections shall be

fully braced to withstand repeated full voltage starts. The bracing system shall essentially eliminate coil vibration under these high current conditions as well as during normal operation. A tieless bracing system will be acceptable. If a tied system is used it shall be such that no tie depends upon the integrity of any other tie within the system.

#### 2.3.6.4 Temperature Detectors

Six standard copper resistance-type temperature detectors, with a resistance of 10 ohms at 25 degrees C 75 degrees F, shall be provided in the stator in accordance with NEMA MG 1 paragraph 20.63. Detectors shall be wired in accordance with paragraph ACCESSORY WIRING AND BOXES.

#### 2.3.6.5 Grounding

The stator frame shall have provisions for solidly grounding to the station ground system which will be furnished and installed by others.

#### 2.3.7 Rotor

The rotor shall be built in accordance with the best modern practice and in such a manner as to secure adequate strength for the operating conditions described herein. The pole pieces shall be built up of thin steel laminations accurately aligned and securely riveted or bolted together. It is preferred that the field poles be secured to the rotor structure by means of dovetails, but an alternate method of construction will be acceptable, provided that evidence of its adequacy, satisfactory to the Contracting Officer, is submitted with the bid.

##### 2.3.7.1 Field Windings

The field windings shall be insulated as specified in paragraph GENERAL REQUIREMENTS. The field coils shall be adequately insulated between turns and from the pole pieces and shall be thoroughly braced to withstand the stresses which could be imposed under maximum pump speed.

##### 2.3.7.2 Starting Windings

Design the starting windings for full-voltage starting, securely built into the field poles and designed to ensure conservative stresses when the unit is operating at maximum pump speed. The bars shall be silver soldered or brazed to heavy end segments to form a low-resistance joint of high mechanical strength. Design the starting windings to permit any pole or group of poles to be removed.

#### 2.3.8 Exciter

Provide each synchronous motor with a direct connected exciter without brushes, commutators, or additional bearings. The exciter shall be capable of supplying continuously, and without overheating, the excitation for the motor to which it is connected when the latter is operating at rated power factor, voltage, frequency, and horsepower. Accomplish the field-protective function and the field switching and application function by semiconductor elements mounted on suitable heat sinks supported on the motor rotor and ventilated by rotation of the rotor. The exciter shall be either built into or so arranged that it is ventilated from the main motor enclosure. The enclosure of the exciter shall be of drip-proof construction comparable to that of the motor. The control system shall apply excitation to the motor field at the speed and phase angle required

to obtain maximum pull-in torque. Insulate the exciter windings as specified in paragraph GENERAL REQUIREMENTS. The field coils shall be adequately insulated between turns and from the pole pieces and shall be thoroughly braced to withstand the stresses which could be imposed under maximum pump speed.

### 2.3.9 Shaft

\*\*\*\*\*  
**NOTE: Use hollow shaft pumps whenever possible, since they are more readily adjusted. Pumps requiring large motors (above 1,000 hp) are limited by the available motors. Investigate the exact motor capabilities and sources of supply when using hollow shafts with motors above 1,000 hp. Solid shafts will be used only when the available motor designs require their use.**  
\*\*\*\*\*

Make the motor shaft of high grade steel, finished all over, and of ample size to drive the pump under maximum load conditions. The shaft shall be of the [solid type and shall be connected to the pump shaft with a rigid adjustable coupling.] [hollow type and shall be connected to the pump shaft above the thrust bearing in a manner that will permit the pump impeller to be adjusted vertically]. Coordinate the connection with the pump shaft and furnish a motor shaft with all provisions, fittings, and devices required to conform to the shafting arrangement specified in Section 22 10 00.00 10 VERTICAL PUMPS, AXIAL-FLOW AND MIXED-FLOW IMPELLER-TYPE, paragraph SHAFTS. See paragraph GENERAL REQUIREMENTS for treatment against corrosion.

### 2.3.10 Bearings

#### 2.3.10.1 Thrust Bearings

Provide thrust bearings of the spring type located above the rotor. A design in which each pivot shoe rests upon a support of metal which may take a permanent deformation in order to equalize the load on the bearing shoes, or in which individual shoe pivots are supported on spring plates or spring disks, is not considered to be of the self-equalizing type and will not be acceptable. The stationary shoes shall be babbitt-lined. The thrust bearing shall have ample capacity to support the maximum pump hydraulic thrust load plus the static load while operating under maximum rated pump conditions. The thrust bearing shall be capable of withstanding without injury the pump being started normally without prior jacking of the rotor. The thrust bearing shall have a removable runner and shall be arranged to permit adjustments, dismantling, and assembly of the runner and shoes without disturbing the stator or rotor, other than jacking the load from the bearing. A spacer plate between the thrust bearing runner plate and the thrust block will not be permitted.

#### 2.3.10.2 Guide Bearings

Except as permitted below, provide the motor with two guide bearings, one located above the rotor and the other below the rotor. The guide bearings shall be capable of withstanding all stresses incident to the normal operation of the unit [and to the maximum runaway speed]. Both guide bearings shall be self-cooled, of the oil-immersed, self-oiling type, and adequate provision shall be made for preventing oil or oil vapor from entering the motor cooling system. The guide bearings shall be of the

split-sleeve type and shall be designed and constructed so that they can be dismantled without disturbing the thrust bearing or the motor rotor. If desired, the Contractor may combine the thrust bearing and the upper guide bearing into a combination integral guide and thrust bearing assembly in a common housing. In such a combination bearing, the vertical side of the thrust-bearing block, but not the runner plate, shall be used as the journal surface.

#### 2.3.10.3 Lubrication

Use lubricating oil containing a corrosion inhibitor. Type and grade of lubricant used shall be shown on a special nameplate which shall be attached to the frame of the motor adjacent to the bearing filling device. In addition to the quantity of lubricant required to initially fill the system, furnish spare lubricant in sufficient quantity to purge and refill the system. Each lubrication system shall include oil reservoirs, oil-level sight gauge, oil piping, valves, and necessary appurtenances.

#### 2.3.10.4 Housing

Bearing housing shall be of a design and method of assembly that will permit ready removal of the bearings, and prevent escape of lubricant and entrance of foreign matter. The bearings shall be protected by the lubricant when the motor is idle. Provide suitable means to apply and drain the lubricant.

#### 2.3.10.5 Cooling

Each thrust bearing shall be self-cooling whenever possible. When required by motor speed or load, provide an oil cooler with suitable coils of corrosion-resisting metal in the oil reservoir of sufficient capacity to maintain the oil at the proper temperature with [30 percent glycol] cooling water entering the coils at a temperature of [30] [\_\_\_\_\_] degrees C and with a minimum pressure of 40 pounds per square inch. Design the cooler for safe operation at a maximum working pressure of 345 kPa 50 psi and shall be subjected at the factory to a hydrostatic test pressure of 517 kPa 75 psi for a period of one hour without leakage. Cooling water will be supplied by a central system, furnished by others, consisting of a radiator, circulating water pump, and piping system terminating at the exterior of each motor. If required an auxiliary-motor-driven circulating oil pump, rated at 480 volts, three-phase, with electrical leads terminated in a special terminal box on the motor, and an oil pressure sensing device shall be included in the bearing oil cooler system. Construct the cooler system so that the thrust bearing can be readily inspected or removed for repairs. Include a water flow indicator with adjustable alarm contacts in the water supply line. The oil reservoir shall have an oil-level gauge with high and low level normally open contacts rated 120 volts ac.

#### 2.3.10.6 Temperature Detectors

Provide a standard copper resistance-type temperature detector, with a resistance of 10 ohms at 25 degrees C 75 degrees F, for each bearing. Casings shall be made of copper. Detectors shall be wired in accordance with paragraph ACCESSORY WIRING AND BOXES.

### 2.4 INSTRUMENTS AND GAUGES

Furnish the following instruments and gauges.

#### 2.4.1 Thermometers

Indicating thermometers, 150 mm 6 inch vapor-tension [dial-type] [digital], with adjustable ungrounded alarm contacts suitable for 120 volts ac shall be provided for (a) the thrust bearing, (b) the thrust bearing oil reservoir, and (c) each guide bearing. The bulbs shall be located so as to indicate the temperatures of the hottest parts. The thermometers shall be mounted on a thermometer panel and located on the motor housing at a location approved by the Contracting Officer. Provide adequate length of tubing with each thermometer. The bulb and tubing shall be insulated where necessary to prevent bearing currents. [The dial-type thermometers shall be of the [round][square] semiflush type with black cases, white dials, and black figures and pointers.] [The digital thermometers shall be square, semiflush type with black cases and minimum 25 mm 1 inch high display.]

#### 2.4.2 Temperature Relay

Provide a pneumatic bearing temperature relay having two sets of electrically independent contacts, located close to the babbitt of the thrust bearing [and each guide bearing]. Each relay shall close its contacts when the bearing temperature reaches approximately 105 degrees C 220 degrees F. The contacts shall have a current-carrying capacity of not less than 10 amperes, shall be ungrounded, and shall be suitable for 120 volts ac. The relays shall be mounted in an approved accessible location and the leads brought to a terminal block mounted on the stator frames in an approved location. The bulbs for the temperature relays shall be easily accessible and constructed for removal and testing without disturbing the bearing or bearing housing. The tubing shall be insulated where necessary to prevent bearing currents.

#### 2.4.3 Oil-Level Gauge

Provide an oil-level gauge for each oil reservoir, with scale of sufficient length to indicate the oil level at all room and operating temperatures. The gauges shall be located near the reservoirs in an approved, accessible location where they can be easily read. Each oil-level gauge shall have adjustable high and low oil-level ungrounded alarm contacts suitable for 120 volts ac.

#### 2.5 PIPING

Design and furnish all piping systems within the motor for bearings, including valves and fittings. Bring these connections out to approved positions at the bottom of the stator frame. All piping shall be clean inside and where ending in open connections for other work, ends shall be capped for protection. Valves and other operating devices shall be easily accessible, and gauges and indicating devices shall be mounted on a control panel as approved by the Contracting Officer. Piping and fittings shall be of copper or brass as required. Valves shall have bronze seats and stems and shall be suitable for the service intended. At all points where the piping system must be disconnected for dismantling operations, provide bolted flange connections or unions. Arrangement of piping and location of valves and joints shall be such that there will be a minimum of disturbance to piping or interference with other service when the motor is dismantled or parts are removed for inspection or repairs.

#### 2.6 WINDING SPACE HEATERS

\*\*\*\*\*

**NOTE: The inclusion or omission of "Winding Space Heaters" will depend upon the decision reached after giving due consideration to the problem of prevention of moisture condensation on the station equipment.**

\*\*\*\*\*

Install heaters in the lower section of the frame or wrap them around the winding end turns. They shall be designed for operation on 120 volts, single-phase, 60-Hz, alternating current and of sufficient capacity or wattage that, when energized, they will hold the temperature of the motor windings approximately 10 degrees C above the ambient temperature. Heaters shall be de-energized when motor is operating.

#### 2.6.1 Construction

The heaters, except for wrap-around type, shall be of the tubular type, constructed with a chrome-nickel heating element embedded in a refractory insulating material, and encased in an approved watertight metal sheath. They shall be designed for continuous operation and have a maximum watt density of 20 watts per square inch. The rate of heat dissipation shall be uniform throughout the effective length of the heater. Cartridge-type heaters of equivalent construction, as approved by the Contracting Officer, will be acceptable. Heaters installed around the winding end turns shall consist of the required turns of heating cable wrapped around the end turns and secured in place before the winding is impregnated.

#### 2.6.2 Element

Heating element shall conform to the requirements of [ASTM B 344](#) for an 80 percent nickel and 20 percent chromium alloy.

#### 2.6.3 Sheath

Sheath shall be of a corrosion-resisting, nonoxidizing metal and shall have a wall thickness not less than [0.625 mm](#) [0.025 inch](#).

#### 2.6.4 Insulation

Insulation shall be a granular mineral refractory material, highly resistant to heat, and shall have a minimum specific resistance of 1,000 megohms per inch cubed at [585 degrees C](#) [1,000 degrees F](#). Insulation for the heating cable (winding wrap-around type heaters) shall be suitable for a conductor temperature of [180 degrees C](#) [356 degrees F](#).

#### 2.6.5 Terminals

Terminals of the heater, including the leads, shall be watertight and shall be provided with leads suitable for making connections to a separate drip-proof terminal box located on the motor frame. The terminal box shall be readily accessible through the crating, so that winding heaters can be energized while motors are in storage.

### 2.7 MAIN LEADS AND TERMINAL BOX

#### 2.7.1 Stator Terminals

Insulated terminal leads shall receive a treatment equal to that of the motor winding. Six leads shall be brought out of the stator frame and

connections shall be made as required for the current transformers in paragraph ACCESSORY WIRING AND BOXES. Provide terminal lugs for connection to the motor shielded single-conductor supply wiring.

### 2.7.2 Stator Terminal Box

Drip-proof cast iron or steel terminal boxes, treated in the same manner specified for frames to resist corrosion, shall be supplied for housing the stator lead connections, surge capacitors, surge arresters, and current transformers and shall have adequate space to facilitate the installation and maintenance of cables and equipment. Boxes shall have a [bolted] [hinged lockable] cover providing unrestricted access, be mounted on the motor frame, and shall have an auxiliary floor supporting structure, when required, supplied by the motor manufacturer. Conduit entrance shall be from the bottom. The boxes shall be designed to permit removal of the motor supply leads when the motor is removed. Provide a "HIGH VOLTAGE [\_\_\_\_\_] VOLTS" warning sign on the cover of the box. When looking down on the motor/pump assembly, the terminal box shall be located between [\_\_\_\_\_] degrees and [\_\_\_\_\_] degrees [counter-] clockwise from the discharge elbow of the pump. A ground bus and means for external connection to the station grounding system shall be provided in the stator terminal box.

### 2.8 SURGE PROTECTION

\*\*\*\*\*  
**NOTE: To obtain the most reliable protection for 2,300- and 4000-volt motors, surge capacitors and arresters, mounted at the motor terminals, should be specified. In addition, it is recommended that station-type arresters be installed on the line side of the supply transformers.**  
\*\*\*\*\*

#### 2.8.1 Surge Capacitors

Furnish and install, in the main terminal box, a three-pole capacitor unit equipped with built-in discharge resistors and using a non-polychlorinated biphenyl (non-PCB) insulating medium. Each pole shall be rated 0.5 microfarad and [2,400] [4,160] volts line-to-line. Provide removable bus links for motor testing. These links shall be treated to resist corrosion, shall be designed to maintain a positive contact, and shall have low contact resistance.

#### 2.8.2 Surge Arresters

\*\*\*\*\*  
**NOTE: Use 3,000 MCOV arresters for 2,400-volt systems or effectively grounded 4,160-volt systems. Use 4,500-MCOV for ungrounded or resistance grounded 4,160-volt systems.**  
\*\*\*\*\*

Surge arresters of the station type with porcelain tops shall be furnished and installed in the main terminal box. The arresters shall be of the metal-oxide type rated [3,000] [4,500] [\_\_\_\_\_] maximum continuous operating voltage line-to-ground. Provide removable bus links for motor testing. These links shall be treated to resist corrosion, shall be designed to maintain a positive contact, and shall have low contact resistance.

### 2.8.3 Space Heater

If recommended by the surge protection manufacturer, furnish a space heater of adequate capacity, rated 120 volts and install it in the terminal box. Space heater maximum watt density shall not exceed 20 watts per square inch.

### 2.9 CURRENT TRANSFORMERS

\*\*\*\*\*

**NOTE: For motor differential protection, the "Flux-Balancing Current Differential" scheme, as shown in Fig. 16 of IEEE C37.96, is preferred and will generally be applicable. In this case, the window-type current transformers should be used. However, when the KVA rating of a motor is approximately one-half the supply transformer KVA rating, or greater, it may be necessary to use the differential scheme shown in Fig. 15 of IEEE C37.96, in which case the "Differential Protection" scheme should be used.**

\*\*\*\*\*

Current transformer shall meet the applicable requirements of [IEEE C57.13](#) and [IEEE C37.96](#). Secondary circuits [shall] [shall not] be grounded at the motor, and all leads from each individual transformer shall be brought out to terminal blocks. They shall be of the dry or compound-insulated type and shall be provided with a suitable means of mounting and for grounding the frame. Each current transformer secondary lead shall be connected to a terminal block of the short-circuiting type and shall be conveniently located to permit short-circuiting the secondary windings without requiring access to the primary bus compartments. The polarity of the current transformers shall be plainly marked. [Each motor shall be provided with three indoor dry-type window transformers with single secondary and rated [50/5 amperes, 600 volts] [\_\_\_\_\_]. Current transformers shall have minimum full-wave insulation level of 10 kV and, when installed, shall meet the requirements for a [60 kV] [\_\_\_\_\_] basic impulse level (BIL). The transformers shall be mounted in the main terminal box and shall be arranged in the "flux-balancing" connection.] [Each motor shall be provided with three current transformers of rated [4,160] [\_\_\_\_\_] and [60 kV] [\_\_\_\_\_] basic impulse level (BIL). The transformers shall be mounted in the main terminal box and shall be connected in the wye point of the winding for use with differential relays.] All current transformers shall be suitable for continuous operation at the full-rated voltage and current at a frequency of 60 Hz. All current transformers shall be designed to withstand, without damage, the thermal and mechanical stresses resulting from short-circuit currents corresponding to ratings of the breakers in the circuits to which they are connected.

### 2.10 ACCESSORY WIRING AND BOXES

Except for current transformer leads and field control leads, all accessory wiring shall terminate in an accessory terminal box, unless otherwise approved by the Contracting Officer. Boxes shall be drip-proof and treated in the same manner specified for frames to resist corrosion. The accessory terminal box shall be furnished with a door hinged full length and shall be mounted on the motor in a location approved by the Contracting Officer. Rigid galvanized steel conduit shall be used wherever practicable and shall be arranged to make removal unnecessary when the motor is dismantled. A wiring diagram within the enclosure shall be provided for all circuits and

each conductor shall be identified with the designation shown on the diagram. All wiring shall terminate on terminal blocks as specified below.

#### 2.10.1 Wiring

Except as otherwise approved, all wiring shall be 125 degrees C rated flexible copper conductors, No. 14 AWG minimum, with 600-volt insulation. The size and type of temperature detector leads may be in accordance with the manufacturer's standard practice and, where required, shall be suitable for contact with lubricating oil. Each detector shall be connected by three leads to terminal blocks, with one wire connected to a common point on the blocks. The common point for the stator detectors shall be separate from that for the bearing detectors.

#### 2.10.2 Terminal Blocks

All terminal blocks shall be molded closed-back type as defined in NEMA ICS 4, rated not less than 600 volts and shall be provided with covers. The terminals shall be screw-clamp type or stud-and-nut type. White or other light-colored marking strips, fastened by screws to the molded sections at each block, shall be provided for circuit designation. Each connected terminal of each block shall have the circuit designation or wire number permanently marked on a strip. Reversible or spare marking strips shall be furnished with each block and at least 10 percent spare terminals shall be provided.

#### 2.11 JACKING PROVISIONS

Provide suitable means for hydraulic jacking of the rotor to permit inspection, adjustment, or removal of the thrust bearing. Provisions shall also be made for blocking the rotor in the fully raised position. The blocking device shall not require maintenance of hydraulic pressure on the jacks while the assembly is in the raised position.

#### 2.12 SPECIAL TOOLS AND EQUIPMENT

Provide special tools, jigs, fixtures, lifting tackle, and instruments which may be necessary in assembly, erection, operation, maintenance, and repair of equipment. Special tools and equipment are those the design, purpose, and use of which are peculiar to equipment furnished and which are not available from normal wholesale or retail outlets. The motor manufacturer shall provide hydraulic jacking devices as required in order to pull the thrust bearing thrust collar from the upper end of the shaft and shall also furnish one complete set of lifting attachments such as detachable eyebolts or special slings for handling various parts with a hoist.

#### 2.13 SET-DOWN FIXTURES

Furnish one separate motor set-down fixture for each motor rating supplied. This fixture, when installed on the operating floor, shall provide sufficient clearance above the floor for the motor shaft and coupling extending below the motor frame. The fixture shall be suitable for holding the motor during assembly and disassembly. Furnish one separate rotor set-down fixture for each motor rating supplied. The fixture shall hold the rotor in the horizontal position above the floor without unduly stressing the rotor pole pieces or laminations. The motor and rotor fixtures shall be shipped to the pumping station prior to the shipment of any motor.

## 2.14 FACTORY TESTS

\*\*\*\*\*  
**NOTE: The designer should carefully consider whether to allow the Contracting Officer to waive these tests. Decision should be based on expertise in the field within the Division or District.**  
\*\*\*\*\*

Give one motor of each rating and type, selected at random by the Contracting Officer, a complete test. The remainder of the motors shall be given a check test. All complete tests shall be [witnessed by the Contracting Officer] [waived in writing].

### 2.14.1 Witness Test

When the Contractor is satisfied that a motor selected for a "Complete Test" performs in accordance with the requirements of the specifications, the Contracting Officer shall be notified and shall be furnished with two copies of the tabulated data, calculations, and curves required by paragraph COMPLETE TEST below or required to confirm the data required in paragraph SUBMITTALS. Three weeks will be required, after receipt, to review the foregoing information. Should the witness test indicate that a motor does not perform in accordance with the requirements of the specifications, changes or corrections shall be made and new complete witness tests run, at no additional cost to the Government.

### 2.14.2 Complete Test

\*\*\*\*\*  
**NOTE: For the large motors (1,500 hp and above), the efficiency is high, i.e. 95 percent at 1/2 to full load, however, efficiency varies with motor design. In general, high efficiency motors are not cost effective in the large size motors covered by this specification. If other than manufacturer's standard efficiency is required, the designer should list those values in paragraph FACTORY TEST.**  
\*\*\*\*\*

A complete test of a synchronous motor shall including the following:

- a. Resistance of armature and field windings.
- b. Polarity of field coils.
- c. High-potential tests of armature and field windings in accordance with **NEMA MG 1** paragraph 21.52.
- d. Air gap measurement.
- e. V-curves (for zero, 1/2, 3/4, and full load).
- f. Determination of the subtransient, transient, and synchronous reactance.
- g. Conventional efficiency tests, in accordance with **NEMA MG 1** paragraph 21.44. Motor shall meet manufacturer's published efficiency

criteria for 1/2, 3/4, and full rated loads. Calculation of efficiency shall include [that portion of the thrust bearing loss produced by the motor itself] [bearing loss due to external thrust load].

h. Tests to determine temperature rise in accordance with [NEMA MG 1](#) paragraph 21.40.

i. Insulation resistance-temperature test, in accordance with [IEEE Std 43](#). Test result values shall be plotted on semilogarithmic graphs, the insulation resistance values as logarithmic ordinates and the temperature values as uniform abscissas. Readings shall be taken at approximately 10 degrees C intervals. Temperature shall be determined by the resistance method. Also, for comparison purposes, a curve indicating the safe operating value of insulation resistance shall be plotted on the same sheet.

j. Noise level tests in accordance with [NEMA MG 1](#) paragraph 20-50.

k. Motor balance in accordance with [NEMA MG 1](#) paragraph 20.54.

l. Conformance test in accordance with [NEMA MG 1](#) paragraph 20.49.

m. Torques. Torque tests shall be performed in accordance with [IEEE Std 115](#) to demonstrate that the values specified in paragraph "Torques," will be met or exceeded.

#### 2.14.3 Check Tests

A check test of a synchronous motor and exciter shall include the following:

a. Routine test in accordance with [NEMA MG 1](#) paragraph 21.51.

b. Cold resistance measurement.

c. Insulation resistance and winding temperature at time the insulation resistance was measured.

d. Conformance test in accordance with [NEMA MG 1](#) paragraph 20.49.

e. Motor balance in accordance with [NEMA MG 1](#) paragraph 20.54.

#### 2.14.4 Stator Winding Coil Tests

All coils, either before or after they are placed in the slots, shall be tested for short circuits between turns of the individual coils by applying a high frequency voltage of not less than 75 percent of the voltage for which the machine is insulated, or by applying a surge test voltage of equivalent value to the terminals of each coil. Equivalent surge voltage shall be a wave whose peak value is equal to 1.06 times the voltage for which the motor is insulated.

#### 2.14.5 Space Heater Tests

Each winding space heater unit shall be tested at the factory for successful operation and dielectric strength.

PART 3 EXECUTION (Not Applicable)

-- End of Section --