



1. EXTERIOR SHEATHING
2. AIR AND VAPOR BARRIER MEMBRANE, WRAP INTO OPENING
4. RIGID INSULATION (WITHOUT VOIDS)
6. FACE BRICK
7. MORTAR
13. SEALANT AND BACKER ROD
14. THERMAL BREAK
15. HEEL BEAD OF SEALANT TO PROVIDE AIR TIGHTNESS (SNAP-IN GLAZING BEAD LEAKS AIR) CONTINUOUS AT ALL FOUR SIDES OF GLASS
16. HIGH PERFORMANCE INSULATING GLASS UNIT (TRIPLE GLAZED INSULATED UNIT WILL IMPROVE ENERGY PERFORMANCE)
17. SPRAY POLYURETHANE FOAM TO IMPROVE THERMAL PERFORMANCE
18. MINERAL WOOL
19. SEALANT AND BACKER ROD (VERIFY COMPATIBILITY WITH ELASTOMERIC FLASHING)
20. INTERIOR GYPSUM BOARD AND CASING BEAD
21. WINDOW ANCHOR CLIP AND FASTENER (SIZE AND SPACING AS REQUIRED)
22. BLOCKING AS REQUIRED
23. ELASTOMERIC FLASHING (EXTRUDED SILICONE SET IN SILICONE SEALANT OR SELF-ADHERING MEMBRANE FLASHING) (VERIFY COMPATIBILITY WITH AIR AND VAPOR BARRIER), 3" MINIMUM OVERLAP AT MEMBRANE JOINTS
25. SPRAY POLYURETHANE FOAM (PREFERRED), OR RIGID INSULATION
34. ALUMINUM WINDOW
35. STUD CAVITY (NO INSULATION)
36. REMOVABLE TRIM HERE TO FACILITATE FUTURE WINDOW REPLACEMENT
37. LINE OF ELASTOMERIC FLASHING BETWEEN ANCHOR CLIPS
38. MASONRY SILL

B WINDOW JAMB AT BRICK VENEER
 GENERIC CONDITION