

BONDING

1. ALL STEEL DOORS AND FRAMES SHALL BE ELECTRICALLY BONDED TO THE MAGAZINE REBAR CAGE.
2. ALL STRUCTURAL AND MISCELLANEOUS ITEMS EMBEDDED IN CONCRETE SHALL BE ELECTRICALLY BONDED TO THE REBAR CAGE BY A MINIMUM OF WIRE TIES.
3. THE REBAR CAGE SHALL BE MADE ELECTRICALLY CONTINUOUS BY A MINIMUM OF WIRE TIES AT 4'-0" ON CENTERS IN ANY DIRECTION.
4. ALL WALL AND CONSTRUCTION JOINTS REQUIRE BONDING. REFER TO THE ELECTRICAL DRAWINGS FOR DETAILS.

BONDING DETAILS