

**SECTION 23 55 23
GAS-FIRED RADIANT HEATERS**

SPEC WRITER NOTES:

1. Use this section only for NCA projects.
2. Delete between // // if not applicable to project. Also delete any other item or paragraph not applicable in the section and renumber the paragraphs.
3. The spec writer shall review the Physical Security Design Manual for VA Facilities to determine and include any Life Safety requirements called out.

PART 1 - GENERAL

1.1 DESCRIPTION

- A. This section specifies gas-fired tubular infrared radiant heaters.
- B. A complete listing of common acronyms and abbreviations are included in Section 23 05 11, COMMON WORK RESULTS FOR HVAC.

1.2 RELATED WORK

SPEC WRITER NOTE: Retain one of two paragraphs below.

- A. //Section 01 00 01, GENERAL REQUIREMENTS (Major NCA Projects).//
- B. //Section 01 00 02, GENERAL REQUIREMENTS (Minor NCA Projects).//
- C. Section 01 33 23, SHOP DRAWINGS, PRODUCT DATA, AND SAMPLES.
- D. Section 01 42 19, REFERENCE STANDARDS.
- E. Section 01 81 13, SUSTAINABLE DESIGN REQUIREMENTS.
- F. //Section 01 91 00, GENERAL COMMISSIONING REQUIREMENTS.//

SPEC WRITER NOTE: If Section 13 05 41 is included in this project the section shall be obtained from VA Masters.

- G. //Section 13 05 41, SEISMIC RESTRAINT REQUIREMENTS FOR NON-STRUCTURAL COMPONENTS.//
- H. Section 23 05 11, COMMON WORK RESULTS FOR HVAC: General mechanical requirements and items which are common to more than one section of Division 23.
- I. //Section 23 08 00, COMMISSIONING OF HVAC SYSTEMS.//
- J. Section 23 11 23, FACILITY NATURAL-GAS PIPING.
- K. Section 26 05 21, LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES (600 VOLTS AND BELOW).
- L. Section 26 05 26, GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS.

1.3 APPLICABLE PUBLICATIONS

SPEC WRITER NOTE: Make material requirements agree with requirements specified in the referenced Applicable Publications. Verify and update the publication list to that which applies to the project, unless the reference applies to all mechanical systems. Publications that apply to all mechanical systems may not be specifically referenced in the body of the specification, but, shall form a part of this specification.

- A. The publications listed below form a part of this specification to the extent referenced. The publications are referenced in the text by the basic designation only.
- B. American National Standard Institute (ANSI):
Z83.20b/CSA 2.34-2011 (R2013) Gas-Fired Low Intensity Infrared Heaters
- C. National Fire Protection Association (NFPA):
54-2015.....National Fuel Gas Code

1.4 SUBMITTALS

- A. Submittals, including number of required copies, shall be submitted in accordance with Section 01 33 23, SHOP DRAWINGS, PRODUCT DATA, AND SAMPLES.
- B. Information and material submitted under this section shall be marked "SUBMITTED UNDER SECTION 23 55 23, GAS-FIRED RADIANT HEATERS", with applicable paragraph identification.
- C. Manufacturer's Literature and Data including: Full item description and optional features and accessories. Include dimensions, weights, materials, applications, standard compliance, model numbers, size, and capacity.
- D. Product Data: Include rated capacities, operating characteristics, furnished specialties, and accessories for each type of product indicated.
- E. Shop Drawings: Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
 - 1. Location and size of each field connection.
 - 2. Location and arrangement of integral controls.
 - 3. Enclosure joints, corner pieces, access doors, and other accessories.
 - 4. Wiring Diagrams: Power, signal, and control wiring.

- F. Complete operating and maintenance manuals including wiring diagrams, technical data sheets, information for ordering replacement parts, and troubleshooting guide:
1. Include complete list indicating all components of the systems.
 2. Include complete diagrams of the internal wiring for each item of equipment.
 3. Diagrams shall have their terminals identified to facilitate installation, operation and maintenance.
- G. //Completed System Readiness Checklist provided by the Commissioning Agent and completed by the contractor, signed by a qualified technician and dated on the date of completion, in accordance with the requirements of Section 23 08 00, COMMISSIONING OF HVAC SYSTEMS.//
- H. //Submit training plans and instructor qualifications in accordance with the requirements of Section 23 08 00, COMMISSIONING OF HVAC SYSTEMS.//

1.5 QUALITY ASSURANCE

- A. Refer to paragraph QUALITY ASSURANCE, in Section 23 05 11, COMMON WORK RESULTS FOR HVAC.

1.6 AS-BUILT DOCUMENTATION

SPEC WRITER NOTE: Coordinate O&M Manual requirements with Section 01 00 01, GENERAL REQUIREMENTS (Major NCA Projects) or Section 01 00 02, GENERAL REQUIREMENTS (Minor NCA Projects). O&M manuals shall be submitted for content review as part of the close-out documents.

- A. Submit manufacturer's literature and data updated to include submittal review comments and any equipment substitutions.
- B. Submit operation and maintenance data updated to include submittal review comments, substitutions and construction revisions shall be //in electronic version on CD or DVD// inserted into a three ring binder. All aspects of system operation and maintenance procedures, including applicable piping isometrics, wiring diagrams of all circuits, a written description of system design, control logic, and sequence of operation shall be included in the operation and maintenance manual. The operations and maintenance manual shall include troubleshooting techniques and procedures for emergency situations. Notes on all special systems or devices shall be included. A List of recommended spare parts (manufacturer, model number, and quantity) shall be furnished. Information explaining any special knowledge or tools the

owner will be required to employ shall be inserted into the As-Built documentation.

- C. The installing contractor shall maintain as-built drawings of each completed phase for verification; and, shall provide the complete set at the time of final systems certification testing. As-built drawings are to be provided, and a copy of them in Auto-CAD version //____// provided on CD or DVD. Should the installing contractor engage the testing company to provide as-built or any portion thereof, it shall not be deemed a conflict of interest or breach of the 'third party testing company' requirement.
- D. Certification documentation shall be provided to COR 10 working days prior to submitting the request for final inspection. The documentation shall include all test results, the names of individuals performing work for the testing agency on this project, detailed procedures followed for all tests, and certification that all results of tests were within limits specified.

PART 2 - PRODUCTS

2.1 TUBULAR INFRARED HEATERS

- A. Description: Factory assembled, piped, and wired, and complying with ANSI Z83.20b/CSA 2.34, UL Listed.
- B. Fuel Type: Design burner for natural gas having characteristics same as those of gas available at Project site.
- C. Combustion Tubing: 100 mm (4 inch) diameter aluminized steel with high-emissivity, high-temperature, corrosion-resistant external finish.
- D. Tubing Connections:
 - 1. Stainless steel couplings or flared joints with stainless steel draw bolts.
 - 2. ////90// //180// degree-bend emitter steel tubing with high-emissivity, high-temperature, corrosion-resistant external finish.//
- E. Reflector: Polished aluminum, 97 percent minimum reflectivity, with end caps. Shape to control radiation from tubing for uniform intensity at floor level with 100 percent cutoff above centerline of tubing. Provide for rotating reflector or heater around a horizontal axis for minimum 30-degree tilt from vertical.
 - 1. Reflector Extension Shields: Same material as reflectors, arranged for fixed connection to lower reflector lip and rigid support to provide 100 percent cutoff of direct radiation from tubing at angles greater than 30 degrees from vertical.

2. Include hanger kit.

F. Accessories:

1. //Protective grilles mounted to reflectors to protect emitter tubing.//
2. //Stainless steel flexible connector with manual valve for gas supply.//
3. //Hanger chain with "S" hooks.//
4. //5 mm (3/16 inch) diameter aluminized steel wire tubing hanger and reflective supports.//
5. //Rigid mounting kits.//

G. Burner Safety Controls:

1. Gas Control Valve: Single-stage, regulated redundant 24-V ac gas valve containing pilot solenoid valve, electric gas valve, pilot filter, pressure regulator, pilot shutoff, and manual shutoff all in one body.
2. Failure Safeguards: 100 percent shutoff of gas flow in the event of flue or power failure.
3. Safety lockout of burner after three consecutive ignition failures.
4. Blocked Vent Safety: Differential pressure switch in burner safety circuit to stop burner operation with high discharge or suction pressure.
5. Control Panel Interlock: Stops burner if panel is open.
6. Indicator Lights: Burner-on indicator light.

H. Burner and Emitter Type: Gravity-vented power burner, with the following features:

1. Emitter Tube: 100 mm (4 inch) diameter, aluminized tubing with sight glass for burner and pilot flame observation.
2. Venting: Connector at exit end of emitter tubing for vent-pipe connection.
 - a. Vent Terminal: //Vertical// //Horizontal//.
3. Burner: Stainless steel.
4. Ignition System: Direct spark //24/25-V ac// //115/170-V ac// with flame rod sensing capabilities.
5. Combustion Blower Fan: Dynamically balanced, direct driven, forward-curved fan with stainless steel impeller and aluminized steel housing, with a minimum temperature rating of 232 degrees C (450 degrees F).

6. Combustion-Air Connection: Duct connection for combustion air to be drawn directly from outdoors by burner fan.

2.2 CONTROLS

- A. Thermostat: Single-stage, wall-mounting type.
 1. Control Transformer: Integrally mounted.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. If an installation is unsatisfactory to the COR, the Contractor shall correct the installation at no additional cost or time to the Government.
- B. Install and connect gas-fired radiant heaters and associated fuel and vent features and systems according to NFPA 54, applicable local codes and regulations, and manufacturer's written installation instructions.
- C. Suspended Units: Suspend from substrate using chain hanger kits and building attachments.
- D. Maintain manufacturers' recommended clearances to combustibles.

3.2 CONNECTIONS

- A. Install piping adjacent to gas-fired radiant heaters to allow service and maintenance.
- B. Gas Piping: Comply with Section 23 11 23, FACILITY NATURAL-GAS PIPING. Connect gas piping to gas train inlet; provide union with enough clearance for burner removal and service.
- C. Ground electric convection heating units according to Section 26 05 26, GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS.
- D. Connect wiring according to Section 26 05 21, LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES (600 VOLTS AND BELOW).

3.3 FIELD QUALITY CONTROL

- A. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- B. Remove and replace malfunctioning units and retest as specified above.

3.4 ADJUSTING

- A. Adjust initial temperature set points.
- B. Adjust burner and other unit components for optimum heating performance and efficiency.

3.5 //SEISMIC BRACING

- A. Where applicable provide Seismic bracing as required under specification Section 13 05 41, SEISMIC RESTRAINT REQUIREMENTS FOR NON-STRUCTURAL COMPONENTS.//

3.6 STARTUP AND TESTING

- A. Make tests as recommended by product manufacturer and listed standards and under actual or simulated operating conditions and prove full compliance with design and specified requirements. Tests of the various items of equipment shall be performed simultaneously with the system of which each item is an integral part.
- B. When any defects are detected, correct defects and repeat test at no additional cost or time to the Government.
- C. //The Commissioning Agent will observe startup and contractor testing of selected equipment. Coordinate the startup and contractor testing schedules with the COR and Commissioning Agent. Provide a minimum notice of 10 working days prior to startup and testing.//

3.7 //COMMISSIONING

- A. Provide commissioning documentation in accordance with the requirements of Section 23 08 00, COMMISSIONING OF HVAC SYSTEMS.
- B. Components provided under this section of the specification will be tested as part of a larger system.//

3.8 DEMONSTRATION AND TRAINING

- A. Provide services of manufacturer's technical representative for //four// // // hour//s// to instruct each VA personnel responsible in the operation and maintenance of units.
- B. //Submit training plans and instructor qualifications in accordance with the requirements of Section 23 08 00, COMMISSIONING OF HVAC SYSTEMS.//

- - - E N D - - -