



Room Finishes, Door, & Hardware Schedule

Program Guide

PG 18-14

This page left intentionally blank

CANCELLED

FOREWORD

This document provides standards for interior finishes, doors, and hardware for new or renovated facilities constructed within the Department of Veterans Affairs. The essential criteria for selection of these materials are their appropriateness for function and space, sustainability, life cycle costs, durability, and ease of maintenance.

Lloyd H. Siegel
Associate Executive Director
Office of Facilities Planning

CANCELLED

This page left intentionally blank

CANCELLED

ACKNOWLEDGMENTS

Credit is due to the following individuals whose guidance, advice, and effort made this publication possible:

OFFICE OF CONSTRUCTION AND FACILITIES MANAGEMENT

Donald L. Myers, AIA, NCARB
Jatinder (Jeet) Kumar
Orest Burdiak
Ronald Johnson
Gary Fischer
Renee Tietjen
Christine Emanuelson, NCIDQ
Alice Bower
James Symanski
Malcolm Junkin

Architect, Director Facilities Standards Service (FSS)
Architect, FSS, COR
Principal Interior Designer
Architect, FSS
Senior Healthcare Architect, FSS
Architect, FSS
VHA Program Manager, Interior Design
Interior Designer, Syracuse VA Medical Center
Sustainable Design Program Manager
CFM Contractor

PRIVATE SECTOR CONSULTANTS

Paul G. Finch, AIA, ACHA, NCARB
Kimberly J. Bernheimer, CID, IIDA, LEED AP ID+C
Lynne B. Manning
Louise A. Vega

Paul Finch & Associates, P.C. dba PF&A Design
Paul Finch & Associates, P.C. dba PF&A Design
Paul Finch & Associates, P.C. dba PF&A Design
Paul Finch & Associates, P.C. dba PF&A Design

This page left intentionally blank

CANCELLED

CONTENTS

SECTION I – GENERAL

Requirements on the use of this Program Guide

SECTION II – DOORS AND HARDWARE

Type, size, glazing, hardware, and special features of wood and metal doors

SECTION III – ROOM FINISHES, DOOR AND HARDWARE SCHEDULE

Door sizes, door and application codes, door symbols, door legend and notes

Chapters of Program Guide 18-9 VA Space Planning Criteria are listed below:

Chapter	Service Area		
General	Telecom, Mechanical Equipment and Elevator	218	Veterans Assistance Unit
	Machine Rooms	220	Credit Union
100	Medical/Surgical Inpatient Units	222	Dental Service
102	Intensive Care Nursing Units	224	Nutrition and Food Service
104	Spinal Cord Injury / Disorders Center	226	Electroencephalography (EEG) Laboratory
106	Community Living Center (CLC)	230	Engineering Service
110	Mental Health and Behavioral Patient Care Units	232	Office of Information and Technology
111	Polytrauma Rehabilitation Center (PRC)	233	Eye Clinic
202	Substance Abuse Clinic	234	Fiscal Service
204	Audiology and Speech Pathology Service	238	Medical Center Director Suite
206	Veterans Canteen Service	240	Pathology and Laboratory Medicine Service
208	Chaplain Service	244	Lobby
210	Cardiovascular Laboratory Service	246	Health Administration Service
212	Pulmonary Medicine Service	248	Medical Media Service
214	Clinical Services Administration	252	Nuclear Medicine Service
		254	Nursing Service Administration

<u>Chapter</u>	<u>Service Area</u>		
		282	Social Work Service
256	Emergency Department (ED) and Urgent Care Clinic (UCC)	284	Logistics Service
		285	Sterile Processing Service
258	Women Veterans Clinical Service (WVCS)	286	Surgical Service: Standard, Intermediate or Complex Center
260	Mental Health Clinic		
261	Day Treatment Center	287	Digestive Diseases - Endoscopy Suite
262	Ambulatory Care (Hospital Based)	290	Voluntary Service
264	PACT Primary Care Clinic (PPCC)	300	Day Hospital
265	Outpatient/PACT Clinic	308	Prosthetic and Sensory Aids Service
266	Human Resources Management	312	Domiciliary
268	Pharmacy Service	316	Dialysis Center
269	Recreation Therapy Service	400	Library Service
270	Physical Medicine and Rehabilitation Service	402	Educational Facilities
272	Psychology Service	406	Environmental Management Service (EMS) Administration
274	Quarters, On-Call		
275	Magnetic Resonance Imaging	408	Environmental Management Service - Laundry and Linen Operation
276	Radiology Service		
277	Radiation Therapy Service	410	Environmental Management Service - Lockers, Lounges, Toilets, and Showers
278	Research and Development		
279	Police Service	420	Childcare Development Center
280	Service Organizations		

CANCELLED

SECTION I – GENERAL

A. USE OF THE PROGRAM GUIDE

1. The requirements in this Program Guide apply to new construction projects and to renovation projects where the existing finishes and door openings are not suitable for the intended use of the space involved. **The Door, Hardware, and Finish Schedules are intended as VA Standards that are intended to be followed for the selection of finishes, doors, and hardware. The Architect, Interior Designer, and Hardware Consultant shall consult and review the requirements with the facility to understand the functions of the rooms for that particular project and adjust finishes, doors, and hardware accordingly. Security systems standards at various facilities may require selection of different devices such as push button locks, card readers, or proximity readers as an example.** Refer to Standard Details PG-18-4 for additional requirements.
2. Doors and hardware requirements are indicated by their respective door symbols and hardware set numbers in Section III of this Program Guide. Additional requirements are shown in Section II, "Doors and Hardware". For door frame requirements refer to Standard Details PG 18-4.
3. Room Codes are from VA Space Planning Criteria (PG 18-9). Reference VA National BIM Standards for guidance.
4. Finishes are scheduled in Section III for the floor, base, wainscot, wall, and ceiling surfaces for each room or space. See list of finish abbreviations in paragraph (b) below.
 - a. Where a combination of materials are separated by the symbol "/" i.e. GWB/CMU, AT/(GWB), etc., the designer shall select the appropriate materials from those listed on the basis of project requirements and cost and shall detail and specify only the selected materials in the construction documents. The "/" indicates the option of materials listed. Where a combination of materials separated by the symbol "-" i.e. GWB-W, etc. indicates an additional material finish or modification.
 - b. The following abbreviations are used for material and finish codes throughout this Guide. The A/E shall coordinate any additional abbreviations, per project requirements, and the construction documents.

ADO	Automatic Door Operator	P	Paint (Exterior and Interior; Transparent, Semi-Transparent, and Opaque Finishes)
AF	Access Flooring	PRB	Profile Base
AT	Acoustical Ceiling (Tile)	PT	Porcelain Tile (Floor and Base)
AT (SP)	(SP) Acoustical Ceiling (with Sprayed Plastic Finish)	QT	Quarry Tile
BIM	Building Information Model	RAF	Resilient Athletic Flooring
C	Concrete	RB	Resilient Base (Rubber or vinyl with factory formed inside and outside corners)
CBB	Concrete Backer Board	RES*	Resinous Flooring
CMU	Concrete Masonry Units (Unit Masonry)	RES-W*	Resinous/Epoxy Wall/Ceiling
CP	Carpet (without Cushion Broadloom)	RF	Rubber Flooring
CPT	Carpet Tile	RRF	Raised Rubber Flooring
CT	Ceramic Tile	RSF	Resilient Sheet Flooring (Chemically Welded Seams)
EFTR	Existing Finish to Remain	RWC	Rigid Vinyl Wall Covering (Wall Protection - Roll or Sheet)
EPY	Epoxy Flooring	S	Solid Surface
EX	Existing	SC	High Build Glazed Coating (Special Coating)
EXP	Exposed	SD	Static Dissipative
GL	Glass (Glazing)	SP	Special Faced
GWB	Gypsum Wallboard Systems	ST	Stone (Cast)
HW	Hardware Set (Finish or Builder's Hardware)	SVT	Solid Vinyl Floor Tile
LN	Linoleum	TER	Terrazzo, Poured
LVT	Luxury Vinyl Tile	TT	Terrazzo Tile (Plastic Matrix)
MAT	Carpet Mat (Walk-Off Mat)	VT	Vinyl Tile (High Content Vinyl)
NO	Number	VWC	Vinyl Wall Covering
PC	Precast (Architectural Precast Concrete Pavers)	WD	Wood
		WSF	Welded Seam Sheet Flooring (Heat Welded with Rod)
		SS	Stainless Steel

* See Paragraph c. below for definitions and specification section references to be used for RES and RES-W

- c. The following definitions and specification section references are to be used for resinous flooring and wall materials. Ensure that Resinous Flooring (RES) or Wall/Ceiling (RES-W) are specified where non-porous seamless surfaces are required/preferred over rigid substrates. Refer to this section for the appropriate flooring/wall/ceiling for the room type and use. There key areas are for recommended use; designer shall select a resinous system for a specific project based on function and aesthetics. Additives may be utilized to achieve slip-resistance where required.

Specification Section Reference	09 67 23.20 09 67 23.21	09 67 23.30	09 67 23.50	09 67 23.60	09 97 33.10
Finish Schedule	RES-2	RES-3	RES-5	RES-6	RES-W
System Description	<p>Medium /Heavy-duty, Decorative (Vinyl Chip) Broadcast resinous flooring with integral cove base</p> <p>Broadcast application for new construction</p> <p>Renovation and heavy duty applications add non climatic epoxy mortar base with Broadcast topping</p>	<p>Heavy -duty, decorative Epoxy trowel quartz mortar chemically resistant seamless mortar base resinous flooring with integral cove base</p>	<p>Heavy-duty Epoxy Urethane terrazzo flooring with integral cove base</p>	<p>Heavy duty urethane and Epoxy mortar flooring system with integral base</p> <p>RES-6A Urethane Climatic areas subject to temperature swings</p> <p>RES-6B Epoxy non Climatic for high abuse and concrete renovation</p>	<p>Seamless resinous coating for walls and ceiling</p>
Area Usage Recommendation	SEE LISTING BELOW				

DECORATIVE MEDIUM DUTY: ISOLATION TOILETS / PATIENT ROOMS	
RES-2	Barrier Suite (Ante Room; Changing Room; Holding Room; Shower Room; Toilet Room and Procedure Laboratory)
	Holding (Room; Quarantine; Radioscopy Waste Decay)
	Infectious Disease Suite (Ante Room; Changing Room; Holding Room; Shower Room; Toilet Room; Autoclave Room and Procedure Laboratory)
	Isolation Bathrooms/Toilet
	Isolation/Seclusion Room (Patient Room; and Toilet Room)
	Patient (Mental Health) Bathroom/Toilet/Shower
	Patient (Mental Health) Vestibule Shower Room

CANCELLED

DECORATIVE MEDIUM DUTY CHEMICAL RESISTANT: PATIENT / VISITOR / STAFF LABORATORIES	
RES-3	Blood Bank (Blood Produce Preparation/Modification; Blood Product Storage and Hemotherapeutics)
	Cell Irradiator
	Cell Sorter
	Chemistry/Special Chemistry
	Clinical Chemistry
	Dialystate Preparation Room
	DNA Sequencing
	Electron Microscope Suite (Microtome Alcove; Scope Room and Preparation Room/Lab)
	Electrophoresis Room
	Extemporaneous Compounding
	High Resolution Mass Spectrometer Room
	Horticulture Therapy
	Immunopathology
	Intravenous Admixture (Anteroom; Aseptic Transfer Room)
	Laboratory, Biomedical research
	Laboratory, Cytology
	Laboratory, Diagnostic
Laboratory, Frozen and Gross Section	

DECORATIVE MEDIUM DUTY CHEMICAL RESISTANT: PATIENT / VISITOR / STAFF LABORATORIES (Continued from previous page)	
RES-3	Laboratory, Frozen Section
	Laboratory, Hematology Coagulation
	Laboratory, Hematology Routine
	Laboratory, Histology
	Laboratory, Procedure
	Laboratory, Radiation
	Laboratory, Rehabilitation Research & Development
	Mass Spectrometer Room
	Microbiology (Biosafety Laboratory; Clinical Microbiology; Mycobacteriology (TB) Laboratory; Mycology Laboratory)
	Microbiology, Media Preparation Room
	Preamplification Room (Regent Prep and Specimen Processing)
	Radioimmunoassay
	Scope Room
	Specimen Accessing, Processing and Distribution
	Surgical Suite (Preparation Room; Recovery ICU; Scrub and Gown Room; Survival OR; Terminal OR; Workroom and Supply)
	Treatment Room
	Urine (Urinalysis) and Feces
	X-Ray Crystallography
Animal Receiving and Examination Room	

DECORATIVE MEDIUM DUTY CHEMICAL RESISTANT: PATIENT / VISITOR / STAFF LABORATORIES (Continued from previous page)	
RES-3	Chemical / Radioisotope Suite (Animal Holding Room; Animal Procedure Laboratory; Hazardous Waste Disposal)
	Clean (Ethylene Oxide Gas Cylinder; Preparation Area)
	Clean Receiving and Bulk Storage Area
	Clean Room
	Clean: Sterile/Non-Sterile Storage Area
	Environmental Suite (Animal Holding and Procedure Laboratory)
	Preparation Area

HEAVY DUTY - TERRAZZO	
RES-5	Corridors
	Lobby
	Passenger Elevator Lobby

HEAVY DUTY - CLIMATIC	
RES-6A	Cell Bank Freezer
	Freezer Room, Ultra Low
	Mortuary Refrigerator (Cold Room)
	Necropsy Room
	Refrigerated Holding, Waste/Carcass
	Refrigerator, Central Tray Retherm
	Refrigerator, Tray Retherm Cart Holding
	Storage, Refrigerated
	Storage, Refrigerated and Frozen Food
	Storage, Refrigerated Blast-Chilled Food (One or Two-day food bank)
	Storage, Refrigerated Garbage/Trash Holding
	Automatic Cart Wash
	Bulk Food Cart Holding Area
	Cage Wash Room (Cage Wash / Tunnel Wash) Manual/Automated (Vivarium)
	Cook/Chill (High Volume)
	Cook/Serve; Kitchen and Servery
	Diet Kitchen
Dishwashing	

HEAVY DUTY – CLIMATIC (continued from previous page)	
RES-6A	Incinerator Room
	Manual Equipment Wash
	Pot Washing
	Preparation, Assembly and Sterilization (SPD)
	Sanitization and Recycling Area
	Serving Kitchen
	Soiled Transition Room (SPD)
	Sorting and Washing
	Storage, Dry Food and Ingredient Control
	Storage, Non-Food
	Storage, Rethemalization of Bulk
	Washing and Sterilization Room, Glassware
	Autoclave room
	Warm Room, 20° C to 37°C

HEAVY DUTY – NON CLIMATIC	
RES-6B	Autopsy Room
	Isolation /Teaching Autopsy Room
	Clean Receiving and Bulk Storage Area
	Detergent and Water Treatment Room (SPD)
	Food Preparation and Production
	Food Service
	Nourishment Preparation
	Pantry
	Tray Assembly Area
	Tray Cart Storage Area, Clean Carts
	Tray Cart Storage Area, Soiled Carts
	Tray Rethem Cart System, Centralized

B. OTHER REQUIREMENTS

1. **SAFETY GLAZING:** Refer to Master Specification Section 08 80 00 – GLAZING and Standard Details PG 18-4.
 - a. Three (3) types of safety glazing are generally used in interior spaces:
 - 1) Fire Glass ("F") in steel frames shall be used in the following areas:
 - a) Observation Windows in fire-rated partitions and smoke partitions.
 - b) Vision panels in fire-rated doors and smoke doors.
 - 2) Laminated Glass ("A") shall be used as vision panels in doors and observations windows in the following areas:
 - a) Mental Health Units.
 - b) Alcohol and Drug Nursing Units.
 - c) Isolation Rooms in Medical, Surgical, and Nursing Units.
 - 1) Tempered Glass ("T") shall be used in all other Observation Windows and Doors with vision panels, including side lights, and as required by Building Codes.
 - b. In non-sprinklered buildings requiring fire-rated corridors, all glazing between rooms and corridors shall be fire glass in steel frames, subject to size and area limitations of jurisdiction having lawful authority over the work.
2. **CORNER GUARDS / HANDRAILS / WALL GUARDS:** For corner protective guard requirements see Section 10 26 00, "Wall and Door Protection."
3. **STAIRWAYS:** Use molded rubber treads on stairs and rubber tile on floor landings and rubber tile on intermediate landings except for stairs exposed to the weather or those in utilitarian areas not open to the public, such as shops, boiler plants, etc.
4. **WALL PROTECTION AT DRINKING FOUNTAINS AND LAVATORIES:** Provide solid surface panels on mold resistant gypsum board on rear walls of Drinking Fountain Alcoves where wallboard or plaster finishes occur and behind lavatories and end walls in Patient Bedrooms, Examination Rooms, Treatment Rooms, etc. at 762 to 1270 mm (30 to 50 inches) wide, usually terminating at nearest inside corner. Solid surfacing shall extend continuously from top of base to 1220 mm (48 inches) minimum above finished floor.

SECTION II - DOORS AND HARDWARE

A. DOORS:

1. For common types and sizes of doors, refer to Architectural Standard Details PG 18-4 Division 08 Openings for door and frame details, except where uncommon conditions occur.
2. Door symbols shall follow VA CAD Standards for projects in BIM. For projects not in BIM and required to be in CAD due to station limitations, conform to the following standards:

The Door Symbols identify the type, size and special features of doors (excluding frames) for use in a room or space. These symbols and designations shall be used at door openings on floor plan and door schedule drawings. The numbers and letters used for Door Symbols have the following meanings:

- a. The first number (or numbers) indicate door type and door material (odd numbers for wood and even numbers for steel), i.e. "1/2, 4, etc." Where combinations appear such as "1/2, 9/10, etc." either material may be used.
 - b. The first letter indicates door size per Section III, i.e. "M, S, V, etc."
 - c. Pairs of letters indicate pairs of doors, i.e. "MM, SS, VV, etc." Active vs. passive leaves will be as indicated in drawings, unless the doors are intended to operate in unison, as scheduled in Section 08 71 00, "Door Hardware."
 - d. When pairs of doors are of differing widths, the first letter shall denote the active leaf.
 - e. Letters after a dash, i.e. "-A", indicate a modification to a door.
3. Walk-in Refrigerator, Elevator Cab, Trash or Linen Chute and Wall or Ceiling Access Doors are specialized doors covered under relevant specification sections.
 4. For additional door requirements see VA Barrier Free Design Standard PG 18-13 and Architectural Design Manual PG 18-10, "Exterior Entrances and Platforms."
 5. Requirements for exterior entrance doors are outlined in Architectural Design Manual, "Automatic Doors" and "Exit and Egress Door Locks", and specification Section 08 71 13, "Automatic Door Operators."
 6. Wood doors, in lieu of steel doors, shall be specified at doors exposed to public view except in humid areas.
 7. Door Swings:
 - a. Doors to Housekeeping Aids Closets (HAC), Mental Health Security Bedrooms shall open out (reverse). Doors shall swing 180 degrees wherever possible.

- b. Doors to Toilet/Shower Rooms that open off Patient Bedrooms shall open out (reverse) from the space containing the toilet or shall have rescue hardware.
8. Where fire-rated door assemblies are required, they shall open in the direction of exit travel and shall have a fire rating as required by jurisdictions having lawful authority over the work.

B. DOOR HARDWARE:

1. **HARDWARE RESPONSIBILITY:** It is recommended that the selection of hardware and the preparation of Builder's (Finish) Hardware Specification be performed by an independent Hardware Consultant (not a manufacturer's representative, manufacturer, distributor, or sales agency) with a minimum five (5) years' experience specifying door hardware for medical/institutional projects. The Hardware Consultant shall prepare specifications for Section 08 17 10, "Integrated Door Assemblies" and Section 08 71 13, "Automatic Door Operators." The Hardware Consultant shall also review the following sections for coordination with the Door Hardware specification: Section 08 11 13, "Hollow Metal Doors and Frames;" Section 08 14 00, "Interior Wood Doors;" Section 08 41 13, "Aluminum-Framed Entrances and Storefronts;" Section 08 34 53, "Security Doors and Frames," and Section 32 31 13, "Chain Link Fences and Gates," based upon the VA Technical Information Library (TIL) Master Construction Specifications PG 18-1. Hardware types not listed in the TIL Master Construction Specifications, e.g. Section 08 42 23, "Sound Control Door Assemblies;" Section 08 42 29, Automatic Entrances;" and Section 32 31 19, "Decorative Metal Fences and Gates," shall be specified on a per project basis, using the section designations as listed in the Construction Specifications Institute's Master Format 2004, and formatted consistent with the TIL VA Master Construction Specifications. The Hardware Consultant shall co-ordinate with Architect for these sections.
2. **HARDWARE SETS:**
 - a. General: Hardware standards for door openings from Corridors to rooms and spaces is listed under column headings "HARDWARE - H.W. NO." in this Program Guide, except as otherwise shown below. These hardware sets correspond to sets of hardware listed in specification Section 08 71 00, "Door Hardware." Hardware Consultant is responsible for selecting, modifying, or developing appropriate hardware sets for each door opening. Hardware Consultant shall consider the following when selecting appropriate hardware:
 - 1) Doors in Smoke and Fire Partitions: The hardware sets listed under the column heading "HARDWARE - H.W. NO." are indicated for both rated and non-rated doors.

In cases where a smoke barrier or fire door must remain open under normal conditions (fail safe), select a hardware set that has a magnetic hold-open or, where wall conditions will not allow, a combination closer-holder instead of a closer only. Magnetic hold-opens and closer-holders must be connected to the fire alarm system.
 - 2) Lead Lined Doors: Coordinate the hardware sets with the lead lined door and frame details shown on the Standard Detail drawings and the project drawings. Refer to Standard Details PG 18-4 Lead Lined Door Detail #SD081113-03, Architectural.

- 3) Chapel Doors: For Corridor entrance doors to Nave, provide a special Chapel hardware set which reflects a spiritual but non-denominational theme.
- 4) Existing Doors or Frames to remain in place: Select and coordinate hardware requirements for these conditions to ensure that suitable and compatible hardware is provided for intended use of space. Door hardware subcontractor shall be required to field verify compatibility of specified hardware with existing conditions (door and frame type, swing, existing hardware preps) prior to submitting hardware schedule for Architect review, and shall advise of any conflicts and propose solutions in such cases.
- 5) Corridor Doors: Cross-corridor doors to Mental Health Units and other Special Care Units may require electric locks to control free movement of patients. Such locks shall meet the requirements of NFPA-101 as well as allow staff movement in and out of Nursing Unit.
- 6) Panic Doors Serving Non-Ambulatory Patients: Exit doors with panic hardware that serve as a required means of egress for non-ambulatory patients shall utilize Integrated Door Assemblies with recessed panic hardware and, where possible, swing-clear hinges to provide maximum clearance for gurney traffic.
- 7) Automatic Swing Door Operators: The Hardware Consultant shall select or develop hardware sets to meet operational requirements of automatic swing door operators where they occur. Provide for concealed wiring of door-mounted sensors (no armored door loops). Provide for electric unlatching of automatic fire doors without compromising physical security requirements (fail secure); such electric unlatching shall be disabled in a fire alarm condition.
- 8) Security Requirements: Hardware Consultant shall obtain detailed security requirements, security plans, and security door elevations from Architect's Security Consultant. Coordinate power for electric door hardware items. Coordinate provision of alarm contacts (by Door Hardware or Security Section) and indicate in the hardware sets so that doors and frames may be properly factory-prepared. Hardware Consultant shall provide a Theory of Operation (narrative) for each Security Hardware (SH-Series) set.
- 9) Hardware Set Numbering Philosophy: Hardware sets should be identified for the type of facility or security requirement:

Prefix

Hardware Set Use

None	INTERIOR DOORS ONLY: GENERAL - Medical Centers, Outpatient Facilities, General Use, Public Areas in Residential Buildings (Community Living Centers (CLC), Domiciliary, etc.)
E	EXTERIOR DOORS ONLY: GENERAL - Medical Centers, Outpatient Facilities, General Use, Public Areas in Residential Buildings (Community Living Centers (CLC), Domiciliary, etc.). Excludes exterior doors from Community Living Centers and Domiciliary, and exterior security (SH) doors.
G	Exterior Gates (sliding or swinging, all materials). Excludes gates with electronic security (SH)
R	Community Living Centers (CLC) and Domiciliary
MH	Mental Health Patient Care Areas
SH	Doors with Electronic Security (e.g., card readers, electric locks, electric panics, delayed egress locks, alarm contacts, etc.). This does not include automatic doors, unless they also have security features, but does apply to interior doors, exterior doors, and exterior gates.

Hardware Set Numbering

Hardware sets will be numbered by door type (single vs. pair) and general function. See the table below for recommended outline.

Each HW # will have variations within its set. For instance, HW-1 Series could include these variations:

- HW-1 Push/Pull, Closer, Stop
- HW-1B Hospital Latch, Overhead Stop (no closer)
- HW-1A Latchset, Closer, Stop

CANCELLED

GENERAL INTERIOR DOORS			
HW #	Category	Single or Pair	Function
1	General - Interior	Single	Non-locking. May be push/pull, hospital latch, or latchset.
2	General - Interior	Single	Privacy. May be standard privacy, hospital privacy (double thumbturn), keyed indicator privacy, or staff key-only entry indicator privacy.
3	General - Interior	Single	Office. May include standard office with thumbturn or entry lock with thumbturn and deadlock.
4	General - Interior	Single	Classroom. May include standard classroom, double-cylinder utility function (free egress always available), classroom hospital latch. Utility. Latch bolt operated by lever from either side, except when outside is locked by key from inside. When outside lever is locker latch bolt retracted by key from outside or by operating inside lever.
5	General - Interior	Single	Storeroom. May include standard storeroom, storeroom with deadbolt, institutional lock (lockable both sides).
6	General - Interior	Single	Panic. May include exit only, passage lever, lockable lever, storeroom lever, pull.
7	General - Interior	Single	Special. Could include roll-up doors, Won doors, operable partitions, sliding doors, ICU/CCU doors, folding doors, etc.
8	General - Interior	Pair	Non-locking. May be push/pull, hospital latch, or latchset.
9	General - Interior	---	Left blank at this time
10	General - Interior	Pair	Classroom. May include standard classroom, double-cylinder utility function (free egress always available), classroom hospital latch. Utility. Latch bolt operated by lever from either side, except when outside is locked by key from inside. When outside lever is locker latch bolt retracted by key from outside or by operating inside lever.
11	General - Interior	Pair	Storeroom. May include standard storeroom, storeroom with deadbolt, institutional lock (lockable both sides).
12	General - Interior	Pair	Panic. May include exit only, passage lever, lockable lever, storeroom lever, pulls.
13	General - Interior	Pair	Special. Could include sliding doors, folding doors, etc.

GENERAL EXTERIOR DOORS			
HW #	Category	Single or Pair	Function
E1	General - Exterior	Single	Entry lock, typically with deadbolt and interior thumbturn. Can also include glass or aluminum storefront door with deadlock.
E2	General - Exterior	Single	Classroom. May include standard classroom or double-cylinder utility function (free egress always available).
E3	General - Exterior	Single	Storeroom. May include standard storeroom or storeroom with deadlock.
E4	General - Exterior	Single	Panic. May include exit only, pull, or lever.
E5	General - Exterior	Single	Special. May include roll-up doors, sliding doors.
E6	General - Exterior	Pair	Entry lock, typically with deadbolt and interior thumbturn. Can also include glass or aluminum storefront pair with deadlock.
E7	General - Exterior	Pair	Classroom. May include standard classroom or double-cylinder utility function (free egress always available).
E8	General - Exterior	Pair	Storeroom. May include standard storeroom or storeroom with deadlock.
E9	General - Exterior	Pair	Panic. May include exit only, pulls, or lever.
E10	General - Exterior	Pair	Special. May include sliding doors.

EXTERIOR GATES			
HW #	Category	Single or Pair	Function
G1	Gate	Single	No locking. Traffic gate.
G2	Gate	Single	Utility. Double-cylinder utility function (free egress always available).
G3	Gate	Single	May include deadlock, padlock, storeroom function lock (with or without deadbolt), or institutional lock.
G4	Gate	Single	Panic. May include exit only, pull, or lever.
G5	Gate	Single	Special. May include rolling or swing-up gates.
G6	Gate	Pair	No locking. Traffic gate.
G7	Gate	Pair	Utility. Double-cylinder utility function (free egress always available).
G8	Gate	Pair	May include deadlock, padlock, storeroom function lock (with or without deadbolt), or institutional lock.
G9	Gate	Pair	Panic. May include exit only, pulls, or lever.
G10	Gate	Pair	Special. May include rolling gates.

RESIDENTIAL UNIT DOORS			
HW #	Category	Single or Pair	Function
R1	Residential	Single	Entry door to unit. May be keyed entry lock with deadbolt, or stand-alone card reader lock.
R2	Residential	Single	No locking. May include latchset or dummy trim with roller latch.
R3	Residential	Single	Privacy.
R4	Residential	Single	Classroom..
R5	Residential	---	Left blank at this time
R6	Residential	---	Left blank at this time
R7	Residential	Pair	No locking. May include latchset or dummy trim with roller latch.

MENTAL HEALTH AREA DOORS			
HW #	Category	Single or Pair	Function
MH1	Mental Health	Single	Non locking. Passage latch, anti-ligature hardware.
MH2	Mental Health	Single	Privacy lock, anti-ligature hardware.
MH3	Mental Health	Single	Classroom lock, anti-ligature hardware.
MH4	Mental Health	Single	Electrified lock, storeroom or closet lock, with card reader, anti-ligature hardware
MH5	Mental Health	Single	Asylum or institutional lock, with dead latch, anti-ligature hardware.
MH6	Mental Health	Pair	Dead latch or passage latch with pulls, anti-ligature hardware.

CANCELLED

ELECTRONIC SECURITY DOORS			
HW #	Category	Single or Pair	Function
SH1	Security	---	Left blank at this time
SH2	Security	Single	Monitored door. Alarm contacts only.
SH3	Security	Single	Electric lockset.
SH4	Security	Single	Electric panic.
SH5	Security	---	Left blank at this time
SH6	Security	---	Left blank at this time
SH7	Security	---	Left blank at this time
SH8	Security	---	Left blank at this time
SH9	Security	Pair	Electric lockset.
SH10	Security	Pair	Electric panic.
SH11	Security	---	Not in Specification at this time.
SH12	Security	Pair	Controlled egress door. Audible alarm (may include alarm in panic bar) or delayed egress panic.

SECTION III – ROOM FINISHES, DOOR, AND HARDWARE SCHEDULE

DOOR SIZES

MARK	WIDTH	HEIGHT
A	547.2 mm (1'-6")	2032.0 mm (6'-8")
B	609.6 mm (2'-0")	2032.0 mm (6'-8")
C	660.4 mm (2'-2")	2032.0 mm (6'-8")
D	711.2 mm (2'-4")	2032.0 mm (6'-8")
E	762.0 mm (2'-6")	2032.0 mm (6'-8")
F	812.8 mm (2'-8")	2032.0 mm (6'-8")
G	863.6 mm (2'-10")	2032.0 mm (6'-8")
H	914.4 mm (3'-0")	2032.0 mm (6'-8")
I	965.2 mm (3'-2")	2032.0 mm (6'-8")
J	1016.0 mm (3'-4")	2032.0 mm (6'-8")
K	1117.6 mm (3'-8")	2032.0 mm (6'-8")
L	1168.4 mm (3'-10")	2032.0 mm (6'-8")
M	547.2 mm (1'-6")	2033.6 MM (7'-0")

DOOR SIZES

MARK	WIDTH	HEIGHT
N	609.6 mm (2'-0")	2033.6 MM (7'-0")
O	660.4 mm (2'-2")	2033.6 MM (7'-0")
P	711.2 mm (2'-4")	2033.6 MM (7'-0")
Q	762.0 mm (2'-6")	2033.6 MM (7'-0")
R	812.8 mm (2'-8")	2033.6 MM (7'-0")
S	914.4 mm (3'-0")	2033.6 MM (7'-0")
T	1016.0 mm (3'-4")	2033.6 MM (7'-0")
U	1066.8 mm (3'-6")	2033.6 MM (7'-0")
V	1117.6 mm (3'-8")	2033.6 MM (7'-0")
W	1168.4 mm (3'-10")	2033.6 MM (7'-0")
X	1219.2 mm (4'-0")	2033.6 MM (7'-0")
Y	914.4 mm (3'-0")	2033.6 MM (7'-0")
Z	UNASSIGNED	UNASSIGNED

- a. Wherever possible, use industry standard door width sizes: 914.4 mm (3'-0"), 1066.8 mm (3'-6"), and 1219.2 mm (4'-0").
- b. Provide 1117.6 mm (3'-8") wide doors where 1219.2 mm (4'-0") wide doors are impractical.

DOOR APPLICATION CODES

A	Laminated Glass	LL	Lead-Lined Doors
ADO	Automatic Door Operator (Swing or Slide)	LP	Light Proof Louver
ALK	Audible Alarm (On Egress)	M	Mechanical Seal for Light Proof & Sound Retarding Door
CL	Stand-Alone Card Reader Lock	P	Panic Hardware
CR	Card Reader	PB	Stand-Alone Pushbutton Lock
D	Double Glazed Tempered Glass	RF	Radiofrequency Shielded Door
DE	Delayed Egress	RR	Remote Release Button
DPS	Door Position Switch (Door Contact)	STC	Acoustic Door Assembly (Indicate STC Rating #)
H	Electric Hold-Open (Wall-Magnet Preferred, or Electro-Mechanical Closer-Holder)	T	Tempered Glass
IC	Intercom	TL	Timer Lock (Electric Lock/Unlock of Door Using Electric Timer)
ID	Integrated Door Assembly	U	Undercut 1"
IL	Interlocked	V	Lead Glass
L	Louver	F	Fire Rated Glass (No Wire)

DOOR SYMBOLS AND LEGEND

Refer to PG 18-4 Standard Details for projects not in BIM.

NOTES:

1. All doors shall be flush face and 44.45 mm (1-3/4 inches) thick unless noted otherwise.
2. Top and side rails shall be 228.6 mm (9 inches) minimum. Bottom rails shall be 304.8 mm (12 inches) minimum.
3. For scheduling door types see SECTION III.
4. Odd door numbers refer to wood doors. Even door numbers refer to metal doors.
5. Numbers in the schedule for door symbol refers to door size, material, and modification. Door frames to be hollow metal, with the exception of room requiring lead lining.
6. See Standard Door Type Detail #SD080000-01 for door types.
7. Patient Room Toilet doors to swing to outside (reverse); where not feasible provide HW-2B hardware.
8. Door Hardware shall conform to the most stringent requirements set forth in this document, VA Technical Information Library, and the latest edition of International Building Code (IBC).

LEGEND: ROOM FINISHES, DOOR, AND HARDWARE SCHEDULE

PREFIX	MEANING	EXAMPLE USE	EXAMPLE EXPANDED
m:	Material	m: SVT	Material: Solid Vinyl Floor Tile (Luxury Vinyl Tile)
f:	Finish	f: W	Finish: Wall Covering (Vinyl Coated Fabric)
da:	Automatic (Door)	da: ADO	Door Automatic: Automatic Door Operator (Swing or Slide)
dg:	Glazing (Door)	dg: T	Door Glazing: Tempered glass
dl:	Lined (Door)	dl: Yes	Door Lined: Yes
dr:	Rating (Door)	dr: 45	Door Rating: 45 minutes
ds:	Security (Door)	ds: CR	Door Security: Card reader
sw:	Swing (Door)	sw: [12]	Door Swing: See Note 12
t:	Type (Door)	t: 19	Door Type: Upper window, Sound Rated, Wood
s:	Size (Door)	s: V	Size: Width = 3'-8", Height = 7'-0"
hw:	Hardware (Door)	hw: 5G	Door Hardware: Defined Variant "G" of General – Interior, Single, Storeroom. May include standard storeroom, storeroom with deadbolt, institutional lock (lockable both sides).

CONVENTION	MEANING	EXAMPLE USE	EXAMPLE EXPANDED
()	Modification	t:40 (T, CR, ID) s:VV	Door Type: Integrated door assembly, steel (Tempered Glass, Card Reader, Integrated Door Assembly), Size: Two leafs of the same size, Width = 3'-8", Height = 7'-0"
[]	Notes	m:GWB [64,80] f:W	Material: Gypsum Wallboard Systems [See notes 64 and 80], Finish: Wall Covering (Vinyl Coated Fabric)

NOTE ID	NOTE TEXT
64	See Design and Construction Procedures PG-18-3, "Noise Transmission Control".
80	Wall Covering installed over Mold Resistant GWB.

NOTES LEGEND:

ID	NOTE TEXT
1	All hardware by vault door manufacturer.
2	Use for non-system furniture environments.
3	Use for systems furniture environments.
4	Ceiling suspension system should be fabricated from non-ferromagnetic material.
5	Aesthetic specialty materials may be used as accents where the design and budget permits.
6	Carpet tile is preferred especially in high traffic areas. Where budget and design conditions do not allow carpet tile; broadloom carpet may be substituted.
7	Ceramic Tile/Porcelain Tile/Quarry Tile/Solid Surfacing/Resinous Flooring-Wall-Base application over concrete backer board.
8	Height will vary depending on profile base selected.
9	Clipped down AT w/smooth washable surface. See Note 18.
10	Concrete floors shall be finished with a colored hardener (non-slip). "Painted Concrete"
11	Detention function; No Free Egress
12	Door from a negative pressured room to swing into the positive (or higher) pressured room/area to maintain proper pressure relationship and direction of air flow.
13	Doors from clean core into operating rooms.
14	Double-acting door.
15	Double-acting doors with dual hold-open features at entrances to oral surgery.
16	Electro-Pneumatic operated neutron shielded door.
17	Exit access doors shall be equipped with panic hardware and shall swing in the direction of egress.

ID	NOTE TEXT
18	Extend enclosed walls to underside of floor slab above and fully seal them to maintain proper pressure relationship and direction of air flow.
19	Extend resinous flooring 10' beyond sterilizers.
20	Ferromagnetic materials used will become permanently magnetized due to the exposure to the magnetic fields of a high-field MRI.
21	A program area that extends into a main lobby/concourse area specified for terrazzo shall also receive terrazzo as the flooring for that program area.
22	Full height partition(s) to underside of structure above.
23	If space is converted to another use, the residual magnetic contamination may impair or incapacitate other electronic/imaging modalities.
24	In Corridor.
25	Intermediate landing to be rubber flooring, stair treads/risers to be molded rubber.
26	Magnetic hold-open.
27	May need shielding, depending upon use. See Standard Details PG-18-4 for shielding (Radio Frequency, Lead, or Electromagnetic).
28	Provide sliding ICU doors with breakaway feature into room.
29	MH-5A used at Seclusion Rooms only.
30	Provide aluminum door type in Section 08 41 13.
31	Multi-occupancy.
32	No privacy feature. Lockable to prevent access.

ID	NOTE TEXT
33	Provide acoustical/tackable wall covering on two walls.
34	Provide painted 3/4" fire retardant plywood over GWB where indicated.
35	Special finishes to be selected on basis of requirements.
36	Provide 1-hour rated enclosure and 6" perimeter concrete curb cast integrally with floor in accordance with NFPA.
37	Provide 1-hour rated in this area.
38	Provide 4 ft. wide metal cased opening for all intra-service Operatories.
39	Provide 4' High SS Wainscot and baked enamel metal ceiling.
40	Provide 6" perimeter concrete curb cast integrally with floor, in accordance with NFPA requirements.
41	Provide a 24" sliding door (manual) between Oral Surgery Rooms.
42	Provide acoustical/tackable wall covering on one wall.
43	Provide anti-fatigue rubber mats.
44	Provide full height solid surface in the shower area. Provide 4'-0" high solid surface in the toilet area.
45	Provide Impact-resistant wall material; see VA "Mental Health Environment of Care Checklist".
46	Provide GWB ceiling at shower.
47	Provide brushed stainless steel wall protection panels.
48	Provide outswing door wherever possible. If door must swing in and is non-rated, revise hardware set to HW-2B.
49	Verify material to match adjacent flooring.

ID	NOTE TEXT
50	See standard details PG-18-4 for shielding requirements.
51	Provide solid surfacing 30" to 50" wide (or terminating at the nearest inside corner) shall go from base to 48" over mold resistant GWB.
52	Provide wall guards and bumper guards in corridors.
53	Not used.
54	Provide wall guards and/or bumper guards where mobile carts and/or mobile equipment are utilized.
55	Provide X door if VAMC includes SCI Unit.
56	Not used.
57	Radio Frequency shielded.
58	Not used.
59	See "Physical Security Design Manual for VA Facilities".
60	See Architectural Design Manual PG-18-10, "Electromagnetic Shielding".
61	Not used.
62	See Design and Construction Procedures PG 18-3, "Physical Security Requirements and Options".
63	Not used.
64	See Design and Construction Procedures PG-18-3, "Noise Transmission Control".
65	See Design and Construction Procedures PG-18-3, "Security".
66	See HVAC Design Manual PG-18-10, "Walk-in Refrigerators and Freezers".
67	See VA "Mental Health Environment of Care Checklist".
68	Not used.

ID	NOTE TEXT
69	Single Occupancy, Unisex.
70	Not used.
71	Single Occupancy. Provide out swing door wherever possible.
72	Single Occupancy. Provide out swing door wherever possible. At MH Hardware sets door MUST swing out.
73	Slip-retardant welded sheet vinyl.
74	At renovation where PT is not an option for drain (if required) resinous poured floor may be used.
75	Structurally isolate to minimize vibrations.
76	Not used.
77	Veneer Plywood Surface required for wall mounted pulleys.
78	Verify astatic or static dissipative flooring material w/ MRI Equipment Vendor.
79	Not used.
80	Wall Covering installed over Mold Resistant GWB.
81	Wall/Surface adjacent to MRI Scanning Room to have Radio Frequency and Magnetic Shielding.

CANCELLED

Chapter **0** Telecom, Mechanical Equipment and Elevator Machine Rooms

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
A. General Areas									
N/A*	Large Telephone Equipment Room	m:EPY	m:RB h:4"	m:GWB [34] f:P		m:EXP	m:Wood t:19 s:SS m:Steel t:20 s:SS	hw:11	1001
N/A*	Electric, Telephone and Signal Closets	m:EPY	m:RB h:4"	m:GWB [34] f:P		m:EXP	m:Wood t:1 s:SS m:Steel t:2 s:SS	hw:5D hw:11	1002
N/A*	Electric, Telephone and Signal Closets (wider than 6-ft. and with 1200 amp or higher devices)	m:EPY	m:RB h:4"	m:GWB [34] f:P		m:EXP	m:Wood t:19 s:SS m:Steel t:20 [17] s:SS	hw:6G hw:12J	1003
N/A*	Mechanical Equipment Room	m:EPY	m:RB h:4"	m:GWB [64] f:P		m:EXP	m:Wood t:19 s:VV m:Steel t:20 s:VV	hw:5G hw:11C	1004
N/A*	Elevator Machine Room	m:EPY	m:RB h:4"	m:GWB [64] f:P		m:EXP	m:Wood t:19 s:V m:Steel t:20 s:V	hw:5G	1005
N/A*	Passenger Elevator Lobbies	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC [54] h:4'- 0"	m:AT	m:Steel t:40 dg:T (ID) s:VV m:Steel t:42 dg:T (ID) s:VV	hw:8	1006
N/A*	Service Elevator Lobbies	m:RES	m:RES h:4"	m:GWB f:P m:CMU f:P	m:RWC h:4'-0" [54]	m:AT	m:Steel t:40 dg:T (ID) s:VV m:Steel t:42 dg:T (ID) s:VV	hw:8	1007
N/A*	Elevator Cab	m:TT	m:TT h:4"	m:PRE-FAB [39]		m:PRE-FAB	t:PRE-FAB	hw:N/A	1008
N/A*	Stairs and Stairwells	m:RF [25]	m:RB h:4"	m:GWB f:P m:CMU f:P		m:EXP	m:Steel t:40 dg:T ds:YES (ID) s:S [17] m:Steel t:42 dg:T ds:YES (ID) s:S [17]	hw:SH-4 hw:SH- 12	1009

Chapter **0** Telecom, Mechanical Equipment and Elevator Machine Rooms

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
A. General Areas									
N/A*	Corridors (Secure)	m:LVT m:SVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:40 dg:T ds:YES (ID) s:VV m:Steel [17] t:42 dg:T ds:YES s:VV	hw:SH-10	1010
N/A*	Corridors (Secure, Automatic Operators)	m:LVT m:SVT	m:RB h:4"	m:GWB [54] f:P	m:RWC [52] h:4'-0"	m:AT	m:Steel t:40 da:ADO dg:T ds:YES (ID) s:VV [17] m:Steel t:42 da:ADO dg:T ds:YES (ID) s:VV [17]	hw:SH-10A	1011
N/A*	Corridors (Non-Secure, Electronic Hold-Open)	m:LVT m:SVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:40 dg:T (ID) s:VV [17] m:Steel t:42 dg:T (ID) s:VV [17]	hw:12C	1012
N/A*	Corridors (Non-Secure, Automatic Operators)	m:LVT m:SVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:40 da:ADO dg:T (ID) s:VV [17] m:Steel t:42 da:ADO dg:T (ID) s:VV [17]	hw:12D hw:12B	1013

Chapter **0** Telecom, Mechanical Equipment and Elevator Machine Rooms

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
A. General Areas									
N/A*	Vestibule (Aluminum Storefront, Automatic Operators)	m:MAT [74]	m:RB h:4"	m:GWB f:P m:CMU f:P		m:AT	m:Aluminum [30] t:40 da:ADO dg:T s:VV [17] m:Aluminum [30] t:42 da:ADO dg:T s:VV [17]	hw:8D	1014

14

Chapter 100 Medical / Surgical Inpatient Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Medical / Surgical Inpatient Unit Calculation									
CALC1	Number of Medical / Surgical Inpatient Units								1015
FA2: Medical / Surgical Inpatient Unit Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1016
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1017
WRF01	Lounge, Family	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4K	1018
NCWD1	Pantry, Family	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:4k	1019
CLSC1	Patient Education / Resource Kiosk	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1020
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1021
TLTF3	Toilet, Family	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1022

Chapter 100 Medical / Surgical Inpatient Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Medical / Surgical Inpatient Unit Patient Area									
BRMS1	Patient Bedroom	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:3 dg:T s:X	hw:1B	1023
TLTS2	Toilet / Shower, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [48]	1024
BRIT1	Patient Bedroom, Airborne Infection Isolation [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:3 [12] dg:T s:X	hw:4P	1025
BRAR1	Anteroom, Airborne Infection Isolation [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:1 [12] dg:T s:X	hw:1K	1026
BRIT2	Patient Bedroom, Protective Environment [18]	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:3 [12] dg:T s:X	hw:4P	1027
BRAR2	Anteroom, Protective Environment Isolation [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:1 [12] dg:T sw:[12] s:X sw:[12]	hw:1K	1028

Chapter 100 Medical / Surgical Inpatient Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Medical / Surgical Inpatient Unit Patient Area									
TLTS2	Toilet / Shower, Patient Isolation	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 18, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2H	1029
BRBA1	Patient Bedroom, Bariatric / Physical Disabilities	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:X	hw:1B	1030
TLTB1	Toilet / Shower, Bariatric / Physical Disabilities Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:X	hw:2H	1031
DAYR1	Dayroom, Recreation	m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:4N	1032
FA4: Medical / Surgical Inpatient Unit Support Area									
NSTA1	Nurse Station	m:LVT	m:RB h:4"	m:GWB [42] f:P		m:AT	t:OPEN	hw:N/A	1033
NSTA3	Alcove, Telemetry Monitoring	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1034
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:CR s:S	hw:SH- 3D	1035
NCWD1	Nourishment Station	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	1036

Chapter 100 Medical / Surgical Inpatient Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Medical / Surgical Inpatient Unit Support Area									
WRCH1	Workroom, Nurse	m:CPT [6] m:VT	m:RB h:4"	m:GWB [42] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1037
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	1038
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	1039
LCCL2	Linen Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F dr:45 min ds:CR s:SS	hw:SH- 9A	1040
SRSE1	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:p	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:4F	1041
SRGC2	Storage, Medical Gas	m:VT	m:RB h:4"	m:GWB [54] f:p	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F dr:45 min s:V	hw:5B	1042
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1043
XRM01	Alcove, Mobile X-Ray Machine	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1044
SRLW2	Alcove, Wheelchair / Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1045
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1046

Chapter 100 Medical / Surgical Inpatient Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Medical / Surgical Inpatient Unit Staff and Administrative Area									
OFA09	Office, Nurse Manager	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1047
OFA09	Office, Nurse Supervisor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1048
OFA07	Workstation, Social Worker	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1049
OFA07	Workstation, Dietitian	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1050
OFA07	Workstation, Ward Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1051
CRA01	Conference Room	m:CPT [6]	m:PRB [8]	m:GWB [42, 64] f:P [5]		m:AT	m:Wood t:19 dg:T s:S	hw:4J	1052
RPR01	Copier / Printer Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1053
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1054
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1055
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1056

Chapter 100 Medical / Surgical Inpatient Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Common Support Area									
DL001	Lounge, Patient Discharge	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:X m:Steel s:X	hw:4K	1057
MMRP2	Materials Handling Terminal, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:SS m:Steel t:12 dg:F ds:YES s:SS	hw:SH- 9A	1058
MMRP3	Materials Handling Terminal, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:CR s:SS	hw:SH- 9A	1059
UTLC2	Chute Room, Waste Disposal	m:RES	m:RES [7] h:4"	m:GWB f:SC	m:SS [47] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min s:X m:Steel t:12 dg:F s:X	hw:1J	1060
UTLC3	Chute Room, Soiled Linen Disposal	m:RES	m:RES [7] h:4"	m:GWB f:SC	m:SS [47] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min s:X m:Steel t:12 dg:F s:X	hw:1J	1061
SRE01	Storage, Multipurpose / Specialty	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:U	hw:4F	1062
SRS01	Storage, Environmental Management Service	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V m:Steel t:12 dg:F s:V	hw:5B	1063
UTR01	Recycling Room	m:VT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	m:Wood t:9 dg:T s:S	hw:SH- 3C	1064

Chapter 100 Medical / Surgical Inpatient Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Common Staff and Administrative Area									
OFA07	Workstation, Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1065
OFA07	Workstation, Physician Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1066
OFA07	Workstation, Nurse Clinician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1067
OFA07	Workstation, Consultant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1068
OFA07	Workstation, Clinical Researcher	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1069
OFA07	Workstation, Clinical Pharmacist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1070
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1071
FA8: Education Area									
OFA09	Office, Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1072
OFA07	Workstation, Intern / Resident / Fellow	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1073
OFA07	Workstation, Patient Care Instructor	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1074

Chapter **100** Medical / Surgical Inpatient Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Education Area									
CLR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	1075

61

CANCELLED

Chapter 102 Intensive Care Nursing Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Intensive Care Nursint Unit Calculation									
CALC1	Number of Intensie Care Nursing Units								1076
FA2: Intensive Care Nursing Unit Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1077
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1078
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1079
TLTF3	Toilet, Family	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1080
WRF01	Lounge, Family	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4K	1081
NCWD1	Pantry, Family	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:4K	1082
CLSC1	Patient Education, Resource Kiosk	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1083

Chapter 102 Intensive Care Nursing Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Intensive Care Nursing Unit Patient Area									
BRIC1	Patient Room, Intensive Care	m:LVT	m:RB h:4"	m:GWB [64] f:SC		m:AT [9] f:SC	m:N/A t:OPEN dg:N/A s:N/A m:Wood t:3 dg:T s:X	hw:N/A hw:1B [28]	1084
TLTU1	Toilet, Intensive Care Patient [18]	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [48]	1085
BRII1	Patient Bedroom, Airborne Infection Isolation [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:3 [12] dg:T s:X	hw:4P	1086
BRAR1	Anteroom, Airborne Infection Isolation [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:1 [12] dg:T s:X	hw:1K	1087
BRII2	Patient Bedroom, Protective Environment Isolation [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:3 [12] dg:T s:X	hw:4P	1088
BRAR2	Anteroom, Protective Environment Isolation [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:1 [12] dg:T s:X	hw:1K	1089

Chapter 102 Intensive Care Nursing Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Intensive Care Nursing Unit Patient Area									
TLTS2	Toilet / Shower, Isolation Patient [18]	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 18, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2H	1090
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1091
FA4: Intensive Care Nursing Unit Support Area									
NSTA1	Nurse Station	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	t:OPEN	hw:N/A	1092
NSTA3	Alcove, Nurse Observation	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1093
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:CR s:S	hw:SH- 3D	1094
NCWD1	Nourishment Station	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	1095
WRCH1	Workroom, Nurse	m:CPT [6] m:VT	m:RB h:4"	m:GWB [42] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1096
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	1097

Chapter 102 Intensive Care Nursing Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Intensive Care Nursing Unit Support Area									
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	1098
LCCL2	Linen Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:SS	hw:SH- 9A	1099
SRSE1	Storage, ICU Equipment	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:4F	1100
SRGC2	Storage, Medical Gas	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F dr:45 min s:V	hw:5B	1101
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1102
XRM01	Alcove, Mobile X-Ray Machine	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1103
SRLW1	Alcove, Wheelchair / Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1104
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1105
FA5: Intensive Care Nursing Unit Staff and Administrative Area									
DUTY1	On-Call Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 s:S	hw:3	1106

Chapter 102 Intensive Care Nursing Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Intensive Care Nursing Unit Staff and Administrative Area									
TLTS1	Toilet / Shower, On-Call Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2H	1107
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1108
OFA09	Office, Nurse Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1109
OFA07	Workstation, Social Worker	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1110
OFA07	Workstation, Dietitian	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1111
OFA07	Workstation, Ward Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1112
RPR01	Copier / Printer Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1113
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1114
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1115

Chapter 102 Intensive Care Nursing Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Intensive Care Nursing Unit Staff and Administrative Area									
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1116
FA6: Support Area									
MMRP2	Materials Handling Terminal, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:SS	hw:SH- 9A	1117
MMRP3	Materials Handling Terminal, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:SS	hw:SH- 9A	1118
UTLC2	Chute Room, Waste Disposal	m:RES	m:RES [7] h:4"	m:GWB f:SC	m:SS [47] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F s:X m:Steel t:12 dg:F s:X	hw:1J	1119
UTLC3	Chute Room, Soiled Linen Disposal	m:RES	m:RES [7] h:4"	m:GWB [54] f:SC	m:SS [47] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F s:X m:Steel t:12 dg:F s:X	hw:1J	1120
SRS01	Storage, Environmental Management Service	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:U m:Steel t:12 dg:F s:U	hw:5B	1121
UTR01	Recycling Room	m:VT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	m:Wood t:9 dg:F s:S	hw:SH- 3C	1122

Chapter 102 Intensive Care Nursing Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Staff and Administrative Area									
OFA07	Workstation, Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1123
OFA07	Workstation, Physician Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1124
OFA07	Workstation, Nurse Clinician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1125
OFA07	Workstation, Consultant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1126
OFA07	Workstation, Clinical Researcher	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1127
OFA07	Workstation, Clinical Pharmacist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1128
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1129
FA8: Education Area									
OFA09	Office, Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1130
OFA07	Workstation, Patient Care Instructor	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1131
OFA07	Workstation, Intern / Resident / Fellow	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1132

Chapter **102** Intensive Care Nursing Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Education Area									
CLR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	1133

58

CANCELLED

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Patient Care Unit Calculation									
CALC1	Number of Acute Care Patient Units								1134
CALC1	Number of Long Term Care Patient Units								1135
FA2: Reception Area									
WRC01	Entrance / Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1136
RECP3	Information Desk	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1137
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1138
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1139
FA3: Acute Care (AC) Unit Patient Area									
BRMS1	AC: One-Bed Patient Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:3 dg:T s:X	hw:1B	1140
BRMS1	AC: Two-Bed Patient Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:3 dg:T s:X	hw:1B	1141

Chapter **104** Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Acute Care (AC) Unit Patient Area									
TLTS2	AC: Patient Bathroom [18]	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2H [48]	1142
BRIT1	AC: Negative Pressure Isolation Patient Room [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:P m:AT f:SP [9]	m:Wood t:3 s:X [12]	hw:4P	1143
BRAR1	AC: Isolation Anteroom [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:1 [12] s:S	hw:1K	1144
TLTS2	AC: Isolation Patient Bathroom [18]	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 18, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 [12] s:U	hw:2H [48]	1145
DAYR1	AC: Day Room / Lounge	m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:X	hw:4N	1146
NCWD1	AC: Nourishment Kitchen	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	1147

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Acute Care (AC) Unit Patient Area									
TLTU1	AC: Patient Toilet	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]	1148
LAUN1	AC: Patient Laundry	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4K	1149
OFDC2	AC: Quiet Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 s:U	hw:4J	1150
FA4: Long Term Care (LTC) Unit Patient Area									
BRMS1	LTC: One-Bed Patient Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:X	hw:1B	1151
BRMS2	LTC: Two-Bed Patient Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:X	hw:1B	1152
TLTS2	LTC: Patient Bathroom [18]	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7 ,44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2H [48]	1153
BRIT1	LTC: Negative Pressure Isolation Patient Room [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:3 [12] dg:T s:X	hw:4P	1154

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Long Term Care (LTC) Unit Patient Area									
BRAR1	LTC: Isolation Anteroom [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:1 [12] dg:T s:X	hw:1K	1155
TLTS2	LTC: Isolation Patient Bathroom [18]	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 [12] s:S	hw:2H [48]	1156
DAYR1	LTC: Day Room/Lounge	m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:4N	1157
NCWD1	LTC: Nourishment Kitchen	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	1158
TLTU1	LTC: Patient Toilet	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2H [48]	1159
LAUN1	TLC: Patient Laundry	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4K	1160
OFDC2	LTC: Quiet Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 s:U	hw:4J	1161

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Acute Care (AC) Support Area									
NSTA1	AC: Nurse Station	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	t:OPEN	hw:N/A	1162
OFA07	AC: Ward Clerk Workstation	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1163
MEDP1	AC: Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:CR s:S	hw:SH- 3D	1164
OFA04	AC: Nurse Supervisor Office	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1165
WRCH1	AC: Patient Charting	m:LVT	m:RB h:4"	m:GWB [42] f:P		m:AT	t:OPEN	hw:N/A	1166
UCCL1	AC: Clean Utility Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	1167
USCL1	AC: Soiled Utility Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	1168
LCCL1	AC: Clean Linen Storage	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dr:45 min s:V	hw:SH- 9A	1169
LCSL1	AC: Soiled Linen Storage	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	1170
SRLW1	AC: Litter Storage	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F dr:45 min s:X	hw:4F	1171

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Acute Care (AC) Support Area									
SRE01	AC: Transfer Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:4F	1172
SRE01	AC: Medical Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:F s:X	hw:4F	1173
SRLW1	AC: Stretcher / Wheelchair Storage Alcove	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1174
SRPB1	AC: Patient Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:4F	1175
JANC1	AC: Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1176
FA6: Long Term Care (LTC) Support Area									
NSTA1	LTC: Nurse Station	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:1 s:S	hw:3E	1177
OFA07	LTC: Ward Clerk Workstation	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1178
MEDP1	LTC: Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3C	1179
OFD01	LTC: Nurse Supervisor Office	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1180
UCCL1	LTC: Clean Utility Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1181

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Long Term Care (LTC) Support Area									
USCL1	LTC: Soiled Utility Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH-3C	1182
LCCL1	LTC: Clean Linen Storage	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:S	hw:SH-9A	1183
LSCL1	LTC: Soiled Linen Storage	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min s:V	hw:SH-3C	1184
SRLW1	LTC: Litter Storage	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:X	hw:4F	1185
SRE01	LTC: Transfer Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:4F	1186
SRE01	LTC: Medical Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:4F	1187
SRLW1	LTC: Stretcher/Wheelchair Alcove	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1188
SRPB1	LTC: Patient Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:X	hw:4F	1189
JANC1	LTC: Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1190
FA7: Patient Area									
DAYR1	Multipurpose Room	m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 da:ADO dg:T s:SS	hw:12H	1191

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Patient Area									
SRS01	Storage, Mulitpurpose / Activities	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:F s:X	hw:4F	1192
XXYYC	Internet Café	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:X	hw:4F	1193
RAMR1	Meditation Room	m:CPT [6]	m:PRB [8] h:4"	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	1194
OFD03	Patient Education	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:X	hw:4J	1195
FSCD1	Resident Dining / Serving	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 da:ADO dg:T s:SS	hw:12H	1196
PTWT1	Tub Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:PT [7, 64] m:CT [7, 64]		m:GWB f:SC	m:Wood t:1 s:X	hw:2H [48]	1197
TRGM1	Exam / Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	1198
PTWT1	Hydrotherapy	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:PT [7, 44] m:CT [7, 44]		m:GWB f:SC	m:Wood t:1 s:X	hw:4M	1199

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Staff and Administrative Area									
WRC02	Visitor Lounge	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	1200
OFA04	Office, Activities Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1201
OFA04	Office, Veterans Service Organization [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1202
OFA04	Office, NSO-PVA Organization [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1203
CRA02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	1204
LCCL1	Linen, Clean Holding, EMS	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1205
DUTY1	Bedroom, On-Call	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 ds:YES s:S	hw:SH-3	1206
TLTS1	Toilet / Shower, On-Call Bedroom	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:19 s:S	hw:2J [71]	1207

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA9: SCI/D Patient Clinic Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1208
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT m:GWB f:P	m:Wood t:1 s:S	hw:3E	1209
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:5'-0" m:CT [7] h:5'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1210
TRGS1	Exam / Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1Q	1211
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2H [48]	1212
EXUD1	Urodynamics: Exam / Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1Q	1213
XDCY1	Urodynamics: Cystoscopy [50]	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:GWB f:SC	m:Wood t:15 s:X	hw:4Q	1214
SRS01	Urodynamics: Storage / Instrument Cleaning Room [50]	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:15 s:X	hw:4Q	1215
RRSS1	Urodynamics: Recovery	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:X	hw:2H [48]	1216

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA9: SCI/D Patient Clinic Area									
DR001	Urodynamics: Dressing Room/Cubicle	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U t:OPEN	hw:2H [48] hw:N/A	1217
TLTS2	Urodynamics: Patient Shower	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] m:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [48]	1218
OFD01	Urodynamics: Urologist Office	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	1219
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1220
UCCL1	Urodynamics: Utility, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1221
OFA04	Office, SCI/D Clinician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1222
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1223
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	1224
NSTA1	Nurse Station	m:LVT	m:RB h:4"	m:GWB [42] f:P		m:AT	t:OPEN	hw:N/A	1225

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA9: SCI/D Patient Clinic Area									
PHOD1	SCI/D Pharmacy	m:RF	m:RF h:4"	m:GWB f:SC		m:AT	m:Steel t:36 dg:F ds:CR s:V	hw:SH-3D	1226
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1227
FA10: SCI/D Patient Therapy Area									
PTES1	Physical Therapy / Kinesiology Therapy	m:RF m:LVT	m:RB h:4"	m:GWB [77] f:P		m:AT	m:Wood t:19 da:ADO dg:T s:SS	hw:12H	1228
OTEV1	Occupational Therapy	m:RF m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 da:ADO dg:T s:SS	hw:12H	1229
XXYYC	Occupational Therapy, PT / OT / KT	m:RF m:LVT	m:RB h:4"	m:GWB [77] f:P		m:AT	m:Wood t:19 da:ADO dg:T s:SS	hw:12H	1230
OTDL1	Activities of Daily Living	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	t:OPEN	hw:N/A	1231
XXYYC	Home Environment Learning	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:R1	1232
XXYYC	Horticulture Therapy	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:U	hw:4K	1233
SRE01	Storage, Equipment	m:EPY	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:X	hw:4F	1234

Chapter **104** Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA10: SCI/D Patient Therapy Area									
PTWT1	Therapeutic Pool	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:PT [7] m:CT [7]		m:AT	m:Wood t:3 da:ADO dg:T s:X m:Steel t:1 da:ADO dg:T s:X	hw:4A	1235
DR001	Dressing Room, Male	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U m:Steel t:2 s:U	hw:2H	1236
DR001	Dressing Room, Female	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 (T) s:U m:Steel t:2 (T) s:U	hw:2H	1237
OFA07	Workstation, Therapist	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1238
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S m:Steel t:2 s:S	hw:2H	1239
FA11: SCI/D Home Care Area									
OFDC2	Interview Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1240
OFA04	Office, Home Care Coordinator [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1241
OFA07	Workstation, SCI/D Home Care Staff	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1242

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA11: SCI/D Home Care Area									
SRE01	Storage, SCI/D Home Care	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:V	hw:5D	1243
FA12: SCI/D Staff and Administrative Area									
OFA09	Office, Spinal Cord Injury / Disorders Center (SCI/D) Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1244
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	1245
OFA07	Workstation, Psychologist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1246
OFA07	Workstation, Social Worker	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1247
OFA07	Workstation, Dietitian	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1248
OFA09	Office, SCI/D Nurse Administrator	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1249
OFA07	Workstation, Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1250
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1251
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	1252

Chapter 104 Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA12: SCI/D Staff and Administrative Area									
MRS01	Medical Records / QA	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4G	1253
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1254
OFA09	Office, Administrative Officer	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1255
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1256
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1257
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1258
TLTS1	Shower, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:CT [7, 44. 64] m:S [7]	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2	1259
FA13: Education Area									
OFA09	Office, Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1260

Chapter **104** Spinal Cord Injury / Disorders Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA13: Education Area									
SL002	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	1261
CRA02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	1262

129

CANCELLED

Chapter 106 Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
A. Residential House and Neighborhood									
VANHG	Residential House, General	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P m:AT	m:Steel t:2 dg:T s:X	hw:R1A	1263
VANHS	Residential House, Specialty	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P m:AT	m:Steel t:2 dg:T s:X	hw:R1A	1264
VANHC	Residential House, Combined	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P m:AT	m:Steel t:2 dg:T s:X	hw:R1A	1265
VANRN	Residential Neighborhood	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P m:AT	m:Steel t:2 dg:T s:X	hw:R1A	1266
B. General Residential House: Resident Areas									
BRNP1	Bedroom, Resident	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R1	1267
BRNP2	Bedroom, Bariatric	m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R7A	1268
TLTS2	Bathroom, Resident	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:X	hw:R3	1269

Chapter **106** Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
B. General Residential House: Resident Areas									
TLTS2	Bathroom, Bariatric	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:P	m:Wood t:1 s:X	hw:R3	1270
LOB02	Vestibule	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R2	1271
DAYR1	Living Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:SS	hw:R7	1272
RAMR1	Quiet Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:GWB f:P m:AT	m:Wood t:19 dg:T s:V	hw:R2B	1273
FSCD1	Dining Room	m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:SS	hw:R7	1274
IPK01	Kitchen and Servery	m:PT	m:PT [7] h:4"	m:PT [7] m:CT [7]		m:GWB f:SC m:AT f:SP	m:Wood t:19 dg:T s:S	hw:R2C	1275
SRS01	Pantry	m:PT	m:PT [7] h:4"	m:GWB f:P		m:GWB f:SC m:AT f:SP	m:Wood t:1 s:S	hw:R2	1276

Chapter 106 Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
B. General Residential House: Resident Areas									
TLTU1	Toilet, Resident/Visitor	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:P m:AT	m:Wood t:19 s:S	hw:R3A [71] hw:4B [31]	1277
NURL1	Laundry	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R2B	1278
C. Specialty Residential House: Resident Areas									
BRNP1	Bedroom, Resident	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R1	1279
BRNP2	Bedroom, Bariatric	m:CPT [6] m:LVT	m:PRB [8] h:4"	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R7A	1280
TLTS2	Bathroom, Resident	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:P m:AT	m:Wood t:1 s:X	hw:R3	1281
TLTS2	Bathroom, Bariatric	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:P m:AT	m:Wood t:1 s:X	hw:R3	1282

Chapter 106 Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
C. Specialty Residential House: Resident Areas									
LOB02	Vestibule	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R2	1283
DAYR1	Living Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:SS	hw:R2B	1284
RAMR1	Quiet Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:GWB f:P m:AT	m:Wood t:19 dg:T s:V	hw:R2B	1285
FSCD1	Dining Room	m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:SS	hw:R7	1286
IPK01	Kitchen and Servery	m:PT	m:PT [7] h:4"	m:PT [7] m:CT [7]		m:GWB f:SC m:AT f:SP	m:Wood t:19 dg:T s:S	hw:R2C	1287
SRS01	Pantry	m:PT	m:PT [7] h:4"	m:GWB f:P		m:GWB f:SC m:AT f:SP	m:Wood t:1 s:S	hw:R2	1288
TLTU1	Toilet, Resident/Visitor	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:P m:AT	m:Wood t:19 s:S	hw:R3A [71] hw:4B [31]	1289
NURL1	Laundry	m:VT	m:RB h:4"	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R2B	1290

Chapter **106** Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
D. Combined Residential House: Resident Areas									
BRNP1	Bedroom, Resident	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R1	1291
BRNP2	Bedroom, Bariatric	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R7A	1292
TLTS2	Bathroom, Resident	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:P	m:Wood t:1 dg:T s:X	hw:R3	1293
TLTS2	Bathroom, Bariatric	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:P	m:Wood t:1 s:X	hw:R3	1294
LOB02	Vestibule	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:X	hw:R2	1295
DAYR1	Living Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:SS	hw:R7	1296

Chapter 106 Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

D. Combined Residential House: Resident Areas

RAMR1	Quiet Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:GWB f:P m:AT	m:Wood t:19 dg:T s:V	hw:R2B	1297
FSCD1	Dining Room	m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:SS	hw:R7	1298
IPK01	Kitchen and Servery	m:PT	m:PT [7] h:4"	m:PT [7] m:CT [7]		m:GWB f:SC m:AT f:SP	m:Wood t:19 dg:T s:S	hw:R2C	1299
SRS01	Pantry	m:PT	m:PT [7] h:4"	m:GWB f:P		m:GWB f:SC m:AT f:SP	m:Wood t:1 s:S	hw:R2	1300
TLTU1	Toilet, Resident/Visitor	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:P m:AT	m:Wood t:19 s:S	hw:R3A [71] hw:4B [31]	1301
NURL1	Laundry	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:S	hw:R2B	1302

E. Residential House (General, Specialty or Combined): Support Areas

NSTA3	House Care / Workstation	m:CPT [6]	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:GWB f:P m:AT	t:OPEN	hw:N/A	1303
-------	--------------------------	-----------	-----------	-----------	---------------	-------------------	--------	--------	------

Chapter **106** Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

E. Residential House (General, Specialty or Combined): Support Areas

LCCL1	Storage, Clean Linen	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:P m:AT f:SP	m:Wood t:11 dg:T s:SS	hw:SH-9A	1304
LCSL1	Storage, Soiled Carts	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:P m:AT [9] f:SP	m:Wood t:1 dg:T s:V	hw:SH-3C	1305
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:GWB f:P m:AT	m:Wood t:11 dg:T s:V	hw:5B	1306
SRSE1	Storage, Medical Supplies	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:GWB f:P m:AT	m:Wood t:1 dg:T s:V	hw:SH-3D	1307
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:GWB f:SC m:AT f:SP	m:Wood t:1 s:U	hw:5D	1308

F. Residential Neighborhood: Patient Areas

DAYR1	Activity / Multipurpose	m:CPT m:SVT	m:RB h:4"	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:19 dg:T s:V	hw:1Q	1309
TLTS2	Bathing Suite	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:PT [7, 64] m:CT [7, 64]		m:GWB f:SC	m:Wood t:1 s:V	hw:4M	1310

Chapter **106** Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
G. Residential Neighborhood: Support Areas									
NSTA1	Neighborhood Care (Nursing) Station	m:LVT	m:PRB [8]	m:GWB [42, 64] f:P		m:GWB f:P m:AT	t:OPEN	hw:N/A	1311
EXRG3	Exam Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:19 s:X	hw:1L	1312
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:S	hw:SH- 3D	1313
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:P m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1314
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:P m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1315
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:GWB f:P m:AT f:SP	m:Wood t:1 s:U	hw:5D	1316
SRLW1	Storage, Stretcher / Wheelchair	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:GWB f:P m:AT	m:Wood t:11 dg:T s:X	hw:5B	1317

Chapter 106 Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
H. Residential Neighborhood: Staff and Administrative Areas									
OFDC1	Office, Activities Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:S	hw:3E	1318
OFD03	Office, Nurse Supervisor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:GWB f:p m:AT	m:Wood t:1 dg:T s:S	hw:3E	1319
CRA01	Conference / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:GWB f:p m:AT	m:Wood t:19 dg:T s:V	hw:4J	1320
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:P	m:Wood t:1 s:S	hw:2 hw:4U	1321
I. Therapeutic Areas									
PTEA1	Physical Therapy	m:RF m:LVT	m:PRB [8]	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:19 dg:T s:SS	hw:10A	1322
OTDL1	Occupational Therapy	m:RF m:LVT	m:PRB [8]	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:19 dg:T s:SS	hw:10A	1323
OFD03	Office, Therapist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:S	hw:3E	1324

Chapter **106** Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
I. Therapeutic Areas									
MEDP1	Pharmacy [59, 62]	m:LVT	m:PRB [8]	m:GWB f:SC		m:GWB f:P m:AT	m:Steel t:36 dg:T s:V	hw:SH-3D	1325
TLTU1	Toilet, Resident	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:P	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1326
J. Resident Support Areas									
RAMR1	Chapel / Medication	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:GWB f:P m:AT	m:Wood t:19 dg:T s:V	hw:4J	1327
XXYYC	Barber / Beauty Salon	m:LVT	m:RB h:4"	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:S	hw:4E	1328
LCCL1	Laundry	m:WSF	m:WSF h:4"	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:V	hw:4K	1329
XXYYC	Housekeeping	m:QT	m:QT [7]	m:GWB f:SC	m:CT [7] h:4'-0"	m:GWB f:P m:AT f:SP	m:Wood t:1 s:U	hw:5D	1330
PMCC1	Maintenance / Engineering Shop	m:SVT	m:RB h:4"	m:GWB [64] f:P	m:RWC h:4'-0"	m:GWB f:P m:AT	m:Wood t:19 dg:T s:V	hw:5G	1331

Chapter **106** Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
J. Resident Support Areas									
COM03	Office, Security	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:S	hw:3E	1332
MMRP1	Receiving / Loading	m:RES	m:RES h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:GWB f:P m:AT	m:Wood t:11 s:V	hw:5F	1333
SRE01	Storage, Bulk	m:SVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:GWB f:P m:AT	m:Wood t:11 dg:T s:V	hw:5F	1334
FSNP1	Food Preparation	m:WSF	m:WSF h:4"	m:GWB f:SC	m:RWC h:4'-0"	m:GWB f:P m:AT f:SP	m:Wood t:19 dg:T s:S	hw:4J	1335
SRPB1	Storage, Resident	m:VT	m:RB h:4"	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:11 dg:T s:V	hw:5	1336

K. Staff and Administrative Areas

LOB01	Lobby	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:S	hw:4G	1337
TLTU1	Toilet, Visitor / Resident	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:P m:AT	m:Wood t:19 s:S	hw:2J [71]	1338

Chapter **106** Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
K. Staff and Administrative Areas									
OFC01	Office, Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:19 dg:T s:S	hw:3G	1339
OFA01	Office, Nursing Administration [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:GWB m:AT	m:Wood t:1 dg:T s:S	hw:3E	1340
OFA02	Office, Nursing Administration [3]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:S	hw:3E	1341
OFD03	Office, Physician	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:GWB f:P m:AT	m:Wood t:19 dg:T s:S	hw:3G	1342
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:GWB f:P m:AT	m:Wood t:19 dg:T s:V	hw:4J	1343
MRS01	Medical Records / QA	m:SVT	m:RB h:4"	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:S	hw:5D	1344
RPR01	Copy Room	m:SVT	m:RB h:4"	m:GWB f:P		m:GWB f:P m:AT	m:Wood t:1 dg:T s:S	hw:4G	1345
OFA03	Cubicle, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:GWB f:P m:AT	t:OPEN	hw:N/A	1346

Chapter **106** Community Living Center (CLC) (Formerly Nursing Home Care Unit)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
K. Staff and Administrative Areas									
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:P m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1347
L. Staff Lockers, Lounge, and Toilets									
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1348
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1349
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1350

Chapter 110 Mental Health and Behavioral Patient Care Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Patient Care Unit Calculation									
CALC1	Number of Mental Health Patient Care Units								1351
FA2: Patient Care Unit Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:GWB f:P	m:Wood t:1 dg:A ds:YES s:U	hw:MH4	1352
OFDC2	Interview Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:19 dg:A s:U	hw:3G	1353
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:P	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1354
FA3: Patient Care Unit Patient Area [67]									
BRNP1	Patient Room, One-Bed	m:WSF	m:WSF h:4"	m:GWB [45, 64] f:P		m:GWB f:P	m:Wood t:1 dg:A s:X	hw:MH1	1355
BRNP2	Patient Room, Two-Bed	m:WSF	m:WSF h:4"	m:GWB [45, 64] f:P		m:GWB f:P	m:Wood t:1 dg:A s:X	hw:MH1	1356
TLTP3	Bathroom, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [45] f:SC	m:S [7,44] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:MH2 [71]	1357

Chapter 110 Mental Health and Behavioral Patient Care Units

FA3: Patient Care Unit Patient Area [67]

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
BRNP1	Patient Room, Bariatric	m:WSF	m:WSF h:4"	m:GWB [45, 64] f:P		m:GWB f:SC	m:Wood t:1 dg:A s:X	hw:MH6 A	1358
TLTP3	Bathroom, Bariatric Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [45] f:P	m:S [7,44] h:4'-0"	m:GWB f:P	m:Wood t:1 s:X	hw:MH2 [71]	1359
BRNP5	Patient Room, Isolation	m:WSF	m:WSF h:4"	m:GWB [18, 45, 64] f:P		m:GWB f:P	m:Wood t:1 dg:A s:X m:Steel t:19 dg:A s:X	hw:MH4 A	1360
BRNP5	Patient Room, Seclusion	m:WSF	m:WSF h:4"	m:CMU f:P m:GWB [45, 64] f:P		m:GWB f:P	m:Wood t:1 dg:A s:X m:Steel t:19 dg:A s:X	hw:MH5 A	1361
BRNP6	Anteroom, Isolation / Seclusion Rooms	m:WSF	m:WSF h:4"	m:CMU f:P m:GWB [18, 45, 64] f:P		m:GWB	m:Wood t:1 dg:A s:S	hw:MH1 A	1362
TLTP3	Bathroom, Isolation / Seclusion Rooms	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [18] f:P		m:GWB f:SC	m:Wood t:19 s:U	hw:MH2 [71] hw:MH5 [11, 29, 71]	1363

Chapter 110 Mental Health and Behavioral Patient Care Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Patient Care Unit Patient Area [67]									
SHWR2	Shower Room, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:S [7,44]	m:S [7,44] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:MH3 [32]	1364
LOB02	Vestibule, Patient Shower Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:S [7,44]	m:S [7,44] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:MH3 A	1365
TLTP1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 45, 64] f:P	m:S [7,44] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:MH2 A [24, 71]	1366
EXRG3	Exam Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:19 s:V	hw:MH1 B	1367
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1368
FSCD1	Dining Room	m:WSF	m:WSF h:4"	m:GWB [5] f:P		m:GWB [5] f:P	m:Wood t:19 dg:A s:U	hw:MH5 [11, 24] hw:MH6 [11, 35]	1369

Chapter 110 Mental Health and Behavioral Patient Care Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Patient Care Unit Patient Area [67]									
DAYR1	Day Room	m:CPT [6]	m:RB h:4"	m:GWB [5, 64] f:P		m:GWB f:P	m:Wood t:19 s:V	hw:MH5 [11, 24] hw:MH6 [11, 35]	1370
OPMH1	Group Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:19 dg:A s:U	hw:MH5 [11, 24] hw:MH6 [11, 35]	1371
NCWD1	Nourishment Station	m:WSF	m:WSF h:4"	m:GWB f:P		m:GWB f:P	m:Wood t:19 dg:T ds:YES s:S	hw:SH- 3C	1372
SRPB1	Storage, Patient	m:WSF	m:WSF h:4"	m:GWB f:P		m:GWB f:P	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1373
NULR1	Laundry Room, Patient	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:11 dg:F s:U	hw:4D	1374
OFDC2	Quiet Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:GWB f:P	m:Wood t:19 dg:A s:U	hw:MH5 [11]	1375
FA4: Patient Care Unit Support Area [67]									
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1376

Chapter 110 Mental Health and Behavioral Patient Care Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Patient Care Unit Support Area [67]									
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 da:PB dg:F dr:45 min ds:YES s:V	hw:SH- 3C	1377
LCCL1	Linen Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:PB s:V	hw:SH- 3C	1378
UTLC1	Linen Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SC	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	1379
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:CR s:S	hw:SH- 3D	1380
SRSE1	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:X	hw:4F	1381
SRGC2	Storage, Medical Gas	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V m:N/A t:OPEN s:N/A	hw:4F hw:N/A	1382
RCA01	Alcove, Crash Cart	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1383
SRS01	Storage, Environmental Management	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V m:Steel t:12 dg:F s:V	hw:5	1384
UTRO1	Recycling Area	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F ds:YES s:S	hw:SH- 3C	1385
COMC1	Data & Tele-Communications Room	m:VT	m:RB h:4"	m:GWB [34] f:P		m:AT	m:Wood t:19 dg:F ds:YES s:S	hw:SH- 3D	1386

Chapter 110 Mental Health and Behavioral Patient Care Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Patient Care Unit Support Area [67]									
UTLC1	Disposal Chute Room, Linen	m:RES	m:RES [7] h:4"	m:GWB [54] f:P	m:SS [47] h:4'-0"	m:AT	m:Wood t:11 da:ADO dg:F s:U	hw:5B	1387
UTC01	Disposal Chute Room, Trash	m:RES	m:RES [7] h:4"	m:GWB [54] f:P	m:SS [47] h:4'-0"	m:AT	m:Wood t:11 dg:F dr:45 min s:U	hw:5B	1388
SRLW2	Alcove, Stretcher / Wheelchair	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1389
FSPT1	Serving Line	m:PT	m:PT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 dg:A s:U	hw:6B [26]	1390
SRS01	Storage, Non Food	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:U s:V	hw:5B	1391
FSCS1	Storage, Bulk Food Carts	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:A s:U	hw:5B	1392
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1393
FA5: Patient Care Unit Staff and Administrative Area									
NSTA1	Nurse Station	m:LVT	m:RB h:4"	m:GWB [42] f:P		m:AT	t:OPEN	hw:N/A	1394
WRCH1	Nurse Workroom	m:CPT [6] m:VT	m:RB h:4"	m:GWB [42] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1395

Chapter 110 Mental Health and Behavioral Patient Care Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Patient Care Unit Staff and Administrative Area									
WRCH1	Dictation Area	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1396
OFA07	Workstation, Substance Abuse	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT f:P	t:OPEN	hw:N/A	1397
CRA01	Conference Room / Report Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	1398
DUTY1	On-Call Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 ds:YES s:S	hw:SH- 3E	1399
TLTS1	Toilet / Shower, On-Call Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:19 s:S	hw:2J	1400
FA6: Staff and Administrative Area									
OFA09	Office, Head Nurse [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:LG s:S	hw:3B	1401
OFA07	Workstation, Ward Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1402
OFA07	Workstation, Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1403

Chapter 110 Mental Health and Behavioral Patient Care Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Staff and Administrative Area									
OFA07	Workstation, Physician Assistant / Nurse Clinician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1404
OFA07	Workstation, Psychologist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1405
OFA07	Workstation, Psychiatrist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT f:P	t:OPEN	hw:N/A	1406
OFA07	Workstation, Chaplain	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT f:P	t:OPEN	hw:N/A	1407
OFA07	Workstation, Social Worker	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT f:P	t:OPEN	hw:N/A	1408
OFA07	Workstation, Dietitian	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1409
OFA09	Office, Nursing Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:LG s:S	hw:3B	1410
OFA07	Workstation, Rehabilitation Medicine Therapist	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1411
OFA07	Workstation, Vocational Rehabilitation Specialist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1412
OFA07	Office, Rehabilitation Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:LG s:S	hw:3B	1413
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1414

Chapter 110 Mental Health and Behavioral Patient Care Units

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Staff and Administrative Area									
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1415
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1416
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1417
FA7: Education Area									
OFA09	Office, Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1418
SL002	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	1419
CRA02	Conference / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:A s:SS	hw:12F	1420

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: PRC Reception Area									
LOB01	Lobby	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:p		m:AT	t:OPEN	hw:N/A	1421
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1422
WRC01	Waiting, General	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1423
WRF01	Waiting, Family	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1424
TLTB1	Toilet, Bariatric	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	1425
BX001	Canteen / Vending Area	m:LVT	m:RB h:4"	m:GWB f:SC		m:AT	t:OPEN	hw:N/A	1426
FA2: Inpatient Unit Patient Area									
BRMS1	Bedroom, Patient	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:3 dg:T s:X	hw:1B	1427

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Inpatient Unit Patient Area									
TLTS4	Toilet / Shower, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]	1428
BRIT1	Bedroom, Airborne Infection Isolation (All) Patient [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC	m:Wood t:3 [12] dg:A s:X	hw:4C	1429
BRAR1	Anteroom, Airborne Infection Isolation (All) [18]	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:GWB f:SC	m:Wood t:1 [12] dg:A s:X	hw:1A	1430
TLTS4	Toilet / Shower, Isolation Patient [18]	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 18, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:19 [12] s:S	hw:2H [48]	1431
SHWR2	Shower, Inpatient Unit	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] m:S	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:1E	1432
FA3: Inpatient Unit Patient Support Area									
NSTA1	Nurse Station, Inpatient	m:LVT	m:RB h:4"	m:GWB [42] f:P		m:AT	t:OPEN	hw:N/A	1433

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Inpatient Unit Patient Support Area									
OFA07	Workstation, Ward Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1434
WRCH1	Report Room, Nurse	m:CPT m:SVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	1435
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH- 3D	1436
NCWD1	Nourishment Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3C	1437
LCCL1	Alcove, Linen	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1438
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1439
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1440
SRE01	Storage, Patient Care Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	1441
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1442
RCA02	Alcove, Equipment	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1443
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1444

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Inpatient Unit Patient and Family Area									
PRD01	Dining Room	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 da:ADO dg:T s:XX	hw:12G	1445
SRE01	Storage, Food Pantry	m:SVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:S	hw:4F	1446
IPK01	Kitchen, OT Training	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:4J	1447
DAYR1	Living Room, Family	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	1448
OFDC2	Quiet Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4N	1449
CLR09	Multipurpose Room, Family Wellness	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:4E	1450
PLAY1	Playroom	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	1451
CRA02	Group Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:SS	hw:10M	1452
LAUN1	Laundry Room, Patient	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT	m:Wood t:1 dg:T s:U	hw:4K	1453
SRPB1	Storage, Patient Luggage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	1454

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Inpatient Unit Patient and Family Area									
TLTU1	Toilet, General	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S [48]	hw:2J [71]	1455
FA5: Inpatient Unit Therapy Patient Area									
PRGY1	Gym, Rehabilitation Therapy	m:RAF	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 da:ADO s:SS	hw:4E	1456
SRE01	Storage, Gym Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	1457
PREV1	Evaluation Room, PT / OT	m:LVT	m:RB h:4"	m:GWB f:P			m:Wood t:19 s:S	hw:3F	1458
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2J [71]	1459
WRTM1	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	1460
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1461
PRRT1	Group Room, Recreation Therapy	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:SS	hw:10M	1462
SRE01	Storage, Recreation Therapy Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	1463

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Inpatient Unit Therapy Patient Area									
CLR01	Computer Activities Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3F	1464
OFA07	Workstation, Recreational Therapist (RT)	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1465
PRDL1	Apartment, Living Skills Training	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:4E	1466
PRNT1	Testing Lab, Neuropsychology	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	1467
PRTM1	BROS Treatment / Office	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 s:U	hw:3E	1468
PRAT1	Inpatient Unit Assistive Technology Lab	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:4E	1469
PRRE1	Rehabilitation Engineering Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:4E	1470
SRS01	Storage, Assistive Technology Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	1471
EXOS1	Office, Speech Language Pathologist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:U	hw:3E	1472
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1473

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Inpatient Unit Staff and Administrative Area									
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1474
OFA07	Workstation, Nurse Educator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1475
OFA04	Office, Provider	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1476
OFA07	Workstation, Clinical Pharmacist / Dietician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1477
OFA07	Workstation, Military Liaison	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1478
WRTM1	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	1479
CRA02	Conference Room	m:CPT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4N	1480
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1481
LR001	Lockers, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1482
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	1483

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Inpatient Unit Staff and Administrative Area									
SHWR1	Shower, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB f:SC m:S [7]	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2	1484
FA7: PTRP Reception Area									
LOB01	Lobby	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	1485
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT f:P	m:Wood t:1 dg:T s:S	hw:3E	1486
WRC01	Waiting, General	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:S	hw:4K	1487
WRF01	Waiting, Family	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:S	hw:4K	1488
TLTB1	Toilet, Bariatric	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	1489

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: PTRP Resident Unit Area									
BRPT3	Bedroom, Resident	m:LVT	m:RB h:4"	m:GWB f:P		m:GWB f:P	m:Wood t:1 dg:T s:U	hw:1B	1490
TLTS3	Toilet / Tub, Resident	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44] f:SC	m:PT h:4'- 0" m:CT h:4'- 0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]	1491
TLTS4	Toilet / Shower, Resident	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]	1492
PRAP1	Apartment, Living Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:GWB f:P	m:Wood t:1 dg:T s:U	hw:R1	1493
BRPT1	Apartment, Bedroom	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:GWB f:P	m:Wood t:1 s:S	hw:R2	1494
TLTS4	Apartment, Toilet / Shower	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [64] f:P	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:19 s:U	hw:2H	1495
PRC03	Apartment, Kitchenette / Laundry	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1496

Chapter **111** Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: PTRP Resident Unit Area									
SRE01	Apartment, Storage	m:VT	m:RB h:4"	m:GWB [54] f:P		m:AT	m:Wood t:11 s:V	hw:5B	1497
FA9: PTRP Resident Unit Support Area									
NSTA6	Nurse Station	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1498
OFA07	Workstation, Ward Clerk	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	1499
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3D	1500
LCCL1	Linen Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:U	hw:SH-3C	1501
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	1502
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	1503
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	1504
SRSE1	Storage, Resident Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:4F	1505
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1506
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1507

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA10:PTRP Resident and Family Support Area									
DAYR1	Living Room, Resident	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:GWB f:P	m:Wood t:1 dg:T s:U	hw:R1	1508
PRD01	Dining Room, Resident	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT m:GWB f:P	t:OPEN	hw:N/A	1509
PRK01	Kitchen, Resident	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1510
LAUN1	Laundry Room, Resident	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT	m:Wood t:1 dg:T s:U	hw:4K	1511
FA11: PTRP Therapy Area									
PRGY2	Gym, Rehabilitation Therapy	m:RAF	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:4E	1512
PREV1	Evaluation Room, PT / OT	m:LVT	m:RB h:4"	m:GWB f:P			m:Wood t:19 s:S	hw:3F	1513
WRTM1	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	1514
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1515
CLR01	Recreational Computer Activities Room	m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 s:SS	hw:10M	1516

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA11: PTRP Therapy Area									
PRAT2	PTRP Assistive Technology Lab	m:LVT	m:RB h:4"	m:GWB [5, 64] f:P		m:AT	m:Wood t:1 s:U	hw:4E	1517
SRS01	Storage, Assistive Technology Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	1518
FA12: PTRP Staff and Administrative Area									
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1519
OFD05	Office, Physiatrist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1520
OFD05	Office, Provider	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1521
EXOS1	Office, Speech Language Pathologist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1522
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	1523
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1524
LR001	Lockers, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1525
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	1526

Chapter **111** Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA13: Outpatient Unit Reception Area									
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1527
RECP4	Kiosk, Patient Check-in	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1528
WRC01	Waiting, General	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	1529
WRC01	Waiting, Family	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	1530
DAYR1	Patient Dayroom	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	1531
TLTB1	Toilet, Bariatric, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	1532
FA14: Outpatient Unit Patient Area									
EXRG0	Exam Room, Outpatient	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1K	1533
OFDC2	Cognitive Therapy / Counseling Room [2]	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	1534

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA14: Outpatient Unit Patient Area

PTM1	Exam Room, EMG	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1K	1535
PTBT1	Exam Room, Chiropractic	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1K	1536
PRP01	Procedure Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP m:GWB f:SC	m:Wood t:19 s:U	hw:4P	1537
CRA02	Group Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:4E	1538
WRTM2	Tele-Health Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1539

FA15: Outpatient Unit Support Area

NSTA4	Nurse Station, Outpatient	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1540
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3D	1541
LCCL1	Linen Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:U	hw:SH-3C	1542
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	1543
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	1544

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA15: Outpatient Unit Support Area									
SRE01	Storage, Medical Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:4F	1545
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1546
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1547
FA16: Outpatient Unit Therapy Area									
PRDT1	Driver Training Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:4E	1548
OTDL1	Living Skills Training	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:4E	1549
PTGL1	Gait Observation Lab	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:4E	1550
SRE01	Storage Room, Gait Lab	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:U	hw:5B	1551
PREX1	Exam Room, Gait Lab	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:U	hw:1K	1552
PRGY3	Gym, Rehabilitation Therapy	m:RAF	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:SS	hw:4E	1553
PREV1	Evaluation Room, PT / OT	m:LVT	m:RB h:4"	m:GWB f:P			m:Wood t:19 s:S	hw:3F	1554

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA16: Outpatient Unit Therapy Area									
WRTM1	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1555
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1556
PRST1	Speech Therapy Lab	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:4E	1557
PRN01	Balance Testing Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1K	1558
PRV01	Vestibular Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1K	1559
PRRT2	Group Room, Recreation Therapy	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:SS	hw:10M	1560
SRE01	Storage, Recreation Therapy Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	1561
OFA07	Office, Recreational Therapist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1562
PRTM1	BROS Treatment / Office	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 s:S	hw:3E	1563
FA17: Outpatient Unit Staff and Administrative Area									
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1564

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA17: Outpatient Unit Staff and Administrative Area									
OFD04	Office, Physiatrist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1565
OFA04	Office, Provider	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1566
EXOS1	Office, Speech Language Pathologist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1567
OFA09	Office, Nurse Case Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1568
OFA07	Workstation, Military Liaison	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1569
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4E	1570
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1571
LR001	Lockers, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1572
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	1573
FA18: PRC Staff and Administrative Area									
OFA09	Office, PRC Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1574

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA18: PRC Staff and Administrative Area									
OFA09	Office, PRC Administrative Officer [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1575
OFA07	Workstation, PRC Administrative Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1576
OFA09	Office, Inpatient Medical Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1577
OFA09	Office, Inpatient Administrative Officer [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1578
OFA07	Workstation, Inpatient Program Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1579
OFA09	Office, Outpatient Medical Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1580
OFA09	Office, Outpatient Administrative Officer [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1581
OFA07	Workstation, Outpatient Program Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1582
OFA09	Office, PTRP Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1583
OFA09	Office, PTRP Administrative Officer [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1584
OFA07	Workstation, PTRP Program Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1585

Chapter 111 Polytrauma Rehabilitation Center (PRC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA18: PRC Staff and Administrative Area									
RPR01	Copy Room / Mail Distribution	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	1586
CRA02	Conference Room, PRC	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4J	1587
FA19: PRC Education Area									
OFA09	Office, Residency Program Director [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1588
OFA07	Workstation, Intern / Resident / Fellow	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1589
CLR01	Conference / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:U	hw:4K	1590

170

Chapter 202 Substance Abuse Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WROC1	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U m:N/A t:OPEN s:N/A	hw:4H hw:N/A	1591
NSTA1	Reception / Communication Center	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U	hw:3	1592
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1593
FA2: Patient Area									
OPMH1	Group Therapy Room	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	1594
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1595
TLTU1	Toilet, Specimen	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71]	1596
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V	hw:5B	1597
FA3: Staff and Administrative Area									
OFA09	Office, Substance Abuse Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:LG s:S	hw:3G	1598

Chapter 202 Substance Abuse Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Staff and Administrative Area									
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1599
OFA07	Workstation, Pharmacy Nurse	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1600
OFA07	Workstation, Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1601
OFA07	Workstation, Psychologist / Chaplain	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1602
OFA07	Workstation, Rehabilitation Counselor	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1603
OFA07	Workstation, Social Worker	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1604
OFA07	Workstation, Statistical Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1605
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	1606
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1607
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1608
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1609

Chapter **202** Substance Abuse Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Education Area									
SL002	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1610
CRA02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	1611

CANCELLED

Chapter 204 Audiology and Speech Pathology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	1612
RECP1	Receptionist / Control Clerk	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT m:GWB f:P	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	1613
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:5'-0" m:CT [7] h:5'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1614
FA2: Audiology Clinic Patient Area									
EXAU1	Exam / Consult Audiologist	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1615
EXAU1	Exam / Consult Audiology Technician	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3F	1616
TREN2	Suite, Audiometric Examination	m:PRE-FAB [63]	m:PRE-FAB	m:PRE-FAB		m:PRE-FAB	t:PRE-FAB	hw:N/A	1617
PEHS2	Booth, Audiometric Examination	m:PRE-FAB [63]	m:PRE-FAB	m:PRE-FAB		m:PRE-FAB	t:PRE-FAB	hw:N/A	1618
HAFR1	Programming / Fitting	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:3F	1619

Chapter 204 Audiology and Speech Pathology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Audiology Clinic Patient Area									
OPMH1	Auditory Rehabilitation	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:3F	1620
BHER1	Instrument Calibration and Storage	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4N	1621
OPAE1	Electrophysiology	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4N	1622
HATL1	Hearing Aid Fabrication/Modification	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4N	1623
EXRG3	Posturography	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:4N	1624
EXRG3	Vestibulography	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:4N	1625
EXEN1	Sinusoidal Vertical Axis Rotational Test (Rotary Chair)	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:4N	1626
EXEN1	Cerumen Management	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:4N	1627
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1628

Chapter 204 Audiology and Speech Pathology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Speech-Language Pathology Clinic Patient Area									
EXOS1	Exam / Consult Room, Speech-Language Pathologist	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1629
EXOS1	Exam / Consult Room, Speech-Language Pathology Assistant	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:3F	1630
WRCH1	CAT (Computer Aided Therapy) Workroom	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4N	1631
EXOS1	Exam Room, Speech Analysis	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4N	1632
TREN1	Special Procedures	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4N	1633
OFDC2	Consult Room Speech-Language Pathology, Individual Therapy	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1634
OPMH1	Speech-Language Pathology Group Therapy	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4N	1635
OPMH3	Observation Core	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4N	1636
FA4: Support Area									
SRSE1	Storage, Equipment and Supplies	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5	1637

Chapter 204 Audiology and Speech Pathology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Staff and Administrative Area									
OFA09	Office, Audiology and Speech Pathology Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64]		m:AT	m:Wood t:19 dg:T s:S	hw:3E	1638
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	1639
OFA07	Workstation, Administrative Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1640
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1641
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1642
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1643
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	1644
FA6: Education Area									
SL002	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1645

Chapter **204** Audiology and Speech Pathology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Education Area									
CRA02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	1646

35

CANCELLED

Chapter 206 Veterans Canteen Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Staff and Administrative Area									
OFA09	Office, Veterans Canteen Service Chief	m:CPT [6]	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1647
OFA09	Office, VCS Food Section Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1648
OFA09	Office, VCS Retail Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1649
CASH1	Secure Money Handling Room [59, 65]	m:SVT	m:RB h:4"	m:GWB [22] f:P		m:AT	m:Steel t:36 ds:CR s:S	hw:SH-3H	1650
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1651
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1652
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1653
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1654
FA2: Retail Store Area									
SRE01	Storage, Retail [59, 65]	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Steel t:2 dg:T s:SS	hw:11A	1655
MMRP1	Receiving Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Steel t:2 dg:T s:SS	hw:11A	1656

Chapter 206 Veterans Canteen Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Retail Store Area									
SRS01	Storage, Remote, Receiving Area [59, 65]	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Steel t:2 dg:T s:SS	hw:11A	1657
BX001	Retail Area	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Steel t:2 da:ADO dg:T s:SS	hw:12H	1658
BX001	Retail Area, Adapted for Spinal Cord Injury Patients	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 da:ADO s:SS	hw:12H	1659
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1660
FA3: Retail Concession Area									
BX001	Retail Display and Storage	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Steel t:2 dg:T s:SS	hw:12G	1661
FA4: Coffee Shop Area									
BX000	Retail Area	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 da:ADO dg:T s:SS	hw:12H	1662
SRE01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:5D	1663
FSCD1	Seating Area	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1664

Chapter 206 Veterans Canteen Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Optical Shop Area									
EYFD1	Eyeglass Fitting and Display, Dispensing Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:SS	hw:10C	1665
EYOT2	Office, Optician / Technician / Storage	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1666
FA6: Barber / Beauty Shop Area									
XXYYC	Barber / Beauty Shop	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1667
FA7: Food Court Support Area									
MMRP1	Receiving, Food Court	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	t:MOTORIZED ROLL UP s:9'-0" x 10'-0"	hw:7	1668
SRS01	Storage, Non-Food	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:V	hw:5E	1669
SRS01	Storage, Dry Food	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:V	hw:5E	1670
RER01	Storage, Refrigerated and Frozen Food	m:RES [63]	m:RES [7] h:4"	m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [66]	hw:N/A	1671
FSTD1	Food Preparation and Production	m:RES	m:RES [7] h:4"	m:CT [7] f:P		m:AT f:SP	t:OPEN	hw:N/A	1672
FSDW1	Dish Washing Area	m:RES	m:RES [7] h:4"	m:CT [7] f:P		m:AT f:SP	t:OPEN	hw:N/A	1673

Chapter 206 Veterans Canteen Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Food Court Support Area									
FSPW1	Pot Washing Area	m:RES	m:RES [7] h:4"	m:CT [7] f:P		m:AT f:SP	t:OPEN	hw:N/A	1674
SRHM1	Sanitation and Recycling Area	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:1 dg:T s:V m:Steel t:2 dg:T s:V	hw:4M	1675
UTC01	Trash Holding Refrigerated Room	m:RES [63]	m:RES [7] h:4"	m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [66]	hw:N/A	1676
UTR02	Waste Pulper System Room	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V m:Steel t:20 dg:T s:V	hw:4M	1677
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1678
FA8: Cafeteria Serving Area									
FSSL1	Serving Area	m:PT	m:PT [7] h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:V	hw:4K	1679
FA9: Cafeteria Dining Area									
FSCD1	Dining Area	m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:SS	hw:6E	1680

Chapter **206** Veterans Canteen Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA10: Vending Area									
BX001	Vending Machine Area	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4K	1681

35

CANCELLED

Chapter 208 Chaplain Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4E	1682
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:5'-0" m:CT [7] h:5'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1683
FA2: Worship Area									
RAS01	Chapel / Worship Area	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:SS	hw:12F	1684
RABS1	Eucharistic Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	1685
RAMR1	Multi Denominational	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	1686
RAMR1	Quiet Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:A s:S	hw:4E	1687
FA3: Staff and Administrative Area									
OFA04	Office, Chaplain [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1688
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	1689

Chapter **208** Chaplain Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Staff and Administrative Area									
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1690
OFA07	Workstation, Student	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1691
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1692
SRS01	Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:A s:S	hw:5D	1693
FA4: Support Area									
SRS01	Storage, Multi-denominational Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:A s:S	hw:5D	1694
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1695
FA5: Education Area									
CLR01	Education / Training Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:A s:U	hw:4E	1696

Chapter 210 Cardiovascular Laboratory Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	1697
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	1698
RECP4	Kiosk, Patient Check-in	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1699
CLSC1	Workstation, Patient Education	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT f:P	t:OPEN	hw:N/A	1700
TLTU1	Toilet, General	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1701
FA2: Non-Invasive Cardiology Patient Area									
OPEC1	EKG Testing Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 s:X	hw:1F	1702
EXRC1	Exam Room, Cardiology	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	1703
EXRC2	Pacemaker ICD Interrogation Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	1704

Chapter 210 Cardiovascular Laboratory Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Non-Invasive Cardiology Patient Area									
OPHM1	Holter Monitor Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:X	hw:4J	1705
OPPE1	Echocardiograph Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:X	hw:4J	1706
OPPE2	Stress Echocardiograph Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:X	hw:4J	1707
OPTM1	Stress Testing Treadmill Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:X	hw:4J	1708
OPTM2	Tilt Table Testing Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4G	1709
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1710
XVC01	Reading Room, ECHO	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	1711
XVC01	Reading Station, EKG	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	1712
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2G [71] hw:4B [31]	1713
FA3: Non-Invasive Cardiology Support Area									
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1714

Chapter 210 Cardiovascular Laboratory Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Non-Invasive Cardiology Support Area									
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	1715
OPHM1	Workroom, Event / Holter Monitor	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4G	1716
SRSE1	Storage, Non-Invasive Cardiology Supplies	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:19 dg:F s:S	hw:4K	1717
SRSE1	Storage, ICD Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:19 dg:F s:S	hw:4K	1718
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:19 dg:F s:S	hw:4K	1719
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1720
SRLW1	Alcove, Wheelchair / Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1721
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1722
FA4: These spaces have moved to Chapter 286									
XCCE1	This space has moved to Chapter 286								
XCCC1	This space has moved to Chapter 286								
XCCE1	This space has moved to Chapter 286								

Chapter 210 Cardiovascular Laboratory Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA4: These spaces have moved to Chapter 286

XCCC1	This space has moved to Chapter 286								
TRTE1	This space has moved to Chapter 286								
USCL4	This space has moved to Chapter 286								
LR003	This space has moved to Chapter 286								
XCMRI	This space has moved to Chapter 286								
TLTU1	This space has moved to Chapter 286								

FA5: These spaces have moved to Chapter 286

XCCI1	This space has moved to Chapter 286								
XCCA1	This space has moved to Chapter 286								
XVC01	This space has moved to Chapter 286								
SRS04	This space has moved to Chapter 286								

Chapter 210 Cardiovascular Laboratory Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: These spaces have moved to Chapter 286									
OREC1	This space has moved to Chapter 286								
XVC01	This space has moved to Chapter 286								
XFDS1	This space has moved to Chapter 286								
MEDP1	This space has moved to Chapter 286								
UCCL1	This space has moved to Chapter 286								
USCL1	This space has moved to Chapter 286								
SL001	This space has moved to Chapter 286								
LR002	This space has moved to Chapter 286								
TLTS1	This space has moved to Chapter 286								
LR002	This space has moved to Chapter 286								

Chapter 210 Cardiovascular Laboratory Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA5: These spaces have moved to Chapter 286

TLTS1	This space has moved to Chapter 286								
RCA01	This space has moved to Chapter 286								
SRLW1	This space has moved to Chapter 286								
LCCL1	This space has moved to Chapter 286								
JANC1	This space has moved to Chapter 286								

FA6: These spaces have moved to Chapter 286

RRSS1	This space has moved to Chapter 286								
RROP1	This space has moved to Chapter 286								
TLTU1	This space has moved to Chapter 286								

Chapter 210 Cardiovascular Laboratory Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: These spaces have moved to Chapter 286									
NSTA1	This space has moved to Chapter 286								
NCWD4	This space has moved to Chapter 286								
RCA01	This space has moved to Chapter 286								
SRE01	This space has moved to Chapter 286								
FA7: Staff and Administrative Areas									
OFA09	Office, Cardiovascular Laboratory Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1758
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	1759
OFA07	Workstation, Physician	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	1760
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1761
OFA07	Office, Nurse Practitioner	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1762

Chapter 210 Cardiovascular Laboratory Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Staff and Administrative Areas									
OFA07	Workstation, Nurse	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1763
OFA07	Workstation, Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1764
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1765
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:4J	1766
WRCH1	Workroom, Cardiology Team	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4G	1767
RPR01	Copier / Printer Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	1768
SRS01	Storage, Forms / Literature	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4G	1769
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	1770
FA8: Education Area									
OFA09	Office, Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1771

Chapter **210** Cardiovascular Laboratory Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Education Area									
OFA07	Workstation, Intern / Resident / Fellow	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1772
CLR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	1773

77

CANCELLED

Chapter 212 Pulmonary Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	1774
RECP1	Reception / Check-In	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	1775
CLSC1	Patient Education / Resource Kiosk	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1776
CLSC3	Patient Education / Resource Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	1777
TLTF3	Toilet, Family	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G	1778
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	1779
FA2: Pulmonary Medicine / Respiratory Care Patient Area									
OPPF1	Testing Lab, Pulmonary Function	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:X	hw:4G	1780

Chapter 212 Pulmonary Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Pulmonary Medicine / Respiratory Care Patient Area									
OPPF2	Testing Lab, Extended Pulmonary Function	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:X	hw:4G	1781
OPPF5	Physiology Lab, Pulmonary Exercise	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:X	hw:4K	1782
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	1783
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H	1784
TLTS2	Toilet / Shower, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1785
FA3: Bronchoscopy Patient Area									
TRPE2	Procedure Room, Bronchoscopy	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:GWB f:SC	m:Wood t:19 dg:T s:X	hw:4P	1786
CSSS1	Equipment Cleaning	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:11 dg:T s:V	hw:4K	1787
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H	1788

Chapter 212 Pulmonary Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Sleep Study Patient Area									
OPPF6	Sleep Study Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T ds:YES s:X	hw:SH-3	1789
TLTS2	Toilet / Shower, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2C [71]	1790
OPPF7	Monitoring Room, Sleep Study	m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3E	1791
OPPF8	Prep Room, Sleep Study	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3E	1792
NCWD2	Nourishment Station	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4N	1793
LCCL1	Alcove, Sleep Study Clean Linen	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1794
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71]	1795
FA5: Prep and Recovery Patient Area									
RRSS1	Prep / Recovery Room	m:WSF	m:WSF h:4"	m:GWB f:SC	m:RWC h:4'-0"	m:AT [9] f:SC	m:Wood t:19 s:S	hw:1B	1796

Chapter 212 Pulmonary Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Prep and Recovery Patient Area									
RROP1	Prep / Recovery Cubicle	m:WSF	m:WSF h:4"	m:GWB f:SC	m:RWC h:4'-0"	m:AT [9] f:SC	t:OPEN	hw:N/A	1797
TLTU1	Toilet, Prep / Recovery Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H	1798
NSTA3	Nurse Station	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	t:OPEN	hw:N/A	1799
MEDP1	Medication Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3D	1800
NCWD4	Alcove, Refreshment Center	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1801
LCCL1	Storage, Clean Linen	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:S	hw:SH- 3C	1802
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1803
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1804
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1805
SRLW1	Alcove, Wheelchair / Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1806
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1807

Chapter 212 Pulmonary Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Support Area									
OPRT1	Respiratory Therapy Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:T s:V	hw:4F	1808
SRGC2	Storage, Medical Gas	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:11 dg:T dr:45 min s:V	hw:4F	1809
SRVE1	Storage, Ventilator	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V	hw:4F	1810
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1811
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V	hw:4F	1812
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1813
SRLW1	Alcove, Wheelchair / Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1814
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	1815
FA7: Staff and Administrative Areas									
OFA09	Office, Director of Respiratory Therapy	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1816
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	1817

Chapter 212 Pulmonary Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Staff and Administrative Areas									
OFA07	Workstation, Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1818
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1819
OFA07	Workstation, Chief Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1820
OFA07	Workstation, Home Care Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1821
OFA07	Workstation, Polysomnographer	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1822
OFA07	Workstation, Respiratory Therapist	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1823
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1824
RPR01	Copier / Printer Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4J	1825
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	1826
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	1827

Chapter **212** Pulmonary Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Staff and Administrative Areas									
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71]	1828
FA8: Education Area									
OFA09	Office, Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1829
OFA07	Workstation, Intern / Resident / Fellow	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1830
CLR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	1831

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Medical Service Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1832
OFA09	Office, Medical Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1833
OFA09	Office, Medical Service Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1834
OFA09	Office, Administrative Officer [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1835
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1836
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1837
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1838
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1839
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1840
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1841

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Hospital Medicine Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1842
OFA09	Office, Hospital Medicine Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1843
OFA09	Office, Hospital Medicine Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1844
OFA09	Office, Administrative Officer [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1845
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1846
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1847
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1848
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1849
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1850
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1851

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Endocrinology Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1852
OFA09	Office, Endocrinology Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1853
OFA09	Office, Endocrinology Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1854
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1855
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1856
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1857
OFA07	Workstation, Chief Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1858
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1859
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1860
FA4: Rheumatology Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1861

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Rheumatology Area									
OFA09	Office Rheumatology Chief	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1862
OFA09	Office, Rheumatology Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1863
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1864
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1865
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1866
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1867
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1868
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1869
FA5: Infectious Diseases Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1870
OFA09	Office, Infectious Diseases Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1871

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Infectious Diseases Area									
OFA09	Office, Infectious Diseases Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1872
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1873
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1874
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1875
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1876
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1877
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:S	hw:5B	1878
FA6: Homeless / Compensated Work Therapy (CWT) Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1879
OFA09	Office, Homeless / Compensated Work Therapy (CWT) Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1880

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Homeless / Compensated Work Therapy (CWT) Area									
OFA09	Office, Homeless / Compensated Work Therapy (CWT) Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1881
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1882
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1883
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1884
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1885
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1886
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1887
FA7: Neurology Service Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1888
OFA09	Office, Neurology Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1889

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Neurology Service Area									
OFA09	Office, Neurology Service Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1890
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1891
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1892
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1893
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1894
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1895
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1896
FA8: Dermatology Service Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1897
OFA09	Office, Dermatology Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1898
OFA09	Office, Dermatology Service Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1899

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Dermatology Service Area									
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1900
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1901
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1902
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1903
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1904
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1905
FA9: Geriatrics Home Based Primary Care (HBPC) Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1906
OFA09	Office, Geriatrics Home Base Primary Care (HBPC) Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1907
OFA09	Office, Geriatrics Home Base Primary Care (HBPC) Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1908
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1909

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA9: Geriatrics Home Based Primary Care (HBPC) Area									
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1910
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1911
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1912
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1913
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1914
FA10: Oncology Service Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1915
OFA09	Office, Oncology Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1916
OFA09	Office, Oncology Service Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1917
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1918
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1919

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA10: Oncology Service Area									
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1920
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1921
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1922
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1923
FA11: Mental Health Telepsychiatry Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1924
OFA09	Office, Mental Health Telepsychiatry Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1925
OFA09	Office, Mental Health Telepsychiatry Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1926
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1927
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1928
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1929

Chapter 214 Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA11: Mental Health Telepsychiatry Area									
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1930
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1931
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:T s:V	hw:5B	1932
FA12: Mental Health Service Area									
OFDC2	Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:3G	1933
OFA09	Office, Mental Health Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1934
OFA09	Office, Mental Health Service Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1935
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1936
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1937
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1938
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1939

Chapter **214** Clinical Services Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA12: Mental Health Service Area									
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1940
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1941

110

CANCELLED

Chapter 218 Veterans Assistance Unit

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Staff and Administrative Area									
OFA04	Office, Unit Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1942
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	1943
OFA04	Office, Veterans Benefits Counselor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	1944
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1945
FA2. Support Area									
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1946

Chapter 220 Credit Union

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Lobby and Teller Area									
CASH1	Staff Area / Service Window [59, 62]	m:LVT	m:RB h:4"	m:GWB f:P f:P		m:AT	t:OPEN	hw:N/A	1947
LOB01	Public Space	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1948
BF001	Automated Teller Machine (ATM) [59, 62]	m:LVT	m:RB h:4"	m:GWB f:P		m:GWB f:P	t:OPEN	hw:N/A	1949
FA2: Staff and Administrative Area									
OFA09	Office, Credit Union Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1950
OFA09	Office, Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	1951
OFA07	Workstation, Loan / Accounts Officer	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1952
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1953
RPR03	Alcove, Copier / Printer [59, 62]	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:GWB f:P	t:OPEN	hw:N/A	1954
FA3: Support Area									
SSV01	Vault [59, 62]	m:VT	m:RB h:4"	m:GWB f:P		m:GWB f:P	m:STEEL t:30 s:X	hw:N/A [1]	1955

Chapter **220** Credit Union

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Support Area									
SRSE1	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	1956
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	1957

11

CANCELLED

Chapter 222 Dental Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA1: Dental Treatment Rooms (DTRs) Calculation

CALC1	Number of DTRs								1958
-------	----------------	--	--	--	--	--	--	--	------

FA2: Reception Area

WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	1959
PLAY1	Playroom	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1960
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	1961
RECP4	Kiosk, Patient Check-in	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1962
CLSC2	Workstation, Patient Education	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	1963
SRLW1	Alcove, Wheelchair	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1964
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	1965

Chapter 222 Dental Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Dental Treatment Patient Area									
WRC03	Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	1966
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T dl:LEAD s:U	hw:3G	1967
DNXS1	X-Ray Room, Panoramic / Cephalometric	m:LVT	m:RB h:4"	m:GWB [50] f:P		m:AT	m:Wood t:15 s:X	hw:4Q	1968
DNXC1	Computerized Tomography (CT) Room, Cone-Beam	m:LVT	m:RB h:4"	m:GWB [50] f:P		m:AT	m:Wood t:19 dl:LEAD s:S	hw:1L	1969
DNXC2	Computerized Tomography (CT) Room, Cone-Beam Control Room	m:LVT	m:RB h:4"	m:GWB [50] f:P		m:AT	m:Wood t:19 dl:LEAD s:S	hw:1L	1970
DNTG1	Dental Treatment Room (DTR), Multi- Functional	m:RF	m:RF h:4"	m:GWB f:SC		m:AT	m:Wood t:19 s:S	hw:1L [15]	1971
DNTG5	Dental Treatment Room (DTR), Special Needs Patient	m:RF	m:RF h:4"	m:GWB f:SC		m:AT	m:Wood t:19 s:S	hw:1L [15]	1972
DNTE1	Dental Treatment Room (DTR), Endodontics	m:RF	m:RF h:4"	m:GWB f:SC		m:AT	m:Wood t:19 s:S	hw:1L [15]	1973
XVC01	Viewing Room, Picture Archiving and Communication System	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:S	hw:3E	1974
WRTM2	Tele-Health Room	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:3E	1975
WRTM1	Team Collaboration Room, Patient	m:RF	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:3E	1976

Chapter 222 Dental Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Dental Treatment Patient Area									
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1977
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H	1978
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3D	1979
UCCL1	Clean Supply Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1980
DN3C3	Storage, Sterile Instruments	m:RF	m:RB h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:U	hw:4K	1981
SRS01	Storage, Dental Supplies	m:RF	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:V m:Wood t:11 dg:F s:SS	hw:5B hw:11B	1982
SRE01	Storage, Mobile Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	1983
FA4: Dental Surgery Suite Patient Area									
WRC03	Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	1984

Chapter 222 Dental Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Dental Surgery Suite Patient Area									
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H	1985
DNTR1	Patient Prep / Recovery Room	m:RF	m:RF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:1B	1986
ORSA1	Scrub Area	m:RF	m:RF h:4"	m:GWB f:SC			t:OPEN	hw:N/A	1987
DNTS1	Oral Surgery Room	m:RF	m:RF h:4"	m:GWB f:SC		m:GWB f:SC m:AT f:SP	m:Wood t:1 [38, 41] s:XX	hw:4B [15]	1988
WRCH1	Workroom, Staff	m:RF	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4J	1989
SRE01	Storage, Equipment	m:SVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	1990
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1991
RCA04	Alcove, Blanket Warmer	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	1992
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1993
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	1994

Chapter 222 Dental Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Dental Surgery Suite Patient Area									
LCCL1	Linen Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:V	hw:SH-3C	1995
LCCL2	Linen Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F s:V	hw:SH-3C	1996
FA5: Dental Laboratories Area									
DNPL1	Laboratory, General Purpose	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	1997
DNPC1	Laboratory, Porcelain / Ceramics	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	1998
DNPL5	Laboratory, Maxillo-Facial	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	1999
DNPL6	Laboratory, Machine Milled Restorations	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2000
DNPL7	Laboratory, Acrylic Processing	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2001
DNPL8	Laboratory, Acrylic Finishing	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2002
DNPL9	Laboratory, Cast Metal	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2003
DNSR2	Laboratory, Shipping and Receiving	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2004
SRS01	Storage, Expandable Laboratory Supplies	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2005

Chapter 222 Dental Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Dental Laboratories Area									
DNMS1	Storage, Dental Models	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2006
SSS01	Storage, Precious Metals	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2007
DNMP1	Work Area, Dental Models Processing	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2008
SRSE1	Storage, Equipment	m:RES	m:RES h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	2009
FA6: Support Area									
OFA07	Workstation, Receiving	m:LVT	m:RES h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2010
DNSR1	Instrument Supply / Receiving	m:EPY	m:RB h:4"	m:GWB f:P	m:RWC [54] h:4'- 0"	m:AT	m:Wood t:11 dg:F dr:45 min s:V	hw:5	2011
SRGC2	Storage, Gas Cylinder / Gas Tank Room	m:EPY	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F dr:45 min s:V	hw:5	2012
SRLW1	Storage, Wheelchairs / Lifts	m:EPY	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5	2013
RCA05	Alcove, CAD / CAM Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2014
RCA01	Alcove, AED	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2015

Chapter 222 Dental Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Support Area									
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	2016
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	2017
MECH1	Dental Equipment Mechanical Room	m:EPY	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:SS	hw:11B	2018
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2019
COMC1	Telecom Closet	m:VT	m:RB h:4"	m:GWB [34] f:P		m:AT	m:Wood t:1 s:S	hw:SH-3D	2020
FA7: Staff and Administrative Areas									
OFA09	Office, Dental Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2021
OFA09	Office, Dentist Director [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2022
OFA09	Office, Administrative Officer [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2023
OFA07	Workstation, Staff Dentist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2024
OFA07	Workstation, Assistant Staff Dentist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2025
OFA07	Workstation, Dental Staff	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2026

Chapter 222 Dental Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Staff and Administrative Areas									
CRA01	Conference Room	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2027
WRTM1	Team Collaboration Room, Staff	m:RF	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	2028
FILE1	Storage, Secure Documents	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:5	2029
RPR01	Copy / Office Supply Room	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4J	2030
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2031
LR002	Locker / Changing Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2032
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	2033
TLTS1	Toilet / Shower, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:CT [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	2034

Chapter 222 Dental Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Education Area									
OFA09	Office, Residency Program Director [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2035
OFA07	Workstation, Dental Auxiliary Training Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2036
WRTM1	Team Collaboration Room, Residents	m:RF	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	2037
OFA07	Workstation, Dental Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2038

81

CANCELLED

Chapter 224 Nutrition and Food Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Main Kitchen Staff and Administrative Area									
OFA09	Office, Nutrition and Food Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2039
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2040
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2041
OFA09	Office, Nutrition and Food Service Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2042
OFA07	Workstation, Internship Director	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:OPEN	hw:N/A	2043
OFA07	Workstation, Clinical Administration Section Chief	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2044
OFA07	Workstation, Dietitian	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2045
OFA07	Workstation, Food Production and Service Foreman	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2046
OFA09	Office, Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2047
OFA07	Workstation, Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2048
OFA07	Workstation, Cost Clerk Accountant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2049

Chapter 224 Nutrition and Food Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Main Kitchen Staff and Administrative Area									
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	2050
COMC1	Communications Center, Food Service	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:V	hw:3E	2051
CRA01	Conference Room / Training, Staff	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2052
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2053
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2054
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	2055
FA2: Main Kitchen Receiving and Storage Area									
MMRP1	Receiving Area	m:RES	m:RES [7] h:4"	m:GWB [54] f:SC m:CMU f:SC	m:RWC h:4'-0"	m:AT	t:MOTORIZED ROLL UP s:9'-0" x 10'-0"	hw:7	2056
SRS01	Storage, Non-Food	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT	m:Wood t:1 dg:T s:V	hw:5F	2057
SRS01	Storage, Dry Food and Ingredient Control	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:1 dg:T s:V	hw:5F	2058

Chapter 224 Nutrition and Food Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Main Kitchen Receiving and Storage Area									
RER01	Storage, Refrigerated and Frozen Food	m:RES [63]	m:RES [7] h:4"	m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [66]	hw:N/A	2059
FA3: Main Kitchen Food Preparation Area									
FSTD1	Food Preparation and Production	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V m:N/A t:OPEN s:N/A	hw:4S hw:N/A	2060
SRS01	Storage, Refrigerated Blast-Chilled Food (Two-Day Food Bank)	m:RES [63]	m:RES [7] h:4"	m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [66]	hw:N/A	2061
SRS01	Storage, Refrigerated Blast-Chilled Food (One-Day Food Bank)	m:RES [63]	m:RES [7] h:4"	m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [63, 66]	hw:N/A	2062
FSSC1	Cook / Chill Center, High Volume	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V m:N/A t:OPEN s:N/A	hw:4N hw:N/A	2063
FSSC1	Rethermalization of Bulk Food	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V m:N/A t:OPEN s:N/A	hw:4N hw:N/A	2064
FSNP1	Nourishment Preparation	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V m:N/A t:OPEN s:N/A	hw:4N hw:N/A	2065

Chapter 224 Nutrition and Food Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Main Kitchen Patient Tray Service Area									
FSTD1	Tray Assembly Area	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V	hw:4S	2066
FSCS1	Tray Cart Storage Area, Clean Carts	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V	hw:4S	2067
SRR01	Refrigerator, Tray Retherm Cart Holding	m:RES [63]	m:RES [7] h:4"	m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [66]	hw:N/A	2068
SRR01	Refrigerator, Central Tray Retherm	m:RES [63]	m:RES [7] h:4"	m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [66]	hw:N/A	2069
SRR01	Tray Retherm Cart System, Centralized	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V	hw:4S	2070
FSCS1	Bulk Food Cart Holding Area, Cook/Serve	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V	hw:4S	2071
FA5: Main Kitchen Sanitation Area									
FSDW1	Dishwashing	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:SS	hw:10F	2072
FSPW1	Pot Washing	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V	hw:10F	2073
FSCS1	Cart Wash Area, Manual	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V	hw:4S	2074
FSCS1	Cart Wash Area, Automated	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V	hw:4S	2075
FSCS1	Tray Cart Storage Area, Soiled Carts	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT [9] f:SP	m:Wood t:19 dg:T s:V	hw:4S	2076

Chapter **224** Nutrition and Food Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Main Kitchen Sanitation Area									
UTR02	Waste Pulper System Room	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:19 dg:T s:V	hw:4S	2077
FA6: Main Kitchen Support Area									
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2078
SRHM1	Storage, Hazardous Supplies	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:1 dg:F dr:45 min s:V	hw:5D	2079
UTC01	Storage, Refrigerated Garbage	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	t:Special	hw:7A	2080
JANC1	Storage, Cleaning Supplies	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:U	hw:5D	2081
UTC01	Recycling / Holding Area	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:T s:V	hw:4S	2082
MECH1	Mechanical Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:V	hw:5G	2083

Chapter 226 Electroencephalography Laboratory

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2084
TLTF3	Toilet, Family	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G	2085
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2086
RECP1	Reception / Check-In	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2087
RECP4	Kiosk, Patient Check-in	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2088
CLSC1	Patient Education / Resource Kiosk	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2089
CLSC3	Patient Education / Resource Room	m:CPT [6]	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:19 s:S	hw:3G	2090
FA2: Patient Area									
OPEE1	Exam Room, EEG	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:1L	2091

Chapter 226 Electroencephalography Laboratory

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
EXRE2	Exam Room, EMG	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:1L	2092
OPPF8	Patient Prep Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 s:S	hw:1F	2093
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]	2094
FA3: Support Area									
XVC01	Reading Room	m:CPT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	2095
OPEE2	EEG / EMG Work Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:U	hw:4K	2096
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2097
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2098
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	2099
LCCL3	Alcove, Clean Linen	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:V	hw:SH- 3C	2100
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2101

Chapter 226 Electroencephalography Laboratory

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Support Area									
SRLW1	Alcove, Wheelchair / Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2102
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2103
FA4: Staff and Administrative Area									
OFA09	Office, EEG Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2104
OFA07	Workstation, Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2105
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2106
OFA07	Workstation, Chief Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2107
OFA07	Workstation, Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2108
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2109
LR002	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2110
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71]	2111

Chapter **226** Electroencephalography Laboratory

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Conference / Classroom									
CLR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2112

29

CANCELLED

Chapter 230 Engineering Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2113
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 m:N/A t:OPEN	hw:3E hw:N/A	2114
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 dg:T s:S	hw:2G [71] hw:4B [31]	2115
FA2: Administrative and Operations Area									
OFA09	Office, Engineering Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2116
OFA09	Office, Engineering Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2117
OFA07	Workstation, Fire and Safety Specialist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2118
OFA07	Workstation, Industrial Hygienist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2119
OFA07	Workstation, Project Engineer	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2120
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2121

Chapter 230 Engineering Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Administrative and Operations Area									
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2122
XXYYZ	Hospital Plans and Drafting Room	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4G	2123
XXYYC	Interior Design Office / Library / Workroom [2]	m:CPT [6]	m:RB h:4"	m:GWB [42] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4J	2124
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2125
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2126
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	2127
FA3: Engineering Control Center									
XXYYC	Engineering Control Center	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4G	2128
FA4: Biomedical Engineering Repair Shop									
OFA07	Workstation, Biomedical Engineer	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2129
BMRA1	Receiving and Cleaning	m:SVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T s:SS	hw:10C	2130

Chapter 230 Engineering Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Biomedical Engineering Repair Shop									
BMER1	Repair	m:SVT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T s:SS	hw:10C	2131
SRE01	Storage Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T s:SS	hw:11	2132
FA5: Shop Area									
PMCW1	Carpentry Shop: Floor Mounted Tools and Equipment	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:20 dg:T s:SS	hw:10G	2133
PMCW1	Carpentry Shop: Workbench and Worktable	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:2 dg:T s:SS	hw:10C	2134
SRE01	Carpentry Shop: Storage	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:AT	m:Steel t:2 dg:T s:SS	hw:11A	2135
PMCW1	Air Conditioning Shop: Floor Mounted Tools and Equipment	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:20 dg:T s:SS	hw:10G	2136
PMCW1	Air Conditioning Shop: Workbench and Worktable	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:2 dg:T s:SS	hw:10C	2137
SRE01	Air Conditioning Shop: Storage	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T s:SS	hw:11A	2138
PMCW1	Plumbing Shop: Floor Mounted Tools and Equipment	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:20 dg:T s:SS	hw:10G	2139
PMCW1	Plumbing Shop: Workbench and Worktable	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:2 dg:T s:SS	hw:10C	2140
SRE01	Plumbing Shop: Storage	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T s:SS	hw:11A	2141

Chapter 230 Engineering Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Shop Area									
PMCW1	Electrical Shop: Floor Mounted Tools and Equipment	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:EXP	m:Steel t:20 dg:T s:SS	hw:10G	2142
PMCW1	Electrical Shop: Workbench and Worktable	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:EXP	m:Steel t:2 dg:T s:SS	hw:10C	2143
SRE01	Electrical Shop: Storage	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T s:SS	hw:11A	2144
PMCW1	Paint Shop: Floor Mounted Tools and Equipment	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:20 dg:T s:SS	hw:10G	2145
PMCW1	Paint Shop: Workbench and Worktable	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:2 dg:T s:SS	hw:10C	2146
SRHM1	Paint Shop: Storage, Flammable	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:GWB f:SC	m:Steel t:9 dg:F dr:45 min s:V	hw:11B	2147
XXYYC	Paint Shop: Paint Area	m:EPY [10]	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T dr:45 min s:SS	hw:10C	2148
PMCW1	Machine Shop: Floor Mounted Tools / Equipment	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:20 dg:T s:SS	hw:10G	2149
PMCW1	Machine Shop: Workbench and Worktable	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:2 dg:T s:SS	hw:10C	2150
SRE01	Machine Shop: Storage	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T s:SS	hw:11A	2151
PMCW1	Mason Shop: Floor Mounted Tools and Equipment	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:EXP	m:Steel t:20 dg:T s:SS	hw:10G	2152

Chapter 230 Engineering Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Shop Area									
PMCW1	Mason Shop: Workbench and Worktable	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:EXP	m:Steel t:2 dg:T s:SS	hw:10C	2153
SRE01	Mason Shop: Storage	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T s:SS	hw:11A	2154
PMCW1	Grounds Maintenance Shop: Workbench / Worktable	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:2 dg:T s:SS	hw:10C	2155
SRE01	Grounds Maintenance Shop: Storage	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:11 dg:F s:U t:2 s:SS	hw:5F hw:E3	2156
XXYYC	Grounds Maintenance Shop: Storage, Covered Outside	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:EXP	t:OPEN	hw:N/A	2157
PMCW1	Locksmith Shop: Workbench / Worktable	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:2 dg:T s:V	hw:5L	2158
SRE01	Locksmith Shop: Storage	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T s:SS	hw:11A	2159
PMCW1	Multi Use Shop: Floor Mounted Tools and Equipment	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:20 dg:T s:V	hw:4S	2160
PMCW1	Multi Use Shop: Workbench / Worktable	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:EXP	m:Steel t:2 dg:T s:SS	hw:10C	2161
SRE01	Multi Use Shop: Storage	m:EPY [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:2 dg:T s:SS	hw:11A	2162
SRHM1	Multi Use Shop: Storage, Flammable	m:EPY [10]	m:RB h:4"	m:CMU f:P		m:GWB f:SC	m:Steel t:9 dg:F dr:45 min s:V	hw:11B	2163

Chapter **230** Engineering Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Shop Area									
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2164

52

CANCELLED

Chapter **232** Office of Information & Technology (OIT)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA1: Reception Area

Main Computer Room

WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2165
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2166
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2167

FA2: Computer Area

Main Computer Room

ITAE1	OIT IT Active Equipment	m:AF	m:RB h:4"	m:GWB [34, 64] f:P		m:AT	m:Wood t:11 dg:T s:S s:SS	hw:4F	2168
ITPE1	OIT IT Passive Distribution Equipment	m:AF	m:RB h:4"	m:GWB [34, 64] f:P		m:AT	m:Wood t:11 dg:T s:S s:SS	hw:4F	2169
FMAE1	FMS Active Equipment	m:AF	m:RB h:4"	m:GWB [34, 64] f:P		m:AT	m:Wood t:11 dg:T s:S s:SS	hw:4F	2170

Chapter 232 Office of Information & Technology (OIT)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Computer Area									
Main Computer Room									
FMPE1	FMS Passive Distribution Equipment	m:AF	m:RB h:4"	m:GWB [34, 64] f:P		m:AT	m:Wood t:11 dg:T s:S s:SS	hw:4F	2171
TEIP1	VoIP Active Equipment	m:AF	m:RB h:4"	m:GWB [34, 64] f:P		m:AT	m:Wood t:11 dg:T s:S s:SS	hw:4F	2172
TEDP1	Digital Telephone (PBX) Equipment	m:AF	m:RB h:4"	m:GWB [34, 64] f:P		m:AT	m:Wood t:11 dg:T s:S s:SS	hw:4F	2173
Other Spaces within the Computer Area									
ITNT1	Network Operations Room	m:SD	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:11 dg:T s:S	hw:4F	2174
ITAD1	Storage, Active Data	m:SD	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:11 dg:T s:S	hw:4F	2175
ITAC1	HVAC and Electrical Equipment, Computer Area	m:RES	m:RES h:4"	m:GWB [64] f:P		m:EXP	m:Wood t:19 dg:T s:V m:Steel t:20 dg:T s:SS	hw:4F	2176
ITBU1	Backup Computer Room	m:AF	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:11 dg:T s:SS	hw:4F	2177

Chapter 232 Office of Information & Technology (OIT)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Computer Support Area									
ITBD1	Receiving/Breakdown Room	m:RES	m:RES h:4"	m:GWB [64] f:P		m:AT	m:Wood t:11 dg:T s:SS	hw:4F	2178
SRE01	Storage, IT Equipment	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:T s:V	hw:4F	2179
ITRD1	Storage, Temporary Data	m:SD	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:11 dg:T s:S	hw:4F	2180
ITWR1	Workroom, Equipment Configuration/Repair	m:SD	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:T s:S	hw:4F	2181
FA4: Telecommunications Support Area									
TEOR1	Telephone Operators Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4F	2182
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71]	2183
SL001	Lounge, Telephone Operators	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4F	2184
TETR1	Telecommunications Room, TR	m:SD	m:RB h:4"	m:GWB [34, 64] f:P		m:EXP	m:Wood t:11 dg:T s:V	hw:4F	2185
TEDR1	Demarc Room	m:SD	m:RB h:4"	m:GWB [34, 64] f:P		m:EXP	m:Wood t:11 dg:T s:U	hw:4F	2186
TEEQ1	Antenna Headend Equipment Room	m:SD	m:RB h:4"	m:GWB [34, 64] f:P		m:EXP	m:Wood t:11 dg:T s:X	hw:4F	2187

Chapter 232 Office of Information & Technology (OIT)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Staff and Administrative Areas									
OFA09	Office, OIT Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2188
OFA09	Office, OIT Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P			m:Wood t:1 dg:T s:S	hw:3E	2189
OFA09	Office, Section Head / Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2190
OFA07	Workstation, Programmer	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2191
OFA07	Workstation, Computer Operator / Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2192
OFA07	Workstation, Customer Service / Help Desk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2193
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2194
RPR01	Copy Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:X	hw:4K	2195
SRS01	Storage, Forms / Literature	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:T s:S	hw:4F	2196
CLR03	Classroom, Computer Training	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	2197
SRS01	Storage, Computer Training	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:S	hw:4J	2198

Chapter **232** Office of Information & Technology (OIT)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Staff and Administrative Areas									
WRCH1	Workroom, Projects	m:CPT [6] m:VT	m:RB h:4"	m:GWB [33] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	2199
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2200
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2201
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2202
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71]	2203

Chapter 233 Eye Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	2204
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2205
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2206
FA2: Patient Area									
EYOT2	Exam / Treatment Room, Optometry	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2207
EYOT2	Exam / Treatment Room, Ophthalmology	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2208
WRC01	Waiting, Dilation	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	2209
EYVF1	Visual Fields Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2210
EYVF1	Photography Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2211
EYVS1	Pre-Testing Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2212

Chapter 233 Eye Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
EYFD1	Eyeglass Fitting and Display, and Dispensing Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2213
XDUS1	Ultrasound / Optical Coherence Tomography Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2214
EYOT2	Eye Procedure Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:19 s:S	hw:1L	2215
TREY2	Laser Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2216
EYER1	Electrodiagnosis Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2217
EYOT2	Exam / Training Room, Low Vision	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2218
EYOT2	Training Room, Low Vision / Polytrauma	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2219
EYCL1	Patient Education / Contact Lens Dispensing Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2220
FA3: Support Area									
UCCL1	Supply Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 s:V	hw:SH-3C	2221
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	2222
MEDP1	Medication Preparation Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 s:S	hw:SH-3D	2223

Chapter 233 Eye Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Support Area									
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	2224
RCA01	Storage, Alcove, Medical Equipment	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2225
SRLW1	Storage, Alcove, Wheelchair	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2226
SRS01	Storage, Eyeglass Frame	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:5D	2227
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2228
FA4: Staff and Administrative Area									
OFA09	Office, Ophthalmology / Optometry Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2229
OFA09	Office, Ophthalmology Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2230
OFA09	Office, Optometry Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2231
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2232
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2233

Chapter 233 Eye Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Staff and Administrative Area									
OFA07	Workstation, Eyecare Provider	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2234
OFA04	Office, Social Work / Intake / Adjustment Counseling	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2235
WRCH1	Nurse Workroom	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4K	2236
SRE01	Support Equipment Area	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2237
RECP3	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT m:GWB f:P	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2238
OFA09	Office, Nurse Manager	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2239
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2240
XVC01	Consult Room / Viewing Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	2241
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4E	2242
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2243
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2244

Chapter **233** Eye Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Staff and Administrative Area									
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2245
FA5: Education Area									
OFA09	Office, Ophthalmology Residency Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2246
OFA09	Office, Optometry Residency Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2247
CRA02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2248

Chapter 234 Fiscal Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:A s:V	hw:4G	2249
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71]	2250
FA2: Staff and Administrative Area									
OFA09	Office, Fiscal Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2251
OFA09	Office, Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2252
RECP1	Reception / Information Desk	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2253
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2254
OFA07	Workstation, Budget Analyst	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2255
OFA09	Office, Auditor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2256
OFA09	Office, Accounting Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2257

Chapter 234 Fiscal Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Staff and Administrative Area									
OFA07	Workstation, Clerical / Technical Staff	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2258
OFA07	Workstation, Travel Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2259
OFA07	Workstation, Patient Funds Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2260
CASH1	Agent Cashier [2, 59, 65]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Steel t:36 s:S	hw:SH-3H	2261
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	2262
FA3: Support Area									
FILE1	Workroom	m:SVT m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	2263
SRS01	Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:A s:S	hw:5D	2264

Chapter 238 Medical Center Director's Suite

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:VWC		m:AT	m:Wood t:1 s:U	hw:4G	2265
FA2: Staff and Administrative Area									
OFA12	Office, Medical Center Director	m:CPT [6]	m:RB h:4"	m:GWB [64, 80] f:VWC		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2266
TLTU1	Toilet, Medical Center Director	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2 [71]	2267
OFA11	Office, Medical Center Associate Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2268
OFA09	Office, Medical Center Assistant Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2269
OFA11	Office, Medical Center Chief of Staff	m:CPT [6]	m:RB h:4"	m:GWB [64, 80] f:VWC		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2270
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2271
OFA07	Workstation, Administrative Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2272

Chapter **238** Medical Center Director's Suite

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Staff and Administrative Area									
OFA07	Workstation, Management Specialist / Special Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2273
FILE1	Workroom	m:SVT m:LVT	m:RB h:4"	m:GWB [42] f:P		m:AT	m:Wood t:1 s:S	hw:4G	2274
OFA07	Workstation, Trainees	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2275
CRA01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64, 80] f:VWC		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2276
FA3: Support Area									
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2277
IPK01	Kitchenette	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2278

Chapter 240 Pathology and Laboratory Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Patient Specimen Collection Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:V m:Wood t:3 dg:T s:N/A	hw:4K	2279
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S t:OPEN	hw:3E hw:N/A	2280
LBBD1	Blood Specimen Collection Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:GWB f:SC m:AT f:SP	m:Wood t:1 dg:T s:V	hw:4	2281
TLTU1	Toilet, Urine Specimen Collection	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:P m:AT [9]	m:Wood t:19 s:V	hw:2G [71]	2282
FA2: Core Laboratory Work Area									
LBBD2	Specimen Accessioning, Processing and Distribution Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2283
XXYYC	Automated Data Processing, Control Area	m:VT m:AF	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:3E	2284
XXYYC	Automated Data Processing, Processor Area	m:VT m:AF	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2285

Chapter **240** Pathology and Laboratory Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Clinical Pathology Work Area									
LMCH3	Clinical Chemistry	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2286
LMCH4	Chemistry, Special Chemistry	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2287
LBRI1	Radioimmunoassay (RIA) [50]	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T dl:RF s:V	hw:4K	2288
LMU03	Urine (Urinalysis) and Feces	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2289
LMHI3	Hematology, Routine Laboratory	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2290
LMHI3	Hematology, Coagulation Laboratory	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2291

Chapter 240 Pathology and Laboratory Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Clinical Pathology Work Area									
LMBB2	Blood Bank, Blood Product Storage, Testing and Issuance (Transfusion Service)	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2292
LMBB3	Blood Bank, Blood Product Preparation/Modification	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2293
LMBB1	Blood Bank, Hemotherapeutics Room	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2294
LMBB2	Blood Bank, Donor Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT	m:Wood t:19 dg:T s:V	hw:4N	2295
LMM02	Microbiology, Clinical Microbiology	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2296
LMM03	Microbiology, Biosafety Laboratory	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2297
LMM03	Microbiology, Mycology Laboratory	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2298

Chapter 240 Pathology and Laboratory Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Clinical Pathology Work Area									
LMM03	Microbiology, Mycobacteriology (TB) Laboratory	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2299
LMM02	Microbiology, Media Preparation Room	m:RES [7]	m:RES [7] h:4"	m:GWB f:RES-W		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2300
LMHC1	Immunopathology	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2301
XXYYC	Fluorescent Microscopy Room	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:V	hw:4K	2302
XXYYC	Automated Data Processing	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4G	2303
FA4: Molecular Testing Suite									
LMML2	Preamplification Room, Reagent Prep	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2304
LMML3	Preamplification Room, Specimen Processing	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2305

Chapter 240 Pathology and Laboratory Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Molecular Testing Suite									
LMML4	Amplification/Instrument Room	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2306
XXYYC	Developing, Printing and Enlarging Dark Room	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:N/A	2307
XXYYC	Automated Data Processing	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4G	2308
FA5: Anatomical Pathology Work Area									
LMHS2	Historical Laboratory	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2309
LMHC1	Frozen and Gross Section Laboratory	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2310
LMCY3	Cytology Laboratory	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:19 dg:T s:V	hw:4K	2311
SRL01	Slide, Block and Records Files	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4G	2312
XXYYC	Automated Data Processing	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4G	2313

Chapter 240 Pathology and Laboratory Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Electron Microscopy Suite									
LBEM2	Scope Room	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 s:V	hw:4L	2314
XXYYC	Dark Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 s:S	hw:N/A	2315
LBEM3	Preparation Room	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2316
XXYYC	Cutting Room	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:3 dg:T s:V	hw:4K	2317
LBEM3	Developing, Printing and Enlarging Dark Room	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:N/A	2318
XXYYC	Finishing Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4G	2319
XXYYC	Automated Data Processing	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4G	2320
FA7: Autopsy Suite									
LBAR1	Autopsy Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:XX	hw:10B	2321

Chapter 240 Pathology and Laboratory Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Autopsy Suite									
XXYYC	Isolation / Teaching Autopsy Room	m:RES	m:RES h:4"	m:GWB [18] f:SC		m:GWB f:SC	m:Wood t:19 dg:T s:X	hw:4S	2322
LBMR1	Mortuary Refrigerator (Cold Room)	m:RES [63]	m:RES h:4"	m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [66]	hw:N/A	2323
LBTS1	Gross Specimen Storage	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2324
TLTS1	Bathroom, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	2325
LR002	Lockers, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2326
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2327
FA8: Support Area									
CSSS2	Storage, Sterilization and Preparation Room	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	2328
SRS01	Storage, Bulk	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:SS s:V	hw:11B hw:5B	2329

Chapter 240 Pathology and Laboratory Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Support Area									
SRR01	Storage, Refrigerated	m:RES	m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:11 dg:F s:SS s:V	hw:11B hw:5B	2330
SRGC2	Storage, Flammable and Toxic Substance	m:RES	m:RES h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:11 dg:F dr:45 min s:V	hw:5B	2331
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2332
FA9: Staff and Administrative Area									
OFA09	Office, Pathology and Laboratory Medicine Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2333
OFA09	Office, Pathology and Laboratory Section Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2334
XXYYC	Workstation, Staff Pathologist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2335
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2336
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2337
OFA07	Workstation, Administrative Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2338

Chapter 240 Pathology and Laboratory Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA9: Staff and Administrative Area									
OFA09	Office, Chief Medical Technologist [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2339
OFA09	Office, Chief Clinical Laboratory Scientist [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2340
OFA07	Workstation, Clinical Laboratory Scientist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2341
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:4J	2342
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2343
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2344
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	2345
FA10: Education Area									
OFA07	Workstation, Pathology Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2346
OFA07	Workstation, Education Coordinator	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2347

Chapter 240 Pathology and Laboratory Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA10: Education Area									
CRA02	Classroom / Laboratory	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:4G	2348
OFA07	Workstation, Student	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2349
LIBB1	Library	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2350

72

CANCELLED

Chapter 244 Lobby

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Lobby Area									
LOB01	Lobby	m:TER [21]	m:TT h:4"	m:GWB [5] f:P		m:AT	m:Steel t:40 da:ADO dg:T s:X	hw:6D	2351
RECP1	Information Desk	m:TER [21]	m:TT h:4"	m:GWB [5] f:P		m:AT m:GWB f:P	m:Wood t:1 s:S t:OPEN	hw:3E hw:N/A	2352
TLTM2	Toilet, Male	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2353
TLTF2	Toilet, Female	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2354
LOB04	Water Fountain Area	m:TER [21]	m:TT h:4"	m:CT m:S [51]		m:AT	t:OPEN	hw:N/A	2355
SRLW1	Storage, Wheelchair	m:TER [21]	m:TT h:4"	m:CT [7]		m:AT	t:OPEN	hw:N/A	2356
LOB03	Telephone, Public	m:TER [21]	m:TT h:4"	m:CT		m:AT	t:OPEN	hw:N/A	2357
OFA07	Workstation, Volunteer	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2358

Chapter 246 Health Administration Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Office of the Chief									
OFA09	Office, Health Administration Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2359
OFA09	Office, Health Benefits Section Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2360
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2361
OFA07	Workstation, Medical Administrative Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2362
OFA07	Workstation, Program Application Specialist (PAC)	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2363
SRS01	Storage Room / Work Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4G	2364
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2365
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	2366
FA2: Health Benefits Section: Centralized Registration Unit (CRU)									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4G	2367

Chapter 246 Health Administration Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Health Benefits Section: Centralized Registration Unit (CRU)									
REC01	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2368
OFA09	Office, Health Benefits Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2369
OFDC2	Consult Room, Decedent Affairs Clerk [2]	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	2370
OFA07	Workstation, MCCR Section Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2371
OFA09	Office, Eligibility Clerk	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:N/A	2372
OFA04	Interview Room, Eligibility	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2373
OFA03	Workstation, Photo Area for Veterans Identification Cards (VIC)	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2374
OFA07	Workstation, Release of Information Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2375
OFA07	Workstation, Program Support Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2376
OFA07	Workstation, Bed Control Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2377
OFA07	Workstation, Medical / Patient Support Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2378

Chapter 246 Health Administration Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA2: Health Benefits Section: Centralized Registration Unit (CRU)

OFA07	Workstation, Lead Patient Services Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2379
SRPB2	Storage, Patient Belongings [2]	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2380
OFA07	Workstation, Outpatient Transfer Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2381
OFA07	Workstation, Inpatient Transfer Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2382
SRS01	Storage, Supplemental Equipment	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:F s:U	hw:N/A	2383

FA3: Health Benefits Section: Outpatient Registration

OFA09	Office, Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2384
-------	------------------------	-----------	-----------	----------------	--	------	---------------------	-------	------

FA4: Health Information Management Section (HIMS)

OFA09	Office, Health Information Management Section (HIMS) Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2385
OFA09	Office, Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2386
OFA09	Office, File Room Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2387
OFA07	Workstation, Billing Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2388

Chapter 246 Health Administration Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Health Information Management Section (HIMS)									
OFA07	Workstation, Coding Unit	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2389
OFA04	Office, Tumor Registry	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:N/A	2390
OFA07	Workstation, QA Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2391
OFA07	Workstation, Release of Information Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2392
OFA07	Workstation, Transcription Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2393
OFA07	Workstation, Transcriptionist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2394
SRSE1	Storage, Transcription Equipment	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4K	2395
OFA07	Workstation, EPRP Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2396
OFA07	Workstation, Record Review Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2397
MRWK1	Document Scanning Station	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:N/A	2398
SRE01	Supply, Document Scanning	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4K	2399

Chapter 246 Health Administration Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Health Information Management Section (HIMS)									
FILE1	File Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4M	2400
FA5: Ward Administration Section (WAS)									
OFA09	Office, Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2401
OFA09	Office, Lead Clerk [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2402
OFA07	Workstation, Ward Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2403
SRS01	Storage, Ward Clerk	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4K	2404
FA6: Fee Services (FS) Section									
OFA09	Office, Fee Services Section Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2405
OFA09	Office, Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2406
RECP3	Reception	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2407
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2408
OFA07	Workstation, Interview	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2409

Chapter **246** Health Administration Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Fee Services (FS) Section									
SRS01	Storage, Supplemental Equipment	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4K	2410
FA7: Office Operations Section									
MRMB1	Mailroom	m:SVT m:RF	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4M	2411
COMC1	Telephone Switchboard Room	m:VT	m:RB h:4"	m:GWB [34] f:P		m:AT	m:Wood t:19 s:S	hw:5G	2412

CANCELLED

Chapter 248 Medical Media Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception and Administration Area									
OFA09	Office, Medical Media Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2413
RECP1	Reception / Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2414
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2415
CRA01	MMS / MMEC Client Review Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	2416
FA2: Photography Service Production Area									
MIPF1	Digital Photo, Editing and Printing Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	2417
MIDR1	Darkroom, Black and White / Color Processing / Printing	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3G	2418
MICL1	Camera Copy Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:X	hw:4K	2419
MICL1	Photomicrography / Photomacrography Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3G	2420
MIST1	Still Photography and Video Recording Studio	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:VV	hw:4K	2421

Chapter 248 Medical Media Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Photography Service Production Area									
TLTU1	Toilet / Changing Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2G [69]	2422
FA3: Illustration Service Production Area									
MIST1	Workroom, Illustrator	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 dg:T s:S	hw:4G	2423
MIST1	Illustration Preparation Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 dg:T s:S	hw:4G	2424
MIST1	Electronic Graphic Design and Publishing	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	2425
FA4: Audiovisual Service Production Area									
XXYYC	Video Editing / CCTV Control Room Video Distribution	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4K	2426
TEEQ1	MATV / CCTV Distribution Headend	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4G	2427
FA5: Central Copy Center Service Production Area									
XXYYC	Central Copy Center	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4K	2428
SRE01	Storage, Paper / Supply	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:T s:V	hw:5B	2429

Chapter 248 Medical Media Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Support Area									
SRE01	Storage, MMS	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	2430
SRE01	Storage, MMEC	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	2431
SRE01	Audiovisual (AV) Equipment Storage/Check-out Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:T s:V	hw:5B	2432
CRA01	Video-Teleconferencing Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4J	2433
FA7: MMVSS Reception and Administration Area									
RECP3	MMVSS Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT m:GWB f:P	t:OPEN	hw:N/A	2434
OFA07	MMVSS Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2435
OFA09	MMVSS Office, Media Services Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2436
CRA01	MMVSS Client Review Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	2437
FA8: MMVSS Photography Production Area									
XXYYC	MMVSS Digital Photo, Editing, and Printing Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4J	2438

Chapter 248 Medical Media Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: MMVSS Photography Production Area									
MIDR1	MMVSS Darkroom, Black and White / Color Processing / Printing	m:RES	m:RES h:4"	m:GWB f:P		m:GWB f:P	m:Wood t:1 s:S	hw:3G	2439
MIST1	MMVSS Camera Copy Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:X	hw:4K	2440
MICL1	MMVSS Photomicrography / Photomacrography Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3G	2441
MIST1	MMVSS Still Photography Studio	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4J	2442
TLTU1	MMVSS Toilet / Changing Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:19 s:S	hw:2G [69]	2443
FA9: MMVSS Illustration Service Production Area									
MIST1	MMVSS Workroom, Illustrator	m:VT	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4J	2444
MIST1	MMVSS Illustration Preparation Room	m:VT	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4J	2445
MIST1	MMVSS Electronic Graphic Design and Publishing	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4J	2446
FA10: MMVSS Audiovisual Service Production Area									
XXYYC	MMVSS Video Recording Studio	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3F	2447

Chapter 248 Medical Media Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA10: MMVSS Audiovisual Service Production Area									
XXYYC	MMVSS Studio Control Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:VV	hw:3F	2448
XXYYC	MMVSS Video Editing Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:X	hw:3F	2449
XXYYC	MMVSS Audio Recording and Narration Sound Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:3F	2450
TEEQ1	MMVSS MATV / CCTV Distribution Headend	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4J	2451
FA11: MMVSS Central Copy Center Service / Production Area									
XXYYC	MMVSS Central Copy Center / Reproduction Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4G	2452
SRE01	MMVSS Storage, Paper / Supply	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:F s:V	hw:5B	2453
FA12: MMVSS Support Area									
SRE01	MMVSS Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:F s:V	hw:5B	2454
SRE01	MMVSS Audiovisual (AV) Equipment Storage / Check-out Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:11 dg:T s:X	hw:5B	2455
CRA01	MMVSS Video-Teleconferencing Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4J	2456

Chapter **248** Medical Media Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA13: VAMC without Medical Media Service									
SRE01	Storage, Audiovisual Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:X	hw:5B	2457
XXYYC	Copy Center	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4G	2458

46

CANCELLED

Chapter 252 Nuclear Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting Area	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	2459
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2460
CLSC1	Patient Education Kiosk / Alcove	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2461
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2462
FA2: Patient Area									
WRC01	Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	2463
PAIA1	Patient Interview Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2464
NMGS1	Scanning Room, NM	m:WSF	m:WSF h:4"	m:GWB [27] f:P		m:AT	m:Wood [27] t:19 dr:RF s:X	hw:4E	2465
NMCR1	Computer Image Processing Area	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4G	2466

Chapter 252 Nuclear Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
CMP01	Data Processing Equipment	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4K	2467
XVC01	Reading and Consultation Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2468
EXRG1	Patient Examination Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2469
NMIR1	Patient Dose Administration Room	m:WSF	m:WSF h:4"	m:GWB [27, 64] f:P		m:AT [9] f:SP	m:Wood t:1 s:X	hw:1F	2470
NMUR1	Thyroid Uptake Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT [9] f:SP	m:Wood t:1 s:X	hw:1F	2471
NMRP1	NM "Hot Lab" / Radiopharmacy	m:WSF	m:WSF h:4"	m:GWB [27] f:P		m:AT [9] f:SP	m:Wood t:1 ds:YES s:U	hw:SH- 3C	2472
OPPE2	Cardiac Stress Testing Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT [9]	m:Wood t:19 s:X	hw:4E	2473
TLTU1	Toilet, NM Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2C [71]	2474
DR001	Dressing Room / Cubicle	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:2 [71]	2475
ORPP1	Holding Bay, Patient Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:4D	2476
XDBD1	Bone Densitometry Room	m:LVT	m:RB h:4"	m:GWB [27, 64] f:P		m:AT	m:Wood t:19 dl:LEAD s:X	hw:4E	2477

Chapter **252** Nuclear Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
NMSS1	PET: Scanning Room, PET / CT	m:WSF	m:WSF h:4"	m:GWB [27] f:P		m:AT [9] f:SP	m:Wood t:15 dl:LEAD s:X	hw:4Q	2478
NMCR1	PET: Control Room	m:WSF	m:WSF h:4"	m:GWB [27] f:P		m:AT	m:Wood t:1 dg:T s:U	hw:3E	2479
XMRC2	PET: System Component Room	m:WSF	m:WSF h:4"	m:GWB [27] f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4K	2480
NMRP1	PET: Radio Chemistry Room	m:WSF	m:WSF h:4"	m:GWB [27] f:P		m:AT [9] f:SP	m:Wood t:1 dg:T s:X	hw:1F	2481
XTLA1	PET: Cyclotron	m:WSF	m:WSF h:4"	m:GWB [27] f:P		m:AT [9] f:SP	m:Wood t:15 s:X	hw:4Q	2482
XVC01	PET: Reading / Staff Consultation Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT [9] f:SP	m:Wood t:19 dg:T s:S	hw:3G	2483
DR001	PET: Dressing Room / Cubicle	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:2 [71]	2484
TLTU1	PET: Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2C [71]	2485
ORPP1	PET: Holding Bay, Patient Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:4D	2486
LBRI1	BAU: Data Reduction and Reporting Receiving / Preparation	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:X	hw:4K	2487
LBRI1	BAU: Assay Preparation	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:X	hw:4K	2488

Chapter 252 Nuclear Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
LBRI1	BAU: Biohazard Preparation	m:WSF	m:WSF h:4"	m:GWB [36] f:SC m:CMU [36] f:SC		m:GWB f:SC	m:Wood t:1 dg:F dr:45 min s:X	hw:4K	2489
LBRI1	BAU: Sample Counting / Measurement	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:X	hw:4K	2490
FA3: Support Area									
WRCH1	Work Area, Staff	m:CPT [6] m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4K	2491
XRM01	Storage, Mobile Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:T s:U	hw:5D	2492
SRR02	Storage, Refrigerated	m:RES	m:RES h:4"	m:GWB f:SC m:CMU f:SC		m:GWB f:SC	m:Wood t:1 s:U	hw:4D	2493
XVC01	PACS / Digital Quality Control Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:3H	2494
XFDS1	PACS / Digital Archival Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	2495
XFSA1	Patient Film Records	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:U	hw:5B	2496
XFDS1	Patient Treatment Files	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:U	hw:5B	2497

Chapter 252 Nuclear Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Support Area									
XTLB1	Biosafety / Health Physics Lab	m:WSF	m:WSF h:4"	m:GWB [36] f:P		m:AT [9] f:SP	m:Wood t:1 dg:F dr:45 min s:V	hw:4G	2498
NMDC1	Storage, Radioactive Waste	m:RES	m:RES h:4"	m:CMU [36] f:SC		m:AT [9] f:SP	m:Wood t:1 s:U	hw:5E	2499
NMDC1	Equipment Calibration	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4K	2500
RCAO1	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2501
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	2502
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	2503
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2504
LLCL1	Alcove, Linen	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2505
SRLW2	Storage, Stretcher / Wheelchair	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:4D	2506
FA4: Staff and Administrative Area									
OFA09	Office, Nuclear Medicine Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2507

Chapter 252 Nuclear Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Staff and Administrative Area									
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2508
RECP3	Reception	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2509
OFA07	Workstation, Administrative Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2510
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2511
OFA07	Workstation, Non-Physician Professional	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2512
OFA07	Workstation, Physicist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2513
OFA07	Workstation, Chief Technologist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2514
OFA07	Workstation, Cyclotron Operator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2515
OFA07	Workstation, PACS Administrator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2516
OFA07	Workstation, Quality Assurance	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2517
WRTM2	Workroom Tele-Nuclear Medicine Office	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2518

Chapter **252** Nuclear Medicine Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Staff and Administrative Area									
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2519
OFA07	Workstation, Data Processing	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2520
OFA07	Workstation, Scheduler	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2521
OFA07	Workstation, Transcriptionist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2522
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2523
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2524
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	2525
FA5: Education Area									
OFA07	Workstation, Resident Intern / Student	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2526

Chapter **254** Nursing Service Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	2527
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2528
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2529
FA2: Staff and Administration Area									
OFA11	Office, Nurse Executive Chief / Patient Care Associate Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2530
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2531
OFA09	Office, Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2532
OFA09	Office, Clinical Services Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2533
OFA09	Office, Administrative Officer [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2534

Chapter 254 Nursing Service Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Staff and Administration Area									
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2535
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2536
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2537
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2538
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	2539
FA3: Education Area									
OFA09	Office, Associate Chief for Education	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2540
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2541
OFA07	Workstation, Instructor	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2542
OFA07	Workstation, Intern / Student	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2543

Chapter **254** Nursing Service Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Education Area									
CLR02	Classroom	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	2544

18

CANCELLED

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Emergency Department: Reception Area									
LOB02	Vestibule, Emergency Department	m:MAT	m:RB h:4"	m:GWB f:P		m:AT m:GWB f:P	m:Steel t:40 [17] da:YES dg:T s:VV m:Steel t:42 [17] da:YES dg:T s:VV	hw:8D	2545
WRC01	Waiting, General	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:S	hw:4K	2546
RECP1	Reception / Check-in	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	2547
RPR03	Alcove, Copier / Printer	m:CPT m:LVT	m:RB h:4"	m:GWB [54] f:P		m:AT	t:OPEN	hw:N/A	2548
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	2549
RECP2	Security Station	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2550
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:5'-0" m:CT [7] h:5'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2551
BX001	Vending Area	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2552
LOB03	Alcove, Public Telephone	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2553
LOB04	Alcove, Water Fountain	m:LVT	m:RB h:4"	m:GWB [54] f:SC	m:CT h:4'- 0"	m:AT	t:OPEN	hw:N/A	2554

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Emergency Department: Reception Area									
SRLW1	Alcove, Wheelchair / Stretcher / Lift	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2555
FA2: Emergency Department: Patient Care Area									
EXTR1	Patient Room, Triage	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:U	hw:1Q	2556
TRET4	Exam / Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1R	2557
TRET4	Exam / Treatment Room, Negative Pressure Isolation	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT f:SP	m:Wood t:19 s:U	hw:1R	2558
BRAR1	Anteroom, Negative Pressure Isolation	m:WSF	m:WSF h:4"	m:GWB [18] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:1 dg:T s:U	hw:1K	2559
TRET4	Exam / Treatment Room, Positive Pressure Isolation	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:19 dg:T s:U	hw:1R	2560
TLTU1	Toilet, Isolation Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 18, 44, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:AT	m:Wood t:19 s:U	hw:2H	2561

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Emergency Department: Patient Care Area									
TRET6	Exam / Treatment Room, Bariatric	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:U	hw:1R	2562
TLTB1	Toilet, Bariatric Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:AT	m:Wood t:19 s:U	hw:2H	2563
EXRG9	Exam / Treatment, SANE	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1R	2564
TLTS2	Toilet / Shower, SANE Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2565
OFDC2	Consult Room, SANE	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T dl:LEAD s:U	hw:3G	2566
SRS01	Storage, SANE Evidence	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	2567
TRET3	Resuscitation Room	m:RES	m:RES h:4"	m:GWB f:RES-W		m:GWB f:SC	t:3 da:YES dg:T s:X	hw:10H	2568
SRS01	Storage, Resuscitation Room Supplies	m:RES	m:RES h:4"	m:GWB [54] f:RES-W	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:11 s:V	hw:4Q	2569

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Emergency Department: Patient Care Area									
TRPR1	Procedure Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 da:YES dg:T s:SS m:Wood t:19 da:YES dg:T s:X	hw:13	2570
OPMH4	Exam / Treatment Room, Mental Health	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:19 s:U	hw:4N	2571
TLTP1	Toilet, Mental Health Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 sw:OUT s:U	hw:MH2 [72]	2572
BRNP5	Intervention (Seclusion) Room, Mental Health	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [45, 64] f:P m:CMU f:P		m:GWB f:P	m:Wood t:19 dg:A s:X	hw:MH5 [11]	2573
NSTA4	Observation Station, Mental Health	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2574
OPCR1	Cast Room, Orthopedics	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SC	m:Wood t:19 s:X	hw:4P	2575
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:19 s:S	hw:2H	2576

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Emergency Department: Patient Care Area									
SHWR1	Shower, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2577
FA3: Emergency Department Observation Patient Care Area									
TRET4	Observation Room	m:LVT m:WSF	m:LVT h:4" m:WSF	m:GWB [45, 64] f:P			m:Wood t:19 s:X	hw:MH5 [11]	2578
NSTA4	Staff Observation Station	m:LVT	m:RB h:4"	m:GWB f:P			m:Wood t:19 s:S	hw:3G	2579
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 sw:OUT s:S	hw:MH2 [72]	2580
FA4: Emergency Department: Imaging Patient Care Area									
WRC01	Sub-Waiting, Imaging Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2581
DR001	Dressing Area, Imaging Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:2H [43]	2582

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Emergency Department: Imaging Patient Care Area									
TLTU1	Toilet, Imaging Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2J [71]	2583
XDR01	Procedure Room, General Radiology	m:RES	m:RES h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:17 dl:LEAD s:X	hw:4Q	2584
XDRC1	Alcove, General Radiology Control	m:RES	m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	t:OPEN	hw:N/A	2585
XCTS1	Procedure Room, CT	m:RES	m:RES h:4"	m:GWB [64] f:SC		m:AT f:sP	m:Wood t:15 dl:LEAD s:X	hw:4Q	2586
XCTC1	Alcove, CT Control	m:RES	m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	t:OPEN	hw:N/A	2587
FA5: Emergency Department: Support Area									
NSTA1	Team Workroom	m:CPT [6] m:VT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2588
NT001	Pneumatic Tube Station	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3E	2589
DUTY1	On-Call Room	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 ds:YES s:S	hw:SH- 3E	2590

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Emergency Department: Support Area									
TLTS1	Toilet / Shower, On-Call Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	2591
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3C	2592
NCWD3	Nourishment Room	m:SVT [49] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3C	2593
LBSP1	Laboratory, Satellite	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2594
CSED1	Decontamination	m:RES	m:RES [7] h:4"	m:S [7, 44]		m:GWB f:SC	m:Wood t:1 s:S	hw:2C [71]	2595
SRS01	Storage, Decontamination Supplies	m:RES	m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 s:V	hw:5B	2596
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2597
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	2598
LCCL3	Alcove, Clean Linen	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2599

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Emergency Department: Support Area									
SRLW1	Alcove, Wheelchair / Stretcher / Lift	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2600
RCA01	Alcove, Emergency Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2601
XRM01	Alcove, Portable Imaging Equipment	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2602
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	2603
SRS01	Storage, Disaster Mitigation Supplies	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	2604
SRLW2	Storage, EMS	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	2605
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2606

FA6: Emergency Department: Staff and Administrative Area

OFA09	Office, Emergency Department (ED) Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2607
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2608
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2609
LR004	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2610

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Emergency Department: Staff and Administrative Area									
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	2611
SL001	Lounge, Staff 2	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2612
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2613
TLTU1	Toilet, Staff 2	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	2614
FA7: Urgent Care Clinic: Reception Area									
LOB02	Vestibule, Urgent Care Clinic	m:MAT	m:RB h:4"	m:GWB f:P		m:AT m:GWB f:P	m:Steel t:40 [17] da:YES dg:T s:VV m:Steel t:42 [17] da:YES dg:T s:VV	hw:8D	2615
WRC01	Waiting, General	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	2616
RECP1	Reception / Check-in	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT m:GWB f:P	m:Wood t:1 dg:T s:S	hw:4K	2617
RPR03	Alcove, Copier / Printer	m:CPT m:LVT	m:RB h:4"	m:GWB [54] f:P		m:AT	t:OPEN	hw:N/A	2618

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Urgent Care Clinic: Reception Area									
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	2619
RECP2	Security Station	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2620
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2621
BX001	Vending Area	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2622
LOB03	Alcove, Public Telephone	m:LVT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2623
LOB04	Alcove, Water Fountain	m:LVT	m:RB h:4"	m:GWB f:SC	m:CT h:4'-0"	m:AT	t:OPEN	hw:N/A	2624
SRLW1	Alcove, Wheelchair / Stretcher / Lift	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2625
FA8: Urgent Care Clinic: Patient Care Area									
EXTR1	Patient Room, Triage	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:U	hw:1Q	2626
EXRG0	Exam Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1R	2627

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Urgent Care Clinic: Patient Care Area									
EXRG0	Exam Room, Negative Pressure Isolation	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:19 s:U	hw:1R	2628
BRAR1	Anteroom, Negative Pressure Isolation	m:WSF	m:WSF h:4"	m:GWB [18] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:1 dg:T s:U	hw:1K	2629
EXRG0	Exam Room, Positive Pressure Isolation	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC m:AT [9] f:SP	m:Wood t:19 dg:T s:U	hw:1R	2630
TLTU1	Toilet, Isolation Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 18, 44, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:AT	m:Wood t:19 s:U	hw:2H	2631
EXB01	Exam Room, Bariatric	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:U	hw:1R	2632
TLTB1	Toilet, Bariatric Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:AT	m:Wood t:19 s:U	hw:2H	2633

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Urgent Care Clinic: Patient Care Area									
EXRG9	Exam / Treatment Room, SANE	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1R	2634
TLTS2	Toilet / Shower, SANE Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:19 s:S	hw:2 [71] hw:4B [31]	2635
OFDC2	Consult Room, SANE	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T dl:LEAD s:U	hw:3G	2636
SRS01	Storage, SANE Evidence	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	2637
TRPR1	Procedure Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 da:YES dg:T s:SS m:Wood t:19 da:YES dg:T s:X	hw:13	2638
OPMH4	Exam Room, Mental Health	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:19 s:U	hw:4N	2639
TLTP1	Toilet, Mental Health Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 sw:OUT s:U	hw:MH2 [72]	2640
BRNP5	Intervention Room, Mental Health	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [45, 64] f:P m:CMU f:P		m:GWB f:P	m:Wood t:19 dg:A s:X	hw:MH5 [11]	2641

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA8: Urgent Care Clinic: Patient Care Area

NSTA4	Observation Station, Mental Health	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2642
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2H	2643
SHWR1	Shower, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 45] m:S	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:MH3 [32]	2644

FA9: Urgent Care Clinic: Imaging Patient Care Area

WRC01	Sub-Waiting, Imaging Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2645
DR001	Dressing Area, Imaging Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:2H [48]	2646
TLTU1	Toilet, Imaging Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2J	2647
XDR01	Procedure Room, General Radiology	m:RES	m:RES h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:17 dl:LEAD s:X	hw:4Q	2648

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA9: Urgent Care Clinic: Imaging Patient Care Area									
XDRC1	Alcove, General Radiology Control	m:RES	m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	t:OPEN	hw:N/A	2649
FA10: Urgent Care Clinic: Support Area									
NSTA1	Team Workroom / Communication Station	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2650
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3C	2651
NCWD3	Nourishment Room	m:SVT [49] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3C	2652
LBSP1	Laboratory, Satellite	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2653
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2654
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	2655
LCCL3	Alcove, Clean Linen	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2656
SRLW1	Alcove, Wheelchair / Stretcher / Lift	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2657

Chapter 256 Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA10: Urgent Care Clinic: Support Area

RCA01	Alcove, Emergency Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2658
XRM01	Alcove, Portable Imaging Equipment	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2659
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	2660
SRS01	Storage, Disaster Mitigation Supplies	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	2661
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2662

FA11: Urgent Care Clinic: Staff and Administrative Area

OFA09	Office, Urgent Care Clinic (UCC) Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2663
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2664
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2665
LR004	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2666
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	2667

Chapter **256** Emergency Department (ED) and Urgent Care Clinic (UCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA11: Urgent Care Clinic: Staff and Administrative Area									
SL001	Lounge, Staff 2	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2668
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2669
TLTU1	Toilet, Staff 2	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	2670

126

CANCELLED

Chapter **258** Women Veterans Clinical Service (WVCS) (For Models 2 and 3)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting, General	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4K	2671
WRF01	Waiting, Family	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4K	2672
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8] h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2673
RPR01	Alcove, Copier / Printer	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2674
OFDC2	Interview / Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	2675
TLTF3	Toilet, Family	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2676
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2677
NCWD4	Alcove, Refreshment Center	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2678
RECP4	Kiosk, Patient Check-in	m:CPT m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2679

Chapter 258 Women Veterans Clinical Service (WVCS) (For Models 2 and 3)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
CLSC1	Workstation, Patient Education	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2680
LAC01	Lactation Room	m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:2G	2681
TLTF3	Toilet, Lactation Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G	2682
FA2: Patient Area									
EXW01	Exam Room, Multipurpose	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2683
EXW01	Exam Room, Gynecology	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2684
EXW01	Exam Room, Cancer Screening	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2685
EXW02	Exam Room, Breast Clinic	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2686
TLTU1	Toilet, Exam Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2687
TROB1	Procedure Room, Gynecology	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 s:U	hw:1Q	2688

Chapter 258 Women Veterans Clinical Service (WVCS) (For Models 2 and 3)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
TLTF1	Toilet, Gynecology Procedure Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2689
TROB2	Procedure Room, Urology-Gynecology	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 s:U	hw:1Q	2690
TLTF1	Toilet, Urology-Gynecology Procedure Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2691
TRAT1	Procedure Room, Alternative Therapy	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 s:U	hw:1Q	2692
CLSC4	Shared Medical Appointment Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2693
WRTM2	Tele-Health Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2694
FA3: Imaging Women's Health Center (WHC) (Model 3 only) Patient Area									
WRC01	Sub-Waiting, Imaging Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	2695
DR001	Dressing Area, Imaging Patient	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:2H [71]	2696

Chapter 258 Women Veterans Clinical Service (WVCS) (For Models 2 and 3)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Imaging Women's Health Center (WHC) (Model 3 only) Patient Area									
TLTU1	Toilet, Imaging Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2697
XDUS1	Procedure Room, Breast Ultrasound	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT	m:Wood t:19 s:U	hw:1Q	2698
XDM01	Procedure Room, Mammography	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT	m:Wood t:19 s:U	hw:1Q	2699
XDM02	Procedure Room, Stereotactic Radiography	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT	m:Wood t:19 s:U	hw:1Q	2700
XDBD1	Procedure Room, Bone Densitometry	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT	m:Wood t:19 s:U	hw:1Q	2701
XVC01	Viewing Room, Picture Archiving and Communication System - PACS	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3G	2702
SRE01	Storage, Imaging Services Medical Equipment	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:V	hw:3E	2703
FA4: Support Area									
LCCL3	Alcove, Clean Linen	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2704
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54]	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2705
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2706

Chapter **258** Women Veterans Clinical Service (WVCS) (For Models 2 and 3)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA4: Support Area

LBSP1	Laboratory, Satellite	m:WSF	m:WSF h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:19 s:U	hw:3E	2707
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-3D	2708
SRE01	Storage, Medical Equipment	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:4F	2709
SRLW1	Alcove, Wheelchair / Stretcher / Lift	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2710
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2711

FA5: Staff and Administrative Area

WRTM1	Shared Documentation Work Area	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2712
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2713
WRTM1	Workroom, Volunteers	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4J	2714
OFA09	Office, Women Veterans Program Manager	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2715
OFA07	Workstation, Women Veterans Program Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2716
OFA07	Workstation, Specialty Provider	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2717

Chapter 258 Women Veterans Clinical Service (WVCS) (For Models 2 and 3)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Staff and Administrative Area									
OFA07	Workstation, RN Care Manager	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2718
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2719
OFA09	Office, Patient Advocate [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2720
OFA04	Office, Benefits Advisor [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2721
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2722
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	2723
LR004	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2724
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2725

FA6: Education Area

OFA09	Office, WVCS Residency Program Director [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2726
OFA07	Workstation, Research Assistant	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2727

Chapter **258** Women Veterans Clinical Service (WVCS) (For Models 2 and 3)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Education Area									
CLR01	Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	2728

58

CANCELLED

Chapter 260 Mental Health Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:GWB f:P	t:OPEN	hw:N/A	2729
NSTA1	Communication Center	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:GWB f:P	m:Wood t:1 s:S	hw:3	2730
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2731
FA2: Patient Area [67]									
EXRG3	Exam Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:19 s:U	hw:4N	2732
TRGM1	Treatment Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:19 s:U	hw:4N	2733
OPMH1	Group Therapy Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:19 s:S	hw:4N	2734
OPMH3	Biofeedback Laboratory Treatment Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:19 s:U	hw:4N	2735
CMP02	Biofeedback Laboratory Control Room / Office	m:WSF	m:WSF h:4"	m:GWB f:P		m:GWB f:P	m:Wood t:1 dg:LG s:U	hw:3B	2736

Chapter 260 Mental Health Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area [67]									
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44] h:4'- 0"	m:AT	m:Wood t:19 s:U	hw:2H	2737
FA3: Staff and Administrative Area									
OFA09	Office, Mental Health Clinic Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:LG s:S	hw:3G	2738
OFDC1	Office, Counselor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:GWB f:P	m:Wood t:1 dg:LG s:S	hw:3B	2739
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2740
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2741
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	2742
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2743
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2744

Chapter **260** Mental Health Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Education Area									
SL002	Team Room	m:CPT [6] m:VT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:20 s:S	hw:SH-4	2745
CRA02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:20 dg:T s:U	hw:4J	2746

CANCELLED

Chapter 261 Day Treatment Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2747
NSTA1	Communication Center	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2748
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2749
FA2: Patient Area									
EXRG3	Exam Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2750
TRGM1	Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2751
DAYR1	Quiet Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 s:U	hw:4E	2752
OPMH1	Group Therapy Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:6C	2753
SL001	Social Activities / Dining / Multipurpose Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:SS	hw:12G	2754
SRS01	Storage, Social Activities	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:U	hw:5	2755

Chapter 261 Day Treatment Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
IPK01	Kitchen	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:V	hw:4N	2756
OPMH3	Biofeedback Laboratory Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:SC		m:AT	m:Wood t:19 s:U	hw:1R	2757
CMP02	Biofeedback Laboratory Control Room / Office	m:LVT m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3B	2758
OTGC1	Education Therapy Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:SS	hw:12G	2759
OTGC1	Occupational Therapy Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:SS	hw:12G	2760
SRE01	Storage, Occupational Therapy	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:U	hw:5	2761
OTGC1	Compensated Work Therapy Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:SS	hw:12G	2762
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2763
FA3: Staff and Administrative Area									
OFA09	Office, Day Treatment Center Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2764

Chapter 261 Day Treatment Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Staff and Administrative Area									
OFDC1	Office, Counselor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3G	2765
OFA07	Workstation, Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2766
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	2767
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2768
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2769
FA4: Education Area									
SL002	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:20 s:S	hw:SH-4	2770
CRA02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	2771

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting, General	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	2772
TLTM1	Toilet, Male	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2773
TLTF1	Toilet, Female	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2774
CLSC1	Patient Education Kiosk / Alcove	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2775
CRA01	Patient Education Conference Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	2776
RECP3	Escort / Messenger Service	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4G	2777
FA2: (MAS) Reception / Central Control and Processing Unit Area									
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2778

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: (MAS) Reception / Central Control and Processing Unit Area									
OFA09	Office, Interview [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2779
OFA07	Workstation, Reception Area Supervisor	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2780
OFA07	Workstation, Bed Control	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2781
OFA04	Office, Health Benefits Advisor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2782
SRLW1	Storage, Wheelchair and Stretcher	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:S	hw:4D	2783
BX001	Vending Machine Area	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2784
FA3: Examination / Treatment Module: General Patient Area									
CALC1	Number of Examination / Treatment Modules								2785
RECP1	MAS: Reception / Treatment Module Control	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2786
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2787

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Examination / Treatment Module: General Patient Area									
TLTM1	Toilet, Male Public / Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2788
TLTF1	Toilet, Female Public / Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	2789
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	2790
LBVP1	Blood Draw	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:V	hw:4K	2791
TLTU1	Toilet, Specimen Blood Draw Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71]	2792
EXRG3	Exam Room, Admit / Screen / Employee Health	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	2793
EXRG3	Exam Room, Medicine / Oncology / Gastroenterology	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	2794
EXRG3	Exam Room, Surgery / Urology / Orthopedics	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	2795
EXRG3	Exam Room, C & P	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	2796

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Examination / Treatment Module: General Patient Area									
EXRG3	Exam Room, Dermatology	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	2797
EXRG3	Exam Room, Podiatry	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	2798
EXRG8	Exam Room, Women's Health / GYN	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	2799
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2C [71]	2800
EXRG6	Exam Room, Isolation	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:SC	m:Wood t:3 [12] s:X	hw:1Q	2801
TLTU1	Toilet, Isolation Exam Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 18, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 [12] s:S	hw:2 [48]	2802
WRC01	Sub-Waiting, General Procedure	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2803
TRGM1	Procedure Room, General	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:19 s:S	hw:4P	2804
TLTU1	Toilet, General Procedure	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2C [71]	2805

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Examination / Treatment Module: General Patient Area									
EXRG4	Nurse Triage	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 s:S	hw:3G	2806
NSTA4	Nurse Station Communication Center	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:1 (S) m:N/A t:OPEN (N/A)	hw:3E hw:N/A	2807
MEDP1	Nurse Station Medication Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 ds:YES s:S	hw:SH- 3D	2808
EXRG4	Nurse Station Intake / Exit Interview Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2809
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	2810
SRE01	Clean Linen, Stretcher and Medical Equipment Storage Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:4F	2811
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2812
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2813
WRC01	Waiting, Immunization Observation Area	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4M	2814
OPIR1	Immunization Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 s:V	hw:4M	2815

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Examination / Treatment Module: General Patient Area									
OPEC1	EKG Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 s:V	hw:4M	2816
PEHS1	Audio Booth, Single Occupancy	m:PRE-FAB [63]		m:PRE-FAB		m:PRE-FAB	t:PRE-FAB	hw:N/A	2817
PEHS4	Audio Booth Suite	m:PRE-FAB [63]		m:PRE-FAB		m:PRE-FAB	t:PRE-FAB	hw:N/A	2818
CRA01	Conference Room, Multipurpose	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:4E	2819
FA4: Examination / Treatment Module Support Area									
OFA01	Office, Agent Orange / POW Clerk	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2820
OFA09	Office, Scheduled Clinics Supervisor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2821
OFA04	Office, Health Benefits Advisor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2822
OFA07	Workstation, Scheduler	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2823
OFA07	Workstation, Compensation and Pension Clerk	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN dg:N/A s:N/A	hw:3E hw:N/A	2824

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Examination / Treatment Module Support Area									
OFA07	Workstation, Prescription Receiving	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2825
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2826
FA5: Examination / Treatment Module Specialty Patient Area									
AIDS Clinic (AIDS)									
OPRT1	AIDS: Aerosolized Pentamidine Procedure Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:GWB f:SC	m:Wood t:19 s:S	hw:4P	2849
Dermatology Clinic (DE)									
TRGS1	DE: Procedure / Treatment Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 s:S	hw:1A	2833
LBDE1	DE: Laboratory	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:1 s:S	hw:4G	2834
MEDP1	DE: Medication Preparation	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 ds:YES s:S	hw:SH-3D	2835
OPDU1	DE: Phototherapy Treatment Room	m:WSF	m:WSF h:4"	m:GWB [7, 44, 64] f:SC		m:AT f:SP	m:Wood t:19 s:S	hw:1R	2836
SHWR1	DE: Phototherapy Shower Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:CT [7, 44] m:S [7, 44]	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2C [71]	2837

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Examination / Treatment Module Specialty Patient Area									
Gastroenterology Clinic (GE)									
TRPE1	GE: Screening Proctoscopic / Sigmoidoscopy Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 s:X	hw:4E	2829
USCL2	GE: Scope Wash Room	m:WSF	m:WSF [7] h:4"	m:GWB [7, 64] f:SC	m:S [7] h:5'-0"	m:AT f:SP	m:Wood t:1 s:S	hw:4G	2830
TREE1	GE: Gastric (Esophageal) Mobility Procedure Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 s:X	hw:4P	2831
TLTU1	GE: Toilet, Gastroenterology Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2C [71]	2832
Genito-Urinary (GU) or Urology Clinic									
TLTU1	GU: Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2C [71]	2827
LBSP1	GU: Urine Testing Alcove	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	t:OPEN	hw:N/A	2828
Moh's Chemosurgery Clinic (MOH)									
RECP1	MOH: Reception / Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	2838

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Examination / Treatment Module Specialty Patient Area									
Moh's Chemosurgery Clinic (MOH)									
EXRG3	MOH: Exam Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	2839
TRGS1	MOH: Procedure Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT	m:Wood t:19 s:S	hw:4P	2840
UCCL1	MOH: Clean Utility Room	m:WSF	m:WSF h:4"	m:GWB f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:V	hw:SH-3C	2841
LBDE1	MOH: Laboratory	m:WSF	m:WSF h:4"	m:GWB [64] f:SP		m:AT f:SP	m:Wood t:1 dg:T s:S	hw:4G	2842
Nutrition Clinic (NUT)									
OFA07	NUT: Dietitian Workstation	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2854
CRA01	NUT: Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	2855
Oncology Clinic (ONC)									
OPCT1	ONC: Chemotherapy Treatment Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:GWB f:SC	m:Wood t:19 s:V	hw:4E	2844
TLTU1	ONC: Chemotherapy Patient Toilet	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2C [71]	2845

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Examination / Treatment Module Specialty Patient Area									
Oncology Clinic (ONC)									
OPCT2	ONC: Chemotherapy Agent Preparation Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:GWB f:SC	m:Steel t:2 ds:YES s:U m:Steel t:36 ds:YES s:U	hw:4G hw:SH-3H	2846
OFA04	ONC: Data Coordinator Tumor Registry Office	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2847
OFDC2	ONC: Family Counseling Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	2848
Orthopedic Clinic (ORTH)									
OPCR1	ORTH: Cast Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 s:X	hw:4P	2843
Prosthetics Clinic (PRO)									
WRC01	PRO: Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2850
SRCS1	PRO: Appliance Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:F s:V	hw:5D	2851
MRPA1	PRO: Mailing Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	2852
OFA07	PRO: Prosthetic Clerk Workstation	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2853

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Employee Health Unit Area									
OFA07	Workstation, Employee Health Nurse	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2856
EXRG0	Exam Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:1L	2857
OFA07	Workstation, Employee Health Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2858
FILE1	Storage, Employee Health Records	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:5D	2859
FA7: Disposition Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2860
OFA09	MAS: Disposition Supervisor Office	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2861
OFA07	MAS: Coding Clerk Workstation	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2862
CASH1	MAS: Patient Funds / Travel Clerk Workroom	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2863
SRPB2	MAS: Patient Belongings Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2864
OFA07	MAS: Billing Clerk Workstation	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2865

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Disposition Area									
OFA07	MAS: Clerk Workstation	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2866
OFA09	MAS: Details Clerk Office	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2867
LBBV1	MAS: Grieving Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	2868
TLTU1	Toilet, Grieving Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2G [71]	2869
OFA07	MAS: Patient Services Assistant Workstation	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2870
CASH1	MAS: Agent Cashier	m:CPT [6]	m:RB h:4"	m:GWB [64, 65] f:P		m:AT	m:Steel t:36 s:S	hw:SH- 3H	2871
FA8: Hospital Based Home Care (HBHC) Area									
OFA07	Workstation, HBHC Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2872
OFA07	Workstation, Secretary and Records	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2873
OFDC2	Interview Room	m:CPT [6]	m:PRB h:4"	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2874
OFA07	Workstation, Social Worker	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2875

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Hospital Based Home Care (HBHC) Area									
OFA07	Workstation, Public Health Nurse	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2876
CRA01	Conference Room, HBHC Team	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	2877
FA9: Support Area									
SRE01	Storage	m:VT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	2878
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2879
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2880
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	2881
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	t:OPEN	hw:N/A	2882
SRLW1	Alcove, Stretcher / Wheelchair	m:LVT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2883
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	2884
RPR01	Copier Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4J	2885
SRS01	Storage, Forms / Literature	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4E	2886

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA10: Staff and Administrative Area									
OFA09	Office, Ambulatory Care ACOS	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2887
SEC01	Secretary / Waiting	m:CPT [6]	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2888
OFA09	Office, Ambulatory Care Administrative Assistant to ACOS [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2889
OFA07	Workstation, Ambulatory Care Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2890
OFA07	Office, Ambulatory Care Nursing Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2891
OFA09	Office, Ambulatory Care Nursing Supervisor [3]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2892
OFA09	Office, Chief MAS for Ambulatory Care [3]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2893
OFA09	Office, Clinic Section Chief [3]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2894
OFA07	Workstation, Ambulatory Care Physician / Provider	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2895
OFA07	Workstation, Advice Nurse	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2896
OFDC1	Office, Counselor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2897

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA10: Staff and Administrative Area									
OFA07	Workstation, Professional	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2898
OFDC2	Interview Room	m:CPT [6]	m:PRB h:4"	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	2899
OFA09	Office, Head Nurse [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	2900
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2901
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2902
WRTM2	Telemedicine Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	2903
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	2904
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	2905
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2906
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	2907

Chapter 262 Ambulatory Care (Hospital Based)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA11: Education Area									
OFA07	Workstation, Preceptor / Consult Room	m:CPT [6]	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2908
OFA07	Workstation, Resident	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2909
OFA07	Workstation, Student	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2910
LIBB1	Library	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	2911
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	2912

141

Chapter 264 PACT Primary Care Clinic (PPCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA1: Patient Aligned Care Team (PACT) Module Calculation

CALC1	Number of PACT Modules								2913
-------	------------------------	--	--	--	--	--	--	--	------

FA2: Patient Aligned Care Team (PACT) Module Reception Area

WRC01	Waiting, Patient Aligned Care Team (PACT) Module	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4K	2914
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S	hw:3E	2915
RECP4	Kiosk, Patient Check-In	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	2916
CLSC1	Workstation, Patient Education	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2917
WRF01	Waiting, Family	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	2918
TLTU1	Toilet, General	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G	2919

FA3: Patient Aligned Care Team (PACT) Module Patient Area

PEHW1	Height / Weight Station	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:U	hw:3E	2920
-------	-------------------------	-------	--------------	-----------	--	------	-----------------	-------	------

Chapter 264 PACT Primary Care Clinic (PPCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Patient Aligned Care Team (PACT) Module Patient Area									
EXPA1	Exam Room, Patient Aligned Care Team (PACT)	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1Q	2921
EXW01	Exam Room, Women's Health	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1Q	2922
TLTU1	Toilet, Women's Health Exam Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G	2923
CLSC4	Shared Medical Appointment Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3E	2924
SRSE1	Storage, Shared Medical Appointment	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:3E	2925
TRPR1	Procedure Room, General	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT	m:Wood t:19 s:U	hw:1Q	2926
TLTB1	Toilet, General Procedure Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2927
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	2928
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2929

Chapter 264 PACT Primary Care Clinic (PPCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Patient Aligned Care Team (PACT) Module Support Area									
RCA02	Alcove, Medication	m:LVT	m:RB h:4"	m:GWB [54] f:P		m:AT	t:OPEN	hw:N/A	2930
SRE01	Storage, Medical Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:4F	2931
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 ds:YES s:V	hw:SH-3C	2932
FA5: Patient Aligned Care Team (PACT) Module Staff and Administrative Area									
OFA07	Workstation, Teamlet	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2933
WRTM2	Tele-Health Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3E	2934
OFA07	Workstation, Extended Team	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2935
WKTM1	Workroom [2]	m:CPT [6] m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3E	2936
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4J	2937
SL001	Lounge, Clinical Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	2938
LR004	Locker Area, Clinical Staff Personal Property	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2939

Chapter **264** PACT Primary Care Clinic (PPCC)

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Patient Aligned Care Team (PACT) Module Staff and Administrative Area									
TLTU1	Toilet, Clinical Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G	2940
FA6: Patient Aligned Care Team (PACT) Module Education Area									
OFA10	Workstation, PACT Team	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2941

Chapter **265** Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Lobby / Reception Area									
LOB02	Vestibule	m:MAT	m:RB	m:GWB f:P		m:AT f:N/A m:GWB f:P			2942
SRLW1	Alcove, Wheelchair	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2943
WRC04	Waiting, PACT 1	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	2944
WRC05	Waiting, PACT 2	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	2945
WRC06	Waiting, PACT 3	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	2946
WRF01	Waiting, PACT Family	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	2947
RECP3	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2948
RECP5	Reception, Accessible	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2949

Chapter **265** Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Lobby / Reception Area									
RECP4	Kiosk, Patient Check-in	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2950
NCWD4	Alcove, Volunteer	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2951
CLSC2	Workstation, Patient Education	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2952
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2953
TLTF3	Toilet, Family	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2954
TLTM2	Toilet, Male	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2955
TLTF2	Toilet, Female	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2956

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Aligned Care Team (PACT) Clinic 1									
PEHW1	Alcove, Height / Weight Station	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2957
PEHW2	Alcove, Height / Weight Accessible Station	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:19 s:U	hw:3E	2958
OFDC2	Consult Room, Patient Aligned Care Team (PACT)	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	2959
EXPA1	Exam Room, Patient Aligned Care Team (PACT)	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2960
TLTU1	Toilet, PACT Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2961
EXW01	Exam Room, Women's Health	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2962
TLTF1	Toilet, Women's Health Exam Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2963
TRPR1	Procedure Room, General	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:19 s:U	hw:1Q	2964
TLTB1	Toilet, General Procedure Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2965

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Aligned Care Team (PACT) Clinic 1									
WRTM2	Tele-Health Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3E	2966
WRTM3	Tele-Retinal Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3E	2967
CLSC4	Shared Medical Appointment Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2968
SRE01	Storage, Shared Medical Appointments	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2969
RCA06	Alcove, Medication	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2970
RCA01	Alcove, Resuscitation	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2971
WRTM1	Team Work Area	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2972
OFA07	Workstation, Extended Team	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2973
WKTM3	Workroom, Patient Aligned Care Team (PACT)	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2974
WKTM1	Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:U	hw:4E	2975

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Aligned Care Team (PACT) Clinic 1									
OFA07	Workstation, Administrative	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2976
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4E	2977
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	2978
SRE01	Storage, Medical Equipment	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:4F	2979
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	2980
LR001	Locker, Staff Personal Property	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	2981
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	2982
FA3: Patient Aligned Care Team (PACT) Clinic 2									
PEHW1	Alcove, Height / Weight Station	m:LVT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2983
PEHW2	Alcove, Height / Weight Accessible Station	m:LVT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2984
OFDC2	Consult Room, Patient Aligned Care Team (PACT)	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	2985

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Patient Aligned Care Team (PACT) Clinic 2									
EXPA1	Exam Room, Patient Aligned Care Team (PACT)	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2986
TLTU1	Toilet, PACT Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2987
EXW01	Exam Room, Women's Health	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	2988
TLTF1	Toilet, Women's Health Exam Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2989
TRPR1	Procedure Room, General	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 s:U	hw:1Q	2990
TLTB1	Toilet, General Procedure Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	2991
WRTM2	Tele-Health Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3E	2992
WRTM3	Tele-Retinal Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3E	2993

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Patient Aligned Care Team (PACT) Clinic 2									
CLSC4	Shared Medical Appointment Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2994
SRE01	Storage, Shared Medical Appointments	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	2995
RCA06	Alcove, Medication	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2996
RCA01	Alcove, Resuscitation	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	2997
WRTM1	Team Work Area	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	2998
OFA07	Workstation, Extended Team	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	2999
WKTM3	Workroom, Patient Aligned Care Team (PACT)	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	3000
WKTM1	Classroom	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:U	hw:4E	3001
OFA07	Workstation, Administrative	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	3002
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4J	3003
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3004

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Patient Aligned Care Team (PACT) Clinic 2									
SRE01	Storage, Medical Equipment	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:4F	3005
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	3006
LR001	Locker, Staff Personal Property	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3007
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3008
FA4: Patient Aligned Care Team (PACT) Clinic 3									
PEHW1	Alcove, Height / Weight Station	m:LVT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3009
PEHW2	Alcove, Height / Weight Accessible Station	m:LVT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3010
OFDC2	Consult Room, Patient Aligned Care Team (PACT)	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	3011
EXPA1	Exam Room, Patient Aligned Care Team (PACT)	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	3012
TLTU1	Toilet, PACT Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3013

Chapter 265 Outpatient / PACT Clinic

FA4: Patient Aligned Care Team (PACT) Clinic 3

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
EXW01	Exam Room, Women's Health	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	3014
TLTF1	Toilet, Women's Health Exam Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3015
TRPR1	Procedure Room, General	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 s:U	hw:1Q	3016
TLTB1	Toilet, General Procedure Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3017
WRTM2	Tele-Health Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3E	3018
WRTM3	Tele-Retinal Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3E	3019
CLSC4	Shared Medical Appointment Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	3020
SRE01	Storage, Shared Medical Appointments	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	3021
RCA06	Alcove, Medication	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3022

Chapter 265 Outpatient / PACT Clinic

FA4: Patient Aligned Care Team (PACT) Clinic 3

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
RCA01	Alcove, Resuscitation	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3023
WRTM1	Team Work Area	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3024
OFA07	Workstation, Extended Team	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3025
WKTM3	Workroom, Patient Aligned Care Team (PACT)	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	3026
WKTM1	Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:U	hw:4E	3027
OFA07	Workstation, Administrative	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3028
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4J	3029
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3030
SRE01	Storage, Medical Equipment	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:4F	3031
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	3032

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Patient Aligned Care Team (PACT) Clinic 3									
LR001	Locker, Staff Personal Property	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3033
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	3034
FA5: Audiology and Speech Pathology Clinic									
HARF1	Hearing Aid Fitting Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4J	3035
EXAU1	Exam / Consult, Audiology	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4J	3036
EXOS1	Exam / Consult, Speech Pathology	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4J	3037
PEHS4	Exam, Audiometric Booth	m:PRE- FAB	m:PRE- FAB h:4"	m:PRE-FAB		m:PRE-FAB	t:PRE-FAB	hw:N/A	3038
OPAE2	Electrophysiology Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4J	3039
EXVE1	Vestibulography Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4J	3040

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Audiology and Speech Pathology Clinic									
OPMH1	Group Therapy Room, Audiology	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4L	3041
OPMH1	Group Therapy Room, Speech Pathology	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4L	3042
TLTU1	Toilet, Audiology Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3043
SRSE1	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	3044
FA6: Dental Clinic									
OFDC2	Consult Room, Dental	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	3045
DNXS1	X-Ray Room, Panoramic / Cephalometric	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT	m:Wood t:15 dl:LEAD s:X	hw:4Q	3046
DNTG1	Dental Treatment Room (DTR), Multi-Functional	m:RF	m:RF h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:U	hw:3E	3047
TLTU1	Toilet, Dental Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3048
WRTM1	Team Work Area, Dental Clinic	m:RF	m:RF h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3049

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Dental Clinic									
DNPL1	Laboratory, Dental Prosthetics	m:RF	m:RF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 s:S	hw:4K	3050
LCCL1	Linen Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 ds:YES s:V	hw:SH- 3C	3051
LCSL2	Linen Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dr:45 min ds:YES s:V	hw:SH- 3C	3052
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	3053
MECH1	Dental Equipment Mechanical Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:SS	hw:11C	3054
FA7: Eye Clinic									
WRC03	Sub-Waiting, Dilation Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3055
EYFD1	Fitting and Dispensing Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3056
EYOT2	Exam / Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1Q	3057
EYOT4	Exam / Training Room, Low Vision	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1Q	3058
EYVS1	Pre-Testing Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1Q	3059

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Eye Clinic									
EYVF1	Visual Fields Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:3G	3060
EYVS1	Photography Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3G	3061
WRTM1	Team Work Area, Eye Clinic	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	3062
OFA09	Office, Blind Rehabilitation (VIST) Counselor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3063
OFA09	Office, Supervisor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3064
FA8: Mental Health Clinic									
OPMH3	Biofeedback	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1L	3065
OPMH1	Group Therapy Room, Mental Health	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:6C	3066
OFDC1	Consult Room, Mental Health	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 s:V	hw:3G	3067
OFDC1	Office, Supervisor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3068
SRS01	Storage, General	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:S	hw:5B	3069

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Mental Health Clinic									
WRTM1	Team Work Area, Mental Health	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	3070
FA9: Multi-Specialty Clinic									
PEHW1	Alcove, Height / Weight Station	m:LVT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3071
PEHW2	Alcove, Height / Weight Accessible Station	m:LVT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3072
OPCR1	Cast Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:19 s:X	hw:4P	3073
OFDC2	Consult Room, Multi-Specialty	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	3074
EXPA1	Exam Room, Multi-Specialty	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1Q	3075
EXPO1	Exam Room, Podiatry	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1Q	3076
TRPR1	Procedure Room, Multi-Specialty	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:V	hw:1Q	3077
TLTB1	Toilet, Multi-Specialty Procedure Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3078

Chapter **265** Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA9: Multi-Specialty Clinic									
OPTM1	Treadmill Room	m:RF	m:RF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:4B	3079
TLTB1	Toilet, Multi-Specialty Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3080
FA10: Physical Medicine and Rehabilitation (PM&R) Clinic									
DR001	Dressing Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 (T) s:U m:Steel t:2 (T) s:U	hw:2H	3081
PTEA1	Treatment Exercise Area	m:RF	m:RF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1Q	3082
PTTC1	Treatment Room	m:RF	m:RF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1Q	3083
OFA09	Office, Therapist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3084
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	3085
TLTU1	Toilet, PM&R Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3086

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA11: Prosthetics and Sensory Aids Clinic									
WRC03	Sub-Waiting, Prosthetics Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3087
OFA03	Workstation, Dispensing Prosthetic Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3088
MRPA1	Mailing Room, Prosthetic Appliances	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:5D	3089
SRCS1	Storage, Prosthetic Appliances	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:V	hw:5E	3090
FA12: Home Based Primary Care									
WRTM1	Team Work Area, Home-Based Primary Care	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	3091
SRE01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:3E	3092
FA13: Radiology Service									
WRC01	Sub-Waiting, Diagnostic Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3093
DR001	Dressing Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 (T) s:U m:Steel t:2 (T) s:U	hw:2H	3094
XDBD1	Bone Densitometer	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:4E	3095

Chapter **265** Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA13: Radiology Service									
XDR01	Radiology Room, General Purpose	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:15 dl:LEAD s:X	hw:4Q	3096
XDRF1	Radiographic / Fluoroscopic (R/F) Room [60]	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:15 dl:LEAD s:X	hw:4Q	3097
TLTU1	Toilet, R/F Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3098
XDUS1	Ultrasound Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:4E	3099
TLTU1	Toilet, Ultrasound Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3100
WRC01	Sub-Waiting, Mammography Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3101
XDM01	Mammography Room [50, 60]	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:1Q	3102
TLTU1	Toilet, Mammography Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	3103
XVC01	Viewing Room, Picture Archiving and Communication System - PACS	m:CPT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3G	3104

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA13: Radiology Service									
OFDR1	Office, Radiology	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3105
OFA07	Workstation, Radiology Tech	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3106
FA14: Pathology and Laboratory Medicine (PLM) Service									
LBVP1	Blood Specimen Collection Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:GWB f:P m:AT [9] f:N/A	m:Wood t:1 s:V	hw:4	3107
TLTU1	Toilet, Specimen Collection	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U		3108
LBGM1	Laboratory, General	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 s:V	hw:4K	3109
LMCH1	Laboratory, Clinical Chemistry	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 s:V	hw:4K	3110
LBSS1	Shipping / Receiving	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3111
SRS01	Storage, Bulk	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:V m:Wood t:11 s:SS	hw:11B hw:5B	3112
SRR02	Storage, Refrigerated	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:V m:Wood t:11 s:SS	hw:11B hw:5B	3113

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA14: Pathology and Laboratory Medicine (PLM) Service									
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	3114
FA15: Pharmacy Service [65]									
PHOD4	Automated Drug Dispensing System	m:RF	m:RF h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3115
PHOW1	Dispensing, Window	m:RF	m:RF h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3116
PHOW1	Prescription Receiveing, Window	m:RF	m:RF h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3117
OFDC2	Consult Room, Pharmacy	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	3118
OFA07	Workstation, Pharmacist	m:RF	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3119
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	3120
PHOD5	Pharmacy, PACT 2	m:RF	m:RF h:4"	m:GWB f:P		m:AT	m:Steel t:36 ds:YES s:V	hw:SH- 3D	3121
PHOD6	Pharmacy, PACT 3	m:RF	m:RF h:4"	m:GWB f:P		m:AT	m:Steel t:36 ds:YES s:V	hw:SH- 3D	3122

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA15: Pharmacy Service [65]									
WKT M4	Data Processing	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4	3123
FA16: Clinic Management									
OFA09	Office, CMO	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3124
OFA09	Office, Nurse Manager	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3125
FA17: Business Services									
WKT M1	Workroom, Business Services	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	3126
FA18: Engineering Service									
BMER1	Repair Shop, Biomedical Engineering	m:RF	m:RF h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:4F	3127
FA19: Logistics Service									
OFA07	Workstation, Logistics	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	3128
DOCK1	Receiving / Shipping Dock	m:C [10]	m:RB h:4"	m:GWB [54] f:P m:CMU f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3129
SRLG1	Storage Area, Logistics PACT 1	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V m:Steel t:12 s:V	hw:5B	3130

Chapter 265 Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA19: Logistics Service									
SRLG2	Storage Area, Logistics PACT 2	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V m:Steel t:12 s:V	hw:5B	3131
SRLG3	Storage Area, Logistics PACT 3	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V m:Steel t:12 s:V	hw:5B	3132
FA20: Police Service									
OFA09	Office, Police Service	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3133
CROP1	Operations Room	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 ds:YES s:S	hw:SH-3	3134
LR001	Locker Room	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3135
POH01	Holding Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Steel t:22 s:S	hw:SH-2	3136
SSS01	Storage, Secure [65]	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:V	hw:5E	3137
FA21: Canteen Service									
BX002	Vending Machine Area	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:V	hw:1F	3138
FSCD4	Canteen, PACT 2	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:SS	hw:12G	3139
FSCD5	Canteen, PACT 3	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:SS	hw:12G	3140

Chapter **265** Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA22: Staff Support Area									
WRTM2	Tele-Health Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:3E	3141
RCA06	Alcove, Medication	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3142
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	3143
WRTM1	Team Work Area, Clinical Support	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3144
OFDC2	Consult Room, Clinical Support	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	3145
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4J	3146
WKTM1	Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:U	hw:4E	3147
LAC01	Lactation Room	m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:3G	3148
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	3149
LR001	Locker, Staff Personal Property	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3150

Chapter **265** Outpatient / PACT Clinic

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA22: Staff Support Area									
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	3151
FA23: COMC1									
COMC1	Communications Room	m:AF	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	3152
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3153
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3154
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	3155
UTC01	Utility Room, Recycled Material	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 s:V	hw:SH- 3C	3156
NT001	Pneumatic Tube Station	m:SVT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	3157

Chapter 266 Human Resources Management

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4	3158
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3159
FA2: Staff and Administrative Area									
OFA09	Office, Human Resources Management Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3160
OFA09	Office, Human Resources Management Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3161
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3162
OFA09	Office, Personnel Management Specialist with Program Responsibility [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3163
OFA07	Workstation, Personnel Management Specialist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3164
OFA07	Workstation, Personnel Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3165
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3166

Chapter 266 Human Resources Management

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Staff and Administrative Area									
CRA02	Conference Room / Placement and Examination Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3167
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3168
FA3: Support Area									
MRS02	Records File, Active Personnel	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4	3169
OFA07	Workstation, Support	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3170
WRCH1	Workroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3171
SRS01	Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:5D	3172

Chapter 268 Pharmacy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Inpatient Pharmacy Work Area									
PHOD2	Dispensing Station	m:RF	m:RF h:4"	m:GWB f:P m:CMU f:P		m:AT f:SP	t:OPEN	hw:N/A	3173
PHOD2	Medication Assignment Area	m:RF	m:RF h:4"	m:GWB f:P		m:GWB f:P	t:OPEN	hw:N/A	3174
PHOD2	Vault, Controlled Substances Work Area [59, 62]	m:RF	m:RF h:4"	m:GWB f:P		m:GWB f:P	m:Steel t:30 ds:YES s:U	hw:SH-3B	3175
PHOD2	Dispensing , Secured Controlled Substances [59, 62]	m:RF	m:RF h:4"	m:GWB f:SC		m:GWB f:P	m:Steel t:30 ds:YES s:U	hw:SH-3B	3176
PHOD2	Repackaging, Extemporaneous	m:RF	m:RB h:4"	m:GWB f:P		m:AT f:SP	t:OPEN	hw:N/A	3177
PHOD2	Stat Counter	m:RF	m:RB h:4"	m:GWB f:P		m:AT f:SP	t:OPEN	hw:N/A	3178
PHIV2	Anteroom, Intravenous Admixture	m:RF	m:RF h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:1F	3179
PHIV2	Aseptic Transfer Room, Intravenous Admixture	m:RF	m:RF h:4"	m:GWB f:SP		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K	3180
XXYYC	Drug Information Area	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	3181
FA2: Inpatient Pharmacy Support Area									
PHBS2	Storage, Controlled Substances Flammable Liquids	m:RES	m:RES h:4"	m:GWB [36, 54] f:P	m:RWC h:4'-0"	m:AT f:SP	m:Steel t:30 dr:45 min ds:YES s:U	hw:SH-3B	3182
PHOD2	Receiving, Breakdown and Verification Area	m:RF	m:RF h:4"	m:GWB f:P		m:AT	m:Steel t:36 s:V	hw:SH-3H	3183

Chapter 268 Pharmacy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Inpatient Pharmacy Support Area									
PHOD2	Receiving, Inventory and Verification Area	m:RF	m:RF h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:V	hw:4F	3184
SRF01	Refrigeration / Freezer, Intravenous Admixture	m:PRE-FAB [63]	m:PRE-FAB [66]	m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [66]	hw:N/A	3185
PHBS2	Storage, Sterile Fluids and Admixture Sets	m:RF	m:RF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:V	hw:5B	3186
SFR01	Refrigeration / Freezer Area	m:RF	m:RF h:4"	m:GWB f:SC		m:GWB f:SC	t:OPEN	hw:N/A	3187
PHBS2	Storage, Active	m:RF	m:RF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3188
RCA02	Storage, Cart	m:VT	m:RB h:4"	m:GWB [54]	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3189
PHBS2	Storage, Poison Control	m:WSF	m:WSF h:4"	m:GWB [54] f:SP	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:V	hw:5B	3190
FA3: Inpatient Pharmacy Education Program									
OFA07	Workstation, Clinical Pharmacy Teaching Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3191
XXYYC	Laboratory, Pharmaceutical Experimentation	m:RF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:V	hw:4K	3192
OFA07	Workstation, Intern / Student	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3193

Chapter 268 Pharmacy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Inpatient Pharmacy Education Program									
OFA10	Carrel, Trainee	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3194
FA4: Inpatient Pharmacy Investigational Drug Program									
PHOD2	Work Area	m:RF	m:RF h:4" h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3195
PHBS2	Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3196
FA5: Inpatient Pharmacy Staff and Administrative Area									
OFA09	Office, Pharmacy Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3197
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	3198
OFA09	Office, Pharmacy Assistant / Associate Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3199
OFA07	Workstation, Pharmacist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3200
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3201
CMP02	Server Room	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 ds:YES s:U	hw:SH-3	3202

Chapter 268 Pharmacy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Inpatient Pharmacy Staff and Administrative Area									
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3203
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3204
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3205
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3206
FA6: Oncology Drug Area									
PHOD2	Preparation Area	m:RF	m:RF h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 s:U m:N/A t:OPEN s:N/A	hw:N/A	3207
PHOD2	Anteroom, Intravenous Admixture	m:RF	m:RF h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:1A	3208
PHOD2	Reference Area	m:RF	m:RF h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 s:U m:N/A t:OPEN s:N/A	hw:N/A	3209
PHBS2	Storage and Clean / Decontamination Area	m:RF	m:RF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:5E	3210

Chapter 268 Pharmacy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Outpatient Pharmacy Patient Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	3211
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3212
FA8: Outpatient Pharmacy Work Area									
PHOD1	Prescription Receiving Window	m:RF	m:RF h:4"	m:GWB [59, 62] f:P		m:AT	m:Steel t:36 ds:YES s:V	hw:SH- 3D	3213
PHOD2	Prescription Filling and Assembly Area	m:RF	m:RF h:4"	m:GWB [59, 62] f:P		m:AT	t:OPEN	hw:N/A	3214
PHOD2	Prescription Dispensing Area	m:RF	m:RF h:4"	m:GWB [59, 62] f:P		m:AT	t:OPEN	hw:N/A	3215
PHOD2	Filling, Active	m:RF	m:RF h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3216
PHOD2	Mail Out, Prescription	m:RF	m:RF h:4"	m:GWB f:P		m:AT	m:Steel t:36 ds:YES s:U	hw:SH- 3D	3217
PHOD2	Receiving, Breakdown and Verification Area	m:RF	m:RF h:4"	m:GWB f:P		m:AT	m:Steel t:36 ds:YES s:V	hw:SH-3	3218
OFA07	Workstation, Inventory Control / Stock Management Clerk	m:RF	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN ds:YES	hw:N/A	3219

Chapter 268 Pharmacy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Outpatient Pharmacy Work Area									
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	3220
FA9: Outpatient Pharmacy Support Area									
PHMP2	Storage, Prepackaged Medication	m:RF	m:RF h:4"	m:GWB f:P		m:GWB f:P	m:Steel t:36 ds:YES s:V	hw:SH-3H	3221
PHMP2	Storage, Controlled Substances and Secured Dispensing Area	m:RF	m:RF h:4"	m:GWB f:P		m:GWB f:P	m:Steel t:36 ds:YES s:V	hw:SH-3H	3222
SRHM1	Storage, Flammable Liquids	m:RES	m:RES h:4"	m:GWB [36] f:SC		m:GWB f:SC	m:Wood t:11 dg:F dr:45 min s:V	hw:5B	3223
SRF01	Refrigeration / Freezer Area	m:RF	m:RF h:4"	m:GWB f:SC		m:GWB f:SC	t:OPEN	hw:N/A	3224
SRCS1	Storage, Prosthetic and Medical Supplies	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	3225
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3226
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3227
FA10: Emergency Response Area									
XXYYC	Pharmacy Cache Area	m:RF	m:RF h:4"	m:GWB f:SC		m:GWB f:P	m:Steel t:30 s:U	hw:N/A	3228

Chapter **268** Pharmacy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

56

CANCELLED

Chapter **269** Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting, General Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	3229
WRF01	Waiting, Family	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	3230
RECP4	Kiosk, Patient Check-In	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	3231
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	3232
TLTU1	Toilet, General Waiting	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3233
TLTF3	Toilet, Family	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3234
CLSC3	Patient Education / Resource Room	m:CPT [6] m:LVT	m:PRB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:19 s:V	hw:4L	3235
NCWD4	Alcove, Refreshment Center	m:LVT	m:RB h:4"	m:GWB [54] f:P		m:AT	t:OPEN	hw:N/A	3236

Chapter 269 Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
SRLW1	Alcove, Wheelchair / Stretcher / Lift	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3237
SRS01	Storage, Reception	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3238
FA2: Recreation / Creative Arts Therapy Area									
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 s:V	hw:3G	3239
EXRA1	Patient Assessment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:3G	3240
RTGR1	Group Room, Recreation Therapy, Small	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:4L	3241
RTGR2	Group Room, Recreation Therapy, Medium	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:4L	3242
RTGR3	Group Room, Recreation Therapy, Large	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:4L	3243
CMR01	Clinical Monitoring Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:4L	3244
SRS01	Storage, Recreation Therapy	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3245
SRS01	Storage, Dance Program	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3246
SRS01	Storage, Music Program	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3247

Chapter 269 Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Recreation / Creative Arts Therapy Area									
OFA07	Workstation, Recreation Therapy Assistant / Aide	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN s:S	hw:N/A	3248
IPK01	Kitchen, Activities of Daily Living (ADL)	m:LVT m:RSF	m:RB h:4"	m:GWB f:SC		m:AT	m:Wood t:19 s:X	hw:3E	3249
SRS01	Storage, ADL Kitchen	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3250
RTCA1	Creative Arts, Group Therapy Room, Small	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:3E	3251
RTCA2	Creative Arts, Group Therapy Room, Medium	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:3E	3252
RTCA3	Creative Arts, Group Therapy Room, Large	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:3E	3253
SRS01	Storage, Creative Arts Group Therapy Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F	hw:5B	3254
OFA07	Workstation, Creative Arts Therapist	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN s:U	hw:N/A	3255
RTAT1	Adaptive Technology (AT) Room, Small	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:3E	3256
SRS01	Storage, Small Adaptive Technology Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:U	hw:5B	3257
RTAT2	Adaptive Technology (AT) Room, Medium	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:3E	3258

Chapter 269 Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Recreation / Creative Arts Therapy Area									
SRS01	Storage, Medium Adaptive Technology Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:U	hw:5B	3259
RTAT3	Adaptive Technology (AT) Room, Large	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:3E	3260
SRS01	Storage, Large Adaptive Technology Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3261
OFA07	Workstation, Adaptive Technology Room	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3262
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2G [71] hw:4B [31]	3263
TLTB1	Toilet, Bariatric Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:X	hw:2G [71] hw:4B [31]	3264
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2G [71] hw:4B [31]	3265
UCCL1	Small Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3266
UCCL1	Medium Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3267

Chapter 269 Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Recreation / Creative Arts Therapy Area									
UCCL1	Large Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3268
USCL1	Small Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	3269
USCL1	Medium Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	3270
USCL1	Large Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	3271
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:S	hw:5D	3272
FA3: Self-Directed Therapy Area									
WRC01	Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8] h:4"	m:GWB [5] f:P		m:AT	m:Wood t:19 s:U	hw:4G	3273
TLTS2	Toilet / Shower, Male Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2G [71] hw:4B [31]	3274
LR002	Locker Room, Gross Motor Activity Male Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3275

Chapter 269 Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Self-Directed Therapy Area									
LR002	Locker Room, Small Gym / Exercise Male Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3276
LR002	Locker Room, Medium Gym / Exercise Male Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3277
LR002	Locker Room, Large Gym / Exercise Male Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3278
TLTS2	Toilet / Shower, Female Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2G [71] hw:4B [31]	3279
LR002	Locker Room, Gross Motor Activity Female Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3280
LR002	Locker Room, Small Gym / Exercise Female Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3281
LR002	Locker Room, Medium Gym / Exercise Female Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3282
LR002	Locker Room, Large Gym / Exercise Female Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3283

Chapter **269** Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Self-Directed Therapy Area									
TLTS2	Toilet / Shower, Universal	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2G [71] hw:4B [31]	3284
LR002	Locker Room, Universal	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3285
RTGY1	Gymnasium, Small	m:RF	m:RB h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:5B	3286
SRE01	Storage, Small Gymnasium	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3287
RTGY2	Gymnasium, Medium	m:RF	m:RB h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:X	hw:5B	3288
SRE01	Storage, Medium Gymnasium	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3289
RTGY3	Gymnasium, Large	m:RF	m:RB h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:X	hw:5B	3290
SRE01	Storage, Large Gymnasium	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3291
RTGY4	Gymnasium Area, Enclosed	m:RF	m:RB h:4"	m:GWB f:SC		m:AT	m:Wood t:11 s:X	hw:5B	3292
SRE01	Storage, Enclosed Gymnasium	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3293

Chapter 269 Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Self-Directed Therapy Area									
RTEW1	Exercise / Weight Room, Small	m:RF	m:RB h:4"	m:GWB f:SC		m:AT	m:Wood t:11 s:X	hw:5B	3294
SRE01	Storage, Small Excercise / Weight Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3295
RTEW2	Exercise / Weight Room, Medium	m:RF	m:RB h:4"	m:GWB f:SC		m:AT	m:Wood t:11 s:X	hw:5B	3296
SRE01	Storage, Medium Excercise / Weight Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3297
RTEW3	Exercise / Weight Room, Large	m:RF	m:RB h:4"	m:GWB f:SC		m:AT	m:Wood t:11 s:X	hw:5B	3298
SRE01	Storage, Large Excercise / Weight Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3299
RTWE1	Wellness Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:X	hw:5B	3300
SRE01	Storage, Wellness Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3301
RTGM1	Gross Motor Activity Room	m:RF	m:RB h:4"	m:GWB f:SC		m:AT	m:Wood t:11 s:X	hw:5B	3302
SRE01	Storage, Gross Motor Activity	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3303
FA4: Aquatic Therapy Area									
WRC01	Sub-Waiting	m:CPT m:LVT	m:PRB [8] h:4"	m:GWB [5] f:P		m:AT	m:Wood t:19 s:U	hw:4G	3304

Chapter **269** Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Aquatic Therapy Area									
TLTS2	Toilet / Shower, Male Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2G [71] hw:4B [31]	3305
LR002	Locker Room, Small Therapeutic / Recreation Pool Male Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3306
LR002	Locker Room, Medium Therapeutic / Recreation Pool Male Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3307
LR002	Locker Room, Large Therapeutic / Recreation Pool Male Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3308
TLTS2	Toilet / Shower, Female Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2G [71] hw:4B [31]	3309
LR002	Locker Room, Small Therapeutic / Recreation Pool Female Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3310
LR002	Locker Room, Medium Therapeutic / Recreation Pool Female Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3311
LR002	Locker Room, Large Therapeutic / Recreation Pool Female Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3312

Chapter **269** Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Aquatic Therapy Area									
TLTS2	Toilet / Shower, Universal	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2G [71] hw:4B [31]	3313
LR002	Locker Room, Universal	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:U	hw:2H	3314
RTTP1	Therapeutic Pool, Small	m:PT m:RES	m:PT [7] h:4" m:RES [7] h:4"	m:PT m:CT		m:AT f:SC	m:Wood t:11 s:X	hw:5B	3315
SRE01	Storage, Small Therapeutic Pool	m:PT m:RES	m:PT h:4" m:RES [7] h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3316
RTTP2	Therapeutic Pool, Medium	m:PT m:RES	m:PT h:4" m:RES h:4"	m:GWB f:SC		m:AT f:SC	m:Wood t:11 s:X	hw:5B	3317
SRE01	Storage, Medium Therapeutic Pool	m:PT m:RES	m:PT h:4" m:RES	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3318

Chapter **269** Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Aquatic Therapy Area									
RTTP3	Therapeutic Pool, Large	m:PT m:RES	m:PT h:4" m:RES h:4"	m:GWB f:SC		m:AT f:SC	m:Wood t:11 s:X	hw:5B	3319
SRE01	Storage, Large Therapeutic Pool	m:PT m:RES	m:PT [7] h:4" m:RES [7]	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3320
RTTP1	Recreation Pool, Small	m:PT m:RES	m:PT h:4" m:RES h:4"	m:GWB f:SC		m:AT f:SC	m:Wood t:11 s:X	hw:5B	3321
SRE01	Storage, Small Recreation Pool	m:PT m:RES	m:PT [7] h:4" m:RES [7]	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3322
RTTP2	Recreation Pool, Medium	m:PT m:RES	m:PT h:4" m:RES h:4"	m:GWB f:SC		m:AT f:SC	m:Wood t:11 s:X	hw:5B	3323
SRE01	Storage, Medium Recreation Pool	m:PT m:RES	m:PT [7] h:4" m:RES [7]	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3324

Chapter **269** Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Aquatic Therapy Area									
RTTP3	Recreation Pool, Large	m:PT m:RES	m:PT h:4" m:RES h:4"	m:GWB f:SC		m:AT f:SC	m:Wood t:11 s:X	hw:5B	3325
SRE01	Storage, Large Recreation Pool	m:PT m:RES	m:PT h:4" m:RES	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:X	hw:5B	3326
EXRA1	Patient Assessment, Aquatic Therapy	m:PT m:RES	m:PT h:4" m:RES h:4"	m:GWB f:SC		m:AT f:SC	m:Wood t:11 s:V	hw:3E	3327
OFA07	Workstation, Aquatic Clerk	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	t:OPEN	hw:N/A	3328
OFA07	Workstation, Life Guard	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	t:OPEN	hw:N/A	3329
TLTS1	Toilet / Shower, Male Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2G [71] hw:4B [31]	3330
LR004	Locker Room, Male Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3331

Chapter **269** Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Aquatic Therapy Area									
TLTS1	Toilet / Shower, Female Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2G [71] hw:4B [31]	3332
LR004	Locker Room, Female Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3333
LAUN1	Laundry Room	m:PT	m:PT h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP [9]	m:Wood t:11 s:X	hw:3E	3334
CHC01	Alcove, Linen Cart	m:PT	m:PT h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3335
SRE01	Storage, Safety Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3336
SRHM1	Storage, Chemical / Pump Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3337
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3338
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	3339
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:S	hw:5D	3340

Chapter 269 Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Staff and Administrative Area									
OFA09	Office, Recreation Therapy Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3341
OFA09	Office, Recreation Therapy Service Assistant Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3342
OFA09	Office, Administrative Officer	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3343
OFA07	Workstation, Secretary / Program Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3344
OFA07	Workstation, Fee-Based Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3345
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3346
CRA01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3347
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3348
LR004	Locker Room, Male Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3349
TLTM1	Toilet, Male Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2G [71] hw:4B [31]	3350

Chapter **269** Recreation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Staff and Administrative Area									
LR004	Locker Room, Female Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3351
TLTF1	Toilet, Female Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2G [71] hw:4B [31]	3352
FA6: Education Area									
OFA09	Office, Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN dg:N/A s:N/A	hw:3E hw:N/A	3353
OFA07	Workstation, Intern / Student	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3354
CLR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3355

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA1: Treatment Station Calculation

CALC1	Number of Physical Therapy Treatment Stations								3356
CALC1	Number of Kinesiotherapy Treatment Stations								3357
CALC1	Number of Kinesiotherapy Psychiatric Treatment Stations								3358
CALC1	Number of Occupational Therapy Treatment Stations								3359
CALC1	Number of Vocational Therapy Treatment Stations								3360
CALC1	Number of Incentive Therapy Program Treatment Stations								3361
CALC1	Number of Work Evaluation Program Treatment Stations								3362
CALC1	Number of Educational Therapy Learning Stations								3363
CALC1	Number Compensated Work Therapy Workstations								3364

FA2: Physical Medicine and Rehabilitation Service (PMRS) Reception Area

WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3365
-------	---------	--------------------	-----------	------------------	--	------	---	-----------------	------

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Physical Medicine and Rehabilitation Service (PMRS) Reception Area									
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	3366
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3367
FA3: Physical Medicine and Rehabilitation Service (PMRS) Patient Area									
EXRG3	Exam / Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:1Q	3368
PTEM1	Electromyography Room [60]	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T dl:RF s:V [55]	hw:4N	3369
PTGL1	Gait Lane	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	3370
PTEA1	Mat Platform Area	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3371

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Physical Therapy Basic Clinic (PTBC)									
PTTC1	PTBC: Private Treatment Table Room	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3F	3372
PTTC1	PTBC: Semi-Private Treatment Table Room	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3F	3373
PTTC1	PTBC: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:1Q	3374
SRE01	PTBC: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:V	hw:5D	3375
UTLC1	PTBC: Utility Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4G	3376
FA5: Physical Therapy Expanded Clinic (PTEC)									
WRC01	PTEC: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3377
PTWT1	PTEC: Full Immersion Hubbard Tank	m:PT	m:PT [7] h:4"	m:CT [7]		m:AT f:SC	m:Wood t:1 s:X	hw:4K	3378
PTWT1	PTEC: Partial Immersion Hubbard Tank	m:PT	m:PT [7] h:4"	m:CT [7]		m:AT f:SC	m:Wood t:1 s:X	hw:4K	3379

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Physical Therapy Expanded Clinic (PTEC)									
PTWT1	PTEC: Whirlpool	m:PT	m:PT [7] h:4"	m:GWB [7] f:SC	m:CT [7] h:4'-0" m:PT [7] h:4'-0"	m:AT f:SC	m:Wood t:1 s:V [55]	hw:4K	3380
TLTU1	PTEC: Patient Toilet	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]	3381
PTEA1	PTEC: Exercise Area	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:4K	3382
EXRG3	PTEC: Special Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3F	3383
DR001	PTEC: Dressing Room / Cubicle	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:2H [71]	3384
OFA07	PTEC: Therapist Workstation	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3385
PTTC1	PTEC: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3G	3386
SRE01	PTEC: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3387

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Physical Therapy Expanded Clinic (PTEC)									
UTLC1	PTEC: Utility Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3388
FA6: Kinesiotherapy Basic Clinic (KTBC)									
PTTC1	KTBC: Treatment Area	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3F	3389
SRE01	KTBC: Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:S	hw:5D	3390
FA7: Kinesiotherapy Expanded Clinic (KTEC)									
WRC01	KTEC: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3391
PTEA1	KTEC: Exercise Area	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V [55]	hw:1Q	3392
EXRG3	KTEC: Special Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V [55]	hw:1Q	3393
OFA07	KTEC: Therapist Workstation	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3394

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Kinesiotherapy Expanded Clinic (KTEC)									
PTTC1	KTEC: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:4N	3395
PTEA1	KTEC: Psychiatric Exercise Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:4N	3396
SRE01	KTEC: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:S	hw:5D	3397
FA8: Occupational Therapy Basic Clinic (OTBC)									
PTTC1	OTBC: Treatment Area	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3F	3398
SRE01	OTBC: Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:S	hw:5D	3399
FA9: Occupational Therapy Expanded Clinic (OTEC)									
WRC01	OTEC: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3400

Chapter **270** Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA9: Occupational Therapy Expanded Clinic (OTEC)									
PTEA1	OTEC: Exercise Area	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V [55]	hw:4N	3401
EXRG3	OTEC: Special Treatment Room	m:LVT m:WSF	m:RB h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3F	3402
OTDL1	OTEC: Orthotic and Splinting Area	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4K	3403
SRS01	OTEC: Patient Projects Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	3404
OFA07	OTEC: Therapist Workstation	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3405
PTTC1	OTEC: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3E	3406
SRE01	OTEC: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:T s:V	hw:5D	3407

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA10: Activities of Daily Living (ADL)									
OTDL1	ADL: Evaluation and Training Center	m:WSF m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4G	3408
FA11: Chiropractic Care (CC)									
WRC01	CC: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3409
EXRG3	CC: Exam / Treatment Room	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3F	3410
OFA07	CC: Chiropractor Workstation	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	3411
FA12: Vocational Rehabilitation Therapy (VRT)									
WRC01	VRT: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G	3412
PTTC1	VRT: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3G	3413
SRE01	VRT: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:S	hw:5D	3414

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA12: Vocational Rehabilitation Therapy (VRT)									
OFA07	VRT: Therapist Workstation	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	3415
FA13: Educational Therapy (ET)									
WRC01	ET: Sub- Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3416
CLR03	ET: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:1Q	3417
SRE01	ET: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:S	hw:5D	3418
OFA07	ET: Therapist Workstation	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3419
FA14: Driver Training Center (DTC)									
WRC01	DTC: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3420

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA14: Driver Training Center (DTC)									
CLR03	DTC: Instruction, Orientation, and Simulator Space	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4G	3421
OFA07	DTC: Driver Training Instructor Workstation	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	3422
FA15: Compensated Work Therapy Clinic (CWT)									
WRC01	CWT: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3423
CLR01	CWT: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64]		m:AT	m:Wood t:19 s:V [55]	hw:1Q	3424
SRS01	CWT: Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:U	hw:5D	3425
TLTU1	CWT: Patient Toilet	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]	3426
WRF01	CWT: Patient Rest Area	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:1Q	3427
OFA09	CWT: Supervisor Office	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3428

Chapter **270** Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA16: Incentive Therapy Program (ITP)									
WRC01	ITP: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3429
RECP4	ITP: Treatment Clinic Sign-in	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:V [55]	hw:1F	3430
SRCH1	ITP: Tool Area	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	3431
TLTS1	ITP: Bathroom	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2H [71]	3432
OFA09	ITP: Supervisor Office	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3433
FA17: Cardiopulmonary Rehabilitation Center									
XXYYC	Cardiopulmonary Rehabilitation Center	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4G	3434

Chapter **270** Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA18: Work Evaluation Program (WEP)									
CLR01	WEP: Basic Clinic	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:3E	3435
WRC01	WEP: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3436
SRE01	WEP: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:V	hw:5D	3437
OFA09	WEP: Case Manager Office	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3438
OFA09	WEP: Supervisor Office	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3439
CLR01	WEP: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:1Q	3440
FA19: Therapeutic Pool									
RTTP2	Pool	m:PT	m:PT [7] h:4"	m:PT [7] m:CT [7]		m:AT f:SC	m:Wood t:1 s:V [55]	hw:4K	3441

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA19: Therapeutic Pool									
TLTS1	Dressing, Showers, and Toilets - Male	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:19 s:U	hw:4B	3442
TLTS1	Dressing, Showers, and Toilets - Female	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:19 s:U	hw:4B	3443
UCCL1	Clean / Soiled Towels / Suits Room	m:PT	m:PT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT [9] f:SC	m:Wood t:1 s:U	hw:SH-3	3444
FA20: Physical Medicine and Rehabilitation Service (PMRS) Support Area									
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4E	3445
LCCL1	Storage Alcove, Linen	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3446
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH-3C	3447
SRLW1	Storage, Stretcher / Wheelchair	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT f:p	m:Wood t:11 dg:F s:X	hw:4D	3448

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA20: Physical Medicine and Rehabilitation Service (PMRS) Support Area									
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3449
FA21: Physical Medicine and Rehabilitation Service (PMRS) Staff and Administrative Area									
OFA09	Office, Physical Medicine and Rehabilitation Service Chief	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3450
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3451
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	3452
OFA09	Office, Physical Medicine and Rehabilitation Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3453
WRC01	Escort Service Area	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3454
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3455
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3456
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3457

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA22: Education Area									
OFA09	Office, Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3458
SL002	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	3459
CRA01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3460
FA23: SCI/D Physical Therapy (SCI/D PT)									
WRC01	SCI/D PT: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3461
PTWT1	SCI/D PT: Full Body Immersion Tank	m:PT	m:PT [7] h:4"	m:PT [7] m:CT [7]		m:AT f:SC	m:Wood t:1 s:V [55]	hw:4M	3462
PTEW1	SCI/D PT: Arm, Hip, and Leg Whirlpool	m:PT	m:PT [7] h:4"	m:PT [7] m:CT [7]		m:AT f:SC	m:Wood t:1 s:V [55]	hw:4M	3463
PTTC1	SCI/D PT: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:1Q	3464
UCCL1	SCI/D PT: Clean Utility / Linen Area	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:SH- 3C	3465

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA23: SCI/D Physical Therapy (SCI/D PT)									
USCL1	SCI/D PT: Soiled Utility Area	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH-3C	3466
SRE01	SCI/D PT: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:S	hw:5D	3467
OFA07	SCI/D PT: Therapist Workstation	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3468
FA24: SCI/D Kinesiotherapy (SCI/D KT)									
WRC01	SCI/D KT: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3469
PTTC1	SCI/D KT: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:1F	3470
SRE01	SCI/D KT: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:V	hw:5D	3471
OFD07	SCI/D KT: Therapist Workstation	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3472

Chapter 270 Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA25: SCI/D Combined Physical Therapy and Kinesiotherapy (SCI/D PT & KT)									
WRC01	SCI/D PT & KT: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3473
PTWT1	SCI/D PT & KT: Full Body Immersion Tank	m:PT	m:PT [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:1 s:V [55]	hw:4M	3474
PTEW1	SCI/D PT & KT: Arm, Leg and Lo-boy Whirlpool	m:PT	m:PT [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:1 s:V [55]	hw:4M	3475
PTTC1	SCI/D PT & KT: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V [55]	hw:1Q	3476
UCCL1	SCI/D PT & KT: Clean Utility / Linen Area	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:1 dg:F s:U	hw:SH-3C	3477
USCL1	SCI/D PT & KT: Soiled Utility Area	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	3478
SRSE1	SCI/D PT & KT: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:S	hw:5D	3479
OFA07	SCI/D PT & KT: Therapist Workstation	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3480

Chapter **270** Physical Medicine and Rehabilitation Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA26: SCI/D Occupational Therapy (SCI/D OT)									
WRC01	SCI/D OT: Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:U m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3481
OEV1	SCI/D OT: Treatment Clinic	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:V [55]	hw:1Q	3482
SRE01	SCI/D OT: Equipment Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:S	hw:5D	3483
OFA07	SCI/D OT: Therapist Workstation	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3484
FA27: SCI/D Activities for Daily Living (SCI/D ADL)									
OTDL1	SCI/D ADL: Activities for Daily Living	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4	3485

Chapter 272 Psychology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	3486
NSTA4	Communication Center	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	3487
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3488
FA2: Patient Area									
EXRG3	Exam Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q	3489
OPMH1	Multipurpose Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	3490
OPMH4	Multipurpose Room w/ Control Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	3491
CMP02	Control Room	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:LG s:U	hw:3B	3492
OPMH2	Group Testing Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:3F	3493

Chapter 272 Psychology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
OPMH3	Biofeedback Laboratory Testing Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:4E	3494
CMP02	Biofeedback Laboratory Control Room / Technician Office	m:SVT m:RF	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:LG s:U	hw:3B	3495
OTWT1	Neurophysiology Laboratory	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:4E	3496
CMP02	Neurophysiology Laboratory Viewing Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:4E	3497
OTEV1	Neurophysiology Vocational Rehabilitation Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	3498
OPMH1	Health Psychology Clinic	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:3F	3499
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2C [71]	3500
FA3: Staff and Administrative Area									
OFA09	Office, Psychology Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:LG s:S	hw:3G	3501
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3502

Chapter 272 Psychology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Staff and Administrative Area									
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3503
OFDC1	Office, Psychologist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:LG s:S	hw:3G	3504
OFA07	Workstation, Vocational Rehabilitation Specialist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3505
OFA07	Workstation, Psychology Intern	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3506
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	3507
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3508
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3509
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3510
FA4: Education Area									
CRA02	Conference Room / Classroom	m:CPT m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3511

Chapter **274** Quarters, On-Call

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Staff Area									
DUTY1	Bedroom, Staff	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 ds:YES s:S	hw:SH- 3E	3512
TLTS2	Bathroom, Shared	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:AT	m:Wood t:1 s:S	hw:2G [71]	3513
TLTS2	Bathroom, Private	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:AT	m:Wood t:1 s:S	hw:2G [71]	3514
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3515
SRS01	Closet, Linen	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:5D	3516
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3517

Chapter 275 Magnetic Resonance Imaging

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	3518
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3519
CLSC1	Patient Education Kiosk / Alcove	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3520
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3521
FA2: Patient Area									
WROC1	Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	3522
XMRS1	MRI Scanning Room [20, 23, 57, 60, 75]	m:WSF [78]	m:WSF [78] h:4"	m:GWB [64] f:P		m:AT [4]	t:Pre-Fab dl:RF		3523
XMRC1	Control Room [60]	m:VT	m:VT h:4"	m:GWB [64, 81] f:P		m:AT	m:Wood t:19 dl:RF s:X	hw:4J	3524

Chapter 275 Magnetic Resonance Imaging

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
XMRC2	System Component Room [60]	m:VT m:AF	m:VT h:4" m:RB h:4"	m:GWB [64, 81] f:P		m:AT	m:Wood t:19 dl:RF s:X	hw:4J	3525
XMRV1	Viewing Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3526
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	3527
DR001	Dressing Room / Cubicle	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3528
WRL01	Holdong Bay, Patient Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3529
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2H [71]	3530
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3531
FA3: Support Area									
SRGC2	Storage, Gas / Cryogen [37]	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Steel t:12 dr:45 min s:SS	hw:11B	3532

Chapter 275 Magnetic Resonance Imaging

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Support Area									
XVC01	PACS: Digital Quality Control	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3533
XFDS1	PACS: Digital Archival Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3534
XFP01	Film Processing Room	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 s:S	hw:3G	3535
XMRE1	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	3536
SRLW1	Storage, Stretcher / Wheelchair	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	3537
LCCL3	Alcove, Linen	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3538
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3539
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	3540
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3541
XVC01	Viewing / Consultation Room: Non-Teaching	m:CPT m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:4J	3542
XVC01	Viewing / Consultation Room: Teaching	m:CPT m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:4J	3543

Chapter 275 Magnetic Resonance Imaging

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Support Area									
WRCH1	Work Area, Staff	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3544
FA4: Staff and Administrative Area									
OFA07	Workstation, Chief Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3545
OFA07	Workstation, Staff Radiologist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3546
OFA07	Workstation, Professional, Non Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3547
OFA07	Workstation, PACS Administrator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3548
OFA07	Workstation, Physicist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3549
OFA07	Workstation, Quality Assurance	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3550
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3551
OFA07	Workstation, Data Processing	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3552
OFA07	Workstation, Scheduler	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3553
OFA07	Workstation, Transcriptionist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3554

Chapter 275 Magnetic Resonance Imaging

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Staff and Administrative Area									
RPR01	Copier Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4J	3555
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3556
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3557
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	3558
FA5: Education Area									
OFA07	Workstation, Resident / Intern	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3559
OFA07	Workstation, Student	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3560
CRR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3561

Chapter 276 Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting, Main	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	3562
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	3563
PAIA1	Patient Interview Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 s:V	hw:3G	3564
CLSC1	Patient Education Kiosk / Alcove	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3565
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3566
FA2: Radiology Patient Area									
WRC01	Sub-Waiting, Radiology	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	3567
XDR01	Radiology Room, General Purpose [50, 60]	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Steel t:15 dl:LEAD s:X	hw:4Q	3568

Chapter 276 Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Radiology Patient Area									
TLTU1	Patient Toilet, General Purpose Radiology	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2G [71]	3569
XDCS1	Chest Room [50, 60]	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:15 dl:LEAD s:X	hw:4Q	3570
DR001	Dressing Room / Cubicle, Radiology	m:WSF m:LVT	m:WSF h:4" m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 s:S	hw:2H [71]	3571
XDR01	Head Room [50, 60]	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:15 dl:LEAD s:X	hw:4Q	3572
XDR01	Tomography Room [50, 60]	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:15 dl:LEAD s:X	hw:4Q	3573
XDRF1	Radiographic / Fluoroscopic (R/F) Room [50, 60]	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:15 dl:RF s:X	hw:4Q	3574
DR001	Dressing Room / Cubicle, R/F	m:WSF m:LVT	m:WSF h:4" m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:2H [71]	3575
TLTU1	Toilet, R/F Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2J [71]	3576

Chapter 276 Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Radiology Patient Area									
WRC01	Sub-Waiting, Mammography / Stereotactic Mammography	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4K	3577
XDM01	Mammography Room [50, 60]	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:15 dl:LEAD s:X	hw:4Q	3578
XDM02	Stereotactic Mammography Room [50, 60]	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:15 dl:LEAD s:X	hw:4Q	3579
DR001	Dressing Room / Cubicle, Mammography	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:2H [71]	3580
TLTU1	Toilet, Mammography Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2J [71]	3581
XDMP1	Mammography Processing Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:17 s:X	hw:4Q	3582
OFDR1	Mammography Quality Assurance	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4G	3583
EXRG3	Mammography Biopsy Exam Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:4K	3584
WRC01	Sub-Waiting, Ultrasound	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	3585

Chapter 276 Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Radiology Patient Area									
XDUS1	Ultrasound Room [50, 60]	m:WSF m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T dl:LEAD [27] s:X	hw:4K	3586
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	3587
DR001	Dressing Room / Cubicle, Ultrasound	m:WSF m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 s:S	hw:2H [71]	3588
TLTU1	Toilet, Ultrasound Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2J [71]	3589
WRL01	Holding Bay, Patient Stretcher	m:WSF m:LVT	m:WSF h:4" m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3590
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	3591
FA3: Interventional Radiology (IR) Patient Area									
WRC01	Sub-Waiting, IR	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	3592
XABP1	This space moved to Chapter 286								

Chapter 276 Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Interventional Radiology (IR) Patient Area									
XACR1	This space moved to Chapter 286								
XACV1	This space moved to Chapter 286								
WRL01	Holding Bay, Patient Stretcher	m:WSF m:LVT	m:WSF h:4" m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3596
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2J [71]	3597
MEDP1	Medication Preparation Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3D	3598
XVC01	Viewing / Consultation	m:CPT [6]	m:RB h:4"	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3599
ORSA1	Alcove, Scrub	m:WSF [73]	m:WSF h:4"	m:GWB [54] f:SC	m:S [7]	m:AT f:SP	t:OPEN	hw:N/A	3600
ORCW1	Sterile Supply / Instrument Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT f:SP	m:Wood t:11 dg:T s:V	hw:4F	3601
SRS01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	3602
XFP01	Film Processing Room	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 s:S	hw:3J	3603

Chapter 276 Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Computed Tomography (CT) Patient Area									
WRC01	Sub-Waiting, CT	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	3604
XCTS1	Scanning Room, CT [50, 60]	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:15 dl:LEAD s:S s:X	hw:4Q	3605
XCTC1	Control Room [50, 60]	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	3606
XMRE1	Power and Equipment Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:17 s:X	hw:4Q	3607
XCTL1	Physician Viewing Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3G	3608
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]	3609
WRL01	Holding Bay, Patient Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3610
MEDP1	Medication Preparation Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3D	3611
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	3612

Chapter 276 Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Support Area									
WRCH1	Work Area, Staff	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4K	3613
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3614
SRLW1	Storage, Stretcher / Wheelchair	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:U	hw:5F	3615
XRM01	Alcove, Mobile X-Ray	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3616
XRM02	Alcove, Mobile C-Arm	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3617
XVC01	Workstation, Tele-Radiology	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3618
XVC01	Office, Tele-Radiology	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3619
SRE01	Storage Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3620
LCCL3	Alcove, Clean Linen	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3621
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3622
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3623

Chapter 276 Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Support Area									
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3624
XVC01	PACS: Digital Quality Control Area	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T dl:LEAD [27] s:U	hw:4K	3625
XFDS1	PACS: Digital Archival Storage Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:S	hw:5B	3626
XCTC1	PACS: 3D Workstation	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	3627
XCTI1	PACS: Computed Radiology (CR) Reader Area	m:WSF m:CPT [6]	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4K	3628
XFP01	Conv. Film: Darkroom Film Processing	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3J	3629
XFP03	Conv. Film: Daylight Processing	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3J	3630
XFSA1	Conv. Film: Film Sorting Area	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3631
XFFA1	Conv. Film: Film Files Storage / Fixed Shelving	m:VT	m:RB h:4"	m:GWB f:P		m:AT f:p	m:Wood t:11 dg:F s:S	hw:5B	3632
XFFA1	Conv. Film: File Storage / Fixed Shelving	m:VT	m:RB h:4"	m:GWB f:P		m:AT f:p	m:Wood t:11 dg:F s:S	hw:5B	3633
SRHM1	Conv. Film: Chemical Storage	m:RES	m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:11 dg:F s:S	hw:5B	3634

Chapter 276 Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Support Area									
XVC01	Viewing / Consultation Room: Non-Teaching	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	3635
XVC01	Viewing / Consultation Room: Teaching	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	3636
FA6: Staff and Administrative Area									
OFA09	Office, Radiologist Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3637
OFA09	Office, Radiology Service Assistant Chief	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3638
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	3639
OFA07	Workstation, Staff Radiologist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3640
OFA07	Workstation, Administrative Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3641
OFA07	Workstation, Professional Non Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3642
OFA09	Office, Chief Technician	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3643
OFA07	Workstation, PACS Administrator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3644

Chapter 276 Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Staff and Administrative Area									
OFA07	Workstation, Physicist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3645
OFA07	Workstation, Quality Assurance	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3646
OFA07	Workstation, Scheduler	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3647
OFA09	Office, Transcription Supervisor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3648
OFA07	Workstation, Data Processing	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3649
OFA07	Workstation, Transcriptionist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3650
RPR01	Copier Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4J	3651
CRR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3652
SL001	Staff Lounge	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3653
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3654

Chapter **276** Radiology Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Staff and Administrative Area									
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	3655
FA7: Education Area									
OFA07	Workstation, Resident / Intern	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3656
OFA07	Workstation, Student	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3657
CRR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3658

Chapter 277 Radiation Therapy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WROC1	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3659
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT m:GWB f:P	t:OPEN	hw:N/A	3660
CLSC1	Patient Education Kiosk / Alcove	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3661
TLTU1	Public Toilet	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3662
FA2: Patient Area									
WRC01	Sub-Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3663
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	3664
XTLA1	Linear Accelerator (IMRT) Room [60, 61]	m:RES	m:RES h:4"	m:GWB [64] f:P		m:AT f:SP	m:Wood t:17 [16] dl:LEAD s:X	hw:4Q	3665
XTEM1	Entrance Maze [60, 61]	m:RES	m:RES h:4"	m:GWB f:P		m:AT f:SP	m:Wood t:17 [16] dl:LEAD s:X	hw:4Q	3666

Chapter 277 Radiation Therapy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
XTLC1	Control Room [60, 61]	m:RES	m:RES h:4"	m:GWB f:P		m:AT f:SP	t:OPEN	hw:N/A	3667
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2H [71]	3668
TRGM1	Procedure / Exam Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT	m:Wood t:19 s:V	hw:4P	3669
EXRG3	Exam Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1Q	3670
TLTU1	Toilet, Exam Room Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2H [71]	3671
DR001	Dressing Room / Cubicle	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:2H [71]	3672
WRL01	Holding Bay, Patient Stretcher	m:WSF m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3673
FA3: Treatment Planning Unit Area									
XTSG1	CT Simulator Unit Room [60]	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT f:SP	m:Wood t:17 dl:LEAD s:X	hw:4Q	3674
XTSC1	Control Room [61]	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT f:SP	t:OPEN	hw:N/A	3675

Chapter 277 Radiation Therapy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Treatment Planning Unit Area									
XFSA1	Film Processing	m:RES	m:RES h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 s:S	hw:3J	3676
XTMF1	Block / Mold Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:T s:V	hw:4K	3677
XDUS1	Ultrasound Planning Unit Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:X	hw:4K	3678
XTTP1	Treatment Planning Computer Room / Dosimetry Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:1F	3679
WRCH1	Work Area, Staff	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3680
FA4: Support Area									
XTRT1	Sealed Source Room [60]	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 dl:LEAD [27] s:X m:Wood t:15 dl:LEAD [27] s:X	hw:4Q	3681
XTLB1	Physics Laboratory	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:4N	3682
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3683
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	3684
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3685

Chapter 277 Radiation Therapy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Support Area									
LCCL3	Alcove, Linen Storage	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	3686
XVC01	PACS: Digital Quality Control Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4G	3687
XFDS1	PACS: Digital Archival Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:S	hw:5	3688
XVC01	Viewing / Consultation Room: Non-Teaching	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	3689
XVC01	Viewing / Consultation Room: Teaching	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4K	3690
XCTI1	3D Workstation	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	3691
XCTI1	Computed Radiology (CR) Reader Area	m:SVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4G	3692
XFP01	Darkroom - Film Processing	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3J	3693
XFP03	Daylight Processing	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3J	3694
XFSA1	Film Sorting Area	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:5D	3695
SRE01	Storage, Support Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4F	3696

Chapter 277 Radiation Therapy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Support Area									
SRLW1	Storage, Stretcher / Wheelchair	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:U	hw:5E	3697
XFFA1	Storage, Film Files	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:S	hw:5	3698
XFFA1	Storage, Film	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:S	hw:5D	3699
SRHM1	Storage, Chemical	m:RES	m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:11 dg:F s:S	hw:5D	3700
FA5: Staff and Administrative Area									
OFA09	Office, Radiation Therapy Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3701
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	3702
OFA07	Workstation, Staff Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3703
OFA07	Workstation, Nurse	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3704
OFA07	Workstation, Professional Non Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3705
OFA07	Workstation, Physicist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3706

Chapter 277 Radiation Therapy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Staff and Administrative Area									
OFA09	Office, Technologist Supervisor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3707
OFA07	Workstation, PACS Administrator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3708
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3709
OFA07	Workstation, Data Processing	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3710
OFA07	Workstation, Quality Assurance	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3711
OFA07	Workstation, Scheduler	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3712
OFA07	Workstation, Transcriptionist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3713
XFFA2	Patient Records Filing	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:S	hw:5	3714
XVC01	Workstation, Tele-Radiology	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3715
CRR01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	3716
RPR01	Copier Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	3717

Chapter 277 Radiation Therapy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Staff and Administrative Area									
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:S	hw:5	3718
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3719
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3720
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3721
FA6: Education Area									
OFA07	Workstation, Resident / Intern	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3722
OFA07	Workstation, Student	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3723
CRR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3724

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Biomedical Research Unit Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3725
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	3726
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3727
FA2: Biomedical Research Unit Research Area									
LBRB1	Laboratory, Biomedical Research	m:RES	m:RES h:4"	m:CMU f:SC		m:AT	m:Steel t:20 dg:T s:X	hw:4C	3728
LBTS1	Tissue Culture Room, Biomedical	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:X	hw:4K	3729
SRR01	Cold Room, 4°C	m:PRE-FAB [63]	m:PRE-FAB [66]	m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [66]	hw:N/A	3730
SRF01	Freezer Room, -20°C	m:RES	m:RES h:4"	m:CMU f:SC		m:GWB f:SC	t:PRE-FAB [66]	hw:N/A	3731
SRS01	Warm Room, 20° to 37°C	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	t:PRE-FAB [66]	hw:N/A	3732

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Biomedical Research Unit Research Area									
SRSE1	Equipment Room	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:RES-W m:CMU f:SC	m:RWC h:4'-0"	m:GWB f:RES-W	m:Wood t:1 dg:T s:V	hw:5E	3733
SRL01	Microscope Room, Dark	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:3F	3734
XXYYC	Laboratory, Radiation [27]	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4Q	3735
XXYYC	Mass Spectrometer Room	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:CT h:4'- 0"	m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4N	3736
XXYYC	High Resolution Mass Spectrometer Room	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4N	3737
XMRE1	Nuclear Magnetic Resonance Room [27]	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:SS	hw:10E	3738
LBEM2	Electron Microscope Suite, Scope Room	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:V	hw:4N	3739
LBEM3	Electron Microscope Suite, Preparation Room/Lab	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4N	3740
XXYYC	Electron Microscope Suite, Microtome Alcove	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4N	3741

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Biomedical Research Unit Research Area									
XXYYC	X-Ray Crystallography	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:X	hw:4N	3742
LBUL1	Cell Bank Freezer Room, Ultra Low	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 s:X	hw:4N	3743
LBUL1	Freezer Room, Ultra Low	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 s:X	hw:4N	3744
XXYYC	Cell Sorter Room, Fluorescent Activated	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4N	3745
XXYYC	Polymerase Chain Reaction (PCR) Suite	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4E	3746
XXYYC	DNA Sequencing Room	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4N	3747
XXYYC	Microscope Room Confocal	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4N	3748
XXYYC	Cell Irradiator Room	m:RES	m:RES h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4N	3749
FA3: Biomedical Research Unit Biosafety Laboratory Area									
XXYYC	BSL3 Suite: Ante Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Steel t:20 dg:T s:X	hw:1L	3750
LBRC1	BSL3 Suite: Procedure Room	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Steel t:20 dg:T s:X	hw:4N	3751
LBTS1	BSL3 Suite: Tissue Culture Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Steel t:20 dg:T s:X	hw:4	3752

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Biomedical Research Unit Biosafety Laboratory Area									
CSSS2	BSL3 Suite: Autoclave Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Steel t:20 dg:T s:X	hw:4	3753
LR002	BSL3 Suite: Clothes Changing Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Steel t:2 s:S	hw:2C [71]	3754
SHWR1	BSL3 Suite: Shower Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:CT [7, 44] m:S [7, 44]	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Steel t:2 s:S	hw:2C [71]	3755
TLTU1	BSL3 Suite: Toilet Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2C [71]	3756
FA4: Biomedical Research Unit Support Area									
LBGW1	Washing and Sterilization Room, Glassware	m:RES	m:RES h:4"	m:GWB f:RES-W m:CMU		m:GWB f:RES-W	m:Wood t:1 dg:T s:V	hw:4S	3757
SRGC1	Storage, Gas Cylinder [37, 40]	m:RES	m:RES h:4"	m:CMU f:P f:SC		m:GWB f:SC	m:Steel t:8 dr:45 min s:V m:Wood t:11 dr:45 min s:V	hw:5B	3758

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Biomedical Research Unit Support Area									
SRGC2	Storage, Flammable Solvent [37, 40]	m:RES	m:RES h:4"	m:CMU f:P m:GWB		m:GWB f:SC	m:Steel t:8 dr:45 min s:V m:Wood t:11 dr:45 min s:V	hw:5B	3759
SRHM1	Storage, Acid [40]	m:RES	m:RES h:4"	m:CMU f:P f:P		m:GWB f:SC	m:Steel t:8 dr:45 min s:V m:Wood t:11 dr:45 min s:V	hw:5B	3760
SRHM1	Storage, Radioactive Waste	m:RES	m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Steel t:17 ds:YES s:V	hw:SH- 3F	3761
SRHM1	Storage, Biohazardous Waste	m:RES	m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Steel t:1 ds:YES s:V	hw:SH- 3F	3762
SRHM1	Storage, Recyclable Waste	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3B	3763
SRS01	Storage, General	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5	3764
FA5: Biomedical Research Unit Staff and Administration Area									
OFA09	Office, Biomedical Research Unit Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3765
OFA09	Office, Biomedical Research Unit Associate Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3766
OFA07	Workstation, Biomedical Research Unit Research Investigator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3767

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Biomedical Research Unit Staff and Administration Area									
OFA09	Office, Administrative Officer [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3768
OFA07	Workstation, Clerical Support	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3769
OFA07	Workstation, Special Staff	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3770
SRE01	Equipment Room	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:S	hw:5	3771
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3772
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3773
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3774
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	3775
SHWR1	Staff Shower	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:CT [7, 44, 64] m:S [7]	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2 [71]	3776

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Health Services Research and Development Staff and Administrative Area									
OFA07	Workstation, Health Services Research and Development Investigator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3777
OFA07	Workstation, Health Services Research and Development Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3778
OFA07	Workstation, Health Services Research and Development Management Analyst	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3779
CMP02	Data Server Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T ds:YES s:S	hw:SH-3H	3780
WRCH1	Data Analysis Equipment / Work Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:5D	3781
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3782
FA7: Rehabilitation Research and Development Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3783
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	3784

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA7: Rehabilitation Research and Development Reception Area									
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3785
FA8: Rehabilitation Research and Development Research Area									
LBRB1	Laboratory, Rehabilitation Research and Development	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Steel t:20 dg:T s:X	hw:4K	3786
LBTS1	Tissue Culture Room, Rehabilitation Research and Development	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Steel t:20 dg:T s:X	hw:4K	3787
CMP02	Data Server	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH- 3H	3788
WRCH1	Data Analysis Equipment / Work Room	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:5D	3789
PAIA1	Patient Interview Room	m:CPT [6]	m:PRB [8] h:4"	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3790
APMS1	Machine Shop	m:EPY	m:RB h:4"	m:GWB [64] f:SC		m:AT	m:Wood t:1 dg:T s:S	hw:4F	3791
SRSE1	Storage, Equipment	m:EPY	m:RB h:4"	m:GWB [54] f:SC m:CMU f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3792
MRS01	Storage, Patient Records	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	3793

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Rehabilitation Research and Development Research Area									
SRS01	Storage, General	m:EPY	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3794
FA9: Rehabilitation Research and Development Service Staff and Administrative Area									
OFA09	Office, Rehabilitation Research and Development Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3795
OFA09	Office, Rehabilitation Research and Development Service Associate Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3796
OFA09	Office, Medical Director [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3797
OFA09	Office, Deputy Director [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3798
OFA07	Workstation, Rehabilitation Research and Development Research Investigator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3799
OFA09	Office, Administrative Officer [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3800
OFA07	Workstation, Secretary / Administrative Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3801
OFA07	Workstation, Management Analyst	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3802
OFA07	Workstation, Special Staff	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3803

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA9: Rehabilitation Research and Development Service Staff and Administrative Area									
OFA07	Workstation, Educational and Training Manager	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3804
OFA07	Workstation, Graduate Student / Post-Doctorial	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3805
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3806
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3807
SRS01	Storage, General	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3808
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3809
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	3810
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3811
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3812

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA9: Rehabilitation Research and Development Service Staff and Administrative Area									
SHWR1	Staff Shower	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7]	m:GWB [7, 44, 64] m:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2 [71]	3813
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3814
FA10: Clinical Research Unit Administrative Area									
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3815
FA11: Veterinary Medical Unit Treatment Area									
VLB01	Diagnostic Laboratory	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3816
VHAU1	Holding Room, Quarantine	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3817
VEX01	Treatment Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3818
VHAU1	Holding Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3819

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA11: Veterinary Medical Unit Treatment Area									
VLB01	Procedure Laboratory	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3820
FA12: Veterinary Medical Unit Surgical Suite									
VSO01	Surgical Suite, Survival OR	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3821
VSO01	Surgical Suite, Terminal OR	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3822
VRRP1	Surgical Suite, Preparation Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3823
VRRP1	Surgical Suite, Scrub / Gown Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T s:S	hw:4C	3824
VRRP1	Surgical Suite, Recovery	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3825
ANCW1	Surgical Suite, Workroom / Supply	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T s:V	hw:4C	3826

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA13: Veterinary Medical Unit Radiographic Suite [27]									
VXER1	Radiographic Suite, Procedure Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:15 s:X	hw:4Q	3827
VXER1	Radiographic Suite, Control	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	t:OPEN	hw:N/A	3828
VXER1	Radiographic Suite, Darkroom	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Wood t:1 s:S	hw:3J	3829
VLAH1	Chemical / Radioisotope Suite, Animal Holding Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T s:X	hw:4C	3830
VSO01	Chemical / Radioisotope Suite, Animal Procedure Laboratory	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T s:X	hw:4C	3831
SRHM1	Chemical / Radioisotope Suite, Hazardous Waste Disposal Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T s:X	hw:4C	3832
FA14: Veterinary Medical Unit Biosafety Laboratory									
XXYYC	BSL3 Infectious Disease Suite: Ante Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:1F	3833
VLAH1	BSL3 Infectious Disease Suite: Holding Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3834

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA14: Veterinary Medical Unit Biosafety Laboratory									
VLB01	BSL3 Infectious Disease Suite: Procedure Laboratory	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3835
CSSS2	BSL3 Infectious Disease Suite: Autoclave Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:1F	3836
XXYYC	BSL3 Infectious Disease Suite: Clothes Changing Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 s:S	hw:2C [71]	3837
NBCD2	BSL3 Infectious Disease Suite: Shower Room	m:RES [74]	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC	m:PT [7] h:4'-0" m:CT h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Steel t:2 s:S	hw:2C [71]	3838
TLTU1	BSL3 Infectious Disease Suite: Toilet Room	m:RES [74]	m:RES [7] h:4"	m:GWB [7, 64] f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 s:S	hw:2C [71]	3839
FA15: Veterinary Medical Unit Barrier Suite									
XXYYC	Barrier Suite: Changing Room	m:RES	m:RES [7] h:4"	m:GWB f:P		m:AT	m:Steel t:2 s:S	hw:2C [71]	3840

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA15: Veterinary Medical Unit Barrier Suite									
SHWR1	Barrier Suite: Shower Room	m:RES [74]	m:RES [7] h:4"	m:GWB [7, 44, 64] f:RES- W m:CMU f:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Steel t:2 s:X	hw:2C [71]	3841
TLTU1	Barrier Suite: Toilet	m:RES [74]	m:RES [7] h:4"	m:GWB [7, 64] f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 s:X	hw:2C [71]	3842
XXYYC	Barrier Suite: Ante Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:1F	3843
VLAH1	Barrier Suite: Holding Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3844
VLB01	Barrier Suite: Procedure	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3845
FA16: Veterinary Medical Unit Environmental Suite									
VLAH1	Environmental Suite: Animal Holding	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3846
VLB01	Enviromental Suite: Procedure Laboratory	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:4C	3847

Chapter **278** Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA17: Veterinary Medical Unit Support Area									
DOCK1	Loading Dock	m:C [10]		m:GWB f:P		m:EXP	t:MOTORIZED ROLL UP s:9'-0" x 10'-0"		3848
VEX01	Animal Receiving / Exam Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:X	hw:1F	3849
VCWA1	Cage Wash Room, Tunnel Washer	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T ds:ADO s:SS	hw:10A	3850
VCWA1	Cage Wash Room, Cage / Rack Washer	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T ds:ADO s:SS	hw:10A	3851
VCWA1	Cage Wash Room, Tunnel Washer and Cage / Rack Washer	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T ds:ADO s:SS	hw:10A	3852
SSC01	Storage, Clean Cage	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC	m:RWC h:4'-0"	m:GWB f:RES-W	m:Steel t:2 dg:T ds:ADO s:SS	hw:10A	3853
SRS01	Storage, Dry Feed and Bedding	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:12 s:X	hw:5B	3854
SRR01	Storage, Walk-in Cold Food	m:PRE-FAB [63]		m:PRE-FAB [66]		m:PRE-FAB [66]	t:PRE-FAB [66]	hw:N/A	3855

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA17: Veterinary Medical Unit Support Area									
VFP01	Kitchen	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:20 dg:T s:S	hw:4K	3856
SRSE1	Storage, Equipment	m:RES m:WSF	m:RES [7] h:4" m:WSF h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:12 dg:F s:SS	hw:11	3857
XXYYC	Necropsy Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T s:X	hw:4C	3858
SRR01	Storage, Walk-in Cold Carcass Holding	m:PRE- FAB [63]		m:PRE-FAB [66]		m:PRE- FAB [66]	t:PRE-FAB [66]	hw:N/A	3859
SRR01	Refrigerated Holding, Waste / Carcass	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T s:X	hw:4C	3860
SRF01	Freezer Holding, Carcass	m:PRE- FAB [63]		m:PRE-FAB [66]		m:PRE- FAB [66]	t:PRE-FAB [66] dg:T	hw:N/A	3861
XXYYC	Holding, Radioisotope Waste Decay	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 s:X	hw:4C	3862
XXYYC	NaOH Digester Room	m:RES	m:RES [7] h:4"	m:GWB f:RES-W m:CMU f:SC		m:GWB f:RES-W	m:Steel t:2 dg:T s:X	hw:4C	3863

Chapter 278 Research and Development

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA18: Veterinary Medical Unit Staff and Administrative Area									
OFA09	Office, Veterinary Medical Unit Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3864
OFA09	Office, Supervisor [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3865
OFA07	Workstation, Veterinary Medical Unit Investigator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3866
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3867
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3868
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3869
SHWR1	Shower, Staff	m:PT m:RES [74]	m:RES [7] h:4"	m:GWB [7, 44, 64] m:SC	m:PT [7] h:4'-0" m:CT h:4'- 0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2 [71]	3870
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3871

Chapter 279 Police Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Duty Area									
CROP1	Operations	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3	3872
SRS01	Holding [59, 62]	m:VT	m:RB h:4"	m:CMU f:P		m:GWB f:P	m:Steel t:22 s:S	hw:SH-2	3873
SRS01	Equipment and Evidence	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3874
SRS01	Storage, Armory and Weapons	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3F	3875
XXYYC	Identification / Registration Issuance	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:11 dg:T ds:YES s:V	hw:SH-3	3876
CRA01	Conference Room / Training	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3877
FA2: Staff and Administrative Area									
OFA09	Office, Police Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3878
OFA09	Office, Police Service Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3879
OFA07	Workstation, Detective	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3880
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3881

Chapter **279** Police Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Staff and Administrative Area									
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3882
LR001	Locker Room, Male Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3883
LR001	Locker Room, Female Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3884
TLTS1	Toilet / Shower, Male Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:CT [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2	3885
TLTS1	Toilet / Shower, Female Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:CT [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2	3886

Chapter 280 Service Organizations

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3887
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3888
FA2: Staff and Administrative Area									
OFA09	Office, Service Organization Representative [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:3E	3889
FA3: Support Area									
SRS01	Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	3890

Chapter **282** Social Work Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	3891
TLTU1	Toilet	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	3892
FA2: Patient Area									
OFA04	Office, Social Worker [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3893
OFA07	Workstation, Social Work Associate	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3894
OFA07	Workstation, Social Work Intern	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3895
FA3: Staff and Administrative Area									
OFA09	Office, Social Work Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3896
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	3897
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3898

Chapter **282** Social Work Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Staff and Administrative Area									
CRA01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3899
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:5B	3900

10

CANCELLED

Chapter 284 Logistics Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA1: Truck Bay Calculation

CALC1	Number of Clean Truck Bays								3901
CALC1	Number of Soiled Truck Bays								3902

FA2: Loading Dock Area

DOCK1	Receiving Dock, Clean	m:C [10]		m:GWB [54] f:P m:CMU f:P			t:OPEN	hw:N/A	3903
DOCK1	Receiving Dock, Soiled	m:C [10]		m:GWB [54] f:P m:CMU f:P			t:OPEN	hw:N/A	3904
DOCK1	Receiving Dock, Nutrition and Food Service	m:C [10]		m:GWB [54] f:P m:CMU f:P			t:OPEN	hw:N/A	3905
MMBK1	Breakout Room	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:11	3906
MMST1	Staging Room, Logical Unit of Measure Delivery (LUM)	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:11	3907
SRGC1	Storage, Full Gas Cylinder	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F dr:45 min s:V m:Steel t:12 dg:F dr:45 min s:V	hw:5B	3908

Chapter **284** Logistics Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Loading Dock Area									
SRGC1	Storage, Empty Gas Cylinder	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F dr:45 min s:V m:Steel t:12 dg:F dr:45 min s:V	hw:5B	3909
SRHM1	Storage, Flammable	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F dr:45 min s:V m:Steel t:12 dg:F dr:45 min s:V	hw:5B	3910
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3911
FA3: Warehouse Area									
MMRP1	Receiving and Issue	m:C [10]	m:RB h:4"	m:GWB f:P		m:AT	t:MOTORIZED ROLL UP s:10'-0" x 10'-0"	hw:7	3912
SSC01	Storage, Equipment Prep and Staging	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V m:Steel t:12 dg:T s:V	hw:5B	3913
SRE01	Storage, Flex	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V m:Steel t:12 dg:T s:V	hw:5B	3914

Chapter **284** Logistics Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Warehouse Area									
SRSE1	Storage, Pandemic	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V m:Steel t:12 dg:T s:V	hw:5B	3915
SRSE1	Storage, Emergency Preparedness	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V m:Steel t:12 dg:T s:V	hw:5B	3916
MMGS1	Storage, Bulk Items	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V m:Steel t:12 dg:T s:V	hw:5B	3917
SRSE1	Storage, Unit Items	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V m:Steel t:12 dg:T s:V	hw:5B	3918
MMRP1	Receiving Breakout and Inspection Room	m:C [10]	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:11	3919
SRS04	Storage, Sterile Consumables (Soft Goods)	m:RES	m:RES h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V m:Steel t:12 dg:T s:V	hw:5B	3920

Chapter **284** Logistics Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Warehouse Area									
NT001	Pneumatic Tube Station	m:SVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:11 dg:T s:V m:Steel t:12 dg:T s:V	hw:5B	3921
FA4: Postal / Mail Service Area									
OFA09	Office, Postal / Mail Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3922
OFA03	Workstation, Postal Clerk	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3923
MRRS1	Mailroom	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S m:Steel t:1 dg:T s:S	hw:4G	3924
RPRO2	Reproduction Room, High Volume	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S m:Steel t:2 dg:T s:S	hw:4G	3925
MRC51	Courier Service Drop-off / Pick-up	m:SVT	m:RB h:4"	m:GWB f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V m:Steel t:12 dg:T s:V	hw:5B	3926
SRSE1	Storage Room	m:SVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V m:Steel t:12 dg:T s:V	hw:5B	3927

Chapter 284 Logistics Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Staff and Administrative Area									
OFA09	Office, Logistics Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3928
OFA09	Office, Logistics Assistant Chief	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3929
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	3930
CRA01	Conference Room / Training Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3931
RPR01	Copier / Office Supply Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4J	3932
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3933
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3934
LR002	Locker / Changing Room, Male	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3935
LR002	Locker / Changing Room, Female	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3936

Chapter 285 Sterile Processing Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Decontamination Area									
CSCR1	Anteroom, Soiled Transition / Drop-off	m:RES	m:RES h:4"	m:GWB f:RES-W		m:GWB f:RES-W	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3937
CSPE1	Alcove, PPE	m:RES	m:RES h:4"	m:GWB [54] f:RES-W		m:GWB f:RES-W	t:OPEN	hw:N/A	3938
CSDE1	Decontamination Work Area	m:RES	m:RES [7] h:4"	m:GWB [7] f:RES-W		m:GWB [7] f:RES-W	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3939
CWSH2	Automated Cart Washer	m:RES	m:RES [7] h:4"	m:CT [7]		m:GWB f:SC	m:Steel t:2 dg:T s:X t:AS REQ'D	hw:10B	3940
CWSH3	Manual Cart Wash	m:RES	m:RES [7]	m:CT [7]		m:GWB f:SC	m:Steel t:2 dg:T s:X t:AS REQ'D	hw:10B	3941
CSWT1	Storage Room, Water Treatment and Detergent	m:RES [19]	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3942
JANC2	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3943

Chapter 285 Sterile Processing Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Scope Processing Area									
CSAR1	Anteroom, Scope Processing	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3944
CSPE1	Alcove, PPE	m:RES	m:RES h:4"	m:GWB [54] f:SC		m:GWB f:SC	t:OPEN	hw:N/A	3945
CSSD1	Decontamination Room	m:RES	m:RES [7] h:4"	m:GWB [7] f:RES-W		m:GWB f:RES-W	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3946
CSSP1	Scope Processing Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3947
CSST1	Scope Staging Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3948
FA3: Preparation and Assembly Area									
CSIA1	Clean Workroom, Instrument Set Assembly	m:WSF	m:WSF h:4"	m:GWB f:SC		m:GWB f:SC	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3949
SRSP1	Storage, Sterile Processing Supplies	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Steel t:12 dg:F s:UU	hw:11B	3950

Chapter 285 Sterile Processing Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Sterilization Area									
CSSS1	Sterilization Area, Steam	m:RES [19]	m:RES h:4"	m:GWB f:RES-W		m:GWB f:RES-W	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3951
CSLT1	Sterilization Area, Low Temp	m:RES [19]	m:RES h:4"	m:GWB f:RES-W		m:GWB f:RES-W	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3952
CSEO1	Ethylene Oxide Gas Sterilization (EtO) Room	m:RES [19]	m:RES h:4"	m:GWB f:RES-W		m:GWB f:RES-W	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3953
CSEO2	Ethylene Oxide Gas Sterilization (EtO) Abator Room	m:RES [19]	m:RES h:4"	m:GWB f:RES-W		m:GWB f:RES-W	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3954
CHC01	Cart Return Area	m:RES [19]	m:RES h:4"	m:GWB f:RES-W		m:GWB f:RES-W	m:Steel t:2 s:UU m:Steel t:12 s:UU	hw:10B	3955
CHC01	Unloading / Cooling Area	m:RES [19]	m:RES h:4"	m:GWB f:RES-W		m:GWB f:RES-W	m:Steel t:2 s:UU m:Steel t:12 s:UU	hw:10B	3956
CSCG1	Equipment, Clean Steam Generator	m:SVT	m:RB h:4"	m:GWB f:SC		m:AT f:SP	m:Steel t:2 s:SS	hw:10D	3957

Chapter 285 Sterile Processing Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Receiving, Storage and Dispatch Area									
SRS01	Vendor Drop-off / Pick-up Area	m:SVT	m:RB h:4"	m:GWB f:SC		m:AT f:SP	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3958
CHC01	Dispatch Area	m:SVT	m:RB h:4"	m:GWB f:SC		m:AT f:SP	t:OPEN	hw:N/A	3959
OFA07	Workstation, Case Cart Dispatch	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT f:SP	t:OPEN	hw:N/A	3960
SRS05	Storage, Sterile Durables (Sterile Instruments)	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Steel t:12 dg:F s:UU	hw:11B	3961
CSCQ1	Case Cart Assembly	m:RES	m:RES h:4"	m:GWB f:RES-W		m:GWB f:RES-W	m:Steel t:2 dg:T s:UU m:Steel t:12 dg:T s:UU	hw:10B	3962
JANC2	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	3963
FA6: Staff and Administrative Area									
OFA09	Office, Sterile Processing Service (SPS) Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3964
OFA09	Office, Sterile Processing Service (SPS) Assistant Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	3965
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	3966

Chapter 285 Sterile Processing Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Staff and Administrative Area									
CRA01	Conference Room / Training Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	3967
RPR01	Copier / Office Supply Room	m:VT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	3968
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	3969
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	3970
LR002	Locker / Changing Room, Male	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3971
LR002	Locker / Changing Room, Female	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	3972
TLTS1	Toilet / Shower, Male	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:CT [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2	3973

Chapter **285** Sterile Processing Services

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA6: Staff and Administrative Area									
TLTS1	Toilet / Shower, Female	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:CT [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2	3974

38

CANCELLED

Chapter 286 Surgical and Endovascular Services

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 1: Inpatient Surgical Facility Reception Area	WTG08	Waiting, General	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U m:N/A t:OPEN dg:N/A s:N/A	hw:4K hw:N/A
FA 1	WTF03	Waiting, Family	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U m:N/A t:OPEN dg:N/A s:N/A	hw:4K hw:N/A
FA 1	RCP03	Reception / Registration	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT m:GWB f:P	t:OPEN	hw:N/A
FA 1	RCHK2	Kiosk, Patient Check-In	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT m:GWB f:P	t:OPEN	hw:N/A
FA 1	TNPG1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]
FA 1	TNPFM	Toilet, Family	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]
FA 1	CLSC1	Patient Education / Resource Kiosk	m:CPT [6]	m:PRB [8]	m:GWB [5] f:P		m:AT m:GWB f:P	t:OPEN	hw:N/A
FA 1	CLSC3	Patient Education / Resource Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G
FA 1	OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G
FA 1	NCWD4	Alcove, Refreshment Center	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'- 0"	m:AT	t:OPEN	hw:N/A
FA 1	SRLW1	Storage, Wheelchair / Litter	m:SVT	m:PRB [8]	m:GWB [5] f:P	m:RWC h:4'- 0"	m:AT	t:11/12 s:X-W	hw:5B
FA 2: Inpatient Surgical Facility Pre-Operative Assessment Unit Area	WTG06	Waiting, Pre-Operative Assessment Unit	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT f:SP	t:Sliding Glass Door dg:T s:8'-0" x 7'-0"	hw:N/A
FA 2	RCP02	Reception / Registration, Pre-Operative Assessment Unit	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	t:OPEN	hw:N/A

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 2	EXRG3	Exam Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q
FA 2	TPG01	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]
FA 2	RCA07	Alcove, Specimen Collection	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	t:OPEN	hw:N/A
FA 2	UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	t:11/12 s:V-W, PB	hw:SH-3C
FA 2	USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	11/12, V, PB	hw:SH-3C
FA 2	WRM4	Team Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	19/20, U-T	hw: 4J
FA 2	SRE01	Storage, Equipment / Clean Supply	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	11/12, V-W	hw: 5B
FA 3: Inpatient Surgical Facility Pre-Operative Holding / Phase II Recovery Patient Area	LR002	Locker / Changing Room, Male Patient	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	1/2, S	hw: 2C
FA 3	TPG01	Toilet, Pre-Operative Holding / Phase II Recovery Male Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44] f:SC	m:PT [7] h:4'-0"	m:AT f:SP	1/2, S	hw: 2C
FA 3	LR002	Locker / Changing Room, Female Patient	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	1/2, S	hw: 2C
FA 3	TPG01	Toilet, Pre-Operative Holding / Phase II Recovery Female Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44] f:SC	m:PT [7] h:4'-0"	m:AT f:SP	1/2, S	hw: 2 subscript 19
FA 3	RRPR1	Patient Bay, Pre-Operative Holding / Phase II Recovery	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC		m:AT f:SP	1/2, V-W	hw: 1D
FA 3	RRPR2	Patient Room, Pre-Operative Holding / Phase II Recovery	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC		m:AT f:SP	1/2, V-W	hw: 1D
FA 3	TPG01	Toilet, Pre-Operative Holding / Phase II Recovery Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44] f:SC	m:PT [7] h:4'-0"	m:AT f:SP	1/2, S	hw: 2 subscript 19
FA 3	NSTA2	Nurse Station	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:SC		m:AT	t:OPEN	hw:N/A
FA 3	WRCH1	Workroom, Provider	m:CPT [6] m:SVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3E
FA 3	SINK1	Handwashing Station	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:SC	m:CT h:4'-0"	m:AT	t:OPEN	hw:N/A

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 3	NCWD3	Nourishment Room	m:LVT m:SVT [85]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3C
FA 3	XVC01	Viewing Room, Picture Archiving and Communication System - PACS	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC		m:AT f:SP	15, S-T	hw: 4Q
FA 3	RCA01	Alcove, Crash Cart	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	t:OPEN	hw:N/A
FA 3	LCCL3	Alcove, Clean Linen	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	t:OPEN	hw:N/A
FA 3	XRM01	Alcove, Portable Imaging Equipment	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A
FA 3	UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C
FA 3	USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 ds:YES s:V	hw:SH-3C
FA 3	SRE01	Storage, Equipment	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B
FA 3	JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:PT [7] h:4'-0"	m:AT [9] f:SP	m:Wood t:1 s:U	hw:5D
FA 3	SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4
FA 3	TNPG1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]
FA 4: Inpatient Surgical Facility Anesthesia Procedure Patient Area	ORPP3	Anesthesia Induction / Procedure Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	1/2, S	hw: 1B
FA 4	NSTA3	Nurse Station, Anesthesia Induction / Procedure Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	t:OPEN	hw:N/A
FA 4	ANCW2	Clean Workroom, Anesthesia	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K
FA 4	SRE02	Equipment Room, Anesthesia	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B
FA 4	MEDP2	Medication Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3D

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 4	WRTM4	Team Room, Anesthesiology	m:WSF	m:WSF h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 5: Inpatient Surgical Facility Surgical Service Patient Area	NSTA5	Control Station	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:15 dg:T s:S m:N/A t:OPEN s:N/A	hw:4! hw:N/A
FA 5	ORGS1	Operating Room, General	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q
FA 5	ORGE1	Equipment Room, General	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:RWC [54] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T s:V	hw:5F
FA 5	OROS1	Operating Room, Orthopedic	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q
FA 5	OROE1	Equipment Room, Orthopedic	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:RWC [54] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T s:V	hw:5F
FA 5	ORCS1	Operating Room, Urology / Cystoscopy	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q
FA 5	ORCE1	Equipment Room, Urology / Cystoscopy	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:RWC [54] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T s:V	hw:5F
FA 5	ORCT1	Operating Room, Cardiothoracic	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q
FA 5	ORCM1	Equipment Room, Cardiothoracic	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:RWC [54] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T s:V	hw:5F
FA 5	ORHL1	Pump Room, Cardiothoracic OR	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:RWC [54] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T s:X	hw:5F
FA 5	ORNS1	Operating Room, Neurosurgical	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 5	ORNE1	Equipment Room, Neurosurgical	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:RWC [54] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T s:V	hw:5F
FA 5	ORRB1	Operating Room, Robotics	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q
FA 5	ORRE1	Equipment Room, Robotics	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:RWC [54] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T s:V	hw:5F
FA 5	ORTR1	Operating Room, Transplant	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q
FA 5	ORTE1	Equipment Room, Transplant	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:RWC [54] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T s:V	hw:5F
FA 5	ORHY1	Operating Room, Monoplane Hybrid	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T dl:LEAD s:S	hw:10H hw:4Q
FA 5	ORHY2	Operating Room, Biplane Hybrid	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T dl:LEAD s:S	hw:10H hw:4Q
FA 5	ORHC1	Control Room, Hybrid OR	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T dl:LEAD s:S	hw:4Q
FA 5	XCCA1	System Component Room, Hybrid OR	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T dl:LEAD s:S	hw: 4Q, 10H
FA 5	ORHE1	Equipment Room, Hybrid OR	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:RWC [54] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T s:V	hw:5F
FA 5	ORHL1	Pump Room, Hybrid OR	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC	m:RWC [54] h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T s:X	hw:5F
FA 5	ORSA1	Scrub Sink Area	m:RES	m:RES h:4"	m:GWB f:SC	m:S [7] h:5'-0"	m:GWB f:SC	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:1M [14] hw:N/A
FA 5	SRLW2	Storage, Stretcher	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	11/12, V-W	hw: 4F
FA 6: Inpatient Surgical Facility Endovascular Service Patient Area	XCCE1	Cardiac Catheterization Laboratory	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:17 dl:LEAD [Note] s:X	hw:10H hw:4Q
FA 6	XCCC1	Control Room, Cardiac Catheterization	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	1/2, S-T	hw: 4K

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 6	XCCA1	System Component Room, Cardiac Catheterization	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:17 s:X	hw:4Q
FA 6	XCEP1	Procedure Room, Electrophysiology	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:17 dl:LEAD [Note] s:X	hw:10H hw:4Q
FA 6	XCEC1	Control Room, Electrophysiology	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	1/2, VV-T	hw: 10D
FA 6	XCCA1	System Component Room, Electrophysiology	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:17 s:X	hw:4Q
FA 6	XABP1	IR / Vascular Procedure Room THESE SPACES CAME FROM ZOLI,Chpt276	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:17 dl:LEAD [Note] s:X	hw:10H hw:4Q
FA 6	XCEC1	Control Room, IR / Vascular Procedure Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	1/2, VV-T	hw: 10D
FA 6	XCCA1	System Component Room, IR / Vascular Procedure Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:17 s:X	hw:4Q
FA 6	OREE1	Equipment Room, Cardiac Catheterization Laboratory and Electrophysiology	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:11 dg:F s:V	hw:5F
FA 6	TRTE1	Transesophageal Echocardiograph (TEE) Procedure Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q
FA 6	TRTE2	Decontamination, TEE Probe	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	1/2, NV-T	hw: 10D
FA 6	TRTE3	Storage, Clean TEE Probe	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	11/12, V-W	hw: 4F
FA 6	ORSA1	Scrub Sink Area	m:RES	m:RES h:4"	m:GWB f:SC	m:S [7] h:5'-0"	m:GWB f:SC	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:1M [14] hw:N/A
FA 6	SRLW2	Storage, Stretcher	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	11/12, V-W	hw: 4F
FA 7: Inpatient Surgical Facility Clean Core Area	ORCC2	Clean Core, Surgical and Endovascular Services	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:VV	hw:10C
FA 7	ORSR1	Immediate Use Sterilization Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:11 dg:T s:V	hw:4C

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 7	RCA03	Alcove, Blood Bank Refrigerator	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:11 dg:T s:V	hw:4C
FA 7	CHC01	Cart Holding, Clean	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:11 dg:T s:V	hw:4C
FA 8: Inpatient Surgical Post-Anesthetic Care Unit (PACU) / Phase I Recovery Patient Area	RRBP1	Patient Bay, PACU / Phase I Recovery	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	t:OPEN	hw:N/A
FA 8	RRIR1	Airborne Infection Isolation (All), Patient Room, PACU / Phase I Recovery	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT [9] f:SP	t:Sliding Glass Door s:8'-0" x 7'-0"	hw: N/A
FA 8	BRAR1	Airborne Infection Isolation (All), Anteroom, PACU / Phase I Recovery	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT [9] f:SP	t:Sliding Glass Door s:8'-0" x 7'-0"	hw: N/A
FA 8	NSTA1	Nurse Station, PACU / Phase I Recovery	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:SC		m:AT	t:OPEN	hw:N/A
FA 8	SINK1	Handwashing Station	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:SC	m:CT h:4'-0"	m:AT	t:OPEN	hw:N/A
FA 8	XVC01	Viewing Room, Picture Archiving and Communication System - PACS	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB f:SC		m:AT	15, S-T	hw: 4Q
FA 8	MEDP2	Medication Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3D
FA 8	UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C
FA 8	USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 ds:YES s:V	hw:SH-3C
FA 8	RCA01	Alcove, Crash Cart	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	t:OPEN	hw:N/A
FA 8	LCCL3	Alcove, Clean Linen	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	t:OPEN	hw:N/A
FA 8	XRM01	Alcove, Portable Imaging Equipment	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A
FA 8	RCA04	Alcove, Blanket Warmer	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A
FA 8	SRE01	Storage, Equipment	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 s:V	hw:5F

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 8	JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:PT [7] h:4'-0"	m:AT [9] f:SP	m:Wood t:1 s:U	hw:5D
FA 8	SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4
FA 8	TNPG1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]
FA 9: Inpatient Surgical Facility Support Area	XCCI1	Instrument Room	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:11 dg:F s:V	hw:5F
FA 9	LBSP2	Laboratory, Satellite	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:S	hw:4G
FA 9	LBUL1	Laboratory, Frozen Section	m:RES m:WSF	m:RES h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:S	hw:4G
FA 9	PHDS1	Pharmacy, Satellite	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC		m:GWB f:SC	m:Steel t:30 dg:T ds:YES s:U	hw:SH-3B
FA 9	MEDP2	Medication Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3D
FA 9	XVC01	Viewing Room, Picture Archiving and Communication System – PACS	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	15, S-T	hw: 4Q
FA 9	CMP02	Surgery Integration Server Room	M:SVT	m:RB h:4"	m:GWB [64] f:P		m:AT	1/2, S-T, CR	hw: SH-3H
FA 9	UCCL3	Utility Room, Surgical Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C
FA 9	RCA01	Alcove, Crash Cart	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	t:OPEN	hw:N/A
FA 9	CHS01	Cart Holding, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C
FA 9	SRGC3	Storage, Gas Cylinder	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	m:Wood t:11 dr:45 s:S	hw:5F
FA 9	UTLC2	Chute Room, Waste Disposal	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C
FA 9	UTLC3	Chute Room, Soiled Linen Disposal	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C
FA 9	JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:PT [7] h:4'-0"	m:AT [9] f:SP	m:Wood t:1 s:U	hw:5D

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 10: Inpatient Surgical Facility Staff and Administration Area	OFA09	Office, Chief of Surgical Service	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 10	OFA09	Office, Chief of Endovascular Service	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 10	OFA09	Office, Assistant Chief of Surgical Service	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 10	OFA09	Office, Assistant Chief of Endovascular Service	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 10	OFA09	Office, Anesthesiology Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 10	OFA09	Office, Assistant Chief of Anesthesiology	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E
FA 10	OFA09	Office, OR Nurse Manager	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 10	OFA09	Office, Nurse Anesthetist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 10	OFA09	Office, OR Coordinator	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 10	OFA07	Workstation, Staff Surgeon	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 10	OFA07	Workstation, Scheduler (OFA07)	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 10	OFA09	Office, Administrative Officer	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 10	OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 10	CFR01	Conference Room	m:CPT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J
FA 10	RPR01	Copier / Office Supply Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4J
FA 10	BMWS1	Workroom, Biomedical Engineer	m:EPY	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT	m:Wood t:1 dg:T s:SS	hw:10C
FA 10	DUTY1	On-Call Room	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 ds:YES s:S	hw:SH-3E

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 10	TSSU1	Toilet / Shower, On-Call Room	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:CT [7, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2
FA 10	LR005	Alcove, Scrubs Distribution	m:RES m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC		m:GWB f:SC	t: OPEN	hw: N/A
FA 10	SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4
FA 10	LR002	Locker / Changing Room, Male Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4
FA 10	TSSM1	Toilet / Shower, Male Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:CT [7, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2
FA 10	LR002	Locker / Changing Room, Female Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4
FA 10	TSSF1	Toilet / Shower, Female Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:CT [7, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2
FA 11: Inpatient Surgical Facility Education Area	OFA09	Office, Surgical Service Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 11	OFA09	Office, Endovascular Service Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 11	OFA07	Workstation, Surgical Service Residency Program Resident / Student	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 11	OFA07	Workstation, Endovascular Service Residency Program Resident / Student	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 11	CLR10	Classroom / Conference Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 12: Ambulatory Surgery Center (ASC) Reception Area	WTG08	Waiting, General	m:CPT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U m:N/A t:OPEN dg:N/A s:N/A	hw:4K hw:N/A
FA 12	WTF03	Waiting, Family	m:CPT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U m:N/A t:OPEN dg:N/A s:N/A	hw:4K hw:N/A
FA 12	RCP03	Reception / Registration	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A
FA 12	RCHK3	Kiosk, Patient Check-In	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t: OPEN	hw: N/A
FA 12	TNPG1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]
FA 12	TNPFM	Toilet, Family	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]
FA 12	CLSC1	Patient Education / Resource Kiosk	m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t: OPEN	hw: N/A
FA 12	CLSC3	Patient Education / Resource Room	m:CPT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G
FA 12	OFDC2	Consult Room	m:CPT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G
FA 12	NCWD4	Alcove, Refreshment Center	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'- 0"	m:AT	t:OPEN	hw:N/A
FA 12	SRLW1	Storage, Wheelchair / Litter	m:SVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'- 0"	m:AT	11/12, X-W	hw: 5B
FA 13: ASC Pre-Procedure Assessment Unit Area	WTG06	Waiting, Pre-Operative Assessment Unit	m:LVT	m:PRB [8]	m:GWB [54] f:P	m:RWC h:4'- 0"	m:AT	t:Sliding Glass Door dg:T s:8'-0" x 7'-0"	hw: N/A
FA 13	RCP02	Reception / Registration, Pre-Procedure Assessment Unit	m:LVT	m:PRB [8]	m:GWB [54] f:P		m:AT	t:OPEN	hw:N/A
FA 13	EXRG3	Exam Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:1Q

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 13	TPG01	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:CT [7, 44] f:SC	m:PT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]
FA 13	RCA07	Alcove, Specimen Collection	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [6, 44] f:SC	m:PT [7] h:4'-0"	m:GWB f:SC	t: OPEN	hw: N/A
FA 13	UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT [9] f:SP	11/12, V-W, PB	hw: SH-3C
FA 13	USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT [9] f:SP	11/12, V, PB	hw: SH-3C
FA 13	WRM4	Team Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT [9] f:SP	19/10, U-T	hw: 4J
FA 13	SRE01	Storage, Equipment / Clean Supply	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT [9] f:SP	11/12, V-W	hw: 5B
FA 14: ASC Pre-Operative Holding / Phase II Recovery Patient Area	LR002	Locker / Changing Room, Male Patient	m:SVT	m:RB h:4"	m:GWB [54] f:P		m:AT	1/2, S	hw: 2C
FA 14	TPG01	Toilet, Pre-Operative Holding / Phase II Recovery Male Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:CT [7, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	1/2, S	hw: 2 subscript 19
FA 14	LR002	Locker / Changing Room, Female Patient	m:SVT	m:RB h:4"	m:GWB [54] f:P		m:AT	1/2, S	hw: 2C
FA 14	TPG01	Toilet, Pre-Operative Holding / Phase II Recovery Female Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:CT [7, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	1/2, S	hw: 2 subscript 19
FA 14	RRPR1	Patient Bay, Pre-Operative Holding / Phase II Recovery	m:WSF	m:WSF h:4"	m:GWB [54] f:SC		m:AT	1/2, V-W	hw: 1D
FA 14	RRPR2	Patient Room, Pre-Operative Holding / Phase II Recovery	m:WSF	m:WSF h:4"	m:GWB [54] f:SC		m:AT	1/2, V-W	hw: 1D

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 14	TPG01	Toilet, Pre-Operative Holding / Phase II Recovery Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:CT [7, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	1/2, S	hw: 2 subscript 19
FA 14	NSTA2	Nurse Station	m:WSF	m:WSF h:4"	m:GWB [54] f:SC		m:AT	t:OPEN	hw:N/A
FA 14	WRCH1	Workroom, Provider	m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3E
FA 14	SINK1	Handwashing Station	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:CT h:4'-0"	m:AT	t:OPEN	hw:N/A
FA 14	NCWD3	Nourishment Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3C
FA 14	XVC01	Viewing Room, Picture Archiving and Communication System - PACS	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	15, S-T	hw: 4Q
FA 14	RCA01	Alcove, Crash Cart	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT f:SP	t:OPEN	hw:N/A
FA 14	LCCL3	Alcove, Clean Linen	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT f:SP	t:OPEN	hw:N/A
FA 14	XRM01	Alcove, Portable Imaging Equipment	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT	t:OPEN	hw:N/A
FA 14	UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C
FA 14	USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 ds:YES s:V	hw:SH-3C
FA 14	SRE01	Storage, Equipment	m:SVT	m:RB h:4"	m:GWB [54] f:P		m:AT	m:Wood t:11 s:V	hw:5B
FA 14	JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:PT [7] h:4'-0"	m:AT [9] f:SP	m:Wood t:1 s:U	hw:5D
FA 14	SL001	Lounge, Staff	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4
FA 14	TNPG1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 15: ASC Anesthesia Procedure Patient Area	ORPP3	Anesthesia Induction / Procedure Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	1/2, S	hw:1B
FA 15	NSTA3	Nurse Station, Anesthesia Induction / Procedure Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	t:OPEN	hw:N/A
FA 15	ANCW2	Clean Workroom, Anesthesia	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:V	hw:4K
FA 15	SRE02	Equipment Room, Anesthesia	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B
FA 15	MEDP2	Medication Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3D
FA 15	WRTM4	Team Room, Anesthesiology	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:19 dg:T s:S	hw:3G
FA 16: ASC Surgical Service Patient Area	NSTA5	Control Station	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:15 dg:T s:S m:N/A t:OPEN s:N/A	hw:4! hw:N/A
FA 16	ORGS1	Operating Room, General	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q
FA 16	ORGE1	Equipment Room, General	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V	hw:5F
FA 16	OROS1	Operating Room, Orthopedic	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q
FA 16	OROE1	Equipment Room, Orthopedic	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:T s:V	hw:5F
FA 16	ORCS1	Operating Room, Urology / Cystoscopy	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 [13] dg:T ds:YES s:SS m:Wood t:1 [13] s:X	hw:10H hw:4Q
FA 16	ORCE1	Equipment Room, Urology / Cystoscopy	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:T s:V	hw:5F

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 16	ORSA1	Scrub Sink Area	m:RES	m:RES h:4"	m:GWB f:SC	m:S [7] h:5'-0"	m:GWB f:SC	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:1M [14] hw:N/A
FA 16	SRLW2	Storage, Stretcher	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	11/12, V-W	hw: 4F
FA 17: ASC Clean Core Area	ORCC2	Clean Core, Surgical Services	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:1 dg:T s:VV	hw:10C
FA 17	ORSR1	Immediate Use Sterilization Room	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:11 dg:T s:V	hw:4C
FA 17	RCA03	Alcove, Blood Bank Refrigerator	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:11 dg:T s:V	hw:4C
FA 17	CHC01	Cart Holding, Clean	m:RES	m:RES h:4"	m:GWB f:SC		m:GWB f:SC	m:Wood t:11 dg:T s:V	hw:4C
FA 18: ASC PACU / Phase I Recovery Patient Area	RRBP1	Patient Bay, PACU / Phase I Recovery	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	t:OPEN	hw:N/A
FA 18	RRIR1	Airborne Infection Isolation (All), Patient Room, PACU / Phase I Recovery	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT [9] f:SP	t:Sliding Glass Door s:8'-0" x 7'-0"	hw:N/A
FA 18	BRAR1	Airborne Infection Isolation (All), Anteroom, PACU / Phase I Recovery	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT [9] f:SP	t:Sliding Glass Door s:8'-0" x 7'-0"	hw:N/A
FA 18	NSTA1	Nurse Station, PACU / Phase I Recovery	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC		m:AT	t:OPEN	hw:N/A
FA 18	SINK1	Handwashing Station	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:CT h:4'-0"	m:AT	t:OPEN	hw:N/A
FA 18	XVC01	Viewing Room, Picture Archiving and Communication System - PACS	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC		m:AT	15, S-T	hw: 4Q
FA 18	MEDP2	Medication Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3D
FA 18	UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C
FA 18	USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 ds:YES s:V	hw:SH-3C

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 18	RCA01	Alcove, Crash Cart	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:CT h:4'-0"	m:AT	t:OPEN	hw:N/A
FA 18	LCCL3	Alcove, Clean Linen	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:CT h:4'-0"	m:AT	t:OPEN	hw:N/A
FA 18	XRM01	Alcove, Portable Imaging Equipment	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:CT h:4'-0"	m:AT	t:OPEN	hw:N/A
FA 18	RCA04	Alcove, Blanket Warmer	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:CT h:4'-0"	m:AT	t:OPEN	hw:N/A
FA 18	SRE01	Storage, Equipment	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 s:V	hw:5F
FA 18	JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT [9] f:SP	m:Wood t:1 s:U	hw:5D
FA 18	SL001	Lounge, Staff	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4
FA 18	TNPG1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]
FA 19: ASC Support Area	XCCI1	Instrument Room	m:PT m:RES [74]	m:RES h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:GWB f:SC	15, S-V	hw:4K
FA 19	LBSP2	Laboratory, Satellite	m:PT m:RES [74]	m:RES h:4" m:WSF h:4"	m:GWB f:SC		m:GWB f:SC	1, S-T	hw:4G
FA 19	LBUL1	Laboratory, Frozen Section	m:PT m:RES [74]	m:RES h:4" m:RES h:4"	m:GWB f:SC		m:GWB f:SC	1, S-T	hw:4G
FA 19	PHDS1	Pharmacy, Satellite	m:PT m:RES [74]	m:RES h:4" m:WSF h:4"	m:GWB f:SC		m:GWB f:SC	30, U-T	hw:SH-3B
FA 19	MEDP2	Medication Room	m:WSF	m:WSF h:4"	m:GWB f:SC		m:AT f:SP	1, S-T	hw:SH-3D
FA 19	XVC01	Viewing Room, Picture Archiving and Communication System – PACS	m:RF m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [64] f:P		m:AT	15, S-T	hw: 4Q
FA 19	CMP02	Surgery Integration Server Room	m:SVT	m:RB h:4"	m:GWB [54] f:P		m:AT	1/2, S-T, CR	hw: SH-3H
FA 19	UCCL3	Utility Room, Surgical Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	11, V-F	hw:SH-3C
FA 19	RCA01	Alcove, Crash Cart	m:WSF	m:RF h:4" m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	t:OPEN	hw:N/A

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 19	CHS01	Cart Holding, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'- 0"	m:AT [9] f:SP	11, V-F	hw:5F
FA 19	SRGC3	Storage, Gas Cylinder	m:SVT	m:RB h:4"	m:GWB [54] f:P		m:AT	11, S	hw:5F
FA 19	UTLC2	Chute Room, Waste Disposal	m:SVT	m:RB h:4"	m:GWB [54] f:P		m:AT	11/12, X-F	hw:1J
FA 19	UTLC3	Chute Room, Soiled Linen Disposal	m:SVT	m:RB h:4"	m:GWB [54] f:P		m:AT	11/12, X-F	hw:1J
FA 19	JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:PT [7] h:4'-0"	m:AT [9] f:SP	m:Wood t:1 s:U	hw:5D
FA 20: ASC Staff and Administrative Area	OFA09	Office, Chief of Surgical Service	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 20	OFA09	Office, Assistant Chief of Surgical Services	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 20	OFA09	Office, Anesthesiology Chief	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 20	OFA09	Office, Assistant Chief of Anesthesiology	m:CPT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E
FA 20	OFA09	Office, OR Nurse Manager	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G
FA 20	OFA09	Office, Nurse Anesthetist	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 20	OFA09	Office, OR Coordinator	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 20	OFA07	Workstation, Staff Surgeon	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 20	OFA07	Workstation, Scheduler	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 20	OFA09	Office, Administrative Officer	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 20	OFA07	Workstation, Secretary	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A
FA 20	CFR01	Conference Room	m:CPT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J
FA 20	RPR01	Copier / Office Supply Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4J

Functional Area	Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	Hardware
FA 20	BMWS1	Workroom, Biomedical Engineer	m:RF	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:T s:SS	hw:10C
FA 20	LR005	Alcove, Scrubs Distribution	m:RF m:WSF	m:RES h:4" m:WSF h:4"	m:GWB f:SC		m:GWB f:SC	t: OPEN	hw: N/A
FA 20	SL001	Lounge, Staff	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4
FA 20	LR002	Locker / Changing Room, Male Staff	m:SVT	m:RB h:4"	m:GWB [54] f:P		m:AT	m:Wood t:1 s:S	hw:SH-4
FA 20	TSSM1	Toilet / Shower, Male Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:CT [7, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2
FA 20	LR002	Locker / Changing Room, Female Staff	m:SVT	m:RB h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4
FA 20	TSSF1	Toilet / Shower, Female Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7, 74] h:4"	m:CT [7, 44] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2

CANCELLED

Chapter **287** Digestive Diseases - Endoscopy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	4080
RECP1	Reception / Check-In	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5]		m:AT	t:OPEN	hw:N/A	4081
RECP4	Kiosk, Patient Check-In	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4082
CLSC1	Patient Education / Resource Kiosk	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4083
CLSC3	Patient Education / Resource Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64]		m:AT	m:Wood t:19 dg:T s:V	hw:3G	4084
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	4085
TLTF3	Toilet, Family	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2H [71]	4086
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2G [71] hw:4B [31]	4087

Chapter 287 Digestive Diseases - Endoscopy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
TREE1	Procedure Room, Endoscopy	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:1 s:X	hw:4M	4088
TREE2	Procedure Room, ERCP/Endoscopic Ultrasound	m:WSF	m:WSF h:4"	m:GWB [64] f:SC		m:AT f:SP	m:Wood t:1 s:X	hw:4P	4089
EXRG0	Exam / Assessment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1Q	4090
RCA02	Alcove, Equipment	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4091
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4092
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2C [71]	4093
FA3: Prep and Recovery Area									
RRSS1	Prep / Recovery Room	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:19 s:S	hw:1B	4094
RROP1	Cubicle, Prep / Recovery	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4095
TLTU1	Toilet, Prep / Recovery Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H	4096

Chapter 287 Digestive Diseases - Endoscopy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Prep and Recovery Area									
NSTA3	Nurse Station	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4097
NCWD4	Alcove, Refreshment Center	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4098
RCA01	Alcove, Crash Cart	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4099
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:SH-3C	4100
FA4: Support Area									
MEDP1	Medication Area	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1	hw:SH-3D	4101
USCL2	Decontamination Room, Scope	m:WSF	m:WSF h:4"	m:GWB f:SC	m:S [7] h:5'-0"	m:AT f:SP	m:Wood t:1 dg:F s:V	hw:4K	4102
USCL3	Reprocessing Room, Scope	m:WSF	m:WSF h:4"	m:GWB f:SC	m:S [7] h:5'-0"	m:AT f:SP	m:Wood t:1 dg:F s:V	hw:4K	4103
USCL4	Storage, Clean Scope	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:1 dg:F s:V	hw:4K	4104
SRS04	Storage, Sterile	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:V	hw:SH-3C	4105
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:SH-3C	4106
UCCL1	Utiity Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:V	hw:SH-3C	4107

Chapter 287 Digestive Diseases - Endoscopy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Support Area									
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	4108
LCCL1	Alcove, Clean Linen	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4109
SRLW1	Alcove, Wheelchair / Stretcher	m:LVT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4110
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	4111
FA5: Staff and Administrative Area									
OFA09	Office, Digestive Diseases - Endoscopy Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4112
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	4113
OFA07	Workstation, Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4114
OFA07	Workstation, Physician Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4115
OFA09	Office, Nurse Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4116
OFA07	Workstation, Nurse Practitioner	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4117

Chapter 287 Digestive Diseases - Endoscopy Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Staff and Administrative Area									
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4118
RPR01	Copier / Printer Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4J	4119
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	4120
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4121
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	4122
FA6: Education Area									
OFA09	Office, Residency Program Director [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4123
OFA07	Workstation, Intern / Resident / Fellow	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4124
CLR01	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	4125

Chapter 290 Voluntary Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
RECP1	Reception / Secretary	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:4G hw:N/A	4126
RECP4	Volunteer Sign-in	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	4127
FA2: Staff and Administrative Area									
OFA09	Office, Voluntary Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4128
OFA09	Office, Voluntary Service Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4129
OFA07	Workstation, Voluntary Service Officer	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4130
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4131
FA3: Volunteer Area									
OFA07	Workstation, VAVS Organization	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4132
CRA01	Multipurpose Workroom	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V m:Wood t:1 s:SS	hw:4F hw:10C	4133

Chapter **290** Voluntary Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Volunteer Area									
SL002	Volunteer Lounge	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	4134
FA4: Support Area									
SRS01	Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V m:Wood t:11 s:SS	hw:5 hw:11	4135

Chapter 300 Day Hospital

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	4136
NSTA1	Communication Center	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	4137
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	4138
FA2: Patient Area									
EXRG3	Exam Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1Q	4139
TRGM1	Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1Q	4140
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	4141
OPMH1	Group Therapy Room	m:CPT [6]	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:4L	4142
FSCD1	Activities / Dining Room	m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 s:SS	hw:12H	4143
SRS01	Storage, Activities / Dining	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:V	hw:5	4144

Chapter 300 Day Hospital

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
DAYR1	Quiet Room	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 s:U	hw:4N	4145
MEDP1	Storage, Medication	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 ds:YES s:S	hw:SH- 3C	4146
NCWD1	Nourishment Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 s:S	hw:4K	4147
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2H	4148
FA3: Staff and Administrative Area									
OFA09	Office, Day Hospital Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4149
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4150
OFDC1	Office, Psychiatrist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4151
OFDC1	Office, Psychologist	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3G	4152
OFDC1	Office, Social Worker	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3G	4153

Chapter **300** Day Hospital

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Staff and Administrative Area									
OFA07	Workstation, Resident Trainee	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4154
OFA07	Workstation, Rehabilitation Therapist	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4155
OFA07	Workstation, Nurse	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4156
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	4157
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4158
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	4159
FA4: Education Area									
CRA02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	4160

Chapter 308 Prosthetics and Sensory Aids Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4G	4161
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4G	4162
CLSC1	Patient Education Kiosk / Alcove	m:CPT [6] m:LVT	m:PRB [8]	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4163
TLTU1	Public Toilet	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	4164
FA2: Patient Area									
EXRG3	Fitting / Exam Room, Soft Goods Fabrication	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1F	4165
EXRG3	Fitting / Exam Room, Custom Fabrication	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:V	hw:1F	4166
EXRG3	Dynamic Alignment Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:V	hw:1F	4167
DR001	Dressing Room	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:2H [71]	4168

Chapter 308 Prosthetics and Sensory Aids Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:U	hw:2H [71]	4169
EYPL1	Eye Fitting Studio	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:U	hw:4E	4170
APFR1	Facial / Body Fitting Studio	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:X	hw:4N	4171
APFB1	Laboratory, Restoration	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:U	hw:4N	4172
TROR1	Team Evaluation/Multi-purpose Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:V	hw:4E	4173
OPCR1	Cast Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:U	hw:4N	4174
FA3: Support Area									
SRSE1	Clean Supply Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH- 3C	4175
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	4176
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:T s:S	hw:5D	4177

Chapter 308 Prosthetics and Sensory Aids Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Support Area									
APLA1	Laboratory, Prosthetic and Orthotic Fume Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:U	hw:4N	4178
UTC01	Trash / Recycling Room Prosthetic and Orthotic	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	4179
APMS1	Laboratory, Prosthetic and Orthotic Dust Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:U	hw:4N	4180
APFB1	Laboratory, Prosthetic and Orthotic Work Station	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:U	hw:4N	4181
BMC01	Laboratory, Prosthetic and Orthotic Maintenance Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:U	hw:4N	4182
SRCS1	Storage, Shoe Modification Materials	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:U	hw:5B	4183
BMCW1	Workspace, Wheelchair Repair	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:F s:V	hw:4E	4184
SRE01	Storage, Wheelchair Active	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:F s:S	hw:4E	4185
SRE01	Storage, Dirty Wheelchair / DME Active	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:F s:S	hw:4E	4186
SRPS1	Storage, Wheelchair Parts	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:F s:S	hw:4E	4187
APLA1	Computer Aided Design / Computer Aided Manufacturing	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4E	4188

Chapter 308 Prosthetics and Sensory Aids Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Support Area									
APSH1	Sewing Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4E	4189
SRLW1	Storage, Stretcher / Wheelchair	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:F s:S	hw:4E	4190
SRPS1	Storage, Orthotics and Prosthetic Parts / Materials Storage	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:F s:S	hw:5D	4191
MRRS1	Prosthetic Appliance Mailing Area	m:VT	m:RB h:4"	m:GWB [54] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:5D	4192
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	4193
FA4: Staff and Administrative Area									
OFA09	Office, Prosthetic and Sensory Aids Service Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4194
OFA09	Office, Prosthetic and Sensory Aid Service Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4195
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	4196
OFA07	Workstation, Purchasing Agent	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4197
OFA07	Workstation, Restoration Clinic	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4198

Chapter 308 Prosthetics and Sensory Aids Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Staff and Administrative Area									
OFA07	Workstation, Orthotic Lab Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4199
CRA01	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	4200
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	4201
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4202
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	4203
FA5: Education Area									
CRA02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	4204

Chapter 312 Domiciliary

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA1: Domiciliary Patient Care Unit Calculation

CALC1	Number of Patient Care Units								4205
-------	------------------------------	--	--	--	--	--	--	--	------

FA2: Reception Area

RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:GWB f:P	m:Wood t:1 s:S	hw:4G	4206
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	4207
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	4208

FA3: Patient Care Unit Patient Area

WRC01	Waiting, Public	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 s:U	hw:4K	4209
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	4210
DAYR1	Lounge, Patient	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	4211
BRUN1	Bedroom, One-Bed Addiction Treatment Program	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:H	hw:R1	4212

Chapter 312 Domiciliary

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Patient Care Unit Patient Area									
BRUN1	Bedroom, Two-Bed Addiction Treatment Program	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:H	hw:R1	4213
BRUN1	Bedroom, One-Bed Domiciliary Homeless Program	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:H	hw:R1	4214
BRUN1	Bedroom, Two-Bed Domiciliary Homeless Program	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:H	hw:R1	4215
BRUN1	Bedroom, One-Bed Health Maintenance Program	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:H	hw:R1	4216
BRUN1	Bedroom, Two-Bed Health Maintenance Program	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:H	hw:R1	4217
BRUN1	Bedroom, One-Bed Post-Traumatic Stress Disorder Residential Rehabilitation Program	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:H	hw:R1	4218
BRUN1	Bedroom, Two-Bed Post-Traumatic Stress Disorder Residential Rehabilitation Program	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:H	hw:R1	4219
BRUN1	Bedroom, One-Bed Traumatic Brain Injury Program	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:H	hw:R1	4220
TLTS2	Bathroom, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC m:AT	m:Wood t:19 s:U	hw:2H	4221

Chapter 312 Domiciliary

FA3: Patient Care Unit Patient Area

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
BRNP1	Bedroom, Bariatric Patient	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:X	hw:R7A	4222
TLTS2	Bathroom, Bariatric Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC m:AT	m:Wood t:1 s:X	hw:R3	4223
XXYYC	Multiple Living Unit: Sleeping Area	m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 ds:YES s:X	hw:4E	4224
IPK01	Multiple Living Unit: Living / Dining / Kitchenette	m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:R2A	4225
TLTS2	Multiple Living Unit: Bathroom	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 44, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC m:AT	m:Wood t:19 s:X	hw:R3	4226
CMP01	Computer Room	m:SVT f:SD m:AF f:SD	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:U	hw:4E	4227
RAMR1	Quiet Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 s:H	hw:4E	4228
IPK01	Multipurpose Room / Kitchenette	m:LVT	m:PRB [8] h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:H	hw:R4	4229

Chapter 312 Domiciliary

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Patient Care Unit Patient Area									
NULR1	Laundry Room	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:H	hw:R2B	4230
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	4231
FA4: Patient Care Unit Support Area									
OFA07	Workstation, Domiciliary Health Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4232
SRS01	Storage, General	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:VV m:Wood t:11 s:U	hw:11 hw:5	4233
SRPB1	Storage, Patient Clothing and Luggage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:U	hw:5B	4234
LCCL1	Clean Linen Room	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 ds:YES s:V	hw:SH- 3C	4235
LCSL1	Collection Room, Linen	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 ds:YES s:V	hw:SH- 3C	4236
LCSL1	Chute Room, Linen Disposal	m:RES	m:RES [7] h:4"	m:GWB f:SC	m:SS h:4'- 0"	m:AT [9] f:SP	m:Wood t:11 da:YES ds:YES s:K m:Steel t:12 da:YES ds:YES s:K	hw:1E	4237
UTC01	Collection Room, Trash	m:RES	m:RES [7] h:4"	m:GWB f:SC	m:SS h:4'- 0"	m:AT [9] f:SP	m:Wood t:11 da:YES ds:YES s:K m:Steel t:12 da:YES ds:YES s:K	hw:1E	4238

Chapter 312 Domiciliary

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Patient Care Unit Support Area									
UTC01	Chute Room, Trash Disposal	m:RES	m:RES [7] h:4"	m:GWB f:SC	m:SS h:4'-0"	m:AT [9] f:SP	m:Wood t:11 da:YES ds:YES s:K m:Steel t:12 da:YES ds:YES s:K	hw:1E	4239
UTC01	Recycling Area	m:VT	m:RB h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:9 s:S m:Steel t:1 s:S	hw:SH-3C	4240
COMC1	Data and Telecommunications Room	m:VT	m:RB h:4"	m:GWB [34] f:P		m:AT	m:Wood t:1 ds:YES s:X	hw:SH-3D	4241
FA5: Core Area Staff and Administration Area									
OFA09	Office, Domiciliary Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4242
OFA09	Office, Clinical Coordinator [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4243
OFA07	Workstation, Section Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4244
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4245
OFA07	Workstation, Provider	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4246
OFD03	Office, Dietician	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4247

Chapter 312 Domiciliary

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA5: Core Area Staff and Administration Area									
OFA07	Workstation, Recreational Therapist	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4248
OFA07	Workstation, Kinesiotherapist	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4249
OFA07	Workstation, Occupational Therapist	m:CPT [6] m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4250
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	4251
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4252
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2G [71] hw:4B [31]	4253
FA6: Core Area Patient Services									
CRA02	Patient Education / Conference / Group Room	m:LVT	m:PRB [8]	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:V	hw:4N	4254
BX001	Vending Area	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4255
FSCD1	Dining Room	m:LVT	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:1 s:SS	hw:12	4256

Chapter 312 Domiciliary

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA6: Core Area Patient Services

DAYR1	Recreation / Therapy Room	m:LVT	m:PRB [8]	m:GWB [42, 64] f:P		m:AT	m:Wood t:1 da:YES s:SS	hw:10A	4257
PTEA1	Physical Therapy Room	m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:1 s:X	hw:4N	4258
OTDL1	Occupational Therapy Room	m:LVT	m:PRB [8]	m:GWB [64] f:P		m:AT	m:Wood t:1 s:X	hw:4N	4259
CRA01	Job Development and Vocational Skill Center	m:LVT	m:RB h:4"	m:GWB [42] f:P		m:AT	m:Wood t:1 s:X	hw:4N	4260

FA7: Core Area Patient Nutrition and Food Service

OFD03	Office, Dietician	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4261
FSSL1	Serving Unit	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:SS	hw:10C	4262
FSCS1	Bulk Food Carts	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:V	hw:4N	4263
SRS01	Non-food Storage	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 s:U	hw:5B	4264

FA8: Core Area Support

SRS01	Storage, Recreation Therapy	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:V	hw:5D	4265
SRS01	Storage, Physical Therapy	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:X	hw:4N	4266

Chapter 312 Domiciliary

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA8: Core Area Support									
SRS01	Storage, Occupational Therapy	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 s:V	hw:4N	4267
SRS01	Storage, Environmental Management	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V	hw:5B	4268
SRS01	Storage, Building Management	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:U	hw:5B	4269
FA9: Medical Clinic Area									
TRGM1	Exam / Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:S	hw:1F	4270
MEDP1	Medication Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 ds:YES s:S	hw:SH- 3D	4271
OFA07	Workstation, Nurse Coordinator	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	4272

Chapter 316 Dialysis Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Reception Area									
WRC01	Waiting	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U	hw:4K	4273
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	m:Wood t:3 dg:T s:U	hw:3E	4274
TLTU1	Toilet, Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:S	hw:2G [71] hw:4B [31]	4275
FA2: Patient Area									
XXYYC	Renal Dialysis, Private Bed Station	m:WSF	m:WSF h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:X	hw:1F	4276
RDC02	Renal Dialysis, Isolation Negative Pressure Bed Station	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:SC		m:GWB f:P m:AT [9] f:SC	m:Wood t:3 [12] s:X	hw:4E	4277
RDC01	Renal Dialysis, Cubicle Chair Station	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4278
XXYYC	Renal Dialysis, Cubicle Bed Station	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4279
TRGM1	Exam / Treatment Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:1L	4280

Chapter 316 Dialysis Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2: Patient Area									
EXRG3	Exam Room, Transplant Follow-up	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 s:X	hw:1L	4281
OFDC2	Consult Room	m:CPT [6]	m:PRB [8]	m:GWB [5, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:3G	4282
RDC01	Training Room, Dialysis	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:X	hw:4J	4283
TLTU1	Toilet, Patient	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2H [71]	4284
TLTU1	Toilet, Patient, Private	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2H [71]	4285
TLTU1	Toilet, Patient Isolation	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 18, 64] f:SC	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:1 s:S	hw:2H [71]	4286
LR001	Locker Room, Patient	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4287
FA3: Support Area									
USCL1	Utility Room, Soiled	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:F dr:45 min ds:YES s:V	hw:SH- 3C	4288

Chapter 316 Dialysis Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Support Area									
UCCL1	Utility Room, Clean	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:V	hw:SH-3C	4289
SRS01	Storage, Clean Supply	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:V	hw:4F	4290
SRSE1	Storage, Sterile Supply	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:V	hw:4F	4291
LCCL1	Storage, Clean Linen	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F s:U	hw:4F	4292
SRSE1	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V m:N/A t:OPEN s:N/A	hw:4F hw:N/A	4293
NCWD1	Nourishment Station	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	4294
MEDP1	Medication Preparation Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T ds:YES s:S	hw:SH-3C	4295
RCA01	Alcove, Crash Cart	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4296
LMCH1	Laboratory, Biochemistry	m:WSF m:RES	m:WSF h:4" m:RES [7] h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:F s:V	hw:4K	4297

Chapter 316 Dialysis Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Support Area									
LBVP1	Laboratory, Venipuncture	m:WSF m:RES	m:WSF h:4" m:RES [7] h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:4K	4298
CSDE1	Equipment Processing, Soiled Receiving	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9]	m:Wood t:11 dg:T s:X	hw:4F	4299
CSSS1	Equipment Processing, Clean Preparation	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:1 dg:T s:X	hw:4F	4300
CSIA1	Equipment Processing, Clean Storage	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:1 dg:F s:X	hw:4F	4301
BMER1	Equipment Processing, Repair Shop	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:1 dg:T s:X	hw:4F	4302
MEDP1	Dialysate Preparation Room	m:WSF m:RES	m:WSF h:4" m:RES [7] h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:V	hw:4F	4303
RDWT1	Water Treatment Room	m:WSF m:RES	m:WSF h:4" m:RES [7] h:4"	m:GWB f:SC		m:AT f:SP	m:Wood t:1 dg:T s:V	hw:4F	4304
SRLW1	Alcove, Wheelchair / Stretcher	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4305
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	4306

Chapter 316 Dialysis Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Staff and Administrative Area									
NSTA1	Nurse Station	m:WSF	m:WSF h:4"	m:GWB [42] f:P		m:AT	t:OPEN	hw:N/A	4307
OFA09	Office, Dialysis Center Chief	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4308
OFA09	Office, Dialysis Center Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4309
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	4310
OFA07	Workstation, Physician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4311
OFA07	Workstation, PA / Resident / Intern	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4312
OFA09	Office, Chief Nurse [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4313
OFA07	Workstation, Chemist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4314
OFA07	Workstation, Dietician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4315
OFA07	Workstation, Social Worker	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4316
OFA07	Workstation, Education Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4317

Chapter 316 Dialysis Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Staff and Administrative Area									
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4318
OFA07	Workstation, Assistant Chemist	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4319
OFA07	Workstation, Assistant Dietician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4320
OFA07	Workstation, Assistant Education Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4321
OFA07	Workstation, Dialysis Lead Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4322
OFA07	Workstation, Student / Trainee	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4323
OFA07	Workstation, Dialysis Support Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4324
OFA07	Workstation, Lab Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4325
CRA02	Conference Room	m:CPT [6]	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	4326
CLR01	Classroom	m:CPT m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	4327
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	4328

Chapter 316 Dialysis Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Staff and Administrative Area									
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4329
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4B [31]	4330
FA5: Education Area									
OFA09	Office, Residency Program Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4331
SL002	Team Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:3G	4332
CRA02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	4333

Chapter 400 Library Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Health Sciences Library Circulation Area									
LIBD1	Circulation Desk Area	m:CPT [6]	m:RB h:4"	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	4334
OFA10	Computer Reference Station	m:CPT [6]	m:RB h:4"	m:GWB [42] f:P		m:AT	t:OPEN	hw:N/A	4335
LIBD1	Card Catalog	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4336
LIBV1	Audiovisual Room	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4N	4337
CLR03	Computer Training Lab	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	4338
CRA03	Media Conference Room	m:CPT [6]	m:PRB [8]	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:U	hw:4J	4339
RPR01	Photocopy / Microfilm Reader-Printer Area	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4340
LIBS1	Seating Area	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	4341
FA2: Health Sciences Library Shelving Area									
LIBP1	Current Periodicals	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4342
LIBP1	Bound Periodicals	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4343
LIBP1	Microfilm	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4344

Chapter 400 Library Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA2: Health Sciences Library Shelving Area

LIBP1	Monograph Collection	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4345
LIBP1	Basic Reference Collection	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4346

FA3: Patient Education Resource Center (PERC)

LIBD1	Circulation Desk Area	m:CPT [6]	m:RB h:4"	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	4347
LIBP1	Shelving	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4348
LIBP1	Reference Area	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4349
LIBS1	Seating Area	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	4350
OFA10	Computer Reference Station	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4351
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:S	hw:5	4352

FA4: Staff and Administrative Area

OFA09	Office, Health Science Library Chief	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4353
OFA07	Workstation, Clerical / Technician / Librarian	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	t:OPEN	hw:N/A	4354

Chapter 400 Library Service

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Staff and Administrative Area									
OFA10	Printer Station	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4355
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	4356
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4357
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	4358
FA5: Support Area									
SRS01	Storage, Audiovisual Equipment	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5B	4359
WRCH1	Workroom	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4N	4360

Chapter 402 Educational Facilities

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Staff and Administrative Area									
OFA07	Workstation, Designated Learning Officer (DLO)	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4361
OFA09	Office, Educational Facilities Associate Chief of Staff (ACOS)	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4362
OFA09	Office, Employee Education Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4363
OFA07	Workstation, Education Administrative Assistant	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4364
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	4365
OFA07	Workstation, Educator / Instructor	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4366
OFA07	Workstation, Workforce Development Coordinator	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4367
OFA07	Workstation, High Performance Development Coordinator (HPDM)	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4368
OFA07	Workstation, Education Technician	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4369
CRA02	Conference Room	m:CPT [6] m:LVT	m:RB h:4" m:PRB [8] h:N/A	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	4370

Chapter 402 Educational Facilities

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Staff and Administrative Area									
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P			m:Wood t:1 dg:T s:V	hw:5E	4371
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	4372
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4373
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	4374
FA2: Nursing Education and Training Area									
OFA09	Office, Associate Chief for Nursing Education [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4375
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	4376
OFA07	Workstation, Nursing Instructor	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4377
CLR02	Conference Room / Classroom	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	4378
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V	hw:5E	4379

Chapter 402 Educational Facilities

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Education Auditorium Area									
AUD01	Educational Auditorium [35]	m:[35]	m:[35]	m:[35]	m:[35]	m:[35]		hw:12F	4380
AUD01	Stage or Instruction Area [35]	m:[35]	m:[35]	m:[35]	m:[35]	m:[35]		hw:N/A	4381
XXYYC	Media Control Room [35]	m:[35]	m:[35]	m:[35]	m:[35]	m:[35]			4382
SRE01	Storage, Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:F s:V	hw:5E	4383
SRS02	Storage, Moveable Furniture	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:1 dg:F s:V	hw:5E	4384
CRA02	Multipurpose Room	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 da:ADO dg:T s:SS	hw:12H	4385
TLTM2	Toilet, Male Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2 [71] hw:4B [31]	4386
TLTF2	Toilet, Female Public	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:19 s:U	hw:2 [71] hw:4B [31]	4387
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	4388
FA4: Education Laboratory Area									
CMP01	Computer Lab	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4E	4389

Chapter **402** Educational Facilities

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Education Laboratory Area									
CRA02	Video Conference Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 s:S	hw:4J	4390
CLR07	Simulation Lab	m:LVT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:4J	4391

31

CANCELLED

Chapter 406 Environmental Management Service (EMS) Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Staff and Administrative Area									
OFA09	Office, EMS Chief	m:CPT	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4392
SEC01	Secretary / Waiting	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S m:N/A t:OPEN s:N/A	hw:3E hw:N/A	4393
OFA09	Office, EMS Assistant Chief [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4394
OFA09	Office, Supervisor	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4395
OFA07	Workstation, Clerical	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4396
FA2: Support Area									
SRSE1	Storage, Environmental Management Supplies and Large Equipment	m:VT	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:V	hw:4K	4397
LCCL1	Distribution Room, Clean Linen	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:11 dg:F ds:YES s:SS	hw:SH-9A	4398
LCSL1	Collection Room, Soiled Linen	m:WSF	m:WSF h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dg:T dr:45 min ds:YES s:SS	hw:SH-9A	4399
UTC01	Trash Collection	m:RES	m:RES [7] h:4"	m:CT [7] m:CMU f:SC		m:EXP	m:Wood t:1 s:X	hw:5F	4400

Chapter **406** Environmental Management Service (EMS) Administration

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA2:. Support Area									
SRPB1	Storage, Patient Personal Items	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5	4401

10

CANCELLED

Chapter 408 Environmental Management Service Laundry and Linen Operation

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Staff and Administrative Area									
OFA09	Office, Laundry Plant Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4402
OFA09	Office, Assistant Plant Manager [2]	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:3E	4403
OFA07	Workstation, Secretary	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4404
BX001	Vending Area	m:LVT	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4405
CRA02	Conference Room / Training Room	m:CPT [6] m:LVT	m:RB h:4"	m:GWB [42, 64] f:P		m:AT	m:Wood t:19 dg:T s:U	hw:4J	4406
SRSE1	Storage, Supplies	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:11 dg:F s:V	hw:5	4407
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:SH-4	4408
LR001	Locker Room, Staff	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4409
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	4410
JANC1	Housekeeping Aides Closet (HAC)	m:QT	m:QT [7] h:4"	m:GWB f:SC	m:CT [7] h:4'-0"	m:AT f:SP	m:Wood t:1 s:U	hw:5D	4411

Chapter 408 Environmental Management Service Laundry and Linen Operation

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Production Area									
LCSL1	Receiving	m:EPY	m:RB h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:GWB f:SC	t:OPEN	hw:N/A	4412
LCSL1	Sorting and Washing	m:RES	m:RES [7] h:4"	m:GWB [7] f:SC		m:GWB f:SC	t:OPEN	hw:N/A	4413
LCCL1	Storage, Linen	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 dg:F s:SS m:Steel t:12 s:SS	hw:10	4414
LCSL1	Central Liquid Supply System	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:V m:Steel t:12 s:V		4415
CWSH2	Cart Washer	m:RES	m:RES [7] h:4"	m:CT [7, 54]		m:GWB f:SC	t:OPEN	hw:N/A	4416
LCCL1	Clean Linen Processing	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4417
LCFA1	Clean Linen Holding and Assembly	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	t:OPEN	hw:N/A	4418
LCCL1	Distribution Cart Storage / Dispatch	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:GWB f:P	t:OPEN	hw:N/A	4419
CSCQ1	Linen Pack Preparation	m:WSF	m:WSF h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:GWB	m:Wood t:1 dg:T s:V m:Steel t:2 s:V	hw:4K	4420
LCS01	Linen Repair	m:WSF	m:WSF h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:V m:Steel t:2 s:V	hw:4K	4421

Chapter 408 Environmental Management Service Laundry and Linen Operation

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Medical Center Linen Support Area									
LCFA1	Linen Chute Collection	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB [54] f:P	m:SS h:4'- 0"	m:AT	m:Wood t:7 dg:T s:V m:Steel t:7 s:V	hw:1J	4422
LCSL1	Soiled Linen Cart Staging	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT [9] f:SP	m:Wood t:11 dr:45 min s:SS m:Steel t:12 dr:45 min s:SS	hw:10	4423
LCCL1	Storage, Clean Linen Cart	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB [54] f:P	m:RWC h:4'-0"	m:AT	m:Wood t:11 s:SS m:Steel t:12 s:SS	hw:10	4424
LCUC1	Uniform Exchange	m:WSF m:RES	m:WSF h:4" m:RES h:4"	m:GWB [54] f:SC	m:RWC h:4'-0"	m:AT f:SP	m:Wood t:1 s:V m:Steel t:1 s:V m:N/A t:OPEN s:N/A	hw:4K hw:N/A	4425

Chapter **410** Environmental Management Service Lockers, Lounges, Toilets, and Showers

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA1: Locker Area									
LR002	Locker Room	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4426
LOB02	Vestibule, Locker Room	m:PT	m:PT h:4"	m:GWB f:SC		m:AT	m:Wood t:1 s:S	hw:SH-4	4427
FA2: Lounge Area									
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	4428
FA3: Toilet and Shower Area									
TLTS1	Toilet / Shower, Male	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:CT	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2	4429
TLTS1	Toilet / Shower, Female	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:CT	m:PT [7] h:4'-0" m:CT [7] h:4'-0" m:S [7, 44]	m:GWB f:SC	m:Wood t:1 s:S	hw:2	4430

Chapter **420** Childcare / Development Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
--------	------------	-------	------	------	------	---------	------	-------	----

FA1: Reception Area

LOB01	Entry / Lobby	m:TT m:LVT	m:TT m:PRB [8] h:N/A	m:GWB [5] f:P		m:AT	m:Wood t:1 dg:T s:S	hw:4G	4431
RECP1	Reception	m:CPT [6] m:LVT	m:PRB [8]	m:GWB [5] f:P		m:AT	t:OPEN	hw:N/A	4432

FA2: Staff and Administrative Area

OFA09	Office, Childcare / Development Center Director	m:CPT [6]	m:RB h:4"	m:GWB [64] f:P		m:AT	m:Wood t:19 dg:T s:S	hw:3G	4433
OFA07	Workstation, Administration	m:CPT [6]	m:RB h:4"	m:GWB f:P		m:AT	t:OPEN	hw:N/A	4434
SL001	Lounge, Staff	m:SVT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:S	hw:SH-4	4435
TLTU1	Toilet, Staff	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT	m:Wood t:1 s:S	hw:2 [71] hw:4U [31]	4436
SRS01	Storage Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:F s:X	hw:5D	4437

FA3: Child Care Area

XXYYC	Infant Activity / Support Area	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4G	4438
-------	--------------------------------	-------	--------------	-----------	--	------	----------------	-------	------

Chapter 420 Childcare / Development Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA3: Child Care Area									
XXYYC	Infant Crib Area	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:V	hw:4G	4439
XXYYC	Pre-Toddler Activity / Support Area	m:LVT	m:PRB [8]	m:GWB [42] f:P		m:AT	m:Wood t:1 s:V	hw:4G	4440
XXYYC	Pre-Toddle Crib Area	m:LVT	m:PRB [8]	m:GWB f:P		m:AT	m:Wood t:1 s:S	hw:4G	4441
XXYYC	Toddler Activity / Support Area	m:LVT	m:PRB [8]	m:GWB [42] f:P		m:AT	m:Wood t:1 s:V	hw:4G	4442
XXYYC	Pre-School Activity / Support Area	m:LVT	m:PRB [8]	m:GWB [42] f:P		m:AT	m:Wood t:1 s:V	hw:4G	4443
XXYYC	School-age Activity / Support Area	m:LVT	m:PRB [8]	m:GWB [42] f:P		m:AT	m:Wood t:1 s:V	hw:4G	4444
NYIR1	Isolation Room [18]	m:WSF	m:WSF h:4"	m:GWB [18, 64] f:P		m:GWB f:SC m:AT [9] f:N/A	m:Wood t:3 [12] s:X	hw:4E	4445
TLTU1	Toilet, Isolation [18]	m:PT m:RES [74]	m:PT [7] h:4" m:RES [7] h:4"	m:GWB [7, 18, 64] f:P	m:PT [7] h:4'-0" m:CT [7] h:4'-0"	m:GWB f:SC	m:Wood t:3 [12] s:X	hw:4E	4446
FA4: Support Area									
FSCD1	Food Service	m:RES	m:RES [7] h:4"	m:CT [7]		m:AT f:SP	m:Wood t:1 s:S	hw:4K	4447

Chapter **420** Childcare / Development Center

Rm Cde	Space Name	Floor	Base	Wall	Wain	Ceiling	Door	HW Nr	ID
FA4: Support Area									
NULR1	Laundry Room	m:VT	m:RB h:4"	m:GWB f:P		m:AT	m:Wood t:1 dg:T s:U	hw:4K	4448
JANC1	Housekeeping Aides Closet (HAC)	m:QT m:QT	m:QT [7] h:4" m:QT [7] h:4"	m:GWB f:SC m:GWB f:SC	m:CT [7] h:4'-0" m:CT [7] h:4'-0"	m:AT f:SP m:AT f:SP	m:Wood t:1 s:U m:Wood t:1 s:U	hw:5D hw:5D	4449

19

3,449

CANCELLED