Ellsworth AFB IFS
20 FEBRUARY 2025

ELLSWORTH AIR FORCE BASE INSTALLATION FACILITIES STANDARDS (IFS)


Installation Elements


Site Development


Facilities Exteriors


Facilities Interiors

APPROVED FOR PUBLIC RELEASE; DISTRIBUTION UNLIMITED

Signature Field KOHLHEPP.DAVID.A.1270111226 Digitally signed by KOHLHEPP.DAVID.A.1270111226
Date: 2025.03.31 16:28:25 -06'00'

AIR FORCE INSTALLATION FACILITIES STANDARDS

2025

Ellsworth Air Force Base IFS

Table of Contents

A. OVERVIEW 5
A01. Facility Hierarchy 6
A02. Facility Quality 6
A03. Facility Districts 6
B. INSTALLATION ELEMENTS 8
B01. Comprehensive Planning 8
B01.1. Installation Development Plan (IDP) 8
B01.1.1. IFS Requirements and Documents
B01.1.2. Brief History of Base
B01.1.3. Future Development
B02. Street Envelope Standards 11
B02.1. Hierarchy of Streets 12
B02.1.1. Arterial Streets
B02.1.2. Collector Streets
B02.1.3. Local Streets
B02.1.4. Special Routes
B02.2. Hierarchy of Intersections 16
B02.2.1. Arterials
B02.2.2. Arterial/Collector
B02.2.3. Collectors
B02.2.4. Special Intersections
B02.2.5. Street Frontage Requirements
B02.2.6. Sight Lines
B02.3. Street Elements 19
B02.3.1. Paving
B02.3.2. Curb and Gutter
B02.3.3. Utility Service Elements
B02.3.4. Traffic Signs
B02.3.5. Street Lighting
B02.3.6. Other
B03. Open Space / Public Space 22
B03.1. Plazas, Monuments and Static Displays 22
B03.1.1. Paved Plazas
B03.1.2. Sculptures, Markers and Statuary
B03.1.3. Static Display of Aircraft
B03.2. Grounds and Perimeters 24
B03.2.1. Parade Grounds
B03.2.2. Parks
B03.2.3. Preserves
B03.2.4. Perimeter Fence
C. SITE DEVELOPMENT 28
C01. Site Design 28
C01.1. Site Design Considerations 28
C01.2. Building Orientation 29
C02. Utilities 30
C02.1. Utility Components 30
C03. Parking Areas 31
C03.1. Configurations and Design 31
C03.1.1. Paving and Striping
C03.1.2. Curbing
C03.1.3. Internal Islands and Medians
C03.2. Parking Structures 34
C03.3. Connectivity 35
C04. Stormwater Management 35
C04.1. Stormwater Requirements 35
C05. Sidewalks, Bikeways and Trails 36
C05.1. Circulation and Paving 36
C05.1.1. Ramps and Stairs
C05.1.2. Lighting
C06. Landscape 39
C06.1. Climate-based Materials 39
C06.1.1. Landscape Design Concept
C06.1.2. Xeriscape Design Principles
C06.1.3. Minimizing Water Requirements
C06.1.4. Plant Material Selection
C06.1.5. Water Budgeting (Hydrozones)
C06.1.6. Base Entrance Landscaping
C06.1.7. Streetscape Landscaping
C06.1.8. Pedestrian Circulation Landscaping
C06.1.9. Parking Lot Landscaping
C06.1.10. Screen/Accent Landscaping
C06.1.11. Other
C07. Site Furnishings 46
C07.1. Furnishings and Elements 46

Table of contents continued on next page

C07.2. Site Furnishings Products, Materials / Color .. 48
C07.2.1. Barbeque Grills
C07.2.2. Benches
C07.2.3. Bike Racks
C07.2.4. Bike Lockers
C07.2.5. Bollards
C07.2.6. Bus Shelters
C07.2.7. Drinking Fountains
C07.2.8. Dumpster Enclosures / Gates
C07.2.9. Fencing
C07.2.10. Flagpoles
C07.2.11. Lighting – Landscape / Accent
C07.2.12. Litter and Ash Receptacles
C07.2.13. Picnic Tables
C07.2.14. Planters – Free Standing
C07.2.15. Play Equipment
C07.2.16. Screen Walls
C07.2.17. Tree Grates
C07.2.18. Other
C08. Exterior Signs 61
C08.1. Colors and Types 61
C08.1.1. Materials and Color Specifications
C08.1.2. Installation and Gate Identification Signs
C08.1.3. Building Identification Signs
C08.1.4. Traffic Control Devices (Street Signs)
C08.1.5. Directional and Wayfinding Signs
C08.1.6. Informational Signs
C08.1.7. Motivational Signs
C08.1.8. Parking Lot Signs
C08.1.9. Regulatory Signs
C08.1.10. Other
C09. Lighting 71
C09.1. Fixtures and Lamping 71
C09.2. Light Fixture Types 72
C09.2.1. Street Lighting
C09.2.2. Parking Lot Lighting
C09.2.3. Lighted Bollards
C09.2.4. Sidewalk Lighting
C09.2.5. Walls / Stairs Lighting
C09.2.6. Other
D. FACILITIES EXTERIORS 76
D01. Supporting the Mission 76
D02. Sustainability 76
D03. Architectural Features 77
D03.1. Orientation, Massing and Scale 78
D03.2. Architectural Character 79
D03.3. Details and Color 80
D03.3.1. Climate-based Data
D03.3.2. Natural Ventilation System
D03.3.3. Thermal Mass
D03.3.4. Thermal Shading
D03.3.5. Renewable Heating/Cooling
D03.3.6. Solar Photovoltaic System
D03.3.7. Solar Thermal System
D04. Building Entrances 87
D04.1. Primary Entrances 88
D04.2. Secondary Entrances 88
D05. Wall Systems 89
D05.1. Hierarchy of Materials 90
D05.2. Layout, Organization and Durability 90
D05.3. Equipment, Vents and Devices 91
D05.4 Wall Systems Materials 91
D05.4.1. Flat Metal Panels
D05.4.2. Brick Veneer
D05.4.3. Architectural Precast
D05.4.4. Stucco Over Sheathing
D05.4.5. Curtain Wall
D05.4.6. Cast-in Place Concrete
D05.4.7. Tilt-up Concrete
D05.4.8. Ribbed Metal Sheeting
D05.4.9. EIFS
D05.4.10.GFRC
D05.4.11.Concrete Block
D05.4.12. Fiber Cement Siding
D05.4.13. Other
D06. Doors and Windows 96
D06.1. Types 97
D06.2. Layout and Geometry 97
D06.3. Glazing and Shading 97
D06.4. Hardware 97
D06.5. Doors and Windows Materials 98
D06.5.1. Anodized Aluminum
D06.5.2. Hollow Metal
D06.5.3. Aluminum-clad Wood
D06.5.4. Other
D07. Roof Systems 101
D07.1. Roof Type and Form 102
D07.2. Roof Slope 102
D07.3. Parapets and Copings 103
D07.4. Color and Reflectivity 103
D07.5. Gutters, Downspouts, Scuppers, Drains 103
D07.6. Roof Vents and Elements 104
D07.7. Clerestories and Skylights 104
D07.8. Vegetated Roof 104

Table of contents continued on next page

D07.9. Roof Systems Materials 105
D07.9.1. Standing Seam Metal
D07.9.2. Membrane Single-ply
D07.9.3. Built-up Multi-ply
D07.9.4. Concrete Tile
D07.9.5. Clay Tile
D07.9.6. Slate Shingles
D07.9.7. Vegetated System
D07.9.8. Ribbed Metal Sheeting
D07.9.9. Composite Shingles
D07.9.10. Other
D08. Structural Systems 108
D08.1. Systems and Layouts 109
D08.2. Structural Systems Materials 109
D08.2.1. Concrete
D08.2.2. Insulated Concrete Forming (ICF)
D08.2.3. Steel
D08.2.4. Pre-Engineered Steel
D08.2.5. Masonry
D08.2.6. Heavy Timber
D08.2.7. Light-gauge Steel
D08.2.8. Lumber Framing
D08.2.9. Other
D09. Mechanical, Electrical and Plumbing 113
D09.1. Passive and Active Systems 114
D09.2. Functionality and Efficiency 114
E. FACILITIES INTERIORS 115
E01. Building Configurations 116
E01.1. Layout and Common Areas 116
E01.1.1. Interior Design Process
E01.1.2. Codes and Regulations
E01.2. Quality and Comfort 117
E02. Floors 118
E02.1. Floor Materials 118
E02.1.1. Prepared Slabs
E02.1.2. Natural Stone and Terrazzo
E02.1.3. Quarry Tile
E02.1.4. Ceramic Tile
E02.1.5. Resilient Floor
E02.1.6. Carpet
E02.1.7. Rapidly-Renewable Products
E02.1.8. Other
E03. Walls 123
E03.1. Wall Materials 123
E03.1.1. Concrete
E03.1.2. Masonry
E03.1.3. Ceramic Tile
E03.1.4. Gypsum Board
E03.1.5. Metal Panels
E03.1.6. Wood Paneling
E03.1.7. Rapidly-Renewable Products
E03.1.8. Other
E04. Ceilings 126
E04.1. Ceiling Materials 126
E04.1.1. Exposed Framing (Roof / Floor Structure Above)
E04.1.2. Exposed Concrete
E04.1.3. Grid and Acoustical Tile
E04.1.4. Gypsum Board
E04.1.5. Metal Panels
E04.1.6. Wood
E04.1.7. Rapidly-Renewable Products
E04.1.8. Other
E05. Doors and Windows 130
E05.1. Doors and Windows and Frames Materials 130
E05.1.1. Aluminum
E05.1.2. Hollow Metal
E05.1.3. Wood
E05.1.4. Other
E06. Casework Systems 133
E06.1. Casework Materials 133
E06.1.1. Plastic Laminate
E06.1.2. Solid Polymer Surface
E06.1.3. Rapidly-Renewable Products
E06.1.4. Metal
E06.1.5 Other
E06.2. Countertop Materials 136
E06.2.1. Plastic Laminate
E06.2.2. Solid Polymer Surface
E06.2.3. Natural Stone
E06.2.4. Cast Stone
E06.2.5. Metal
E06.2.6 Other
E07. Furnishings 138
E07.1. Durability and Serviceability 138
E07.2. Accessories 138
E08. Interior Signs 138
E08.1 Types and Color 138
E08.2. Interior Signs Materials 139
E09. Lighting, Power and Communication 139
E09.1. Functionality and Efficiency 139
E09.2. Types and Color 139
F. Appendices 140
G. Appendices 149

A. OVERVIEW

Comply with Air Force Corporate Standards for Overview:
http://afcfs.wbdg.org/index.html

This Installation Facilities Standards (IFS) document is part of the Air Force Corporate Facilities Standards (AFCFS) program to assist bases in implementing and maintaining facilities standards as appropriate for efficient operations within the respective climate region. IFS fully replaces, consolidates and simplifies existing facilities standards documents, such as the Architectural Compatibility Plan (ACP) or ACGs, FEPs, etc., and organizes information using the same structure, or Table of Contents, as the AFCFS website.

IFS reflects the AFCFS' concepts of "Facility Hierarchy" (categorizing facilities into group numbers) and "Facility Quality" (assigning an appropriate level of quality to each group number) and applies these principles at the base level. Applicable DoD and Air Force criteria such as UFCs, AFIs, Memoranda, and UFGSs (Guide Specs) are referenced and linked within IFS to ensure the document is always current.

Navigating within this IFS is efficient and straightforward. Please use the interactive Table of Contents to locate subject matter, and click on the title of a section to access it. From any page, click on the "Back to Table of Contents" footer to return. Content is organized into 4 major sections: Installation Elements, Site Development, Facilities Exteriors and Facilities Interiors.

This IFS document begins as a fill-in PDF form, which is fully editable, and becomes a "living document" that can be regularly updated by base-level personnel following a format that is consistent across the Air Force. While the format is standardized, IFS content is customized for base operations and the local climate to ensure mission success while emphasizing reduced maintenance and reduced initial costs, life-cycle costs, energy use, and water use.

1. Conformance to Air Force Corporate Facilities Standards (AFCFS) and Installation Facilities Standards (IFS) are required by Air Force Instruction (AFI) 32-1023 and Air Force Memorandum. Please refer to the AFCFS website for links to documentation on current policy.

2. Requests to deviate from any installation facilities standards, that are Unified Facilities Criteria (UFC) requirements, will follow the process outlined in the AFCFS for UFC waivers and exemptions.

3. All Air Force designs including Non-Appropriated Funds (NAF) facilities are required to conform to AFCFS per Air Force Instruction (AFI) 32-1023; AFCFS will be used to formulate Installation Facilities Standards (IFS) per the AFI. The Base Civil Engineer (BCE) maintains and implements the IFS.

4. Please refer to the AFCFS website as a portal to reference materials and requirements documents for design and construction projects (via links). Specific references to current DoD memoranda and Air Force criteria are updated periodically to provide the most current guidance and requirements. Programming, design and contract documents should list "current edition" for all reference and requirements documents. The documents in force at the date of execution of the design and/or construction contract will be the governing version.

5. *Advanced Modeling Requirements:*
   For all Air Force projects requiring advanced modeling, to include 3D visualization, Building Information Modeling (BIM), facility data, quantity take-off, geospatial, etc., follow the Army standards. Refer to USACE Minimum Model Matrix (M3) and Project Execution Plan (PxP) which outline required model uses. Refer to CAD BIM Technology Center (Contract Requirements) *for more information on M3 and PxP.*

6. Joint Bases will implement IFS under their Joint-Base designation with volume numbers for individual installations following the IFS Development Tool template. For example, for Joint Base Langley-Eustis, provide: Vol. 1 Langley AFB and Vol. 2 Fort Eustis.

7. References and Supplementary Documents listed in Appendix G are included in these Installation Facilities Standards by reference and are fully part of this document. Please refer to Appendix G for a listing of documents, which are available via hyperlink for viewing and downloading.

8. Host Nation Facilities: Use the International Building Code(r) (IBC) for planning, design and construction of all facilities built for Host Nation personnel use outside of the United States and its territories and possessions. Use the IBC in conjunction with Status of Forces agreements (SOFA), bilateral agreements or other Host Nation (HN) agreements.
   UFC 1-200-01 DoD Building Code: https://www.wbdg.org/dod/ufc/ufc-1-200-01

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Ellsworth AFB Main Gate



Sculpture as Focal Point in Group 1



Historical Pride Hangar



Preserved Open Space at Housing

A01. FACILITY HIERARCHY

Comply with AF Corporate Standards for Facility Hierarchy (and subsections):
http://afcfs.wbdg.org/facility-hierarchy/index.html


A02. FACILITY QUALITY

Comply with AF Corporate Standards for Facility Quality (and subsections):
http://afcfs.wbdg.org/facility-quality/index.html

A03. FACILITY DISTRICTS

Comply with AF Corporate Standards for Facility Districts (and subsections):
http://afcfs.wbdg.org/facility-districts/index.html

Image Tool 800 x 800



Note: *Apply the base-wide standards in this IFS for Installation Elements, Site Development, Facilities Exteriors and Facilities Interiors (products, materials, color, etc.). Following application of the base-wide standards, refer to the Appendix and apply any additional requirements specifically related to the Facility District.*

B. INSTALLATION ELEMENTS

Comply with Air Force Corporate Standards for Installation Elements:
http://afcfs.wbdg.org/installation-elements/index.html


B01. COMPREHENSIVE PLANNING

Comply with Air Force Corporate Standards for Comprehensive Planning:
http://afcfs.wbdg.org/installation-elements/comprehensive-planning/index.html

B01.1. Installation Development Plan (IDP)

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440


◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 2 Image Tool 250 x 188



Department of Defense, Department of the Air Force and Air Force Base Criteria



Typical Site Plan Diagram



Typical Floor Plan Diagram

1. The Base Civil Engineer is responsible for developing, maintaining and implementing the installation's Comprehensive Planning documents and to ensure that the Installation Development Plan (IDP) is prepared, maintained, and implemented following AFI 32-1015.

B01.1.1. IFS Requirements and Documents

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Preserved Open Space and Water Feature



Street Envelope Standards



Landscape Standards



Building Standards

1. Maintain this Installation Facilities Standards (IFS) as a Component Plan of the base's Installation Development Plan (IDP).

End of Section

B01.1.2. Brief History of Base

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Open House at Pride Hangar during the Mid 1950's



Minuteman Missile Display at Pride Hangar



Transporter Erector at Ellsworth AFB, c. 1963



RB-36s Prepare to Take Off

Ellsworth was originally established as Rapid City Army Air Base (AAB) in 1941 but later changed its name in honor of Brigadier General Richard E. Ellsworth. On January 2, 1942, the U.S. War Department gave the newly established installation its first task of training B-17 Flying Fortress heavy bomber units. Construction began for the assignment on September 30, 1942 and ended with the completion of five hangars and three concrete runways. Bombers continued their training as the war drew to a close, but on July 15, 1945 Rapid City AAB was placed on standby due to the demobilization of the Army Air Forces. The base was reactivated on October 11, 1945 and assigned to the Continental Air Force. In 1947, the 28th Bombardment Wing began flying the B-29 Superfortress. Then in July 1949, after renovations to the runway, the wing underwent a conversion for the B-36 Peacemaker. President Dwight D. Eisenhower visited the base on June 13, 1953 to dedicate it in memory of Brigadier General Ellsworth and the base was renamed in his honor. Ellsworth flew 400 missions during World War II and commanded the 28th Strategic

Reconnaissance Wing. In 1956, Strategic Air Command (SAC) began replacing all of the 28th's B-36 aircraft with all-jet B-52 Stratofortresses, and on June 14, 1957 the new planes were received. All base units in 1958 came under the command of the 821st Strategic Aerospace Division at Ellsworth.

In 1986, the 28th Bombardment Wing made preparations to phase out the old B-52 fleet for the incorporation of the B-1B Lancer and, in March of the same year, more renovations were made to the base including new enlisted dormitories, new security police squadron headquarters, and runway improvements. The 28th's B-52s left early in 1986 and the B-1Bs were received in January 1987.

On June 1, 1992, the Air Force inactivated the SAC and reassigned Ellsworth to the new Air Combat Command (ACC). With the change in command, the 28th received the new mission of worldwide munitions delivery. This remained Ellsworth's operating command until October 1, 2015 when the base became part of the 8th Air Force under the control of Global Strike Command.

B01.1.3. Future Development

(•) Applicable ( ) N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

( ) Applicable (•) N/A Small graphics do not apply



High Performance and Sustainable Buildings Are Required by UFC for Future Development

1. Follow AFI 32-1015 for Air Force Comprehensive Planning, the Comprehensive Planning Process, Comprehensive Planning Requirements, and Geospatial Mapping.

2. Address all future development under the Installation Development Plan (IDP).

B02. STREET ENVELOPE STANDARDS


Comply with Air Force Corporate Standards for Installation Elements:
http://afcfs.wbdg.org/installation-elements/index.html

Comply with AF Corporate Standards for Street Envelope Standards:
http://afcfs.wbdg.org/installation-elements/street-envelope-standards/index.html


B02.1. Hierarchy of Streets

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Hierarchy of Streets



Street Envelope Section


Undivided Arterial

1. Develop and evolve a hierarchical transportation network of arterial, collector and local streets following UFC 3-201-01 and its industry references.

2. Provide consistent functionality throughout the installation and a level of visual quality relating to the adjacent Facility Group number.

3. Routes along facilities in Group 1 may have materials, finishes and features with a higher visual quality than Groups 2, 3 and 4. Reduce maintenance requirements by installing highly durable materials and finishes in routes along Group 3 industrial facilities.

4. Special routes may have a visual quality comparable to those along facilities in Group 1.

5. Create and maintain arterials with two lanes of traffic in each direction with landscaped or paved medians as applicable to the local climate and adjacent facility group designation / land use.

6. Minimize stops and turns along arterials. Eliminate on-street parking along arterials and collector streets.

7. Connect arterials to local streets with appropriately scaled collector streets.

8. Provide appropriate landscape setbacks and pedestrian buffers along all streets.

9. Minimize and consolidate curb cuts along streets.

10. Ensure access for emergency and service vehicles.

11. Define bicycle traffic routes in the Installation Development Plan or its applicable component plans.

12. Provide illustrations in the Installation Facilities Standards (IFS) to include street cross-sections and plans for every type of street specified on the installation. At a minimum provide dimensions for vehicular traffic-lanes, curb radii, medians, bike lanes, pedestrian buffers, sidewalks, crosswalks, tree planting areas, and on-street parking configurations.


13. Define appropriate force protection features, site furnishings, signs, lighting, utilities, and paving in the IFS.

End of Section


B02.1.1. Arterial Streets

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Travel Lane (a): 12' Median (b): 12' Curb and Gutter (c): 2' Sidewalk / Landscape (d): 12') Setback (f): Min. 35' or per AT



Paved Median



Rock Mulch Median



Preserved Sight Lines at Main Gate

1. Stops and turns should be minimized and on-street parking will not be allowed at any point along arterial streets.

2. Provide sidewalks on at least one side of arterial streets and both sides of arterial streets in developed areas. Provide a 6 foot buffer between the road and sidewalk where space allows.


3. Limit curb cuts on arterial streets to entries into major facilities, building groups and major parking areas.

4. Reinforce the importance of arterial streets with appropriate signs, plantings and street lighting.

B02.1.2. Collector Streets

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 2 Image Tool 250 x 188



Travel Lane (a): 12' Median (b): N/A Curb and Gutter (c): 2' Landscape (d): 10' Sidewalk (e): 6' Setback (f): Min. 35' or per AT



Trees Adjacent to Developed Area



Native Grasses in Undeveloped Area

1. Provide sidewalks on at least one side of collector streets and both sides of collector streets where functionally required. Buffers are preferred but not required on collector streets.


2. On street parking may be allowed on one side where secondary roads are over 28 feet wide but not less than 34 feet wide. Parking will not interfere with intersections or traffic flow.

3. Signs, plantings and street lighting should reinforce the designation of "collector" street.

B02.1.3. Local Streets

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Travel Lane (a): 11′ Median (b): N/A Curb and Gutter (c): 1.5′ Landscape (d): 15′ Sidewalk (e): 6′



Residential Scale and Detailing



Detached Sidewalk



Controlled Access Gates

1. Provide sidewalks on at least one side of collector streets and both sides of local streets where functionally required. Buffers are preferred but not required on collector streets.

2. On street parking may be allowed following UFC industry references.

3. Signs, plantings and street lighting should reinforce the designation of "local" street.

4. Cul-de-sacs are only permitted in family housing areas.

B02.1.4. Special Routes

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Develop all special routes consistently with those adjacent to Group 1 facilities.

B02.2. Hierarchy of Intersections

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

○ Applicable ◉ N/A Small graphics do not apply



Passive Systems: Traffic Circle with Low Maintenance Xeric Landscape Features

1. Provide a hierarchy of intersections to include arterial, arterial-collector, collector, collector-local and local following UFC 3-201-01 and its industry references.

2. Passive systems such as traffic circles are preferred to active systems such as signalized intersections. Aggressively pursue passive systems to lower maintenance requirements and reduce energy use.

3. Use a level of visual quality for an intersection equal to the quality found in the related streetscape, which corresponds to the adjacent Facility Group number.

End of Section

B02.2.1. Arterials

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 1 Image Tool 250 x 188



Divided Arterial

1. Provide an informal grouping of low lying native ground cover and shrubs as a focal point at all four corners. Trees may be used in areas of higher density development where grey-water irrigation is available. Monuments and static displays may be integrated into arterial intersection designs.

B02.2.2. Arterial/Collector

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Provide an informal grouping of low lying native ground cover and shrubs as an accent at all four corners in developed areas. Trees may be used in areas of higher density development where grey-water irrigation is available.

B02.2.3. Collectors

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Provide an informal grouping of low lying native ground cover and shrubs as an accent at all four corners in developed areas.

B02.2.4. Special Intersections

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Develop all special intersections consistently with those adjacent to Group 1 facilities.

End of Section

B02.2.5. Street Frontage Requirements

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 1 Image Tool 250 x 188



Building Setback

1. Consistently maintain open space buffers following B03.2.3. Preserves.

2. Refer to C06.1.7. Streetscape Landscaping for planting and screen wall requirements along street frontage.

B02.2.6. Sight Lines

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 1 Image Tool 250 x 188



Preserved Sight Lines

1. Provide adequate sight lines for an effective and safe traffic operation per American Association of State Highway and Transportation Officials (AASHTO) standards and local municipality guidelines.

End of Section

B02.3. Street Elements

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 1 Image Tool 250 x 188



Standard Crosswalk Striping

1. Emulate the streetscape area's pre-development hydrology using passive and active design features to help sustain the adjacent regionally appropriate landscape. Coordinate with the base Stormwater Management Plan.

2. Employ systems, materials and techniques to maximize streetscape sustainability. Consider pervious paving and reflectivity of surfaces appropriate for the local climate.

3. Install at-grade curbing and/or raised-profile curb and gutter as applicable to direct stormwater to bioswales and rain gardens as source water for vegetation. Do not paint concrete curbing.

4. Provide all on-site utility service lines and equipment below grade when adjacent to Facility Group 1. In routes along Group 2, 3 and 4, when mounting elements such as utility cabinets, communications equipment and water valves above grade is unavoidable, paint these consistently and provide visual screening following Installation Facilities Standards (IFS).

5. Provide traffic control devices including access control point/entry control facility signs, speed limit signs and street name signs following the current edition of the Manual on Uniform Traffic Control Devices (MUTCD) per UFC 3-120-01.

6. Crosswalk markings must follow the MUTCD for Streets and Highways, current edition. Provide white markings that define the edges of the crosswalk or a tone of lines defining the area of the crosswalk consistent with common practices found in the adjacent municipality.

7. Follow UFC 3-120-01 for directional and wayfinding signs and address both vehicular and pedestrian traffic.

8. Reduce energy consumption and reduce maintenance requirements by providing street lighting only when functionally required to ensure safety and to address antiterrorism following UFC 4-010-01. Ensure the quality and quantities of lighting and fixtures are appropriate for the adjacent Facility Group number.

End of Section

B02.3.1. Paving

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 1 Image Tool 250 x 188



Asphaltic Concrete Paving


1. Pavement design must comply with UFC 3-250-01. Ensure appropriate analysis and design of subgrade conditions to promote low maintenance, high performance pavements. Apply all applicable best practices from Appendix B of the UFC.

2. Materials must be specified in accordance with UFC 3-250-01 and must conform to requirements set forth in the Unified Facility Guide Specifications (UFGS) for concrete and bituminous pavement.


B02.3.2. Curb and Gutter

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Group 1, 2 and 3 Section



Group 4 Section



Integrated Sidewalk and Retaining Wall

1. Curb all parking, access roads and streets (except remote/isolated).

2. All streets should have integral concrete curbs and gutters. Painted curbs are prohibited because they are very difficult to maintain.

3. Use concrete for sidewalks and curbs. Do no use asphalt curbs.

End of Section

B02.3.3. Utility Service Elements

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Provide all utility service lines below grade when streets are adjacent to Facility Group 1; when mounting elements (such as utility cabinets, communications equipment and water valves) above grade is unavoidable, paint these consistently and provide visual screening following Site Development, Landscaping.

2. Overhead service lines along streets adjacent to Facility Groups 2, 3 and 4 are discouraged.

B02.3.4. Traffic Signs

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188


Median Indication


Roundabout Symbol


Standard Street Sign

1. Refer to Exterior Signs, Colors and Types for Traffic Control Devices, which includes signs.

B02.3.5. Street Lighting

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Refer to the Lighting section for appropriate applications along streets.

B02.3.6. Other

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

B03. OPEN SPACE / PUBLIC SPACE

Comply with Air Force Corporate Standards for Installation Elements:
http://afcfs.wbdg.org/installation-elements/index.html

Comply with AF Corporate Standards for Open Space / Public Space:
http://afcfs.wbdg.org/installation-elements/open-space-public-space/index.html

B03.1. Plazas, Monuments and Static Displays

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Natural features and culturally or historically significant features or events may be recognized and acknowledged with physical elements such as plazas, monuments and static displays. However, limit these elements on the base to ensure judicious use of resources and to reduce ongoing maintenance requirements.

2. Design highly durable plazas, monuments and static displays with a level of quality comparable to Facility Group 1.

3. Link plazas, monuments and static displays to the pedestrian circulation system. Install landscaping, site furnishings and lighting appropriate for the application and local climate following Installation Facilities Standards (IFS).

4. Select systems, products and materials for paving, walls, and structures following IFS.

B03.1.1. Paved Plazas

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 2 Image Tool 250 x 188



Central Area of Focus



Rock Paving

1. Mitigate heat island by providing high-albedo, shaded plazas. Pervious pavers will be used on all plazas and courtyards in Facility Groups 1 and 2; use pervious concrete in Groups 3 and 4. The designer will incorporate appropriate expansion and construction joints.

2. Pavers will match the color of pavers used on adjacent sidewalks using base standard earth tone range of colors including tans, and browns. Bricks used on plazas will typically be 4" x 8" size.

End of Section

B03.1.2. Sculptures, Markers and Statuary

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188


Sculpture Adjacent to Group 1 Facility


Marker at Static Display


Posts Anchored to Concrete Pad

1. Relate new sculpture, markers and statuary to the base's architectural design theme. Generally limit these elements to frequently used locations adjacent to Facility Group 1 and highly traveled community pedestrian spaces.

2. Consider entry gates as possible sites for new displays.

3. All proposed memorials must follow AFI 36-3108 and be limited to highly deserving individuals or groups as deemed appropriate by the installation leadership. Living memorials (tree plantings / etc.) are discouraged due to added maintenance requirements.

4. When sculpture requires a base, match the materials and / or color palette of adjacent buildings.

5. Use direct or indirect lighting to accentuate features or enhance an intended effect.

6. Ensure that all sculpture, markers and statuary are honorable and inspiring, provide a sense of place, positively contribute to the base's visual quality, and encourage pride for the community and the US Air Force.

B03.1.3. Static Display of Aircraft

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 2 Image Tool 250 x 188


Ground-Mounted Display


Integrated Paving and Landscape

1. Follow IFS base-wide standards for all elements of the display area with specific attention to traffic sight lines, pedestrian circulation, site furnishings, signs, and lighting. Address requirements for the Facility District as well.

2. Generally locate concrete base/foundation structures for static displays below grade.

3. At static displays where pedestrian paths are provided, a minimum of one trash receptacle and one bench will be provided. Receptacle and bench design must conform to IFS requirements.

B03.2. Grounds and Perimeters

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 2 Image Tool 250 x 188



Preserved Open Space



Standard Colors for Utility Elements

1. Provide formal spaces for parade and review functions, recreational areas and parks following the base's Installation Development Plan (IDP) and Installation Facilities Standards (IFS). Refer to the Site Furnishings topic for additional information.

2. Maintain preservation areas following the IDP and IFS.

3. Comply with UFC 4-010-01 DoD Minimum Antiterrorism Standards for Buildings and UFC 4-022-03 Security Fences and Gates for all elements associated with the base's gates and perimeter fence.

4. Identify and describe base-wide utility corridors in the IDP.

5. Base-wide utility infrastructure will be inconspicuous. Bury utility service lines below grade when adjacent to Facility Group 1 and when economically feasible for Facility Groups 2, 3 and 4. When service lines are located above grade, create an ordered, coordinated appearance.

6. Follow the requirements of this IFS regarding all utility structures and service lines located above grade that visually impact the installation.

7. Where screening of utility equipment and structures is provided, allow adequate and proper clearance for safety and maintenance.

8. Reduce visual clutter and visual impact of the following items through a combination of careful placement, screen walls, landscaping and painting:
- Electrical switch-stations.
- Sewage lift stations.
- Water well pumps, storage tanks and/or related structures.
- Gas piping, meters and similar incidental items.
- Above ground fuel storage tanks.
- Any ground-mounted freestanding utility item exposed to view.

9. Larger structures such as electrical switch-stations, sewage lift stations, fuel storage tanks and mechanical/electrical equipment will be screened from view, using materials, forms, and colors in the screen walls which match those respective design elements present at adjacent buildings.

10. Paint above-ground equipment and associated components such as electrical piping or exposed plumbing lines in the color "Chateau Brown" by Sherwin-Williams SW 7510 (Brown Color).

11. Maintain currently buried utility service lines as a visual asset.

12. Bury the following exposed above-grade items in future projects when economically feasible:
- Electrical power grid and service lines.
- Telephone lines.
- Cable TV lines.
- Communications lines.
- Exterior lighting service lines.
- Any similar system of above-ground lines serving the base.

13. Consolidate and enclose service utility lines in underground utility corridors when feasible. Create routes along the inside edge of parking lot islands.

B03.2.1. Parade Grounds

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Follow UFC 3-201-02, Appendix B for the planning and design process and criteria for parade grounds.

2. Establish and maintain parade grounds only where there is a confirmed need and provide landscape materials appropriate for the locale following IFS.

3. Bleachers may be installed only when there is a documented requirement at parade grounds. Nonferrous metals that do not require painting or going maintenance are preferred. The Base Civil Engineer will determine quantities, sizes, and products on a case-by-case basis.

B03.2.2. Parks

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 6 Image Tool 250 x 188


Paved Pedestrian Circulation


Park Pavilion


Pocket Park Playground



Defined Play Area



Pier as Amenity



Elevated Park Structure

1. Bleachers may be installed only when there is a documented requirement at parks and fields for recreational events. Follow guidance under Parade Grounds.

2. Picnic pavilions may be provided in parks where there is a documented need.

B03.2.3. Preserves

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Open Space Adjacent to Family Housing



Water Feature as Amenity



Wetland Area

1. Preserve areas adjacent to runways, taxiways, aprons, golf course roughs, storage areas, antenna facilities, and ammunition storage areas, as open space.

2. Provide minimal maintenance with mowing as needed for controlling bird behavior for airfield safety, or eliminating fire hazards.

End of Section

B03.2.4. Perimeter Fence

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 6 Image Tool 250 x 188


Brick Pier and Metal Fencing at Group 1


Controlled Vehicle Access at Main Gate


Controlled Pedestrian Access


Metal Fencing with Outrigger Design


Remote Area Chain Link and Cable Fencing


Chain Link Fence with Outriggers

1. Design, install and maintain the base's perimeter fence following UFC 4-022-03.

2. Stringently comply with AT requirements following UFC 04-010-01 for all spaces adjacent to the base's perimeter fence and all gates.

3. Fencing, gates and other elements associated with the main gates will be a level of quality equivalent to Facility Group 1.

4. Maintain a positive visual quality along the traffic corridor on both sides of the main gates. Specifically address pedestrian access, circulation and common areas.

End of Section

C. SITE DEVELOPMENT

Comply with Air Force Corporate Standards for Site Development:
http://afcfs.wbdg.org/site-development/index.html

C01. SITE DESIGN

Comply with AF Corporate Standards for Site Design / NEPA:
http://afcfs.wbdg.org/site-development/site-design-nepa/index.html

C01.1. Site Design Considerations

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Collect documentation to validate approvals and completion of the NEPA process.

2. Ensure site design compliance with the Installation Development Plan (IDP) and its component plans and Installation Facilities Standards (IFS).

3. Promote integrated design with on-site solutions such as engineered small-scale hydrologic controls verses base-wide infrastructure; consider open space, natural features, bioswales, building roofs, streets, and paved surfaces.

4. Limit the impact of development on land and water resources. All site elements and infrastructure will reinforce an image of sustainability, with reduced energy demand, renewable-energy usage, and water conservation.

5. Consider energy conservation during site design for the following categories: building and site lighting, auxiliary systems and equipment (refrigerators, elevators, etc.), building envelope, electric power and distribution, HVAC systems and equipment, service hot water, energy management (metering, EMCS).

6. Coordinate on-site renewable-energy systems and components to minimize area requirements and maximize efficiencies. Appropriately buffer and screen these and other mechanical systems and equipment.

7. New building projects should preserve open space and protect natural habitat.

8. Conform to existing topography to the greatest extent possible and use slopes to increase site and building efficiencies. Design sites to minimize irrigation and impacts to stormwater runoff.

9. Carefully study new project sites to identify the character of adjacent buildings, streets, landscaping, and site design elements. Reinforce the existing character in new site design.

10. Consider relationships to adjacent facilities and district / centralized heating and cooling infrastructure and cost effectively connect building systems to harvest heat, grey water or other beneficial byproducts.

11. Minimize existing and planned obstructions from landscaping, structures, topography, and adjacent developments to preserve solar access and natural ventilation.

12. Purposefully integrate service access, receiving and storage areas to eliminate the need for visual screening.

13. Appropriately connect to the base network of streets, sidewalks and trails using drive aisles, parking areas, walkways, paths, and bicycle routes addressing both vehicles and pedestrians.

14. Applicably coordinate heat island mitigation in paving and roof designs when implementing an integrated approach to stormwater management.


15. Consider the location of “Designated Tobacco Use Areas (DTA).”

End of Section


C01.2. Building Orientation

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440


◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 6 Image Tool 250 x 188




Conceptual Site Analysis and Site Design Diagram




Local Solar Data




Local Climate Data




Site Data



East-West Axis



Optimum Solar Control



Optimized Shading

1. Ensure the site will accommodate optimum requirements for building orientation, which is with the long axis parallel to the east/west direction for rectilinear CONUS buildings.

2. Meet Installation Facilities Standards (IFS) requirements for the locations of the building's passive and renewable-energy systems—including geothermal and solar systems—and exterior shading systems.

3. Locate the building(s) and permitted ancillary structures to promote solar gain, solar shading, natural ventilation, rainwater harvesting, wind buffering and other beneficial passive systems. Consider natural ventilation during the design of HVAC systems.

4. Consider relationships to adjacent sites and their facilities and infrastructure, and cost effectively integrate building systems to harvest heat, grey water or other beneficial byproducts.

5. Consider the "public side" of the building, its views and the location of the main entrance.

C02. UTILITIES

Comply with AF Corporate Standards for Site Development:
http://afcfs.wbdg.org/site-development/index.html

Comply with AF Corporate Standards for Utilities:
http://afcfs.wbdg.org/site-development/utilities/index.html

C02.1. Utility Components

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Standard Color for Ground-Mount



Screen Wall



Standard Color for Elements

1. Provide all on-site utility service lines below grade for Facility Group 1; when mounting elements (such as utility cabinets, communications equipment and water valves) above grade is unavoidable, paint these consistently and provide visual screening following Installation Facilities Standards (IFS).

2. Provide installation of utility infrastructure to support near term and future electric vehicle charging stations.

3. Define all service entry points into the building and route distribution below grade into an interior space within the facility; exposed conduits, cables and wires on exterior walls are not permitted for Facility Group 1.

4. Install meters per AF Corporate standards and in support of Automated Revenue Management Services (ARMS). Base prefers Centron electric meters with Itron ERT capabilities and Dresser rotary gas meters.

5. Integrate use of Honeywell brand for all control systems. J&A provided by base CE.

6. Limit exterior mechanical distribution systems such as exterior steam, chilled water, and hot water distribution to Group 3 facilities; when required for Group 1 and 2 facilities integrate with the architecture and provide visual screens following IFS.

7. Direct roof drainage to underground collection when feasible or provide splash blocks / paved channels to intercept roof drainage at grade.

End of Section

C03. PARKING AREAS


Comply with AF Corporate Standards for Site Development:
http://afcfs.wbdg.org/site-development/index.html

Comply with AF Corporate Standards for Parking Areas:
http://afcfs.wbdg.org/site-development/parking-areas/index.html


C03.1. Configurations and Design

○ Applicable ◉ N/A Large graphics do not apply


◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 6 Image Tool 250 x 188



Small Lot Configuration



Large Lot Configuration



Facility Group 1 Configuration



Adjacent Parking Lot



Accessible Spaces Configuration



Rock Mulch Island

1. Evaluate adjacent sites and cost-effectively consolidate parking areas to maximize efficient use; ensure that all areas meet accessibility guidelines.

2. Generally envision on-site parking as a series of small connected singular areas selectively placed around the facility served, rather than a single large area; buffer parking areas from the facility main entrance with a transition space and provide drop-offs to decrease close-in parking. Comply with IFS standards while meeting antiterrorism (AT) requirements.

3. Integrate at-grade and raised-profile curbing, permeable paved areas, and parking islands with the stormwater system and direct stormwater to bioswales and rain gardens as source water for regionally appropriate native vegetation.

4. Curbed parking lot islands should be avoided for snow removal operations.

5. Define pedestrian access with approved hardscape and provide shading along the primary path from the parking area to the main entrance of the building.

6. Coordinate suitable landscape or barriers integrated with walls and fences to ensure adequate force protection.

7. Accessible parking spaces must be marked according to UFC 3-120-01 and its references in ABAAS and the MUTCD.

8. Consider locations and requirements of near term and future electric vehicle charging stations.

9. Designate preferred parking spaces for electric vehicles and carpools near the main entrance.

10. Consider cost-effectively integrating solar photo-voltaic arrays into covered parking structures.

11. Reserved parking is discouraged except for Facility Group 1.

12. On-street parking is discouraged except in multi-use areas. When used, provide approved on-street parking configurations following UFC 3-201-01.

13. Access and service drives should accommodate the largest vehicle serving the facility.

End of Section

C03.1.1. Paving and Striping

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

Facility Group 1 paving materials will be as follows.

Primary:	Asphaltic concrete
Secondary:	Concrete
Accent:	Permeable pavers

Facility Group 2 paving materials will be as follows.

Primary:	Asphaltic Concrete
Secondary:	N/A
Accent:	N/A

Facility Group 3 paving materials will be as follows.

Primary:	Concrete where operationally required
Secondary:	Asphaltic Concrete
Accent:	N/A

Facility Group 4 paving materials will be as follows.

Primary:	Asphaltic Concrete
Secondary:	N/A
Accent:	N/A

1. All new parking lots in Groups 1 and 2 must be constructed of asphalt paving.

2. Porous paving may be considered on a case-by-case basis.

3. Cost-effectively provide light-colored concrete to reduce heat island effect; otherwise install asphaltic concrete paving. Dirt, gravel, and grass lots are not allowed.


4. Use consistent striping, angles and stall sizes in all parking areas.

All parking will be marked with white stripes of paint or applied vinyl coatings. Red or yellow markings will only be used for safety purposes and must be kept to a minimum. All lines will be four inches (4") wide.


C03.1.2. Curbing

○ Applicable ◉ N/A Large graphics do not apply


◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



"Barrier" Curb



"Mountable" Curb



Header Curb

Facility Group 1 curbing / edging materials will be as follows.

Primary:	Concrete
Secondary:	N/A
Accent:	N/A

Facility Group 2 curbing / edging materials will be as follows.

Primary:	Concrete
Secondary:	N/A
Accent:	N/A

Facility Group 3 curbing / edging materials will be as follows.

Primary:	Concrete
Secondary:	N/A
Accent:	N/A

Facility Group 4 curbing / edging materials will be as follows.

Primary:	Concrete
Secondary:	N/A
Accent:	N/A

1. Define all parking lots with either raised profile or at-grade curbing to promote drainage and protect paving edges. All raised curbs will be the rolled (mountable) type.

2. Integrate curbing to direct stormwater to bioswales and rain gardens as source water for regionally appropriate native vegetation.

3. Wheel stops are not permitted except at locations where car bumpers could contact adjacent items such as poles, signs or pedestrians.

C03.1.3. Internal Islands and Medians

◯ Applicable ◉ N/A Large graphics do not apply

◯ Applicable ◉ N/A Small graphics do not apply

1. Install landscape islands and medians as visual breaks, to reduce heat island effects and to accommodate bioswales and rain gardens with consideration for snow removal. Coordinate suitable landscape or barriers integrated with walls and fences to ensure adequate force protection.

2. When lighting is necessary, contain fixture bases within medians or internal landscape islands.

C03.2. Parking Structures

◯ Applicable ◉ N/A Large graphics do not apply

◯ Applicable ◉ N/A Small graphics do not apply

1. Parking structures are encouraged in land-constrained locations when economically feasible.

2. Consider near term and future electric vehicle charging stations and renewable energy generation development during the analysis and design.

3. Consider opportunities for integrating parking structures into multi-use developments with pedestrian-oriented uses located on the ground floor and parking on upper levels; ensure AT guidelines are fully addressed.

4. Structures may be constructed below grade with roofs serving as vegetated areas or plazas.

End of Section

C03.3. Connectivity

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 1 Image Tool 250 x 188



Adjacent Parking Area

1. Refer to the Installation Development Plan (IDP) for locations of transit stops and pedestrian and cycling networks; provide appropriately sized sidewalks and bike paths to connect facilities and users to these networks.

2. Provide amenities such as rain and shade shelters, trees, and benches to encourage and facilitate use of public transportation.

3. Evaluate the IDP for the current and planned network of roads and optimally develop vehicular access to and from the site.

C04. STORMWATER MANAGEMENT

Comply with AF Corporate Standards for Site Development:
http://afcfs.wbdg.org/site-development/index.html

Comply with AF Corporate Standards for Stormwater Management:
http://afcfs.wbdg.org/site-development/stormwater-management/index.html

C04.1. Stormwater Requirements

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 6 Image Tool 250 x 188



Bridge as Amenity



Roadway Catch Basin



Indistinct Drainage Feature



Grass Area Swale



Area Drain



Rock Mulch Near Foundation

1. Design all stormwater systems including retention ponds, detention areas, channels, etc. as on-site amenities that are consistent with natural systems and drainage patterns, that help sustain the base landscape with beneficial functionality and that provide aesthetic appeal; coordinate with the base Stormwater Management Plan.

2. Incorporate bioswales into the design of all roadway, parking and facility roof systems to enhance water quality and support the overall stormwater system.

3. When underground drainage systems are required establish a maintenance program to include removal of sediments and debris; inspect joints seasonally for alignment to prevent leakage and the development of voids and surface failures.

4. Cost-effectively integrate stormwater systems with AT measures.

5. Downspouts are to be connected to an underground stormwater system located below frost depth; wherever possible.

6. For further direction on stormwater and environmental base standards refer to Appendix.

C05. SIDEWALKS, BIKEWAYS AND TRAILS

Comply with AF Corporate Standards for Site Development:
http://afcfs.wbdg.org/site-development/index.html

Comply with AF Corporate Standards for Sidewalks, Bikeways and Trails:
http://afcfs.wbdg.org/site-development/sidewalks-bikeways-trails/index.html


C05.1. Circulation and Paving

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 6 Image Tool 250 x 188



Formal Configuration



Bicycle and Jogging Trail



Colored Concrete Paving



Attached Sidewalk



Concrete Trail



Detached Sidewalk in Family Housing

Facility Group 1 sidewalks, plazas, and courtyards paving materials will be as follows.

Primary:	Pervious Pavers
Secondary:	Concrete Edging
Accent:	N/A

Facility Group 2 sidewalks, plazas, and courtyards paving materials will be as follows.

Primary:	Pervious Pavers
Secondary:	Concrete Edging
Accent:	N/A

Facility Group 3 sidewalks, plazas, and courtyards paving materials will be as follows.

Primary:	Permeable concrete
Secondary:	N/A
Accent:	N/A

Facility Group 4 sidewalks, plazas, and courtyards paving materials will be as follows.

Primary:	Permeable concrete
Secondary:	N/A
Accent:	N/A

1. Maintain efficient geometry and accessibility to connect building entrances to adjacent parking areas and activity areas and to the base transportation system following AT. Efficiently use materials to optimize life-cycle costs and to minimize maintenance.

2. Generally conform horizontal layouts of sidewalks to the geometric configuration of adjacent buildings, streets, parking lots, and other adjacent related site amenities. Occasional meanders and/or jogs may be included to capture views, to coordinate with landscaping or accommodate site constraints.

3. Walks in parking areas will provide a direct path using "safe islands" and "peninsulas" to encourage safety. Walks parallel to streets will follow streetscape guidelines. Clearly mark pedestrian crossings at vehicular routes.

4. Mitigate heat island by providing high-albedo, shaded sidewalks. Pervious pavers will be used on all sidewalks, plazas and courtyards in Facility Groups 1 and 2; use pervious concrete in Groups 3 and 4. The designer will incorporate appropriate expansion and construction joints.

5. Only experienced contractors will install pervious pavements.

6. Consider an integrated approach that could include stormwater management (permeable surfaces) and complement the design of the storm drainage system when appropriate.

7. Pedestrian paths should be at least 5′ in width to allow for comfortable side-by-side walking.

8. Sidewalks leading to a building main entrance and at the interior of parking lots will be a minimum width of 6′. Walks greater than 10′ wide may be used at high-density pedestrian areas where volumes of traffic justify added material.

9. Where cars park adjacent and head-in to the sidewalk and wheel stops are not used, such perimeter walks will be increased to a minimum width of 8' to accommodate overhangs of the parked vehicles.

10. All sidewalks will have positive drainage to prevent ponding of water or ice accumulation with slopes ranging from 2.1% to 4.2%. Walks with a slope greater than 4.2% will be designed as ramps following accessibility guidelines. All walks will have a minimum cross slope of 2.1%.

11. Pavers will conform to the following range of color: earth tones such as beige, tans, and browns. Pavers used on walks will typically be 4" x 8" in size.

12. Connect to the bicycle circulation system and provide bicycle parking with a suitable means for securing bicycles following IFS. Consider changing/shower facilities for use by cyclists.

13. Refer to the Installation Development Plan for future trails, bicycle paths, and sidewalks.

C05.1.1. Ramps and Stairs

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Main Entrance Stair



Site Stair at Group 1



Site Stair at Group 3

1. Use ramps instead of stairs for sidewalks, bikeways and trails and at all buildings where possible. Where steps are unavoidable, follow UFC 1-200-01 and its references to the International Building Code.

C05.1.2. Lighting

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Provide lighting for all stairs and landings where traffic warrants.

2. Refer to the Lighting section for path lighting along sidewalks, bikeways and trails.

End of Section

C06. LANDSCAPE

Comply with AF Corporate Standards for Site Development:
http://afcfs.wbdg.org/site-development/index.html

Comply with AF Corporate Standards for Landscape:
http://afcfs.wbdg.org/site-development/landscape/index.html

C06.1. Climate-based Materials

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188


Native Grasses


Regional Species


Adapted Grasses

1. Use only native, naturally occurring, drought tolerant indigenous plant species (including grasses) appropriate for the locale to promote energy efficiency and water conservation, preserve drainage patterns, inhibit erosion, improve air quality, lower maintenance, and add beauty.

2. Follow details and specifications of the American Standard for Nursery Stock, current edition.

C06.1.1. Landscape Design Concept

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 6 Image Tool 250 x 188


Preserved Natural Grasses


Trees as Accent


Integrated Topography



Rock Retaining Wall



Limited Lansdcape Area



Grasses as Focus

1. Develop, maintain and implement a climate-based plant list with landscape features using a regionally appropriate palette of materials to promote energy efficiency, preserve drainage patterns, inhibit erosion, improve air quality, lower maintenance and add beauty. Follow UFC 3-201-02 Landscape Architecture.

2. Landscaping is required for all newly developed sites and facilities; preserve existing native landscape where possible and avoid overplanting.

3. Concentrate landscaping in Facility Group 1 and along major thoroughfares and integrate these landscaped areas into the base's stormwater management plan. Refer to the Streetscape Envelope Standards in this IFS.

4. All Facility Group 1 and 4 sites will be landscaped at their entire perimeter; limit formal planting arrangements to formal spaces typically associated with Group 1. Landscape public spaces near the main entrances of Group 1 facilities.

5. Facility Group 2 and 3 sites may have a native undisturbed landscape except at the main entrances of Group 2, which should be newly landscaped.

6. Facility plantings will follow the Installation Facilities Standards (IFS) plant list, which is based on the specific microclimates created by the adjacent building: shadow areas, protected areas, zones adjacent to thermal mass, and availability of rainwater and/or grey water.

7. Provide open spaces as transitions between developed and native areas that promote quality of life and provide visual relief and allow walkable connections to the transportation system.

8. Return suitable areas to a natural state to minimize and, whenever possible, eliminate ground maintenance requirements; expand prairie areas where appropriate with native plants to eliminate mowing and maintenance requirements.

9. In tree clusters replace grass with naturalized shrub beds and leaf litter mulch to eliminate mowing requirements.

10. Use plantings in open spaces to reinforce the space as a visual asset.

11. Consider landscape windbreaks when suitable for the local climate.

12. Integrate security requirements into the landscape design. Coordinate the heights of trees and shrubs and note restrictions for plantings following UFC 4-010-01.

13. Berms may be used as an integral part of the overall landscape strategy for screening, security and/or visual interest.

End of Section

C06.1.2. Xeriscape Design Principles

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Drought Tolerant Species



Xeric Species



Xeric Planting

1. Apply xeriscape principles following UFC 3-201-02, Appendix B, and Air Force Corporate Facilities Standards.

2. Facility plantings are encouraged to use native plant species and to consider specific microclimates created by the adjacent building: shadow areas, protected areas, zones adjacent to thermal mass, and availability of rainwater and/or grey water.

C06.1.3. Minimizing Water Requirements

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Limited Landscaping at Group 1



Landscaping at Main Entrance



Rock Mulch at Group 3

1. Reasonably reduce demand on potable water while seeking opportunities to increase alternative water sources for irrigation. Reduce or eliminate the use of potable/domestic water for purposes of landscape architecture maintenance, consistent with existing legal or contractual obligations, and prohibit potable-water irrigation in new construction beyond establishment following current DoD and Air Force policy.

End of Section

C06.1.4. Plant Material Selection

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 2 Image Tool 250 x 188



Indigenous Plant Materials



Grasses and Rock Mulch

1. Use only native, naturally occurring plant materials including grasses or turf suited for the local climatic conditions in the landscape design; potable-water irrigation systems are discouraged beyond the establishment period.

2. Use "Premium Farm Lawn Seed Mix" as standard grass seed mixture.

3. New facilities are encouraged to use native plant species as indicated on the current Plant List available from the Base Civil Engineer.

4 Trees should be the focus of landscape plantings and, where possible, should be a mix of deciduous and evergreen species for variety; provide tree grates when appropriate and use tree guards on smaller trees.

5. Ground covers are only recommended when minimal maintenance is required.

6. Turf areas should be limited to those that can be sustained by natural rainfall or grey water (non-potable) irrigation systems; turf may be defined by at-grade concrete mow strips to lessen maintenance.

7. Analyze soils and provide organic amendments as needed to improve plant growth and conserve water.

8. All plant material will have one-year warranty and is subject to approval by the Base Landscape Architect.

End of Section

C06.1.5. Water Budgeting (Hydrozones)

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188


Separation of Planting Areas


Rock Mulch Area with Trees


Tree as Site Accent

1. Comply with DoD and Air Force policy on potable-water irrigation systems.

2. Provide irrigation systems in new construction to establish plant materials following "Water for Landscaping" in UFC 1-200-02. Note the climate zone and annual rainfall for the locale.

3. New buildings will cost-effectively integrate a grey-water reclamation system following UFC 1-200-02, which provides source water for an automatic drip irrigation system; connect adaptive plantings adjacent to facilities to a grey-water irrigation system when available and discontinue the use of potable water for irrigation after the establishment period.

4. Provide irrigation design following UFC 3-201-02. Install drip irrigation products and components following UFGS Section 32 84 24 Irrigation Sprinkler Systems. Match the color of valve box lids to the adjacent ground treatment (i.e. green at turf & native seed areas, brown at wood mulch & rock areas).

5. Life cycle cost-effectively equip irrigation systems to sense soil moisture, rainfall and wind to minimize unnecessary watering; incorporate drip irrigation systems as the primary source.

C06.1.6. Base Entrance Landscaping

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 2 Image Tool 250 x 188


Rock Mulch and Decorative Boulders


Turf Area Near Main Entrance

1. At the main gate, reinforce a sense of arrival through a well-designed concentration of landscape elements consistent in visual quality with Facility Group 1.

2. Ensure landscaping has seasonal features with spring and fall color and a combination of evergreen and deciduous trees and shrubs for winter interest.

3. Integrate base signs and street and pedestrian lighting whenever feasible.

C06.1.7. Streetscape Landscaping

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188


Native Grasses


Attached Sidewalk and Retaining Wall


Xeric Planting in Median

1. Provide landscape designs with plant materials appropriately representing the level of quality of the adjacent Facility Group number. Refer to the Installation Elements section.

2. Select a variety of regionally appropriate streetscape plantings and grading to create a visual interest.


C06.1.8. Pedestrian Circulation Landscaping

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188


Grasses as Focal Point


Grasses and Trees


Native Grasses

1. Define walkways with landscaping where appropriate.

2. Provide rest areas along the pedestrian circulation network with human-scaled deciduous shade trees. Supplement tree plantings with finely textured shrubs when appropriate for the climate.

3. Provide wind breaks where required.

C06.1.9. Parking Lot Landscaping

◯ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ◯ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188


Grass Area Buffer


Rock Mulch and Trees


Grass Area Swale

1. Integrate appropriate landscaping elements into parking areas to visually soften the appearance at a minimum rate of 5 percent of the total area.

2. Avoid trees that drop sap, fruit, or seeds, and use long-lived species; keep trees trimmed, removing dead and dying trees or branches.

3. Provide planting in islands within parking lots for shade and appeal following IFS and the base stormwater management plan.

4. Rain garden islands will be landscaped to receive rainwater runoff from adjacent impervious parking areas to be absorbed into the ground/planting bed. Native plants and groundcovers are recommended within the rain garden areas, which can survive without supplemental irrigation once established.

C06.1.10. Screen/Accent Landscaping

◯ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ◯ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 2 Image Tool 250 x 188


Ornamental Accent Planting


Foundation Panting

1. Provide complimentary accent landscaping at monuments and static displays.

2. At Facility Group 1, provide landscaping adjacent to all freestanding signs without distracting from the written communication.

3. Provide landscape screening of utility elements adjacent to Facility Group 1.

4. Providing landscaping as visual screening is preferred to the construction of walls and fences; berming and mounding may supplement landscape screening.

C06.1.11. Other

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

C07. SITE FURNISHINGS

Comply with AF Corporate Standards for Site Development:
http://afcfs.wbdg.org/site-development/index.html

Comply with AF Corporate Standards for Site Furnishings:
http://afcfs.wbdg.org/site-development/site-furnishings/index.html

C07.1. Furnishings and Elements

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188


Benches at Main Entrance


Bollards and Railings at Entrance


Screen Enclosure

1. Provide a coordinated consistent inventory of site furnishings to positively contribute to the visual environment, image, and identity of the base; ensure durability, low maintenance, reduced visual clutter, and compatibility with the adjacent architecture.

2. Remove poorly located or redundant litter / ash receptacles, newspaper and bicycle racks, telephone booths, vending machines, walls and fences to reduce visual clutter and to lessen the requirements for maintenance.

3. Group 1 and 2 site furnishings will be determined by the designer and approved by the Base Architect. Group 3 and 4 site furnishings will be vinyl coated steel utilizing a mesh, open weave design. Generally match the site furniture of adjacent facilities and the facility district.

4. Install needed outdoor seating (benches and low walls) in public gathering spaces near main and secondary building entrances. Low walls will match facility architecture.

5. Benches in Groups 1, 2 and 3 will be determined by the designer and approved by the Base Architect. Provide vinyl coated aluminum benches in Group 4 and parks.

6. Integrate functional bicycle racks with the design of the building's main entrance grounds in Facility Groups 1 and 2 while meeting AT requirements.

7. Limit the use of bollards, but when necessary for force protection use pre-cast concrete non-illuminated bollards in Groups 1 and 2; steel pipe bollards in Group 3; and decorative aluminum bollards in Group 4 and parks and trails. Illuminated bollards may be used as approved on a case-by-case basis.

8. Locate architecturally coordinated containers for recycling, litter, ash, vending, etc., to minimize visual clutter and not visible from the building's main entrance. Minimize the use of freestanding planters.

9. Generally limit picnic tables, barbeque grills and drinking fountains to lodging, dormitories, housing areas, parks and recreation areas following IFS.

10. The Installation Flagpole location must comply with the guidance for the display of flags in AFI 34-1201. Each Air Force installation is authorized to fly one United States Flag, normally in front of the installation headquarters. Waivers for non-authorized locations must be submitted in accordance with AFI 33-360 and approved waivers (AF Form 679) must be maintained by the installation protocol office.

11. Refer to the Overview Section "Facility Hierarchy" topic of this AFCFS for guidelines regarding ancillary structures such as pavilions and shade shelters.

12. Bus shelters will be provided only where there is a documented need and when approved on a case-by-case basis. Generally emulate the designs of adjacent shelters using factory finished dark bronze finished metal structure.

13. Monuments and static displays will be limited. New elements are generally discouraged unless these are fully vetted through the base's approval process and designed following IFS.

14. When visual screening is necessary, consider landscaping as the first option; screen walls are permitted only in Group 1 finished and detailed with material to match the adjacent building. Do not use concrete masonry units (CMU) as an exposed finish for walls.

15. For fencing, apply the standards for "Products, Materials and Color" in the following section. Limit those with the highest visual quality to Facility Group 1 where there is sustained maintenance. Define all levels of security and visual quality.

16. Do not use chain-link fencing at Group 1, 2 or 4 facilities; Limit the use of barbed-wire outriggers on chain-link fencing at industrial sites, unless required for additional security or protection of assets.

17. Wood fencing may be used in Facility Group 4 and in recreation areas following IFS for material and finish when there is sustained periodic maintenance.

18. Provide trash dumpster enclosures for Group 1 with material and detailing to match adjacent facility and for Groups 2 and 3 with metal screen walls; all gates will be metal factory finished dark bronze finish.

19. Specify screen wall materials and finishes that do not require painting or maintenance beyond periodic cleaning.

20. Group 1, 2 and 3 picnic tables and seating will be precast concrete similar to benches. Group 4 and recreational areas will have vinyl-coated steel picnic tables and seating. Generally limit picnic tables, barbeque grills and drinking fountains to lodging, dormitories, housing areas, parks and recreation areas.

21. Limit the use of freestanding planters to areas with ongoing maintenance.

22. Provide kiosks only where there is a documented need for visual communication of posted messages. When used, match adjacent facilities in materials and detailing and consolidate kiosks with other site furnishings within 30 feet of major pedestrian paths. Limit kiosks to facility Groups 1 and 2 and parks.

23. Manufacturers listed in sections C07.2.1. - C07.2.18. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

C07.2. Site Furnishings Products, Materials and Color

Note: *Apply the below base-wide standards for Site Furnishings (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

C07.2.1. Barbeque Grills

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Charcoal**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☑ Other

Mfr: Most Dependable Fountains, Inc.

Color: Natural stainless steel

Finish: Mill

Model #: SS BBQ Grill

Other: Concrete foundation, coordinate with Base Architect

UFGS: N/A



Type: **Natural Gas**

Applies to: ☐ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☑ Other

Mfr: BBQ Coach

Color: Natural stainless steel

Finish: Mill

Model #: 32" 4-Burner

Other: Built-in Concrete or masonry, coordinate with Base Architect

UFGS: N/A

C07.2.2. Benches

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type:

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Materials, Inc.

Color: Weatherstone Gray

Finish: Standard Finish (Smooth)

Model #: Mesa, rectangular design

Other: N/A

UFGS: N/A

C07.2.3. Bike Racks

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☑ Other

Mfr: Brandir International Inc.

Color: Galvanized

Finish: Factory

Model #: The Ribbon Bike Rack, RB-07

Other: N/A

UFGS: N/A

C07.2.4. Bike Lockers

○ Applicable ◉ N/A

C07.2.5. Bollards

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Lighted Round Dome Top**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☑ Other

Mfr: Lithonia Lighting Products


Color: Dark bronze

Finish: Anodized aluminum

Model #: KBA

Other: Flared cone, 3000K LED Lamp

UFGS: N/A



Type: **Building Protection, steel**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☑ Other

Mfr: (Bollard Cover) Reliance Foundry

Color: Brown cover may be field painted dark bronze

Finish: Factory


Model #: 6" Steel pipe, concrete filled, Cover: R-7173

Other: A 1" (25.4 mm) rigid conduit and box with shroud may be provided at top of bollard with a receiver/key switch application

UFGS: N/A

C07.2.6. Bus Shelters

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **1**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☑ Group 4 ☑ Other

Mfr: Custom

Color: Dark Bronze

Finish: Powder coated

Model #: Gabled roof

Other: Provide concrete slab and 2 pre-manufactured aluminum benches

UFGS: N/A

C07.2.7. Drinking Fountains

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Pedestal**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☑ Group 4 ☐ Other

Mfr: Most Dependable Fountains, Inc.

Color: Natural

Finish: Stainless Steel


Model #: MDF 440 SMSS

Other: Accessible

UFGS: N/A

C07.2.8. Dumpster Enclosures / Gates

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **1: Brick and Steel**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom


Color: Red brick blend, dark brown doors

Finish: Face brick, powder coated doors

Model #: Match adjacent building

Other: Steel gates and hardware, dark brown, dumpsters will be painted dark brown

UFGS: Section 04 20 00 Unit Masonry



Type: **2: CMU and Steel**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom

Color: Beige CMU blend, dark brown doors

Finish: Split face CMU, powder coated doors


Model #: Match adjacent building

Other: Steel gates and hardware, dark brown, dumpsters will be painted dark brown

UFGS: Section 04 20 00 Unit Masonry

C07.2.9. Fencing

◉ Applicable ○ N/A Number of base standards 7 Image Tool 250 x 188



Type: **Style A Barrier: High security, high visibility**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom


Color: Dark bronze or black

Finish: Powder coated

Model #: Steel posts, rails and pickets (vertical, bent outward at top)

Other: Brick or split face CMU piers may be used

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications



Type: **Style B Barrier: High security, medium visibility**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom


Color: Dark bronze or black

Finish: Powder coat

Model #: Steel grid: flat bar stock verticals, round rod horizontals

Other: Steel posts, horizontal bars, braces, and accessories, in heights, lengths, and gauges as required; Close all ends of tubing

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications



Type: **Style C Barrier: High security, low visibility**

Applies to: ☐ Group 1 ☐ Group 2 ◉ Group 3 ☐ Group 4 ☐ Other

Mfr: General Wire Company


Color: Dark bronze or black

Finish: Powder coated galvanized steel

Model #: Chain link, steel posts and rails, gates and accessories

Other: N/A

UFGS: Section 32 31 13 Chain Link Fences and Gates



Type: **Style D Barrier: Low security, High visibility**

Applies to: ◉ Group 1 ◉ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom


Color: Beige brick blend, dark brown fencing

Finish: Face brick, powder coated metal

Model #: Brick Piers with steel posts, rails and pickets

Other: Brick: 2'x2' (Height as required, equally spaced 12' to 40'), Steel posts: 4"x4" (equally spaced), Rails: 2"x2", Pickets: 1"x1" (6"o.c.); close all ends of tubing

UFGS: Section 04 20 00 Unit Masonry, Section 05 50 13 Misc. Metal



Type: **Style E Barrier: Low security, High visibility**

Applies to: ☉ Group 1 ☉ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom

Color: Beige brick blend, dark brown fencing

Finish: Powder coated metal

Model #: Brick Piers with steel posts, rails and alternating panels

Other: Brick: 2'x2' (Height as required, equally spaced 8' to 40'), Steel posts: 4"x4" (equally spaced), Rails: 1-1/4"x1-1/2", vertical steel panels spaced alternately on each side of the rails; matching gates; close all ends

UFGS: Section 04 20 00 Unit Masonry, Section 05 50 13 Misc. Metal



Type: **Style F Barrier: Very low security, high visibility**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ☉ Group 4 ☉ Other

Mfr: Custom

Color: Integral mixed Davis Colors: dark warm gray

Finish: Factory

Model #: Post and rail

Other: Concrete 3-rail, wood-grain textured (4,000 psi at 28 days); Posts: 39" height, 8' spacing, set 30" deep below grade with footing, typical

UFGS: SECTION 03 33 00 Cast-In-Place Architectural Concrete



Type: **Style G Barrier (Alternate): Very low security, high visibility**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ☑ Group 4 ☐ Other

Mfr: James Hardie Building Products, Inc.

Color: Off white and Earth tones

Finish: Factory

Model #: Post and rail with vertical boards

Other: Posts: Height as required, 8' max. spacing; apply boards to outside face.

UFGS: Not Available (SECTION 074646 Fiber Cement Siding)

C07.2.10. Flagpoles

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **1**

Applies to: ☑ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Eder Flag

Color: Natural aluminum

Finish: Satin Lustre

Model #: ECL30 IH, Internal Halyard

Other: 5" Butt Dia. 33' H (30' Exposed)


UFGS: N/A

C07.2.11. Lighting – Landscape / Accent

Please refer to the Lighting section.

C07.2.12. Litter and Ash Receptacles

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Style 1: Precast concrete**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Materials, Inc.

Color: Weatherstone Gray

Finish: Smooth

Model #: TR-3225 Sante Fe (round or square)

Other: Rigid plastic internal liner, http://materialsinc.com/wp-content/uploads/2014/10/TR-3225_SANTA_FE.pdf

UFGS: N/A



Type: **Style 2: Metal**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☑ Other

Mfr: Wabash Valley

Color: Black or as approved

Finish: Perforated Pattern

Model #: Urbanscape "E" with liner, 32 Gallon

Other: With dome top, without side door

UFGS: N/A

C07.2.13. Picnic Tables

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Concrete, Round**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Belson

Color: White or brown

Finish: Ground & polished, or acid wash

Model #: TF312512, 4 seats

Other: N/A

UFGS: N/A



Type: **Steel, Rectangular**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ☑ Group 4 ☑ Other

Mfr: Wabash Valley

Color: Brown top and seats, black base

Finish: Factory


Model #: Signature Series, 46" Square Pedestal Tables with 4 Seats

Other: Perforated pattern, in-ground mount

UFGS: N/A

C07.2.14. Planters

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Precast concrete**

Applies to: ☑ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Materials, Inc.

Color: Weatherstone Gray

Finish: Smooth

Model #: Santa Fe

Other: N/A

UFGS: N/A

C07.2.15. Play Equipment

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Steel**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ☑ Group 4 ☑ Other

Mfr: Little Tikes Commercial

Color: Varies

Finish: Powdercoated Steel


Model #: N-R-G Freestyle

Other: Coordinate with Base Architect

UFGS: N/A

C07.2.16. Screen Walls

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Brick / Steel**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom

Color: Beige brick blend, dark brown fencing

Finish: Powder coated metal

Model #: Brick Piers with steel posts, rails and alternating panels

Other: Brick: 2'x2' (Height as required, equally spaced 8' to 40'), Steel posts: 4"x4" (equally spaced), Rails: 1-1/4"x1-1/2", vertical steel panels spaced alternately on each side of the rails; matching gates; close all ends

UFGS: Section 04 20 00 Unit Masonry, Section 05 50 13 Misc. Metal

C07.2.17. Tree Grates

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Cast Iron**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Neenah Enterprises, Inc.

Color: Natural cast iron

Finish: Cast

Model #: 2-Piece, round or square

Other: N/A

UFGS: N/A

C07.2.18. Other

○ Applicable ◉ N/A

1. Not applicable.

C08. EXTERIOR SIGNS

Comply with AF Corporate Standards for Site Development:
http://afcfs.wbdg.org/site-development/index.html

Comply with AF Corporate Standards for Exterior Signs:
http://afcfs.wbdg.org/site-development/exterior-signs/index.html

C08.1. Colors and Types

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Aluminum Standout Letters



Pedestal Sign at Group 1


Wall Mounted Sign

1. Provide concise functional signs as a visually unifying element with consistent colors and types for all Installation and Gate Identification Signs; Building Identification Signs; Traffic Control Devices; Directional and Wayfinding Signs; and Informational and Motivational Signs.

2. Provide signs with the lowest overall life cycle costs considering initial cost, ongoing maintenance and lifespan while meeting quality standards. Follow IFS for specifications appropriate for the local climate to withstand weathering.

3. Reduce the number of signs, reduce visual clutter and provide only essential signs required for identification, directions, instructions, and customer service following UFC 3-120-01. Remove non-conforming signs during renovation projects.

4. Use clear concise terms for content consistent with UFC 3-120-01.

5. Display of emblems on building exterior walls or other permanent structures is prohibited by UFC.

6. Raised “standout” letters and numbers may be used for Group 1 with approval on a case-by-case basis.

7. Group 2 and 3 facilities will have wall mounted facility signs with sizes and layouts following UFC 3-120-01. Signs are not permitted for Group 4 facilities.

8. Only one identification sign is permitted at each building entrance. Include a building address consistent with US Postal Service protocols following UFC 3-120-01.

9. Traffic Control Devices, which regulate vehicular traffic on the installation, must conform to the standards in the Manual of Uniform Traffic Control Devices (MUTCD) published by the Federal Highway Administration. Coordinate street signs with this IFS.

10. Provide Directional and Wayfinding Signs and address both pedestrian and vehicular traffic following UFC 3-120-01 for size, layout and content.

11. Reserved parking signs should be kept to a minimum. When approved, provide post-mounted sign faces in base standard materials and colors. Consider "bracketing" a designated area with a single sign at each end.

12. Parking lot identification signs may be used to identify areas or rows within large lots.

13. Follow the guidelines and requirements in ABAAS and the MUTCD for accessible parking signs.

14. Follow UFC 3-120-01 for Informational and Motivational Signs for size, layout and content.

15. Symbols or pictographs (graphic expressions of actual objects) may be used to indicate service, mandatory / prohibitory, sports, and recreation when rapid communication is necessary.

16. Force Protection signage may be applied to glass doors using white vinyl lettering.

17. Refer to UFC 3-120-01 for prohibited signs, which include those with animated, blinking, chasing, flashing, or moving effects.

18. Manufacturers listed in sections C08.1.1. - C08.1.10. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

C08.1.1. Materials and Color Specifications

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 1 Image Tool 250 x 188



Wayfinding Sign

1. Fabricate sign panels from aluminum sheet, minimum 12 gauge for durability. Sign posts will be powder coated steel with capped ends in a concrete base.

2. Fence mounted sign panels may be attached with exposed fasteners.

3. All signage must follow Federal Highway Administration (FHWA) Manual on Uniform Traffic Control Devices (MUTCD) using standard colors. Refer to MUTCD color specifications, which provide cross-referenced Pantone Matching System (PMS) numbers.
   a. Standard Blue
   b. Standard Dark Bronze (also Federal Standard Color 30040)
   c. Standard Red
   d. Standard Black (non-reflective)
   e. Standard White
   f. Standard Brown

Continue to the Next Page

Materials and Color Specifications

◉ Applicable ○ N/A Number of base standards 3 Image Tool 250 x 188



Type: **Typical Sign Fce**

Applies to: ◉ Group 1 ◉ Group 2 ◉ Group 3 ☐ Group 4 ◉ Other

Mfr: Custom


Color: Medium bronze

Finish: Matte vinyl

Model #: Aluminum flat sheet

Other: Mount to square posts. Provide sizes following UFC.

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications



Type: **Typical Sign Post**

Applies to: ◉ Group 1 ◉ Group 2 ◉ Group 3 ☐ Group 4 ◉ Other

Mfr: Custom


Color: Dark bronze, powder coat finish

Finish: Matte

Model #: Extruded aluminum with capped top ends

Other: Square posts and squared ends. Provide engineered sizes.

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications



Type: **Typical Sign Base**

Applies to: ◉ Group 1 ◉ Group 2 ◉ Group 3 ☐ Group 4 ◉ Other

Mfr: Custom

Color: Natural Gray

Finish: Sonotube-formed


Model #: 24" height x 12" diameter, as engineered.

Other: At grade with 3/4" chamfer. Provide engineered sizes.

UFGS: UFGS 03 30 00 Cast-in-place Concrete

C08.1.2. Installation and Gate Identification Signs

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Primary, Secondary and Tertiary (Uses per UFC)**

Applies to: ◉ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom

Color: Dark bronze, brushed aluminum, accents per UFC

Finish: Powder coat or vinyl sign face


Model #: Metal frame and panels, buff stone base

Other: White vinyl lettering. Provide dimensions per UFC. Secondary signs will match primary sign's materials, but will be smaller in size per UFC. Tertiary signs will follow the UFC.

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications

C08.1.3. Building Identification Signs

◉ Applicable ○ N/A Number of base standards 5 Image Tool 250 x 188



Primary: Group 1

Type: **Freestanding Primary Sign (Sizes and Uses per UFC)**

Applies to: ◉ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom


Color: Medium brown face, dark bronze posts, white vinyl lettering

Finish: Powder coat or vinyl sign face

Model #: Aluminum sheet face, extruded aluminum posts

Other: Provide layout and sizes per UFC.

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications



Secondary: Group 2

Type: **Freestanding Secondary Sign (Sizes and Uses per UFC)**

Applies to: ☐ Group 1 ◉ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom


Color: Medium brown face, dark bronze posts, white vinyl lettering

Finish: Powder coat or vinyl sign face

Model #: Aluminum sheet face, extruded aluminum posts

Other: Provide layout and sizes per UFC.

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications



Type: **Freestanding Tertiary Sign (Sizes and Uses per UFC)**

Applies to: ☐ Group 1 ☐ Group 2 ☑ Group 3 ☐ Group 4 ☑ Other

Mfr: Custom


Color: Medium brown face, dark bronze posts, white vinyl lettering

Finish: Powder coat or vinyl sign face

Model #: Aluminum sheet face, extruded aluminum posts

Other: Provide layout and sizes per UFC.

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications



Type: **Wall Mounted**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom

Color: Medium brown, white lettering

Finish: Satin vinyl applied to aluminum sheet

Model #: Aluminum sheet with vinyl face and vinyl lettering

Other: Provide layout and sizes following UFC.

UFGS: N/A



Type: **Glass Mounted**

Applies to: ☑ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom

Color: White vinyl lettering

Finish: Matte vinyl

Model #: Machine-cut sheet vinyl

Other: Apply vinyl lettering to glass. Provide sizes following UFC.

UFGS: N/A

C08.1.4. Traffic Control Devices (Street Signs)

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Street Signs**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☑ Group 4 ☐ Other

Mfr: Custom

Color: White reflective lettering on a Standard Brown background

Finish: Powder coat or vinyl sign face


Model #: Aluminum sign face, control arm or pole mounted

Other: Mount 7' above grade minimum, pictographs and logos are prohibited on street name signs per UFC.

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications

C08.1.5. Directional and Wayfinding Signs

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Vehicular**

Applies to: ◉ Group 1 ◉ Group 2 ◉ Group 3 ◉ Group 4 ◉ Other

Mfr: Custom


Color: Medium brown face, dark bronze posts, white reflective lettering

Finish: Powder coat or vinyl sign face

Model #: Aluminum sheet face, extruded aluminum posts

Other: Conform to the requirements of the MUTCD and its DoD Supplement. Provide types and sizes where required by UFC.

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications



Type: **Pedestrian**

Applies to: ◉ Group 1 ◉ Group 2 ◉ Group 3 ◉ Group 4 ◉ Other

Mfr: Custom

Color: Medium brown face, dark bronze posts

Finish: Powder coat or vinyl sign face

Model #: Aluminum sheet face, extruded aluminum posts

Other: White vinyl lettering. Provide types and sizes where required by UFC.

UFGS: Section 05 50 13 Miscellaneous Metal Fabrications

C08.1.6. Informational Signs

○ Applicable ◉ N/A Large graphics do not apply

○ Applicable ◉ N/A Small graphics do not apply

1. Minimize informational signs such as static display signs, hours of operation, and project signs to reduce visual clutter.

2. Static display signs will have standard brown color.

3. Hours of operation signs will have a level of quality equivalent to the Facility Group number.

4. Temporary / Project Signage will be judiciously placed to avoid visual clutter. Schedule and arrange for the removal of these signs prior to installation.

C08.1.7. Motivational Signage

◯ Applicable ◉ N/A Large graphics do not apply

◯ Applicable ◉ N/A Small graphics do not apply

1. Provide professionally produced motivational signs as important elements of campaigns to boost morale, improve safety, aid in recruiting, and accomplish other motivational objectives. Consolidate this signage to reduce visual clutter.

2. Motivational signs will be limited to an electronic "marquee" type changeable sign near each gate. Temporary signs are not permitted. Motivational information may also be posted in a small, printed format on kiosks in specified, high pedestrian use areas. Refer to kiosks under Site Furnishings.

3. Follow UFC 3-120-01 for color and layout. Note that animated, blinking, chasing, flashing, or moving effects are prohibited by the UFC.

4. Mount marquee signs on reinforced concrete bases with a natural warm gray color.

C08.1.8. Parking Lot Signs

◯ Applicable ◉ N/A

C08.1.9. Regulatory Signs

◯ Applicable ◉ N/A

1. Regulatory signage, which restricts, warns and advises, will be limited to those mandated under Highway/Traffic, Government Warning, and/or Parking Regulation. Follow UFC 3-120-01 and its industry references for color and layout.

2. Provide a comprehensive, systematic approach to regulatory signage to avoid clutter and confusion from “over signage.”

3. Maintain base warning signs for safety and security at the base perimeter and at specific secure areas. Use these to notify visitors of restrictions governing conduct on the base, as well as other security procedures.

End of Section

C08.1.10. Other

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Cast Aluminum Letters**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: A.R.K. Ramos, GEMINI

Color: Dark bronze, Natural Aluminum

Finish: Clear, Medium bronze, Bronze Anodized

Model #: F-4 Aluminum, F-6M Aluminum, F-8 Bronze

Other: Coordinate location and mounting with CES

UFGS: Section 10 14 00.10 Exterior Signage

End of Section

C09. LIGHTING

Comply with AF Corporate Standards for Site Development:
http://afcfs.wbdg.org/site-development/index.html

Comply with AF Corporate Standards for Lighting:
http://afcfs.wbdg.org/site-development/lighting/index.html

C09.1. Fixtures and Lamping

○ Applicable ◉ N/A Large graphics do not apply

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Street Lighting



Parking Lot Lighting



Pedestrian Circulation Lighting

1. Provide, coordinate and efficiently install street, parking lot, sidewalk and facility lighting with appropriate luminaires, lamping, placement and spacing following UFC 3-530-01 and Installation Facilities Standards (IFS); ensure the level of quality is consistent with the adjacent facility group number. Pole-mounted, wall-mounted and bollard fixtures are permitted.

2 Integrate controls to automatically reduce lighting power during periods of non-activity; automatically turn off power when sufficient daylight is available.

3. Ensure continuity and consistency of lighting elements. In new construction generally match post types, fixture types, styles, heights, sizes, materials, colors, and lamp types of adjacent facilities and the facility district.

4. Economically provide renewable-energy power sources such as solar photovoltaic when feasible.

5. Use appropriately designed or shielded luminaires to direct light downward to minimize light pollution and intrusion onto adjacent sites and to facilitate night training.

6. Calculate illuminant levels for all lighting applications following UFC 3-530-01 and ensure compliance with pre-curfew maximum brightness level requirements.

7. Sufficiently address environmental factors to prevent corrosion and weathering of fixtures, plinths and other components.

8. Wall mounted fixtures should respond to the architectural character of the facility.

9. Efficient accent lighting of architectural and landscape features may be provided for Group 1, lodging and historical applications. Accent lights in ground-mounted locations may be provided for static displays and signs when these do not conflict or cause hazards with overhead aircraft.

10. Comply with UFC 3-530-01 for light source technology and lamp types. High efficiency lamping such as LED is preferred for most applications.

11. Provide round tapered, square non-tapered, or round non-tapered aluminum poles and aluminum fixtures with square, rectangular or circular housings in colors and shapes to match adjacent facilities and the facility district.

12. Install lighted bollards only at Group 1 and high-traffic Group 2 facilities. Generally match materials, colors and shapes of adjacent facilities and the facility district.

13. Install natural warm gray color, smooth finished concrete bases for all poles in heights appropriate for the facility group and application. Generally Groups 1, 2 and 4 will have at-grade bases. Group 3 will have taller bases for added durability.

14. When parking lot lighting is necessary, provide an illuminated path to the building's main entrance. Pole bases should be contained within an internal landscape median or island.

15. To facilitate snow removal in parking lots, ensure pole lighting is on the outside perimeter of lot.

16. Consistently install lighting for sidewalks, bikeways and trails to match adjacent facilities.

17. Landscape accent lighting may be used in public gathering spaces and in Group 1 facilities. Coordinate the design, luminaire selection, and placement with the location of trees, shrubs, and site furnishings.

18. All parking lot poles will be brown, hurricane proof, 4" square tube style LED. Height dependent upon application/coverage.

19. All streetlight poles will be metal, hurricane proof, tapered with LED streetlight matching existing lighting on base.

20. All bases will be concrete and extended 30" above ground level.


21. Manufacturers listed in sections C09.2.1. - C09.2.6. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

C09.2. Light Fixture Types

Note: *Apply the below base-wide standards for Light Fixtures (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

C09.2.1. Street Lighting

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☑ Group 4 ☑ Other

Mfr: Hubbell, Kim Lighting


Color: Dark bronze anodized (or clear anodized as approved by BCE)

Finish: Factory

Model #: Rectilinear Cutoff, Single Arm or Dual Arm Mount

Other: Lamp: LED. Follow manufacturer's recommendations for fixture base.

UFGS: N/A



Type: **Style 2**

Applies to: ☑ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Hubbell, Kim Lighting

Color: Clear anodized as approved by BCE

Finish: Factory


Model #: Round Cutoff, Single Arm or Dual Arm Mount

Other: Lamp: LED. Follow manufacturer's recommendations for fixture base.

UFGS: N/A

C09.2.2. Parking Lot Lighting

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Parking Lot Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☑ Other

Mfr: Hubbell, Kim Lighting


Color: Dark bronze anodized (or clear anodized as approved by BCE)

Finish: Factory

Model #: Rectilinear or Round Cutoff, Single Arm or Dual Arm Mount

Other: Lamp: LED. Follow manufacturer's recommendations for fixture base.

UFGS: N/A



Type: **Parking Lot Fixture Base**

Applies to: ◉ Group 1 ◉ Group 2 ◉ Group 3 ☐ Group 4 ◉ Other

Mfr: Custom

Color: Natural gray

Finish: Trowel

Model #: Form-cast, round

Other: N/A

UFGS: Section 03 33 00 Cast-In-Place Architectural Concrete

C09.2.3. Lighted Bollards

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Lighted Round Dome Top**

Applies to: ◉ Group 1 ◉ Group 2 ☐ Group 3 ☐ Group 4 ◉ Other

Mfr: Lithonia Lighting Products

Color: Dark bronze

Finish: Anodized aluminum


Model #: KBA

Other: Flared cone, 3000K LED Lamp. Follow manufacturer's recommendations for fixture base.

UFGS: N/A

C09.2.4. Sidewalk Lighting

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Rectilinear Cutoff**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☑ Other

Mfr: Hubbell, Kim Lighting

Color: Dark Bronze Anodized (or Clear Anodized as approved by BCE)

Finish: Anodized aluminum

Model #: Rectilinear Cutoff, Single Arm or Dual Arm Mount

Other: Lamp: LED. Follow manufacturer's recommendations for fixture base.

UFGS: N/A

C09.2.5. Walls / Stairs Lighting

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Vista Lighting

Color: Dark bronze anodized

Finish: Smooth

Model #: Aluminum Step and Brick Lights, 5230 round louvered

Other: Lamp: LED

UFGS: N/A

C09.2.6. Other

○ Applicable ◉ N/A

D. FACILITIES EXTERIORS

Comply with Air Force Corporate Standards for Facilities Exteriors:
http://afcfs.wbdg.org/facilities-exteriors/index.html

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Optimum Orientation with Shading and Daylighting Features



Generous Functional Overhangs



Entrance Expressed as a Feature



Horizontal Emphasis in Massing

D01. SUPPORTING THE MISSION

Comply with AF Corporate Standards for Supporting the Mission:
http://afcfs.wbdg.org/facilities-exteriors/supporting-the-mission/index.html

D02. SUSTAINABILITY

Comply with Air Force Corporate Standards for Sustainability:
http://afcfs.wbdg.org/facilities-exteriors/supporting-the-mission/index.html

D03. ARCHITECTURAL FEATURES

Comply with AF Corporate Standards for Facilities Exteriors:
http://afcfs.wbdg.org/facilities-exteriors/index.html

Comply with AF Corporate Standards for Architectural Features:
http://afcfs.wbdg.org/facilities-exteriors/architectural-features/index.html

Insert 3 photos for each facility group.

Image Tool 250 x 188

Group 1





Group 2





Group 3





Group 4





D03.1. Orientation, Massing and Scale

1. Orient new buildings to maximize energy efficiency, passive solar and daylighting potential of the building; narrow buildings oriented along an east-west axis are preferred to minimize heat gain in the summer months and maximize heat gain in the winter months resulting in less overall energy usage.

2. Provide orthogonal geometry for principal building form; angular geometry may be used sparingly for Group 1 and used only for emphasis at specific areas such as building entrances and stairwells.

3. Maintain a human scale and reduce the visual scale of large buildings with sub-massing related to interior functional operations; create consistent form and scale in adjacent buildings with compatible profiles or silhouettes.

(●) Applicable ( ) N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

(●) Applicable ( ) N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Orientation and Massing with Deep Overhangs and Colonnades for Shading



Functional Daylighting Feature



Massing Used to Define Entrance



Massing Articulated at a Human Scale

4. Building heights will not be limited; however, building heights over 2 stories will be considered on a case basis.

5. Combine functions where practical to avoid a proliferation of small, independent structures.

6. Use and coordinate shading devices with orientation and for function.

D03.2. Architectural Character

1. Develop architectural features, materials and detailing appropriate for the Facility Group designation. Refer to Building Entrances, Wall Systems and Roof Systems.

2. Respond to the local climate and regional influences with environmentally functional architectural features.

3. For new facilities design generally maintain consistency and visual unity in the character of the adjacent buildings through compatible architectural features: repeated use of similar forms such as roofs, and through recurring elements such as doors, windows, materials and colors.

4. Reinforce the campus environment and educational theme with a related architectural theme expressive of innovation and technology that represents the current Air Force Global Strike Command mission.

5. Emphasize the "Prairie Modern" style unique to Ellsworth Air Force Base. It consists of broad, strong, horizontal masonry wall elements (recalling the linearity of the prairie) into which are inserted light, vertically oriented, (often glazed) elements which serve as visual landmarks as well as points of entry. While the Rushmore Center clearly stands out as the apex of the "Prairie Modern" style on the base, the 37th Bomb Squadron Life Support Facility at 129 Ryan Street and the 28th Bomb Wings Headquarters and Operations Building on Scott Drive all exemplify elements of the "Prairie Modern" style.

(●) Applicable ( ) N/A Select number of graphics / images (large: 800 px x 440 px) to insert 2 Image Tool 800 x 440

(●) Applicable ( ) N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Broad, Strong, Horizontal Elements



Base Standard Materials



Predominant Use of Brick



CMU Base



Group 4 Residential Materials

6. All facilities will express sustainability through their orientation, massing, shape, form, materials, and detailing. Provide louvers, fins and other shading devices to control heat gain and glare and to and improve energy efficiency.

7. Strive for economical construction without compromising a high-quality, professional appearance.

D03.3. Details and Color

1. Provide a palette of earth-tone colors related to the native landscape in brick, block, stucco and powder-coated metals. Refer to wall systems for detailed material listings.

2. Relate the level of architectural detailing to the Facility Group number.

3. Use only integrally colored materials as the predominant exterior building material; do not use materials that require field painting and ongoing maintenance.

4. Provide consistent and compatible colors for every exterior building feature, including walls, roofs, doors, windows, gutters, downspouts, utility and mechanical elements, and other visible elements.

◉ Applicable ○ N/A Select number of graphics / images (large: 800 px x 440 px) to insert 1 Image Tool 800 x 440

◉ Applicable ○ N/A Select number of graphics / images (small: 250 px x 188 px) to insert 3 Image Tool 250 x 188



Base Standard Materials and Colors Detailed for Group 3



Variation in Color Affecting Scale



Details Used Prominently at Main Entrance



Coordinated Materials, Details and Color

5. Noncorrosive metals with factory applied color finishes are required.

6. Combine details and color with orientation, massing, scale and architectural character to maintain base compatibility.

7. Manufacturers listed in sections D03.3.2. - D03.3.7. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

End of Section

D03.3.1. Climate-based Data and Life-Cycle Cost-Effective Passive and Natural Design Strategies:

- ○ Climate dominated by mechanical cooling
- ◉ Climate dominated by mechanical heating
- ○ Climate with similar mechanical cooling / heating needs
- ○ Climate with minimal mechanical cooling / heating needs

- ○ Climate with high humidity
- ○ Climate with moderate humidity
- ◉ Climate with low humidity

- ◉ High Solar Insolation
- ○ Moderate Solar Insolation
- ○ Low Solar Insolation

- ○ Soils with High Thermal Conductivity
- ◉ Soils with Average Thermal Conductivity
- ○ Soils with Low Thermal Conductivity

Other: Proximity to medium-high wind power class

Other: None at this time

Facility: Narrow buildings along E-W axis are preferred

Wall: Integral shading features and devices / interior masonry thermal mass walls (for heating)

Doors: Recessed are preferred

Windows: Limit north-facing windows / maximize windows on south façades with shading

Roof: High to medium albedo, minimal to moderate slope

Structure: Do not expose ferrous metals. Provide factory finished non-ferrous metals or concrete

MEP: Ground-source and solar photovoltaic following LCCA

Other: Optimize shading devices to provide summer shade and allow winter solar heat gain

Other: Internal thermal mass walls may be used for heating following LCCA

Note: *Apply the below base-wide standards for Architectural Features (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

D03.3.2. Natural Ventilation System

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1 Aluminum Windows**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Kawneer (or equivalent)

Color: Dark Bronze (or clear anodized as approved by BCE

Finish: Anodized

Model #: 2x4, slider or awning type

Other: Provide thermally broken frames.

UFGS: Section 08 41 13 Aluminum-Framed Entrances and Storefronts

D03.3.3. Thermal Mass

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1 Interior Wall Material**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom, TBD

Color: Red brick blend

Finish: Light texture

Model #: Coursed unit masonry

Other: Brick is preferred. Concrete block may only be used in Group 3 when approved by the BCE.

UFGS: Section 04 20 00 Unit Masonry

D03.3.4. Thermal Shading

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1 Wall Devices**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Kawneer (or equivalent) or custom

Color: Dark bronze

Finish: Factory, to match frames


Model #: Louver

Other: Shading devices may be attached to frames or structure

UFGS: Section 08 41 13 Aluminum-Framed Entrances and Storefronts

D03.3.5. Renewable Heating/Cooling

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1 Geothermal (Ground Source)**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☑ Group 4 ☐ Other

Mfr: Climate Master

Color: N/A

Finish: N/A

Model #: N/A

Other: Vertical ground loop well field

UFGS: Section 23 81 47 Water-Loop and Ground-Loop Heat Pump Systems

D03.3.6. Solar Photovoltaic System

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Roof-Mounted PV Panels**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☑ Group 4 ☐ Other

Mfr: TBD

Color: Factory

Finish: Matte

Model #: Flat plate collector

Other: Coordinate installation with roofing manufacturer

UFGS: Section 26 31 00 Solar Photovoltaic (PV) Components



Type: **Ground-Mounted PV Panels**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☑ Other

Mfr: TBD

Color: Factory

Finish: Matte

Model #: Flat plate collector, fixed or tracking

Other: Coordinate with local utility provider

UFGS: Section 48 14 00 Solar Photovoltaic Systems

D03.3.7. Solar Thermal System

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Wall-Mounted or Roof-Mounted Panels**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☑ Group 4 ☑ Other

Mfr: TBD

Color: Factory

Finish: Matte

Model #: Flat plate collector

Other: N/A

UFGS: Section 48 14 13 Solar Liquid Flat Plate And Evacuated Tube Collectors

D04. BUILDING ENTRANCES

Comply with AF Corporate Standards for Facilities Exteriors:
http://afcfs.wbdg.org/facilities-exteriors/index.html

Comply with AF Corporate Standards for Building Entrances:
http://afcfs.wbdg.org/facilities-exteriors/building-entrances/index.html

Insert 3 photos for each facility group.

Image Tool 250 x 188

Group 1





Group 2





Group 3





Group 4





D04.1. Primary Entrances

1. Emphasize the primary entrance in the overall building design with a projecting or recessed covering for weather protection following Installation Facilities Standards (IFS) for Facility Group designations.

2. Provide vestibules at entries in Groups 1, 2 and 3 unless used infrequently or serving unconditioned space following ASHRAE 90.1.

3. Fully integrate all elements including the design of handicap ramps in the overall design of the primary entrance in an organized uncluttered appearance.

4. Install paved transitional spaces sized for the building function and occupancy.

5. Install appropriate lighting and site furniture following AT and IFS.

6. Protect entrances in cold climates from falling ice and snow.

7. Provide porte cocheres or covered drop-offs when justified for lodging and medical facilities; do not use for prestige or architectural accents.

D04.2. Secondary Entrances

1. Provide vestibules at entries in Groups 1, 2 and 3 unless used infrequently or serving unconditioned space following ASHRAE 90.1; use of stair towers as vestibules for multi-story buildings is encouraged when building and / or energy codes are satisfied.

2. Reflect the character of the primary entrance to a lesser extent with a smaller scale.

3. Include a recess or projection for weather protection and shading.

4. Integrate service and egress doors and loading areas with the building design by matching the materials and detailing and reflect the overall quality of the facility.

5. Incorporate egress structures such as stair towers into the facility design.

6. Canopies may be used for service and loading areas; weather protection beyond weatherstripping is not required at doors used only for life safety egress.

7. Develop building massing and orientation to minimize the appearance of service and loading areas; physically and visually separate these from primary entrances.

8. Loading areas must be organized, orderly and have an uncluttered appearance.

End of Section

D05. WALL SYSTEMS

Comply with AF Corporate Standards for Facilities Exteriors:
http://afcfs.wbdg.org/facilities-exteriors/index.html

Comply with AF Corporate Standards for Wall Systems:
http://afcfs.wbdg.org/facilities-exteriors/wall-systems/index.html

Comply with AFCFS Recommended Materials:
http://afcfs.wbdg.org/facilities-exteriors/wall-systems/materials/index.html

Insert 3 photos for each facility group.

Image Tool 250 x 188

Group 1





Group 2





Group 3





Group 4





D05.1. Hierarchy of Materials

1. Group 1 facilities may have more refined detailing than Group 2 and Group 2 may have more definition than Group 3.

2. Group 1 and 2 facilities will be a combination of brick masonry or, alternatively, integrally colored split face or ground face concrete masonry units (CMU). Buildings should be limited to one primary type of masonry, with an option to include an accent feature of a complementary type and/or color.

3. Multi-story Group 1 facilities may include a transition in material, color or detailing to create a visual base.

4. Brick masonry walls may be accented with precast concrete bases, string courses and/or cornices. In addition, patterning of the brick is encouraged to provide a sense of scale to the buildings.

5. Patterning of CMU walls, such as the insertion of half-height courses, is encouraged for achieving a human scale. Provide patterning in CMU to articulate building entrances.

6. All CMU and mortar should be manufactured and installed with additives to discourage efflorescence.

7. Small-scale Group 3 facilities will be compatible with adjacent facilities and may use CMU, metal panels or metal sheeting.

8. Large-scale Group 3 facilities, generally located along the Flight Line and in the Facilities Engineering District, should be predominantly metal panels or metal sheeting with a masonry base. Brick or integrally colored split face or ground face CMU may be used as a base matching the material, height and color of adjacent administrative or support structures.

9. Metal wall panels should be factory-finished aluminum or galvanized steel. Ribbed metal sheeting is acceptable for Group 3 facilities and inconspicuous areas of Group 2 facilities. Refer to Appendix F for special requirements of Facility Districts.

10. Group 4 will be a combination of fiber cement horizontal siding and accents of brick.

11. Generally limit materials and type, i.e., brick to a single color on Group 2, 3 and 4 facilities.

12. Use high-performance building envelopes following UFC 1-200-02.

13. Use detailing that is not subject to excessive weathering. Provide wall accents consistently throughout the base.

14. Use integrally colored materials and factory-finished metals. Do not paint concrete block.

15. Manufacturers listed in sections D05.4.1. - D05.4.13. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

D05.2. Layout, Organization and Durability

1. Organize wall components including doors, windows, accents, shading devices, control joints, etc., to provide an ordered, professional appearance.

2. Integrate shading devices into the overall composition of the wall.

3. Integrate fixed shading devices as at all exterior glazing exposed to summer UV heat gain as a passive design measure to reduce energy use. Ensure adequate shading at west entrances. Deciduous trees may be used for shading.

4. Shading systems may be included as part of a manufacturer's window system or may be custom systems integrated into the wall.

5. Provide appropriate transitions between dissimilar materials to mitigate effects of thermal expansion and galvanic action.

6. All joint sealants will be slightly darker than adjacent surfaces.

7. Materials requiring regular maintenance are not permitted; do not use exposed structural steel or other materials that require painting.

8. Refer to C07.2.16. Screen Walls for materials and colors of freestanding walls.

9. Refer to D07. Roofs for downspouts.

D05.3. Equipment, Vents and Devices

1. Arrange all mechanical, electrical, fire alarm, lightning protection and other system components to create an orderly appearance that integrates with the wall system.

2. Do not expose conduits, cables, piping, lightning protection components, etc. on exterior walls; if unavoidable in renovations, finish these elements to match the adjacent wall surface.

3. Avoid visual clutter and where surface-mounted elements are required they will match the wall color.

D05.4 Wall Systems Materials

Facility Group 1 wall materials will be as follows.

Primary:	Brick or Concrete Masonry Units (CMU)
Secondary:	Architectural Precast (with Brick)
Accent:	Optional: Metal Panels with BCE approval

Facility Group 2 wall materials will be as follows.

Primary:	Brick or Concrete Masonry Units (CMU)
Secondary:	Architectural Precast (with brick)
Accent:	Alternate Coursing and Relief (with CMU)

Facility Group 3 wall materials will be as follows.

Primary:	Ribbed Metal Sheeting
Secondary:	Brick or CMU Base
Accent:	Optional: Metal Sheeting in Alternate Color

Facility Group 4 wall materials will be as follows.

Primary:	Fiber Cement Siding
Secondary:	Fiber Cement Siding, Trim Boards
Accent:	Brick

Note: *Apply the below base-wide standards for Wall Systems (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

D05.4.1. Flat Metal Panels

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: 3A Composites

Model #: Alucobond Plus Anodized Collection

Color: Neutral colors, silver and warm gray

Finish: Anodized

Other: "V" route and return, vertical or horizontal expansion joints

UFGS: Section 07 42 13 Metal Wall Panels:
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 07 42 13.pdf
Section 07 42 63 Fabricated Wall Panel Assemblies:
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 07 42 63.pdf

D05.4.2. Brick Veneer

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Modular Face Brick**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☑ Group 4 ☐ Other

Mfr: Local, TBD

Model #: Face brick

Color: Red blend

Finish: Straight edges, smooth texture

Other: Nominal size: 4x8x2.6

UFGS: Section 04 20 00 Unit Masonry:
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 04 20 00.pdf

D05.4.3. Architectural Precast

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Coursed Precast**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Local, TBD

Model #: Smooth casting

Color: Light beige

Finish: Very light texture

Other: N/A

UFGS: Section 03 45 00 Precast Architectural Concrete:
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 03 45 00.pdf

D05.4.4. Stucco Over Sheathing

○ Applicable ◉ N/A

D05.4.5. Curtain Wall

○ Applicable ◉ N/A

D05.4.6. Cast-In-Place Concrete

○ Applicable ◉ N/A

D05.4.7. Tilt-Up Concrete

○ Applicable ◉ N/A

D05.4.8. Ribbed Metal Sheeting

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Lap Seam**

Applies to: ☐ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Berridge

Model #: Lap Seam Panel

Color: Silver or dark bronze per BCE approval

Finish: Ribbed texture, factory finished

Other: 24 Gauge Steel

UFGS: Section 07 42 13 Metal Wall Panels:
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 07 42 13.pdf

D05.4.9. EIFS

○ Applicable ◉ N/A

D05.4.10. GFRC

○ Applicable ◉ N/A

D05.4.11. Concrete Block

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Concrete Masonry Unit (CMU) Ground Face**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Local TBD


Model #: 8x8x16 nominal, face and corner units

Color: Light or medium beige

Finish: Ground with exposed aggregate

Other: N/A

UFGS: Section 04 20 00 Unit Masonry:
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 04 20 00.pdf



Type: **Concrete Masonry Unit (CMU) Split Face**

Applies to: ◉ Group 1 ◉ Group 2 ◉ Group 3 ☐ Group 4 ☐ Other

Mfr: Local TBD

Model #: 8x8x16 nominal, face and corner units

Color: Medium beige or dark tan

Finish: Heavy texture

Other: N/A

UFGS: Section 04 20 00 Unit Masonry:
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 04 20 00.pdf

D05.4.12. Fiber Cement Siding

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ◉ Group 4 ☐ Other

Mfr: James Hardie Building Products, Inc.

Model #: Horizontal Lap Siding, Shingle Siding

Color: Earth tones

Finish: Wood texture

Other: Hardie Plank, Hardie Shingle

UFGS: SECTION 074646 Fiber Cement Siding:
(Not Available on UFGS)

D05.4.13. Other

○ Applicable ◉ N/A

D06. DOORS AND WINDOWS

Comply with AF Corporate Standards for Facilities Exteriors:
http://afcfs.wbdg.org/facilities-exteriors/index.html

Comply with AF Corporate Standards for Doors and Windows:
http://afcfs.wbdg.org/facilities-exteriors/doors-and-windows/index.html

Comply with AFCFS Recommended Materials:
http://afcfs.wbdg.org/facilities-exteriors/doors-and-windows/materials/index.html

Insert 3 photos for each facility group.

Image Tool 250 x 188

Group 1





Group 2





Group 3





Group 4





D06.1. Types

1. Clear anodized aluminum doors, windows and frames with thermal breaks are preferred for Facility Groups 1-3 because they show less wear and weathering than dark anodized finishes; match the color of the door and frame. For renovation projects the color of new windows, doors and frames may match the existing ones.

2. Aluminum clad wood windows are preferred for Facility Group 4.

3. Standard-sized hinged doors are preferred. Use sliding, folding, overhead, sectional and other door configurations only to support mission operations.

4. Preference for "Rytec" overhead doors as the installation standard.

5. Automatic doors are allowed only where functionally necessary.

6. Limit hollow metal doors and frames to security doors, utility rooms and mechanical rooms in Groups 1 and 2 and to any application in Group 3 facilities.

7. Utility and emergency egress doors will match the wall color.

8. Passive thermal comfort methods of ventilation are encouraged where life cycle cost justified.

9. Windows must meet force protection requirements.

10. Adjacent joint sealants should be slightly darker than the frame color.

11. Manufacturers listed in sections D06.5.1. - D06.5.4. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

D06.2. Layout and Geometry

1. Visually and functionally compose openings in walls for the climate-specific exposure.

2. Consistently use opening type, size, placement, mullion pattern, and color to reinforce the overall architectural design.

3. Openings will augment interior lighting and space conditioning needs.

4. Protect against vandalism, intrusion and coordinate sound ratings.

D06.3. Glazing and Shading

1. Tinted, energy-efficient, low-e, double-pane glazing is encouraged; provide triple-pane glazing in extreme environments.

2. Glazing color will follow Installation Facilities Standards (IFS).

3. Translucent wall panels may be integrated into wall systems.

4. Do not use mirrored glazing.

5. Fully integrate applicable shading designs for overhangs, louvers, light shelves and grilles.

6. Where appropriate, install window screens to take advantage of natural ventilation.

D06.4. Hardware

1. Provide hardware appropriate for the Facility Group while considering activity and frequency of use and local climate; hardware may be of higher visual quality for Facility Group 1.

2. Ensure hardware will perform throughout the facility's lifespan without showing extreme wear.

3. Select finishes that will not degrade by intensity of operation or exposure to the elements.

4. All locks to be compatible with "Best" locks with 7-pin removable core.

5. Magnetic switches for security doors will be integrated with door and frame; not surface mounted.

6. Use consistent finishes and color on window and door systems throughout a facility. For renovation projects the color of new hardware may match the existing hardware.

7. Design building systems to eliminate the need for security screens whenever possible.

D06.5. Doors and Windows Materials

Note: *Apply the below base-wide standards for Doors and Windows (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

D06.5.1. Anodized Aluminum

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Anodized Aluminum Doors, Windows and Frames**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Kawneer (or equivalent)

Color: Dark brown anodized

Finish: Matte

Model #: 2x4

Other: Provide thermally broken frames

UFGS: Section 08 41 13 Aluminum-Framed Entrances and Storefronts:
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 41 13.pdf



Type: **Anodized Aluminum Doors, Windows and Frames**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Kawneer (or equivalent)

Color: Clear anodized

Finish: Matte


Model #: 2x4

Other: Provide thermally broken frames

UFGS: Section 08 41 13 Aluminum-Framed Entrances and Storefronts:
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 41 13.pdf

D06.5.2. Hollow Metal

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type:

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Hollow Metal Doors, Windows and Frames

Color: Dark brown

Finish: Powder coated, satin

Model #: 2x4 frame

Other: Provide thermally broken frames

UFGS: Section 08 11 13 Steel Doors and Frames:
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 11 13.pdf

D06.5.3. Aluminum-clad Wood

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Aluminum-clad Residential**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ☑ Group 4 ☐ Other

Mfr: Marvin

Color: White or Earth tones

Finish: Powder coated, satin

Model #: Aluminum-clad wood windows

Other: Double hung

UFGS: Section 08 14 00 Wood Doors
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 14 00.pdf

D06.5.4. Other

○ Applicable ◉ N/A

D07. ROOF SYSTEMS

Comply with AF Corporate Standards for Facilities Exteriors:
http://afcfs.wbdg.org/facilities-exteriors/index.html

Comply with AF Corporate Standards for Roof Systems:
http://afcfs.wbdg.org/facilities-exteriors/roof-systems/index.html

Comply with AFCFS Recommended Materials:
http://afcfs.wbdg.org/facilities-exteriors/roof-systems/materials/index.html

Insert 3 photos for each facility group.

Image Tool 250 x 188

Group 1






Group 2





Group 3





Group 4





D07.1. Roof Type and Form

1. Use proven, cost-effective roof systems with high durability, weather resistance, and low maintenance that are compatible with Installation Facilities Standards (IFS) and requirements for the designated Facility Group. Include the following criteria for snow load and frost depth:

Snow Load: 30 PSF (flat roof), equivalent ground snow load of 42 PSF
Frost Depth: 42" below grade

2. Generally match the roof type and form of existing adjacent facilities in new construction.

3. Group 1 and 2 buildings will use sloped standing seam metal roofs. Single ply membrane minimal-slope roofs may be used as approved on a case-by-case basis.

4. Standing Seam Metal Roofs (SSMR) are to include a continuous snow retention system (snow guards) along the entire roof edge to prevent damage to the gutters from sliding snow and ice.

5. Snow guards are to be rail type attached to the standing seam and match roof color.

6. Provide calculations to determine if more than one row of snow guards are required due to roof area size.

7. Install white EPDM on minimal-slope roof applications. Provide fully adhered EPDM installation following UFC 3-110-03. Note that mechanically fastened EPDM systems are prohibited by UFC.

8. Provide screens for roof-mounted appendages and equipment of the same materials, which are used predominantly in the building's roof systems.

9. Roof translucent panels are permitted only for Group 1 facilities.

10. Group 2 and 3 facilities under 5,000 sf and narrow in plan geometry, may use gabled standing seam metal roofs. Larger facilities may use sloped-roof features in conjunction with predominantly minimal-sloped "flat" membrane roofs.

11. Group 4 facilities will have gabled or hipped composite shingle roofs.

12. Roof eaves will extend beyond the exterior wall for roof drainage and shading. Provide overhangs for shading in response to local climatic conditions, sized and proportioned to the height of the facility and to the window openings being shaded.

13. South-facing eaves will coordinate with adjacent wall-mounted shading devices.

14. The color, shape and slope of the eave and soffit will be compatible with adjacent facilities.

15. Keep roofs uncluttered and minimize penetrations.

16. Diminish massive roofs into coordinated smaller components consistent with adjacent facilities; avoid random, arbitrary changes.

17. Increase the insulation value of existing roofing systems during renovations if supported by life cycle cost and structural analysis.

18. Roofs will be maintained for the life of the system and replaced in accordance with UFC 3-110-04 and AFI 32-1051. A warranty is required on all new roofs.

19. Manufacturers listed in sections D07.9.1. - D07.9.10. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

D07.2. Roof Slope

1. Group 1 and 2 buildings will use sloped roofs, min. 3:12.

2. Low-sloped roofs are allowed for larger structures or to match existing conditions on renovation projects. Minimal-sloped roofs may also be used for Group 3 facilities in high-visibility areas.

3. Group 4 facilities will use 4:12 to 6:12 roof slopes.

4. Ensure adequate drainage, and connect to the subsurface rain collection system where available.

5. Provide roof slopes to accommodate solar photovoltaic, solar thermal, passive systems and daylighting when applicable following UFC 1-200-02.

6. Provide underlayments as required for the roofing type as directed by the UFC.

D07.3. Parapets and Copings

1. Extend wall materials vertically above the roof line and provide metal copings to match the wall. Ensure copings are properly flashed and detailed to avoid roof leaks.

D07.4. Color and Reflectivity

1. Sloped roofs in Groups 1 and 2 and smaller facilities in Group 3 will be medium bronze finish to match adjacent facilities and follow requirements of IFS.

2. All minimal-slope membrane roofs will use only use high-albedo, high reflectivity color to help decrease the temperature around the buildings and minimize damage to human and wildlife habitat.

3. Sloped roofs in Group 4 will be earth tones.

4. Comply with UFC 3-110-03 and ASHRAE 90.1 for Solar Reflectance Index (SRI) and thermal requirements.

5. All roof flashing will match the color of the predominant background material.

D07.5. Gutters, Downspouts, Scuppers, Drains

1. All sloped roofs will use gutters and downspouts. Gutters will be outside the fascia.

2. Internal roof drainage systems are not permitted in new construction. Minimal-sloped roofs will be sloped to drain to the building perimeter through scuppers into downspouts.

3. All gutters and fascias will match the roof color.

4. In accordance with UFC 3-110-03 Roofing, prepare calculations to determine drainage requirements for gutters and downspouts per the method specified in the Sheet Metal and Air Conditioning Contractors National Association's (SMACNA) Architectural Sheet Metal Manual, current edition.

5. Calculations are to include gutter attachment to the building since the roof areas can be larger in area than typical; and therefore carry more weight when storm water and ice accumulation is considered.

6. Calculations are to be completed by a registered architect/engineer and all details noted including: gutter size and attachment to the building as well as any structural sub-framing required for attachment, downspout sizes, locations and wall attachment, and gauge of all materials.

7. Use scuppers as required in parapet walls. Arrange scuppers in an orderly manner consistent with other elements of the wall system.

8. When open scuppers are connected to downspouts, provide transitions consistent with adjacent facilities.

9. Integrate downspouts with the architectural details of the wall system and arrange in an orderly, non-prominent appearance. Generally blend downspouts with the color of the wall (not contrasting it).

10. Fabricate downspouts from non-corrosive materials such as aluminum or zinc-coated steel. Provide powder-coated finishes in medium bronze.

11. All downspouts will be closed box.

12. Provide angled transitional pieces for downspouts to fit closely against the wall for their entire length.

13. Coordinate locations of downspouts to conceal control joints in masonry walls when possible.

14. Place downspouts away from building entries. Water discharged should not run across sidewalks.

13. Splashblock will be poured in place concrete for appropriate drainage.

D07.6. Roof Vents and Elements

1. Minimize and consolidate roof penetrations into a single, inconspicuous point whenever possible.

2. On sloped roofs clad pipe penetrations to match the roofing material.

3. Avoid the use of rooftop mechanical equipment, however for renovations and unavoidable configurations ensure units are screened.

4. Provide access points and service routes to equipment that protect the roof.

5. Screen all large vents.

6. Ensure attic spaces are properly vented at ridges and soffits.

7. Match roof color for all exposed equipment and vents.

8. Avoid roof-mounted antenna systems.

9. Arrange Lightning Protection Systems (LPS) components in an ordered, uncluttered, inconspicuous appearance and integrated into the organization of the roof and wall systems.

10. Ensure that LPS roof mounting systems are approved by the roofing manufacturer.

11. Additions to a roof should not interfere with LPS or other rooftop systems that may be required.

12. Permanent fall protection must be included with any addition to a roof with a slope above 3:12 per UFC 3-110-03 to a roof with a slope above 3:12 per UFC 3-110-03.

D07.7. Clerestories and Skylights

1. Clerestories and skylights are permitted in Group 1 facilities. These are allowed in Group 3 facilities only when serving passive systems and are justifiable by life-cycle analysis.

2. Clerestories are preferred to skylights to avoid roof penetrations. Skylights, when permitted, must be simple in shape and integrated with the roof system to eliminate leakage.

3. Design clerestories and skylights using the same principles for seasonal shading that are required for walls and roof overhangs.

4. Translucent panel systems are preferred in clerestory applications due to lack of window cleaning.

5. Clerestories and skylights must comply with UFC 4-10-01.

D07.8. Vegetated Roof

1. Not applicable.

End of Section

D07.9. Roof Systems Materials

Note: *Apply the below base-wide standards for Roof Systems (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

D07.9.1. Standing Seam Metal

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Berridge

Color: Medium bronze

Finish: Matte

Model #: Tee-Panel

Other: Shed, gabled or hipped standing seam metal

UFGS: Section 07 61 14 Steel Standing Seam Roofing
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 07 61 14.00 20.pdf

D07.9.2. Membrane Single-ply

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Carlisle Systems

Color: Off-white

Finish: Smooth

Model #: TPO single-ply, “flat” minimal slope

Other: N/A

UFGS: Section 07 53 23 Ethylene-Propylene-Diene-Monomer Roofing
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 07 53 23.pdf
Section 07 54 50 TPO Thermoplastic Single-Ply Roofing
(Not Available on UFGS)

D07.9.3. Built-up Multi-ply

○ Applicable ◉ N/A

D07.9.4. Concrete Tile

○ Applicable ◉ N/A

D07.9.5. Clay Tile

○ Applicable ◉ N/A

D07.9.6. Slate Shingles


○ Applicable ◉ N/A

D07.9.7. Vegetated System

○ Applicable ◉ N/A

D07.9.8. Ribbed Metal Sheeting

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☐ Group 1 ☐ Group 2 ◉ Group 3 ☐ Group 4 ☐ Other

Mfr: Berridge

Color: Galvalume

Finish: Factory

Model #: High Seam Tee-Panel

Other: 24 gauge steel, Width: 16" Batten height: 1-3/4"

UFGS: Section 07 41 13.19 Batten-Seam Metal Roof Panels
(Not Available on UFGS)

D07.9.9. Composite Shingles

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ☑ Group 4 ☐ Other

Mfr: Tamko

Color: Earth Tones

Finish: Factory

Model #: Heritage

Other: Gabled or hipped with transverse gable or hipped features

UFGS: Section 07 31 13 Glass-fiber-reinforced Asphalt Shingles
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 07 31 13.pdf

D07.9.10. Other

○ Applicable ◉ N/A

D08. STRUCTURAL SYSTEMS

Comply with AF Corporate Standards for Facilities Exteriors:
http://afcfs.wbdg.org/facilities-exteriors/index.html

Comply with AF Corporate Standards for Structural Systems:
http://afcfs.wbdg.org/facilities-exteriors/structural-systems/index.html

Comply with AFCFS Recommended Materials:
http://afcfs.wbdg.org/facilities-exteriors/structural-systems/materials/index.html

Insert 3 photos for each facility group.

Image Tool 250 x 188

Group 1





Group 2





Group 3





Group 4





D08.1. Systems and Layouts

1. Pre-engineered structural steel framing may be used for Groups 1, 2 and 3 facilities; Installation-appropriate thermal envelopes, materials and detailing are required. Include the following criteria for snow load and frost depth:

Snow Load: 30 PSF (flat roof), equivalent ground snow load of 42 PSF
Frost Depth: 42" below grade

2. Select economical structural systems that integrate roof and wall systems.

3. Narrow buildings 60' or less in width with column-free interiors are preferred for office, administrative and personnel spaces; when interior columns are required optimize the structural grid layout for open-plan arrangements.

4. Fully coordinate structural grids with exterior window systems to align columns with window frames or wall systems.

5. When structure is exposed provide an organized appearance and coordinate with mechanical, electrical, plumbing, fire protection, information technology, and communications systems.

6. Limit the use of specialty systems (such as space frames, vaults or domes) and of structure as a visual feature.

7. Cost-effectively design interior bearing walls as thermal mass.

8. Manufacturers listed in sections D08.2.1. - D08.2.9. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

D08.2. Structural Systems Materials

Note: *Apply the below base-wide standards for Structural Systems (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

D08.2.1. Concrete

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Cast-In-Place**

Applies to: ☑ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom

Color: Natural Gray

Finish: Light texture

Model #: Post and beam and/or waffle slab

Other: N/A

UFGS: Section 03 30 53 Miscellaneous Cast-In-Place Concrete
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 03 30 53.pdf
Section 03 33 00 Cast-In-Place Architectural Concrete
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 03 33 00.pdf
Section 03 47 13 Tilt-Up Concrete
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 03 47 13.pdf

D08.2.2. Insulated Concrete Forming (ICF)

○ Applicable ◉ N/A

D08.2.3. Steel

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Rigid Framing**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: US Steel

Color: Shop primed

Finish: Matte

Model #: Structural steel shapes

Other: N/A

UFGS: Section 05 12 00 Structural Steel
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 05 12 00.pdf

D08.2.4. Pre-Engineered Steel

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Moment Frame**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Behlen Building Systems

Color: Factory primed

Finish: Matte

Model #: Moment Frame

Other: Draped insulation may be used behind wall system;
Behlen standing seam roof system may be used for Group 3

UFGS: Section 13 12 00 Steel Building Systems
(Not Available on UFGS)
Section 13 34 19 Metal Building Systems
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 13 34 19.pdf

D08.2.5. Masonry

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Load-Bearing Masonry**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Custom

Color: Beige

Finish: Smooth texture

Model #: Brick or CMU

Other: N/A

UFGS: Section 04 20 00 Unit Masonry
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 04 20 00.pdf

D08.2.6. Heavy Timber

○ Applicable ◉ N/A

D08.2.7. Light-gauge Steel

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Steel Framing**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ☑ Group 4 ☐ Other

Mfr: Steelrite

Color: Factory

Finish: Galvanized

Model #: Structural framing shapes

Other: N/A

UFGS: Section 05 45 00 Light Gauge Steel Framing System
(Not Available on UFGS)

D08.2.8. Lumber Framing

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Lumber Framing**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ◉ Group 4 ☐ Other

Mfr: Boise Cascade Wood Products

Color: N/A

Finish: S4S

Model #: Structural dimensional lumber

Other: N/A

UFGS: Section 06 10 00 Rough Carpentry
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 06 10 00.pdf
Section 06 11 00 Wood Framing and Sheathing
(Not Available on UFGS)

D08.2.9. Other

○ Applicable ◉ N/A

D09. MECHANICAL, ELECTRICAL AND PLUMBING


Comply with AF Corporate Standards for Facilities Exteriors:
http://afcfs.wbdg.org/facilities-exteriors/index.html

Comply with AF Corporate Standards for Mechanical, Electrical and Plumbing:
http://afcfs.wbdg.org/facilities-exteriors/mechanical-electrical-and-plumbing/index.html

Insert 3 photos for each facility group.

Image Tool 250 x 188

Group 1



Group 2





Group 3





Group 4





D09.1. Passive and Active Systems

1. Fully integrate passive heating and cooling systems into facility designs whenever practical for the local climate prior to the design of active mechanical systems.

2. Provide optimized passive and active systems; design active mechanical systems to supplement thermal mass walls and floors.

3. Develop renewable energy systems including geo-exchange (ground source heat pumps) when life cycle cost effective.

4. Performance display screens, which report energy performance and utility savings, are encouraged; when provided locate these in building lobbies or common areas.

5. Solar domestic hot water systems are required when life cycle cost effective for the climate.

6. Integrate shading into building exteriors to reduce solar heat gain during hot seasons.

D09.2. Functionality and Efficiency

1. Fully coordinate mechanical, electrical, plumbing (MEP) and fire protection systems with each other and with the building structure, enclosure, thermal envelope and interior design.

2. Ensure direct exterior access is provided (for CE) to main mechanical and electrical rooms.

3. Screen exterior equipment from primary views (landscape, building masses, screen walls) and comply with AT requirements.

4. Keep equipment away from main building entrances; locate service area/yard on least visible side of a building.

5. Coordinate the location of all exterior meters, equipment and devices to provide convenient access and an overall coordinated and orderly appearance.

6. Design emergency generator systems integrally with all other building systems and avoid incompatible building additions; locate generators near service areas and ensure they are not visible from primary entrances.

7. When structure is exposed as a finished ceiling, fully integrate MEP and fire protection systems to provide an organized uncluttered appearance.

8. Conceal ducts, piping, conduits, devices, etc., when permanent walls, suspended ceilings or raised floors are provided; locate sprinkler heads in orderly configuration.

9. Limit interior wall-mounted equipment in occupied personnel spaces; avoid surface-mounted conduit and pipes.

10. Provide efficient utility rooms with layouts to facilitate system performance and maintenance; provide convenient access to controls, clearly label systems and include operating and maintenance instructions.

11. Separate mechanical and electrical and communications rooms.

12. Integrate recessed and wall-mounted fixtures such as fire standpipe cabinets and drinking fountains within permanent walls.

End of Section


E. FACILITIES INTERIORS

Comply with Air Force Corporate Standards for Facilities Interiors:
http://afcfs.wbdg.org/facilities-interiors/index.html

Insert 3 photos for each facility group.


Image Tool 250 x 188

Group 1





Group 2





Group 3





Group 4





E01. Building Configurations

Comply with Air Force Corporate Standards for Building Configurations:
http://afcfs.wbdg.org/facilities-interiors/buildings-configurations/index.html

1. Provide open-plan configurations for office, administrative, operational and related activities and spaces for maximum flexibility. Use a "core and shell" approach in which all building systems, infrastructure and permanent interior partitions anticipate two or more uses (operations) during a facility's lifespan.

2. Create flexible interior configurations using Furniture, Fixtures & Equipment (FF&E) and limit private offices and private rooms. Refer to AFMAN 32-1084 for space requirements. To the greatest extent, limit permanent partitions to core areas such as toilet rooms, stairs, mechanical and utility rooms.

3. Use more durable long-lasting finishes in core areas for walls, ceilings, floor coverings and built-in casework. Coordinate interior FF&E layouts with structural grids during space planning.

4. Provide high-performance building configurations following UFC 1-200-02. Ensure passive design strategies are cost effectively incorporated before active mechanical systems are designed.

5. Comply with UFC 1-200-01, general building requirements. UFC 1-200-01 provides applicability of model building codes and government unique criteria for typical design disciplines and building systems, as well as for accessibility, antiterrorism, security, high performance and sustainability requirements, and safety.

6. Meet security and force protection requirements in UFC 4-010-01: DoD Minimum Antiterrorism Standards for Buildings.

7. Comply with AFCFS for supporting mission requirements, addressing human comfort and well being, and creating highly flexible interiors while satisfying metrics for high performance and sustainable buildings.

8. Provide a level of quality for interior features, materials and finishes that is appropriate for the Facility Group number. Group 1 may receive higher quality than Groups 2 thru 4. Refer to Facility Hierarchy.

9. Through open-plan configurations, preserve all passive and natural design strategies and fully integrate facility interiors with overall building systems.

10. Professional interior designers, or architects with significant interior design experience, must accomplish the design and review of applicable new construction, renovations and maintenance projects.

11. Consult with the State Historic Preservation Officer (SHPO) and base-level Historic Preservation offices regarding proposed changes to properties listed on or eligible for listing on the National Register of Historic Places. Follow requirements of The National Historic Preservation Act and Secretary of the Interior Standards for the Treatment of Historic Properties.

12. Maintain architectural compatibility following AFCFS and this Installation Facilities Standards (IFS) document to create continuity while avoiding monotony.

E01.1. Layout and Common Areas

Comply with Air Force Corporate Standards for Layout and Common Areas:
http://afcfs.wbdg.org/facilities-interiors/buildings-configurations/layout-and-common-areas/index.html

1. Create open-plan interior environments to accommodate changes.

2. Limit interior partitions, private offices and rooms; use furniture or modular systems to provide privacy and acoustic control.

3. When partitions are functionally justified such as for conference rooms, use systems furniture and moveable (demountable) floor-to-ceiling wall systems for acoustical or visual privacy.

4. Proportion lobbies and common spaces based on type of function, activity and facility group.

5. Allow no direct sight lines into restrooms.

6. Situate utility and core areas to minimize impact on daylighting and to maximize use as thermal buffers.

7. Ensure electrical, lighting and communications system can be adaptable to configuration changes.

8. Avoid power poles to the maximum extent; when poles are necessary minimize the number and coordinate locations with furniture placement and other elements.

9. Avoid sloping floors to maintain flexibility and eliminate future structural changes.

10. Special consideration may apply to Sensitive Compartmented Information Facilities (SCIFs).

E01.1.1. Interior Design Process

1. Comply with UFC 3-120-10 for the Comprehensive Interior Design (CID,) which includes both Structural Interior Design (SID) and Furniture, Fixtures & Equipment (FF&E) design services.

2. Use a collaborative, integrated planning and design team, composed of user, government support staff, and appropriate professionals. Integrate architectural features using simple detailing to create a professional appearance; avoid extravagant or excessive detailing.

3. Ensure interior designs satisfy the functional requirements within the context of flexibility, sustainability and the building's energy performance.

4. Base space planning on square foot allocations from AFM 32-1084. Identify special requirements if any, such as privacy separation, VIP areas, gathering spaces and storage. Note: The occupant's rank and position will influence the square footage and selection of materials.

5. Provide clear circulation and pathway finding for both horizontal and vertical directions that accommodate the number of personnel in the facility.

6. Maximize efficiencies in the space plan for functional relationships and adjacencies for all facility users. Efficiently create and situate rooms and support rooms such as conference / meeting rooms and break rooms.

7. Provide interior design building-related illustrations, drawings, schedules, materials selections, specifications and cost estimates as listed in UFC 3-120-10. Refer to Furnishings in this IFS also.

8. SID Format must follow UFC 3-120-10.

9. Base the FF&E package on the furniture footprint developed in the SID. Identify all new or existing equipment needed and its users within each facility or each area of the facility. Provide specific information on: equipment sizes, electrical requirements, ventilation requirements, weight (if heavy), quantity, and security level if required. Presume all administrative spaces have computers and supporting equipment.

E01.1.2. Codes and Regulations

1. Refer to UFC 1-200-01 for modifications to the International Building Code (IBC) to determine applicable sections of the IBC. Both the IBC Chapter 3 and UFC 3-600-01 govern "Use and Occupancy Classification" for example.

2. Fire code requirements will be as defined in the International Building Code (IBC) and must be used where dictated by UFC 1-200-01 DoD Building Code (General Building Requirements) except where noted in UFC 3-600-01 (Fire Protection Engineering For Facilities).

3. National Fire Protection Association (NFPA) 101 must be utilized to determine the occupancy classification as it relates to fire/ smoke resistance rating of interior non-load bearing partitions (other than occupancy separation), means of egress, interior finish, features of fire protection (including vertical openings) and associated requirements.

E01.2. Quality and Comfort

Comply with Air Force Corporate Standards for Quality and Comfort:
http://afcfs.wbdg.org/facilities-interiors/buildings-configurations/quality-and-comfort/index.html

1. Include durability in the life cycle cost analysis for best-value material selections with long life expectancies that do not show excessive wearing.

2. Select long-lasting materials and finishes for permanent core areas such as lobbies, restrooms and stairs.

3. Select low-maintenance materials and products that reduce ongoing servicing and repair and that are easy to clean.

4. Relate the visual quality of finishes to the Facility Group number.

5. Building and interior configurations should address both operations and climatic responses.

6. Convey a professional image; avoid trendy patterns and textures.

7. Use materials and finishes that provide a healthy indoor environment.

8. Orient interior spaces toward views while maintaining cost-effective building performance and efficiency.

9. Promote air movement and daylighting for human health and wellbeing.

E02. Floors

Comply with Air Force Corporate Standards for Floors:
http://afcfs.wbdg.org/facilities-interiors/floors/index.html

E02.1. Floor Materials

Facility Group 1 floor materials will be as follows.

Primary:	Prepared Slabs (Ground, Polished)
Secondary:	Porcelain tile
Tertiary:	Carpet, Rubber Stair Treads

Facility Group 2 floor materials will be as follows.

Primary:	Prepared Slabs (Ground, Polished)
Secondary:	Ceramic tile
Tertiary:	Carpet, Rubber Stair Treads

Facility Group 3 floor materials will be as follows.

Primary:	Prepared Slabs (Ground)
Secondary:	Prepared Slabs (Sealer)
Tertiary:	N/A

Facility Group 4 floor materials will be as follows.

Primary:	Carpet
Secondary:	Ceramic tile
Tertiary:	N/A

1. Natural stone and terrazzo flooring may be used in high traffic areas of Group 1 as approved on a case-by-case basis.

2. Resilient and rapidly renewable flooring may be used in low traffic areas in Group 1, 2 and 4.

3. Manufacturers listed in sections E02.1.1. - E02.1.8. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

End of Section

Note: *Apply the below base-wide standards for Floors (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

E02.1.1. Prepared Slabs

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Style 1, Ground and Polished**

Applies to: ☑ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Local (TBD)

Color: Natural gray cement, light to dark beige aggregates

Finish: Fine polished texture

Model #: Medium to small aggregate

Other: N/A

UFGS: Section 03 35 45 Polished Concrete Finishing
(Not Available on UFGS)



Type:

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Local (TBD)

Color: Natural gray cement, light to dark beige aggregates

Finish: Medium polished texture, slip resistant

Model #: Medium to small aggregate

Other: N/A

UFGS: Section 03 35 45 Polished Concrete Finishing
(Not Available on UFGS)

E02.1.2. Natural Stone and Terrazzo

○ Applicable ◉ N/A

E02.1.3. Quarry Tile

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☐ Group 1 ◉ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Daltile

Color: Earth tones

Finish: Matte, slip resistant

Model #: N/A

Other: Use in commercial kitchen flooring.

UFGS: Section 09 30 10 Ceramic, Quarry, and Glass Tiling
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 30 10.pdf

E02.1.4. Ceramic Tile

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Style 1 Porcelain**

Applies to: ◉ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Daltile

Color: Earth tones

Finish: Matte, slip resistant

Model #: Porcelain tile

Other: Use in high traffic areas. Epoxy grout is recommended.

UFGS: Section 09 30 10 Ceramic, Quarry, and Glass Tiling
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 30 10.pdf



Type: **Style 2 Ceramic**

Applies to: ◉ Group 1 ◉ Group 2 ◉ Group 3 ◉ Group 4 ☐ Other

Mfr: Daltile

Color: Earth tones

Finish: Matte, slip resistant

Model #: Ceramic tile

Other: Use in low traffic area toilet rooms.

UFGS: Section 09 30 10 Ceramic, Quarry, and Glass Tiling
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 30 10.pdf

E02.1.5. Resilient Floor

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Style 1 Stair Treads**

Applies to: ◉ Group 1 ◉ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Roppe


Color: Neutral tones

Finish: Factory

Model #: Raised design rubber tread

Other: Stair treads material

UFGS: Section 09 65 00 Resilient Flooring
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 65 00.pdf



Type: **Luxury Vinyl Tile**

Applies to: ◉ Group 1 ◉ Group 2 ◉ Group 3 ◉ Group 4 ☐ Other

Mfr: Shaw

Color: Dark, neutral and natural wood colors

Finish: Factory protective finish < 20mil


Model #: To be determined (TBD)

Other: Consider finish and thickness > 20 mil wear for areas of high foot traffic such as entry ways. Install in a staggered pattern.

UFGS: Section 09 65 00 Resilient Flooring
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 65 00.pdf

E02.1.6. Carpet

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Style 1**

Applies to: ◉ Group 1 ◉ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Mohawk Group


Color: Neutral multi-colored tones/patterned/solid

Finish: Yarn: Nylon 6 or 6.6/cut pile or loop pile

Model #: Broadloom, 6' wide rolled, carpet tiles, entry walk-off carpet

Other: N/A

UFGS: UFGS 09 68 00 Carpeting
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 68 00.pdf



Type: **Style 2**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ◉ Group 4 ☐ Other

Mfr: Shaw

Color: Dark, neutral and natural wood colors

Finish: Factory protective finish < 20mil

Model #: Carpet tiles

Other: Consider finish and thickness > 20 mil wear for areas of high foot traffic such as entry ways. Install in a staggered pattern. See also: UFGS Section 09 65 00 Resilient Flooring

UFGS: UFGS 09 68 00 Carpeting
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 68 00.pdf

E02.1.7. Rapidly-Renewable Products

○ Applicable ◉ N/A

E02.1.8. Other

○ Applicable ◉ N/A

E03. Walls

Comply with Air Force Corporate Standards for Walls:
http://afcfs.wbdg.org/facilities-interiors/walls/index.html

E03.1. Wall Materials

Facility Group 1 wall materials will be as follows.

Primary:	Brick (or otheras approved by the BCE)
Secondary:	Gypsum board (painted)
Tertiary:	Ceramic tile (restrooms)

Facility Group 2 wall materials will be as follows.

Primary:	Brick
Secondary:	Gypsum board (painted)
Tertiary:	Ceramic tile (restrooms)

Facility Group 3 wall materials will be as follows.

Primary:	Ground face block, sealed (do not paint)
Secondary:	N/A
Tertiary:	Ceramic tile (restrooms)

Facility Group 4 wall materials will be as follows.

Primary:	Gypsum board (painted)
Secondary:	N/A
Tertiary:	Ceramic tile (restrooms)

1. Follow UFC 3-450-01 (Vibration and Noise Control) for acoustic design issues including speech privacy, sound isolation or sound masking.

2. Select and apply paint with sheens (gloss levels) appropriate for the application following UFGS Section 09 90 00 Paints and Coatings.

3. Provide ceramic tile on wet walls of kitchens, toilet rooms, locker rooms, etc., in all facility groups.

4. Neutral split-face or ground-face integrally colored block with a clear sealer may be used in Group 3. Do not paint block.

5. Provide rubber base on drywall partitions in Groups 1 and 2.

6. Hardwood base may only be used in Group 1 as approved on a case-by-case basis.

7. Hardwood chair rails / bumper rails may be used in high-use areas of Groups 1 and 2; aqueous clear finishes are preferred to reduce maintenance; plastic chair rails are permitted only in medical applications.

8. Decorative moldings may be used only in Group 1 when approved on a case-by-case basis.

9. Corner guards are permitted only in high traffic spaces with wheeled or cart use such as private service areas in Groups 1 and 2; stainless steel corners guards with a brushed finish may be judiciously used in Group 3.

10. Group 4 may use painted composite wood base.

11. Manufacturers listed in sections E03.1.1. - E03.1.8. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

Note: *Apply the below base-wide standards for Walls (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

E03.1.1. Concrete

○ Applicable ◉ N/A

E03.1.2. Masonry

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Modular Face Brick**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Local (TBD)

Color: Beige blend

Finish: Light texture

Model #: Coursed unit masonry

Other: Brick is preferred. Concrete block may only be used in Group 3 when approved by the BCE.

UFGS: Section 04 20 00 Unit Masonry
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 04 20 00.pdf

E03.1.3. Ceramic Tile

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☑ Group 4 ☐ Other

Mfr: Daltile

Color: Earth tones

Finish: Gloss, Semi-gloss

Model #: Ceramic wall tile

Other: Located on wet walls in restrooms

UFGS: Section 09 30 10 Ceramic, Quarry, and Glass Tiling
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 30 10.pdf

E03.1.4. Gypsum Board

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☑ Group 4 ☐ Other

Mfr: US Gypsum

Color: Solid Earth tone colors

Finish: Paint (Sheen per UFGS)

Model #: Tapered edge

Other: N/A

UFGS: Section 09 29 00 Gypsum Board
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 29 00.pdf
Section 09 90 00 Paints and Coatings
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 90 00.pdf

E03.1.5. Metal Panels

○ Applicable ◉ N/A

E03.1.6. Wood Paneling

○ Applicable ◉ N/A

E03.1.7. Rapidly-Renewable Products

○ Applicable ◉ N/A

E03.1.8. Other

○ Applicable ◉ N/A

E04. Ceilings

Comply with Air Force Corporate Standards for Ceilings:
http://afcfs.wbdg.org/facilities-interiors/ceilings/index.html

E04.1. Ceiling Materials

Facility Group 1 ceiling materials will be as follows.

Primary:	Exposed Framing (Roof / Floor Structure Above)
Secondary:	Grid and Acoustical Tile
Tertiary:	N/A

Facility Group 2 ceiling materials will be as follows.

Primary:	Exposed Framing (Roof / Floor Structure Above)
Secondary:	Grid and Acoustical Tile
Tertiary:	Gypsum Board (painted)

Facility Group 3 ceiling materials will be as follows.

Primary:	Exposed Framing (Roof / Floor Structure Above)
Secondary:	Exposed Framing (Roof / Floor Structure Above)
Tertiary:	Gypsum Board (painted)

Facility Group 4 ceiling materials will be as follows.

Primary:	Gypsum Board (painted)
Secondary:	N/A
Tertiary:	N/A

1. Accent ceiling materials such as metal, wood, and rapidly renewable may be used in Group 1 as approved on a case-by-case basis.

2. Follow UFC 3-450-01 (Vibration and Noise Control) for acoustic design issues including speech privacy, sound isolation or sound masking.

3. Manufacturers listed in sections E04.1.1. - E04.1.8. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

Note: *Apply the below base-wide standards for Ceilings (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

E04.1.1. Exposed Framing (Roof / Floor Structure Above)

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Vulcraft

Color: Neutral colors reviewed on a case-by-case basis

Finish: Field painted (Sheen per UFGS)

Model #: Formlok floor and roof decking

Other: N/A

UFGS: Section 05 30 00 Steel Decks
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 05 30 00.pdf

E04.1.2. Exposed Concrete

○ Applicable ◉ N/A

E04.1.3. Grid and Acoustical Tile

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Armstrong

Color: White

Finish: Factory


Model #: 2'x2' Tegular with reveal edge and fine texture, grid 15/16"

Other: Performance characteristics are Class A; NRC-0.70; CAC-40; LR-0.86; minimum recycled content 82%.

UFGS: Section 09 51 00 Acoustical Ceilings
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 51 00.pdf

E04.1.4. Gypsum Board

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☑ Group 4 ☐ Other

Mfr: US Gypsum

Color: Solid neutral colors

Finish: Paint (sheen per UFGS)

Model #: Tapered edge

Other: N/A

UFGS: Section 09 29 00 Gypsum Board
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 29 00.pdf
Section 09 90 00 Paints and Coatings
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 09 90 00.pdf

E04.1.5. Metal Panels

◯ Applicable ◉ N/A

E04.1.6. Wood

◯ Applicable ◉ N/A

E04.1.7. Rapidly-Renewable Products

◯ Applicable ◉ N/A

E04.1.8. Other

◯ Applicable ◉ N/A

Not applicale.

End of Section

E05. Doors and Windows

Comply with Air Force Corporate Standards for Doors and Windows:
http://afcfs.wbdg.org/facilities-interiors/doors-and-windows/index.html

E05.1. Doors and Windows and Frames Materials

Facility Group 1
door (frame) and window frame materials will be as follows.

Primary:	Aluminum, clear anodized
Secondary:	Hollow metal (painted)
Tertiary:	N/A

Facility Group 1
door (leaf) materials will be as follows.

Primary:	Hardwood veneer
Secondary:	Hollow metal (painted)
Tertiary:	N/A

Facility Group 2
door (frame) and window frame materials will be as follows.

Primary:	Aluminum, clear anodized
Secondary:	Hollow metal (painted)
Tertiary:	N/A

Facility Group 2
door (leaf) materials will be as follows.

Primary:	Hardwood veneer
Secondary:	Hollow metal (painted)
Tertiary:	N/A

Facility Group 3
door (frame) and window frame materials will be as follows.

Primary:	Hollow metal (galvanized, painted)
Secondary:	Hollow metal (galvanized, painted)
Tertiary:	N/A

Facility Group 3
door (leaf) materials will be as follows.

Primary:	Hollow metal (galvanized, painted)
Secondary:	Hollow metal (galvanized, painted)
Tertiary:	N/A

Facility Group 4
door (frame) and window frame materials will be as follows.

Primary:	Wood
Secondary:	N/A
Tertiary:	N/A

Facility Group 4
door (leaf) materials will be as follows.

Primary:	Wood solid core
Secondary:	Composite solid core
Tertiary:	N/A

1. Hardwood casings may be provided over metal frames in Group 1 as approved on a case-by-case basis.

2. Paneled textured doors are preferred in Group 4.

3. Do not use hollow-core wood doors.

4. Generally match original hardware in renovations.

5. Manufacturers listed in sections E05.1.1. - E05.1.4. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

End of Section

Note: *Apply the below base-wide standards for Doors and Windows (products, materials and color). Then refer to the Appendix and apply any additional requirements specifically related to the Facility District in which the project is located.*

E05.1.1. Aluminum

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Kawneer

Color: Clear anodized

Finish: Factory

Model #: InFrame Interior Framing, (2x4 nominal framing)

Other: Satin stainless steel hardware

UFGS: Section 08 41 13 Aluminum-Framed Entrances and Storefronts
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 41 13.pdf
Section 08 71 00 Door Hardware
https://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 71 00.pdf

E05.1.2. Hollow Metal

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Steel Doors**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Steelcraft


Color: Neutral colors

Finish: Paint (sheen per UFGS)

Model #: Hollow metal, 2" w. frames, 16 gauge (welded corners) grouted solid

Other: Provide in Group 3 and in utility areas of Group 1 and 2. Provide A25 "galvannealed" coating. All interior steel doors will have a factory applied primer finish. Provide satin stainless steel hardware.

UFGS: Section 08 11 13 Steel Doors and Frames
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 11 13.pdf
Section 08 71 00 Door Hardware
https://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 71 00.pdf



Type: **Steel Frames**

Applies to: ◉ Group 1 ◉ Group 2 ◉ Group 3 ☐ Group 4 ☐ Other

Mfr: Steelcraft

Color: Neutral colors

Finish: Paint (sheen per UFGS)

Model #: Hollow metal, frame grouted solid

Other: Satin stainless steel hardware

UFGS: Section 08 11 13 Steel Doors and Frames
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 11 13.pdf
Section 08 71 00 Door Hardware
https://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 71 00.pdf

E05.1.3. Wood

◉ Applicable ○ N/A Number of base standards 2 Image Tool 250 x 188



Type: **Style 1, Administrative**

Applies to: ◉ Group 1 ◉ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Simpson

Color: Natural hardwood veneer

Finish: Clear Sealer, satin (aqueous)

Model #: 3'x7'x 1 ¾", solid core

Other: Satin stainless steel hardware, Glass lites may be used. Stained birch veneer face, 5 ply construction, rotary cut finish.

UFGS: Section 08 14 00 Wood Doors
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 14 00.pdf
Section 08 71 00 Door Hardware
https://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 71 00.pdf



Type: **Style 2, Residential**

Applies to: ☐ Group 1 ☐ Group 2 ☐ Group 3 ☑ Group 4 ☐ Other

Mfr: Simpson

Color: Natural hardwood veneer or paint grade

Finish: Clear Sealer or paint, satin (aqueous)

Model #: Full slab or panels

Other: Satin nickel hardware

UFGS: Section 08 14 00 Wood Doors
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 14 00.pdf
Section 08 71 00 Door Hardware
https://www.wbdg.org/FFC/DOD/UFGS/UFGS 08 71 00.pdf

E05.1.4. Other

○ Applicable ◉ N/A

E06. Casework Systems

Comply with Air Force Corporate Standards for Casework Systems:
http://afcfs.wbdg.org/facilities-interiors/casework-systems/index.html

E06.1. Casework Materials

1. Select casework systems and materials considering durability, maintenance requirements and LCCA.

2. Natural stone and cast stone countertops may only be used in Group 1 with approval on a case-by-case basis.

3. Metal cabinets and countertops will be provided in heavy-use operations and in Group 3.

4. Refer to AFCFS for approved materials.

5. Manufacturers listed in sections E06.1.1. - E06.1.5. and E06.2.1. - E06.2.6. are provided only to establish a level of quality for use when designers write the salient characteristics of the brand-name item in project specifications following Federal Acquisition Regulations (FAR).

Continue to the Next Page

E06.1.1. Plastic Laminate

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1, Low Use Areas**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Formica

Color: Medium Earth tones and neutral tones

Finish: Light textured

Model #: High pressure laminate

Other: Combine with matching solid-surface banding on casework edges.

UFGS: Section 06 41 16.00 10 Plastic-Laminate-Clad Architectural Cabinets
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 06 41 16.00 10.pdf

E06.1.2. Solid Polymer Surface

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1, High Use Areas**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Corian

Color: Medium Earth tones and neutral tones

Finish: Light textured


Model #: Solid Surface

Other: Faces and edge banding

UFGS: Section 12 36 00 Countertops
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 12 36 00.pdf

E06.1.3. Rapidly-Renewable Products

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1 Moderate Use Areas**

Applies to: ☑ Group 1 ☑ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Plyboo

Color: Natural or amber

Finish: Satin

Model #: Flat grain bamboo plywood

Other: FSC® Certified 100%.

UFGS: Section 12 32 00 Manufactured Wood Casework
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 12 32 00.pdf

E06.1.4. Metal

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1**

Applies to: ☐ Group 1 ☐ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Steel Sentry

Color: Natural stainless steel or neural colors (steel)

Finish: Mill (stainless) or Powder coated (steel)

Model #: Lab, workbench, computer workstation

Other: Provide highly durable fabrications and finishes in Group 3 which are subjected to heavy use.

UFGS: Section 12 31 00 Manufactured Metal Casework
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 12 31 00.pdf

E06.1.5. Other

○ Applicable ◉ N/A

E06.2. Countertop Materials

E06.2.1. Plastic Laminate

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1, Low Use Areas**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Formica

Color: Medium Earth tones and neutral tones

Finish: Light textured

Model #: High pressure laminate

Other: Only use rounded half or full bullnose and integral backsplash. Do not use plastic laminate edge banding on front edges.

UFGS: Section 06 41 16.00 10 Plastic-Laminate-Clad Architectural Cabinets
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 06 41 16.00 10.pdf

E06.2.2. Solid Polymer Surface

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1, High Use Areas**

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Corian

Color: Medium Earth tones and neutral tones

Finish: Light textured

Model #: Solid Surface

Other: Faces and edges

UFGS: Section 12 36 00 Countertops
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 12 36 00.pdf

E06.2.3. Natural Stone

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1, Group 1 High Visibility, Heavy Use**

Applies to: ☑ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Local (TBD)

Color: Neutral tones

Finish: High polish, sealer


Model #: Custom cut slabs

Other: N/A

UFGS: Section 12 36 00 Countertops
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 12 36 00.pdf

E06.2.4. Cast Stone

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type: **Style 1, Group 1 High Visibility, Heavy Use**

Applies to: ☑ Group 1 ☐ Group 2 ☐ Group 3 ☐ Group 4 ☐ Other

Mfr: Local (TBD)

Color: Neutral tones

Finish: High polish, sealer


Model #: Custom cast or cut slabs

Other: N/A

UFGS: Section 12 36 00 Countertops
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 12 36 00.pdf

E06.2.5. Metal

◉ Applicable ○ N/A Number of base standards 1 Image Tool 250 x 188



Type:

Applies to: ☑ Group 1 ☑ Group 2 ☑ Group 3 ☐ Group 4 ☐ Other

Mfr: Local (TBD)

Color: Natural stainless steel

Finish: Mill

Model #: Custom fabricated countertops

Other: Provide integral fronts, sides and backsplash

UFGS: Section 12 31 00 Manufactured Metal Casework
http://www.wbdg.org/FFC/DOD/UFGS/UFGS 12 31 00.pdf

E06.2.6. Other

○ Applicable ◉ N/A

E07. Furnishings

Comply with Air Force Corporate Standards for Furnishings:
http://afcfs.wbdg.org/facilities-interiors/furnishings/index.html

E07.1. Durability and Serviceability

Comply with AF Corporate Standards for Durability and Serviceability:
http://afcfs.wbdg.org/facilities-interiors/furnishings/durability-and-serviceability/index.html

E07.2. Accessories

Comply with AF Corporate Standards for Accessories:
http://afcfs.wbdg.org/facilities-interiors/furnishings/accessories/index.html

1. Comply with AFCFS.

E08. Interior Signs

Comply with Air Force Corporate Standards for Interior Signs:
http://afcfs.wbdg.org/facilities-interiors/interior-signs/index.html

E08.1 Types and Color

Comply with Air Force Corporate Standards for Types and Color:
http://afcfs.wbdg.org/facilities-interiors/interior-signs/types-and-color/index.html

E08.2. Interior Signs Materials

1. Natural stone, masonry and cast stone signs may only be used in Group 1 with approval on a case-by-case basis.

E09. Lighting, Power and Communication

http://afcfs.wbdg.org/facilities-interiors/lighting-power-and-communication/index.html

E09.1. Functionality and Efficiency

Comply with Air Force Corporate Standards for Functionality and Efficiency:
http://afcfs.wbdg.org/facilities-interiors/lighting-power-and-communication/functionality-and-efficiency/index.html

E09.2. Types and Color

1. Comply with AFCFS.


F. APPENDIX - Facility Districts

- (•) Applicable
- ( ) N/A

Comply with Air Force Corporate Standards for Facility Districts:
http://afcfs.wbdg.org/facility-districts/index.html

Facilities Districts Overview Map:

Image Tool 800 x 600



Note: *Apply the base-wide standards in this IFS for Installation Elements, Site Development, Facilities Exteriors and Facilities Interiors (products, materials, color, etc.). Following application of the base-wide standards, refer to the Appendix and apply any additional requirements specifically related to the Facility District.*


Enter No. of Facility Districts 4

The following Facility Districts list exceptions to the base standards that are unique to each district. Please refer to the Site Development, Facilities Exteriors, and Facilities Interiors sections of this IFS for base standards.

Name of District: F01. Town Center

Image Tool 800 x 600

Map of District



Photos for each facility group within the Facility District as applicable.

Image Tool 250 x 188

Group 1	◯ Applicable	◉ N/A
Group 2	◯ Applicable	◉ N/A
Group 3	◯ Applicable	◉ N/A
Group 4	◯ Applicable	◉ N/A
Other	◯ Applicable	◉ N/A

Continue to the Next Page

Town Center District

The Town Center District is composed of approximately 1,395 acres surrounding all the gates, housing, office space and community services. This district is community focused and the nature of this area should be walkable and dense, with administrative work, living, and complementary functions as the primary land use. A main square should sit at the center of this district that is close to housing, dormitories, dining and community activities. Major amenities should be within a 10-minute walk of the town square. Other features within the Town Center should include gathering places for social events, multi-story flex-use buildings and access to outdoor recreation.


Facilities in the Town Center District should continue to be pedestrian in scale. Application of the installation prevailing architectural theme, “Prairie Modern” style, should be implemented during major renovations or new construction as appropriate.

Continue to the Next Page

Name of District: F02. Airfield

Image Tool 800 x 600

Map of District



Photos for each facility group within the Facility District as applicable.

Image Tool 250 x 188

Group 1	◯ Applicable	◉ N/A
Group 2	◯ Applicable	◉ N/A
Group 3	◯ Applicable	◉ N/A
Group 4	◯ Applicable	◉ N/A
Other	◯ Applicable	◉ N/A

Continue to the Next Page

Airfield District

The Airfield District, provides airfield support and maintenance facilities. The Airfield District is made up of approximately 1,815 acres located on the western side of the installation. It is bordered to the east by the PRIDE District and to the north by the Northside District. Due to the mission-critical nature of the land uses contained in this district, increased security measures are required. Permitted land uses in this district include airfield operations and maintenance, industrial, light industrial and open space.


Application of the installation prevailing architectural theme, “Prairie Modern” style, should be implemented during major renovations or new construction as appropriate.

Continue to the Next Page

Name of District: F03. PRIDE

Image Tool 800 x 600

Map of District



Photos for each facility group within the Facility District as applicable.

Image Tool 250 x 188

Group 1	◯ Applicable	◉ N/A
Group 2	◯ Applicable	◉ N/A
Group 3	◯ Applicable	◉ N/A
Group 4	◯ Applicable	◉ N/A
Other	◯ Applicable	◉ N/A

Continue to the Next Page

PRIDE District

The PRIDE District, is primarily composed of industrial uses to support the base flying mission. The district is named after the PRIDE Hanger, a historic aircraft hangar currently used for recreation and special events. This district covers approximately 525 acres located in the center of the base. The Town Center and Airfield Districts lie to the east and west, respectively, with the Northside District to the north. Multiple functions exist in this district including the flying squadrons, aircraft and Air Ground Equipment (AGE) maintenance, POL, Fire Station, Base Operations and Base Supply.

Application of the installation prevailing architectural theme, “Prairie Modern” style, should be implemented during major renovations or new construction as appropriate. Facilities in this district are industrial in nature, should generally match adjacent buildings to ensure architectural compatibility and will follow standards for Facility Group 3 as defined in this IFS.

Continue to the Next Page

Name of District: F04. Northside

Image Tool 800 x 600

Map of District



Photos for each facility group within the Facility District as applicable.

Image Tool 250 x 188

Group 1	◯ Applicable	◉ N/A
Group 2	◯ Applicable	◉ N/A
Group 3	◯ Applicable	◉ N/A
Group 4	◯ Applicable	◉ N/A
Other	◯ Applicable	◉ N/A

Continue to the Next Page

Northside District

The Northside District, is primarily composed of the MSA and firearm training ranges. The district is located along the northern border of the base with the Airfield, PRIDE and Town Center Districts to the south. The munitions area occupies the western half of the district, and firing ranges lie on the eastern half. The northern border of the Northside District is vacant land that drops off steeply while overlooking the plains below. This district covers approximately 1,508 acres. Facilities in this district are industrial in nature, should generally match adjacent buildings to ensure architectural compatibility and will follow standards for Facility Group 3 as defined in this IFS.

End of Section

Continue to the Next Page

G. APPENDIX - References

Comply with Air Force Corporate Standards:
http://afcfs.wbdg.org/index.html

Note: The below listed documents are provided as supplements to this IFS. If there are any discrepancies between the requirements of this IFS and the Supplemental Documents, the IFS will govern.

The numbering system follows Unified Facilities Guide Specifications (UFGS) divisions. Only the divisions with supplemental information are included.

28th CIVIL ENGINEER SQUADRON

G01 Ellsworth AFB IFS General Requirements
Includes General Geospatial Work Description, Mapping / Survey Standards, Drawings Submittals
https://www.wbdg.org/FFC/AF/AFIFS/G01_Ellsworth_AFB_IFS_General_Requirements.pdf

G01.57 Ellsworth AFB IFS Section 01800 Environmental Provisions
Includes Environmental Preservation and Protection, Management and Disposal of Waste, Recycling, Submittals
https://www.wbdg.org/FFC/AF/AFIFS/G01.57_Ellsworth_AFB_IFS_Environmental_Provisions.pdf

G09 Ellsworth AFB IFS Finishes
Includes Facilities Exteriors Paints and Coatings, Colors
https://www.wbdg.org/FFC/AF/AFIFS/G09_Ellsworth_AFB_IFS_Finishes.pdf

G21 Ellsworth AFB IFS Fire Suppression
Includes Automatic Sprinkler Systems: Fire Codes and Regulations
https://www.wbdg.org/FFC/AF/AFIFS/G21_Ellsworth_AFB_IFS_Fire_Suppression.pdf

G22 Ellsworth AFB IFS Plumbing
Includes Plumbing Design, Fixtures, Products, Piping, Natural Gas
https://www.wbdg.org/FFC/AF/AFIFS/G22_Ellsworth_AFB_IFS_Plumbing.pdf

G23 Ellsworth AFB IFS Heating Ventilating and Air Conditioning (HVAC)
Includes Mechanical Design, Air Conditioning and Heating Systems, Energy Management Control Systems (EMCS)
https://www.wbdg.org/FFC/AF/AFIFS/G23_Ellsworth_AFB_IFS_Heating_Ventilating_Air_Conditioning.pdf

G26 Ellsworth AFB IFS Electrical
Includes Electrical Design, Products, Generators, Lightning Protection Systems (LPS), Interior and Exterior Lighting, Memorandum Regarding LPS / Air Terminals
https://www.wbdg.org/FFC/AF/AFIFS/G26_Ellsworth_AFB_IFS_Electrical.pdf

G27 Ellsworth AFB IFS Communications
Includes Facility Telecommunications Systems
https://www.wbdg.org/FFC/AF/AFIFS/G27_Ellsworth_AFB_IFS_Communications.pdf

G28 Ellsworth AFB IFS Electronic Safety and Security
Includes Fire Alarm System Requirements
https://www.wbdg.org/FFC/AF/AFIFS/G28_Ellsworth_AFB_IFS_Electronic_Safety_Security.pdf

G33 Ellsworth AFB IFS Utilities
Includes Underground Electrical Distribution
https://www.wbdg.org/FFC/AF/AFIFS/G33_Ellsworth_AFB_IFS_Utilities.pdf