

Halon 1301 Fire System. FAC: 8999

CATCODE: 880234

OPR: AFCEC/COS

OCR: AFCEC/CXF

1.1. **Description.** Halon 1301 systems are no longer authorized for use in new construction and should be replaced in accordance with UFC 3-600-01, ETL 01-18, *Fire Protection Engineering Criteria - Electronic Equipment Installations*, and ETL 95-1, *Halon 1301 Management Planning Guidance, with Change 1*.

1.2. **Requirements Determination.** See UFC 3-600-01, ETL 01-18, and ETL 95- 1.

1.3. **Scope Determination.** See UFC 3-600-01, ETL 01-18, and ETL 95-1.

1.4. **Dimensions.** See UFC 3-600-01, ETL 01-18, and ETL 95-1.

1.5. **Design Considerations.** See UFC 3-600-01, ETL 01-18, and ETL 95-1.