



US Army Corps
of Engineers®

ENGINEERING AND CONSTRUCTION BULLETIN

No. 2021-4

Issuing Office: CECW-EC

Issued: 18 Feb 21

Expires: 18 Feb 23

SUBJECT: Cybersecurity Design Requirements for Non-Permanent Facilities.

CATEGORY: Directive and Guidance.

1. **References:**

a. Unified Facilities Criteria (UFC) 1-201-01, Non-Permanent DoD Facilities in Support of Military Operations, 01 January 2013

b. Unified Facilities Criteria (UFC) 4-010-06 Change 1, Cybersecurity of Facility-Related Control Systems, 18 January 2017

c. Unified Facilities Guide Specification (UFGS) 25 05 11, Cybersecurity for Facility-Related Control Systems, 1 November 2017

2. **Purpose.** This ECB provides direction and guidance for the use of UFC 4-010-06 and UFGS 25 05 11 for the design of non-permanent facilities.

3. **Applicability.** This ECB applies to the design of all non-permanent facilities which include control systems using UFC 1-201-01 as design criteria.

4. **Background.** The DoD Risk Management Framework (RMF) applies to all DoD information systems, which include control systems regardless of whether they support permanent or non-permanent facilities. Reference (a) is currently undergoing revision, and this revision will incorporate reference (b) as a requirement for non-permanent facilities in the same manner as other UFCs are referenced.

5. **Directive.** All new non-permanent facility designs incorporating control systems and all existing non-permanent facility design projects incorporating control systems which did not include UFC 4-010-06 and which have not completed design (acceptance of final design) must incorporate UFC 4-010-06 into the design.

6. **Point of Contact.** HQUSACE point of contact for this ECB is Joseph Bush, CECW-EC, 217-373-4433, Joseph.Bush@usace.army.mil.

//S//

PETER L. STURDIVANT, P.E.
Chief, Engineering and Construction
U.S. Army Corps of Engineers