

Medical/Dental Clinic

Preventive Maintenance Schedule

System: Fire/Smoke Dampers

| Maintenance Task Description | Frequency * | Skill Level ** | Time Hours *** |
|--|----------------|----------------------|----------------------|
| Check fire damper and fire/smoke damper and fusible link. Replace if required | A | A | 0.25 |
| Check smoke damper opening and closing with air handling unit operation. | A | A | 0.25 |

* Frequency Legend

| | |
|----|---------------|
| D | Daily |
| W | Weekly |
| M | Monthly |
| Q | Quarterly |
| SA | Semi-Annually |
| A | Annually |

** Skill Level Legend

| | |
|----|-----------------------|
| O | Unskilled Laborer |
| A | Apprentice Mechanic |
| J | Journeyman Mechanic |
| M | Master Mechanic |
| FT | Factory Trained Tech. |

*** The time indicated is
for the required to
service one unit