
PROJECT Medical/Dental

| DATA | | PUMP NO. CWP-1 | PUMP NO. CWP-2 | PUMP NO. HWP-1 | PUMP NO. HWP-2 | PUMP NO. |
|--------|--|----------------|----------------|----------------|----------------|----------|
| DESIGN | Location | Equip.Rm. | Equip.Rm. | Mech.Rm. | Mech.Rm. | |
| | Service | AH-1&2 | AH-1&2 | Coils | Coils | |
| | Manufacturer | Taco | Taco | Taco | Taco | |
| | Model Number | VI3008 | VI3008 | V12008 | V12008 | |
| | Serial Number | NS | NS | NS | NS | |
| | GPM/Head. | 188/69 | 188/69 | 46/69 | 46/69 | |
| | Req. NPSH | NS | NS | NS | NS | |
| | Pump RPM | 1760 | 1760 | 1775 | 1775 | |
| | Impeller Diam. | 8.1 | 8.1 | 8.2 | 8.2 | |
| | Motor Mfr./Frame | Baldor | Baldor | Baldor | Baldor | |
| | Motor HP/RPM | 7.5/1760 | 7.5/1760 | 3.0/1775 | 3.0/1775 | |
| | Volts/Phase/Hertz | 460/3/60 | 460/3/60 | 460/3/60 | 460/3/60 | |
| | F.L. Amps/S.F. | 10.8/1.15 | 10.8/1.15 | 4.1/1.15 | 4.1/1.15 | |
| ACTUAL | Seal Type | NA | NA | NA | NA | |
| | Pump Off-Press. | NA | NA | NA | Na | |
| | Valve Shut Diff. | NA | NA | NA | NA | |
| | Act. Impeller Diam. | 8.1 | 8.1 | 8.2 | 8.2 | |
| | Valve Open Diff. | 20.9 | 28.9 | 30 | 30 | |
| | Valve Open GPM | 188 | 188 | 46 | 46 | |
| | Final Dischg. Press. | 39.3 | 39.6 | 63.0 | 63.0 | |
| | Final Suction Press. | 7.4 | 9.9 | 33.0 | 33.0 | |
| | Final ΔP | 28.9 | 29.5 | 30 | 30 | |
| | Final GPM | 188 | 188 | 46 | 46 | |
| | Voltage $\begin{smallmatrix} T_1-T_2 & T_2-T_3 \\ T_3-T_1 \end{smallmatrix}$ | 460 | 460 | 460 | 460 | |
| | Amperage $T_1 T_2 T_3$ | 10.0 | 10.1 | 4.0 | 3.9 | |
| | | | | | | |

REMARKS:

TEST DATE 6/3/02 READINGS BY [REDACTED]