

Medical/Dental Clinic

Preventive Maintenance Schedule

System: Filter Sections

Maintenance Task Description	Frequency *	Skill Level **	Time Hours ***
Check filters and replace if dirty	M	A	0.25
Check filter access door gaskets and filter seals. Replace if req'd.	SA	A	0.25
Check filter manometer and calibrate if required.	A	A	0.25

* Frequency Legend	
D	Daily
W	Weekly
M	Monthly
Q	Quarterly
SA	Semi-Annually
A	Annually

** Skill Level Legend	
O	Unskilled Laborer
A	Apprentice Mechanic
J	Journeyman Mechanic
M	Master Mechanic
FT	Factory Trained Tech.

*** The time indicated is for the required to service one unit
--