

POL-AIR 16261  
START-UP SHEET VFD'S

DATE 7/6/02

JOB MEDICAL DENTAL CLINIC

UNIT #

MFG. YORK

M#

SUPPLY SECTION

SUPPLY VFD M#

S# OR ORDER #

MOTOR MANUFACTURER# BALDOR

MODEL # 2539T

VOLTS 460 RUNNING AMP 48.5 FLA 49 HP 40 RPM 1770

FRAME 324T PHASE 3

RETURN SECTION

RETURN VFD M#

S#

MOTOR MANUFACTURER# BALDOR

MODEL # 2515T

VOLTS 460 RUNNING AMP 21.0 FLA 25 HP 20 RPM 1760

FRAME 256T PHASE 3

UNIT CHECK LIST

✓ INSPECT UNIT ✓ TIGHTEN NUTS/BOLTS ✓ TIGHTEN ELECTRICAL ✓ TEST, START, CALIB.

NOTES