

System: Valve and Valve Actuators

Maintenance Task Description	Frequency *	Skill Level **	Time Hours ***
Inspect valve linkages and visually verify smooth operation over the entire operating range of the actuator.	A	J	0.25
Inspect and tighten electrical wiring connections at each actuator.	A	J	0.25
Inspect valve for leakage and corrosion and repair or replace valve if required.	A	J	0.25

* Frequency Legend	
D	Daily
W	Weekly
M	Monthly
Q	Quarterly
SA	Semi-Annually
A	Annually

** Skill Level Legend	
O	Unskilled Laborer
A	Apprentice Mechanic
J	Journeyman Mechanic
M	Master Mechanic
FT	Factory Trained Tech.

*** The time indicated is for the required to service one unit
--