

POL-AIR
START-UP SHEET16261
VFD'S

DATE 7 16 102

JOB MEDICAL DENTAL CLINIC

UNIT #

MFG. YORK

M#

S#

SUPPLY SECTION

SUPPLY VFD M#

S# OR ORDER #

MOTOR MANUFACTURER# BALDOR

MODEL # 2539T

VOLTS 460 RUNNING AMP 34.6 FLA 49 HP 40 RPM 1770

FRAME 324T PHASE 3

RETURN SECTION

RETURN VFD M#

S#

MOTOR MANUFACTURER# BALDOR

MODEL # 2515T

VOLTS 460 RUNNING AMP 15.1 FLA 25 HP 30 RPM 1760

FRAME 256T PHASE 3

UNIT CHECK LIST

☒ INSPECT UNIT ☒ TIGHTEN NUTS/BOLTS ☒ TIGHTEN ELECTRICAL ☒ TEST, START, CALIB.

NOTES