

## **Water Chillers & ACCU's:**

Safety instructions to observe when working with this equipment is as follows:

- Warning:** When working on Water Chiller or ACCU electrical components, provide lockout device, a lockout tag and a tag-out device on electrical breaker or on the disconnect switch, see sheet PART I - Page 5-9 & 5-10 for panel, breaker and/or disconnect switch. The devices shall be in full compliance with Appendix 1i-13.
- Caution:** All clothing should be checked to insure that loose ends of clothing or other objects may not be caught in the rotating machinery.
- Caution:** Be sure that the unit is properly grounded before working on the unit.
- Caution:** Never pressurize the unit in excess of the manufacturers recommended pressures.
- Caution:** Before opening the compressor housing for repair, the internal pressure within the compressor must be relieved.
- Caution:** Removal and reinstallation of the compressor, chiller evaporator and condenser heads will require special lifting equipment that is capable of handling the weight. Special care and safety will be required to prevent injury to personnel and equipment from swinging equipment.