

PART II - PRIMARY SYSTEMS INFORMATION

1. HEATING, VENTILATING SYSTEMS

1. Operation

- g. Environmental Considerations - The following items of equipment require special operation, reporting, testing analysis or inspection to comply with federal or local environmental laws:

CAUTION: (1) Hydronic Chemical Treatment Systems: Chemicals must be handled and stored in accordance with manufacturers written instructions.

CAUTION: (2) Backflow preventers shall be routinely inspected and tested to insure proper operating function in accordance with local regulations or other more stringent governing requirements.

CAUTION: (3) Air Cooled Chiller Refrigerant shall be handled and stored in accordance with the California Environmental Regulations and the EPA (Environmental Protection Agency)