

B. Normal Operations

Operation of the sprinkler system is completely automatic. Valves outside and inside the building tagged "control valve" are to remain in the open position. Electric tamper switches on each valve will send a trouble signal if unauthorized operation occurs.