


BOILER START-UP DATA

PROJECT NAME: [REDACTED]	JOB #: _____
	DATE: 3-22-02

UNIT #	BOILER 1			
MANUFACTURER	LOCHINVAI			
MODEL #	CBN1435			
SERIAL #	L016745			
SETPOINT (DEGREES)	130			
LIMIT SETPOINT (DEGREES)	200			
NG-PRESSURE INPUT W.G.	10.5"			
NG-MANIFOLD PRESSURE INPUT W.G.	3.8"			
EWT TEMPERATURE	90			
LWT TEMPERATURE	130			
FLOW SWITCH CALIB.	YES			
LOW WATER TEST	YES			
LIMIT TEST	YES			
BTU INPUT	1,435,000			
BTU OUTPUT	1,200,000			
SYSTEM APPLICATION	HVAC			
E.M.S.	CLIMATEC			

COMMENTS:(USE REVERSE SIDE FOR ADDITIONAL COMMENTS)

TECHNICIAN SIGNATURE: _____



DATE: 7-30-02

15181

CENTRIFUGAL PUMPPROJECT NAME: [REDACTED]

DATE: 5-22-02

TECHNICIAN: [REDACTED]

JOB #:

PUMP ID	BOILER PUMP I	BOILER PUMP II		
MANUFACTURER	TACO	TACO		
MODEL # / SIZE	V12008	V12008		
SERIAL #	9032815	9032816		
SERVICE / LOCATION	MEZZ	MEZZ		
MOTOR MFR.	BALDOR	BALDOR		
FRAME / TYPE	182 / JH	182 / JH		
HORSEPOWER	3	3		
MOTOR RPM	1725	1725		
VOLTAGE / PHASE	460.3	460.3		
AMPERAGE SPEC'D/ACTUAL	4.1 / 3.6	4.1 / 3.6		
SERVICE FACTOR	1.15	1.15		
HEATER / O.L. SIZE	6	6		
P.S.I. DISCHARGE DES/ACTUAL	TAB	TAB		
P.S.I. SUCTION DES/ACTUAL	TAB	TAB		
FT. OF HEAD DES/ACTUAL	TAB	TAB		
SHUT - OFF HEAD	TAB	TAB		
G.P.M.	TAB	TAB		

COMMENTS: (USE REVERSE SIDE FOR ADDITIONAL COMMENTS)

1. Make up H2O - preset = 12 PSI9
2. Combustion pipe mounted blower

TECHNICIAN SIGNATURE: [REDACTED]

DATE: 7-30-02