

Alpha Mechanical

15720

AIR HANDLER

PROJECT NAME: [REDACTED]

Job#

TECHNICIAN: [REDACTED]

DATE


EQUIP. I.D.	AH1-SF	AH1-RAF	AH2-SF	AH2-RAF
MANUFACTURER	YORK	YORK	YORK	YORK
MODEL #	40H005W952H1	39D101X113H1	40H005W952H1	39D101X113H1
SERIAL #	Z0111020099	Z0109280103	Z0111020109	Z0109280108
VOLTAGE/PHASE	460 / 3	460 / 3	460 / 3	460 / 3
BLOWER	SF	RAF	SF	RAF
MOTOR/FRAME	BALDOR/324T	BALDOR/255T	BALDOR/40	BALDOR/256T
HORSEPOWER/TYPE	40	20	40	20
AMPERAGE SPEC'D/ACTUAL	43 / 31	25 / 18		25 / 21
SHEAVE SIZES				
MOTOR	13.6 X 2 B - SK	4.43D - S4	8.0 x 2P - SK	15.4 X 3B SK
	Bushing SK-2 1/8	SH 1 5/8	SK x 2 - ME	SK 2 7/16
FAN	18.4 x 2B - SK	13.6 3 B-SK	12.4 X 2B-SK	4.6K X 3B - SD
	BUSHING SK2 7/16	SK X 2 7/16	XKX2 7/16	1518 SDX
BELT SIZE (QTY)	BX144 (2)	BX85 (3)	BX123 (2)	BX89 (3)
COND. FANS				
AMPERAGE SPEC'D/ACTUAL				
COOLING TEMPERATURE				
SA DEGREE F/AMBIENT	58 F		59 F	
HEAT DEGREE F	78 F		78 F	
HEATING TEMPERATURE				
SA DEGREE F/AMBIENT				
EAT DEGREE F				
FILTER SIZE (QTY)				
ENERGY MGMT				
VFD MATCH				
VFD SIGNAL				
SYSTEM APPLICATION				

TECHNICIAN SIGNATURE [REDACTED]

DATE

7-30-02

Dave Dennison Co., Inc.
MANUFACTURERS' REPRESENTATIVE



15720
FAN & VAN CERTS.

ALPHA MECHANICAL

TO: [REDACTED]

RE: [REDACTED]

DEAR [REDACTED]

THE EQUIPMENT AND MATERIALS PROVIDED TO ALPHA MECHANICAL BY THE DAVE DENNISON CO. FOR THE PROJECT [REDACTED] MEDICAL DENTAL BUILDING REPLACEMENT P-936:

→ GREENHECK FANS AND VENTS
→ GREENHECK FIRE AND SMOKE DAMPERS,
→ KRUEGER AIR TERMINAL BOXES
E.H. PRICE AIR DISTRIBUTION

MEET OR EXCEED THE REQUIRED PLANS AND SPECIFICATIONS PROVIDED TO US BY ALPHA MECHANICAL DATED JUNE 6, 2000.

ALL EQUIPMENT AND MATERIALS PROVIDED WERE APPROVED BY THE MECHANICAL ENGINEER AND THE ARCHITECT PRIOR TO RELEASE.

IF YOU HAVE ANY QUESTIONS, PLEASE FEEL FREE TO CALL

SINCERELY,

[REDACTED]