




# AIR OUTLET TEST REPORT (Flow Hood)

PROJECT Medical/Dental SYSTEM EF-2-1 & EF-2-2

OUTLET MANUFACTURER Price TEST APPARATUS Flow Hood

AREA SERVED	OUTLET			DESIGN	PRELIMINARY		FINAL	PERCENT OF DESIGN
	NO.	TYPE	SIZE	AIRFLOW CFM (l/s)	AIRFLOW CFM (l/s)		AIRFLOW CFM (l/s)	
2C	1	O	16x14	620			650	EF-2-1
2C16	2	ER	10x10	190			190	
				810			840	
2C10	1	H	*	240			230	EF-2-2
2C12	2	O	*	235			235	
2C11	3	B	*	40			40	
2C13	4	"	*	75			70	
2C08	5	D	"	80			75	
2C07	6	"	"	80			85	
2C03	7	A	"	70			70	
2C24	8	D	"	70			75	
2A13	9	G	"	210			200	
2C05	10	A	8x8	30			30	
				1130			1110	

REMARKS:



TEST DATE 6/3/02 READINGS BY [Redacted]