

# MEDICAL/DENTAL CLINIC

## 8. HVAC FILTERS

Filter Identification	Equipment Served	Location	Type & Media	Efficiency	Size mm H x W x D	Quantity	Notes
PF - 1	AHU-1		Pleated Media (Rigid)	30	20 x 20 x 2	24	1, 2
AF - 1	AHU-1		Pleated Media (Rigid)	90	20 x 20 x 12	15	1, 3
PF - 2	AHU-2		Pleated Media	30	20 x 20 x 2	24	1, 2
AF - 2	AHU-2		Pleated Media	30	20 x 20 x 12	15	1, 3
Package A/C Units 1-4	Communication Room A/C Unit	1B-21, 1C-13, 2B-12, 2C-015	Washable	--	---	--	--
FAC-5	AC-5	2D04A	Pleated Media	30	20 x 20 x 1	1	1, 2
FAC-5A	AC-5	2D04A	Pleated Media	60	20 x 20 x 12	1	1, 4

1. Efficiency in accordance with ASHRAE Filter Test Standard 52.1-1992, Atmospheric Dust Spot Test.
2. Filters are located in the filter housing in the air handling unit.
3. Filters are located in discharge of unit.
4. Located in R.A. filter grill.