



OUTLET MANUFACTURER Price TEST APPARATUS Flow Hood

REMARKS:




# AIR OUTLET TEST REPORT (Flow Hood)

PROJECT Medical/Dental SYSTEM EF-1-2, 1-3 & EF-1-4

OUTLET MANUFACTURER Price TEST APPARATUS Flow Hood

AREA SERVED	OUTLET			DESIGN	PRELIMINARY		FINAL	PERCENT OF DESIGN
	NO.	TYPE	SIZE	AIRFLOW CFM (l/s)	AIRFLOW CFM (l/s)		AIRFLOW CFM (l/s)	
1B04	1		*	430			440	EF-1-2
	2		*	430			450	
				860			890	
1E30	1	D	*	65			70	EF-1-3
1E10	2	A	*	35			35	
1E09	3	"	*	35			40	
1D26	4	"	*	35			35	
1E01	5	D	*	65			70	
1E02	6	WER	*	540			550	
1E03	7	A	*	30			30	
1D39	8	"	*	35			45	
1B17	9		*	280			285	
1B14	10	C	*	60			65	
1B16	11	A	*	30			30	
1B05	12	"	*	35			40	
1B11	12A	"	*	35			40	
1B02	12B	"	*	40			40	
				1285			1375	
	1		*	35			35	EF-1-4
	2		*	35			35	
				70			70	

REMARKS:



TEST DATE 6/3/02 READINGS BY [REDACTED]