


FAN TEST REPORT

PROJECT Medical/Dental

FAN DATA	FAN NO. SF-1	FAN NO.	FAN NO.			
Location	2D-05					
Service	2D-05					
Manufacturer	Greenheck					
Model Number	SS1-20-432-A15					
Serial Number	NS					
Type/Class	NS					
Motor Make/Style	Marathon					
Motor H.P./RPM/Frame	1.5/1725/56H					
Volts/Phase/Hertz	480/3/60					
F.L. Amps/S.F.	2.4/1.15					
Motor Sheave Make/Model	Direct Drive					
Motor Sheave Diam./Bore	" "					
Fan Sheave Make	" "					
Fan Sheave Diam./Bore	" "					
No. Belts/Make/Size	" "					
Sheave ϕ Distance	" "					
TEST DATA	DESIGN	ACTUAL	DESIGN	ACTUAL	DESIGN	ACTUAL
CFM L/S	3100	3000				
Fan RPM	1750	NA				
S.P. In/Out	NS	NA				
Total S.P. ESP Pa	125	NA				
Voltage T_1-T_2 T_2-T_3 T_3-T_1	480	460				
Amperage T_1 T_2 T_3	2.4	2.0				

REMARKS:

TEST DATE 6/3/02READINGS BY [Redacted]