

NOTES:

1. SEE TYPICAL EQUIPMENT MOUNTING HEIGHTS SCHEDULE. SEE SECTION 7.01

KEY NOTES:

1. SIZE WINDOWS TO THE MAXIMUM ALLOWED BY NF-3-400-01 (LATEST EDITION).
DESIGN: ENERGY CONSERVATION & ASHRAE 90.1 (LATEST EDITION) ASHRAE
ENERGY STANDARD FOR BUILDINGS EXCEPT LOW-RISE RESIDENTIAL BUILDINGS,
BUILDING ENVELOPE REQUIREMENTS APPENDIX B
2. WINDOW COVERINGS IN ISOLATION ROOMS MUST MEET
FACILITY INFECTION CONTROL GUIDELINES.
3. EMERGENCY CART NEEDS TO BE LOCATED
IN CLOSE PROXIMITY TO ICU/CCU OR CVICU PATIENT ROOMS
4. M4811 MAY PUMP, INTRA-AORTIC ONLY BE USED IN THE CCU OR CVICU DEPENDING
ON THE ACUITY OF THE PATIENT
5. M0925 VENTILATOR MAY BE DELETED FROM THE EQUIPMENT LIST IF THIS EQUIPMENT
IS PROVIDED BY RESPIRATORY THERAPY DEPARTMENT
6. M4200, OTOSCOPE/OPHTHALMOSCOPE, MAY NOT BE DESIRED ASK FACILITY USER
7. MOUNT ITEMS M0750, M0755, M0765, M4100, M4250, M4266, M7905, ON THE CEILING
MOUNTED SERVICE MODULE U0002
8. PROVIDE WALL MOUNTED ROOM PRESSURE ALARM
9. IN PEDIATRIC ICU, CHANGE M7845, PHYSIOLOGICAL BEDSIDE MONITOR, TO M7855,
INFANT MONITOR
10. IN PEDIATRIC ICU CHANGE M7007, BED, TO M7015, CRIB, AND PROVIDE M7020, TOP
11. IN PEDIATRIC NEONATAL ICU CHANGE F0260, PATIENT CHAIR , TO F0315, SLEEPER CHAIR
AS DETERMINED BY FACILITY POLICY
12. VISION LITE WITH INTERNAL BLINDS, OPERATING CONTROL FROM BOTH SIDES
13. LAVATORY TO BE EQUIPPED WITH ELECTRONIC SENSOR OPERATED FAUCET
14. BASEBOARD RADIATOR MAY OCCUR ALONG EXTERIOR WALL
15. CUBICLE CURTAIN IN ISOLATION ROOMS MUST MEET FACILITY INFECTION
CONTROL GUIDELINES.
16. MOUNT A5145 ROBE HOOK 1372 [4'-6"] AFF
17. DRY ERASE BOARD, F3050-18"H x 24"W
18. MOUNT ROBE HOOK 1575 [5'-0"] A.F.F.


**BEDROOM, ISOLATION,
ICU/CCU NEGATIVE (BRII1)**

4.01.06


NURSING UNITS – NEGATIVE PRESSURE

FLOOR /EQUIPMENT PLAN

DATE: 04/24/2006



NORTH



SOUTH

NOTES

1. SEE TYPICAL EQUIPMENT MOUNTING HEIGHTS SCHEDULE. SEE SECTION 7.01

KEY NOTES:

1. IN FILL BELOW INTERMEDIATE RAIL WITH PRE FINISHED ALUMINUM SANDWICH PANEL
2. DRY ERASE BOARD, F3050 – 18"H x 24"W

**BEDROOM, ISOLATION,
ICU/CCU NEGATIVE (BRII1)**

4.01.06

NURSING UNITS – NEGATIVE PRESSURE



ELEVATIONS

DATE: 04/24/2006

0 1000 2000



1:50 SCALE (MILLIMETERS) 253



NOTES

1. SEE TYPICAL EQUIPMENT MOUNTING HEIGHTS SCHEDULE. SEE SECTION 7.01

KEY NOTES:

1. ITEM M0430 VIDEO RECORDER/PLAYER LOCATED IN WARDROBE
2. LAVATORY TO BE EQUIPPED WITH ELECTRONIC SENSOR OPERATED FAUCET

BEDROOM, ISOLATION, ICU/CCU NEGATIVE (BRII1)

4.01.06

NURSING UNITS – NEGATIVE PRESSURE


ELEVATIONS

DATE: 04/24/2006


0 1000 2000



1:50 SCALE (MILLIMETERS) 254



EAST (BRIAR - 1)



WEST (BRIAR - 1)

NOTES

1. SEE TYPICAL EQUIPMENT MOUNTING HEIGHTS SCHEDULE. SEE SECTION 7.01

KEY NOTES:

1. MOUNT A5145 ROBE HOOK1575 [5'-2"] A.F.F.
2. LAVATORY TO BE EQUIPPED WITH ELECTRONIC SENSOR FAUCET

**BEDROOM, ISOLATION,
ICU/CCU NEGATIVE (BRII1-BRAR1)**

4.01.06

NURSING UNITS – NEGATIVE PRESSURE


ELEVATIONS

DATE: 04/24/2006


0 1000 2000




1:50 SCALE (MILLIMETERS) 255



NORTH
(BATHROOM)



EAST
(BATHROOM)



SOUTH
(BATHROOM)

NOTES

1. SEE TYPICAL EQUIPMENT MOUNTING HEIGHTS SCHEDULE. SEE SECTION 7.01

KEY NOTES:

1. PROVIDE A5109 & A5110 GRAB BARS THAT COMPLY WITH ADA.
2. MOUNT A5145 ROBE HOOK 1372 [4'-6"] A.F.F.

**BEDROOM, ISOLATION,
ICU/CCU NEGATIVE (BRII1-TLTS2)**

4.01.06

NURSING UNITS – NEGATIVE PRESSURE


ELEVATIONS

DATE: 04/24/2006

0 1000 2000



1:50 SCALE (MILLIMETERS) 256



OVER-ALL ELEVATION CEILING MOUNTED SERVICE MODULE

NOTE:

1. REFER TO ENLARGED ELEVATION OF SERVICE MODULE FOR UTILITIES & ACCESSORIES

KEY NOTES:

1. DOUBLE ARM (MONITOR)
2. DOUBLE ARM (SERVICE MODULE)
3. LOW VOLTAGE PROVISIONS
4. MONITOR SHELF

BEDROOM, ISOLATION, ICU/CCU NEGATIVE (BRII1)

4.01.06

NURSING UNITS – NEGATIVE PRESSURE



ELEVATIONS

DATE: 04/24/2006

0 1000 2000





1:50 SCALE (MILLIMETERS) 257



BACK

FRONT



LEFT

RIGHT


ENLARGED ELEVATION SERVICE MODULE

**BEDROOM, ISOLATION,
ICU/CCU NEGATIVE (BRII1) 4.01.06**

NURSING UNITS - NEGATIVE PRESSURE

ELEVATIONS

DATE: 04/24/2006



1:30 SCALE (MILLIMETERS)

KEY NOTES:

1. FLAT SCREEN ADAPTER
2. FLAT SCREEN ARM
3. BASKET (9.5"x9.5"x4" APPROX)
4. BOTTLE SLIDE
5. IV POLE HOLDER W/ 4 IV HOOKS
6. FIXED SHELF
7. 2 DRAWERS
8. BASKET (6.5"x4"x5")
9. NIGHT LIGHT SWITCH (OPTIONAL)
10. STAT CLOCK TIMER
11. NURSE CALL PROVISION
12. CORD WRAP
13. HORSESHOE RAIL
14. CODE BLUE
15. FOR INTERFACE (OPTIONAL LOCATION
IF NOT ON HEADWALL)
16. STAT CLOCK POWER
17. NIGHT LIGHT (OPTIONAL)

**BEDROOM, ISOLATION,
ICU/CCU NEGATIVE (BRII1)**

4.01.06

NURSING UNITS – NEGATIVE PRESSURE

ELEVATIONS

DATE: 04/24/2006

Medical Equipment Room Guide Plates

4.01 Nursing Unit

Plate Number 4.01.06

Room Name: Bedroom, Isolation, ICU/CCU Negative

SEPS# BR11

JSN	Nomenclature	Qty	Army	Navy	AF	Utilities					
			Cat	Cat	Cat	1	2	3	4	5	6
A5075	Dispenser, Soap, Disposable	1	C	C	C	.	.	.	.	.	.
A5080	Dispenser, Paper Towel, SS, Surface Mounted	1	A	A	A	.	.	.	.	.	.
A5106	Waste Disposal Unit, Sharps w/Glove Dispenser	1	C	C	C	.	.	.	.	.	.
A5180	Track, Cubicle, Surface, Mounted, With Curtain	1	A	A	A	.	.	.	.	.	.
A5210	Bracket, Television, Wall Mounted w/Adjustable Arm	1	A	A	A	.	.	.	.	.	.
A5220	Bracket, Television, Wall Backing	1	A	A	A	.	.	.	.	.	.
A6305	Drapes, Pair	1	C	C	C	.	.	.	.	.	.
C0025	Cabinet, Wardrobe, 1 Door	1	A	A	A	.	.	.	.	.	.
CE050	Cabinet W/H, 2SH, 2 DO, Sloping Top 38x48x13	1	A	A	A	.	.	.	.	.	.
CT030	Countertop, High Pressure Laminate	1	A	A	A	.	.	.	.	.	.
Fo230	Chair, Drafting, Rotary	1	C	C	C	.	.	.	.	.	.
F0355	Footstool, Straight	1	C	C	C	.	.	.	.	.	.
F2000	Basket, Wastepaper, Round, Metal, 18 H x 16 Dia	2	C	C	C	.	.	.	.	.	.
F3200	Clock, Battery, 12 " Diameter	1	C	C	C	.	.	.	.	.	.
F3050	Dry Erase Board 18x 24	1	C	C	C	.	.	.	.	.	.
M0430	Recorder / Player, Cassette, Video	1	C	C	C	.	A	.	.	.	.
M0500	Television, Color, 20" Diagonal	1	C	C	C	.	A	.	.	.	.
M0750	Flowmeter, Air, Connect w/50 PSI Supply	2	C	C	C	.	.	F	.	.	.
M0755	Flowmeter, Oxygen, Low Flow	3	C	C	C	.	.	A	.	.	.
M0765	Regulator, Vacuum	3	C	C	C	.	.	E	.	.	.
M0925	Ventilator, ICU, Adult	1	C	C	C	.	A	.	.	.	.
M3070	Hamper, Linen, Mobile, w/Lid	1	C	C	C	.	.	.	.	.	.
M3072	Frame, Infectious Waste Bag w/Lid	1	C	C	C	.	.	.	.	.	.
M4100	Sphygmomanometer, Aneroid, Headwall Mounted	1	C	C	C	.	.	.	.	.	.
M4200	Otoscope/Ophthalmoscope, Wall Mounted	1	C	C	C	.	A	.	.	.	.
M4250	Pump, Syringe, Infusion	2	C	C	C	.	A	.	.	.	.
M4266	Pump, Volumetric, Infusion, Multiple Line	3	C	C	C	.	A	.	.	.	.
M4811	Pump, Intra-Aortic, Balloon	1	C	C	C	.	A	.	.	.	.
M7007	Bed, Patient, Electric, Special Care	1	C	C	C	.	A	.	.	.	.
M7040	Table, Overbed	1	C	C	C	.	.	.	.	.	.
M7435	Light, Overbed, Direct and Indirect	1	A	A	A	.	F	.	.	.	.
M7845	Monitor, Physiological, Bedside, 4 Channel	1	C	C	C	D	A	.	.	.	.
M7905	Oximeter, Pulse	1	C	C	C	.	A	.	.	.	.
M7910	Thermometer, Electronic	1	C	C	C	.	.	.	.	.	.
P3100	Lavatory, Vitreous China, Slab Type	1	A	A	A	.	.	.	.	.	.
U0001	Cart, Mobile Charting, ICU	1	C	C	C	.	.	.	.	.	.
U0002	Service Module, Prefabricated, Ceiling Mounted, ICU	1	A	A	A	.	F	G	.	.	.

April 24, 2006

Medical Equipment Room Guide Plates

4.01 Nursing Unit

Plate Number 4.01.06

Room Name: Bedroom, Isolation, ICU/CCU Negative (TLTS2)

SEPS# BR11

JSN	Nomenclature	Qty	Army	Navy	Utilities						
			Cat	Cat	AF Cat	1	2	3	4	5	6
A1066	Mirror, Foatglass, SS Frame	1	A	A	A	.	.	.	.	.	.
A5030	Bench, Stall, Shower, Built In	1	A	A	A	.	.	.	.	.	.
A5075	Dispenser, Soap, Disposable	1	C	C	C	.	.	.	.	.	.
A5080	Dispenser, Paper Towel, SS, Surface Mounted	1	A	A	A	.	.	.	.	.	.
A5090	Disposal, Sanitary Napkin, SS, Surface Mounted	1	A	A	A	.	.	.	.	.	.
A5109	Grab Bar, 1-1/4" Dia., SS, 2 Wall, W/C Accessible	1	A	A	A	.	.	.	.	.	.
A5110	Grab bar, 1-1/4" Dia., SS, 2 wall, Shower Use	1	A	A	A	.	.	.	.	.	.
A5145	Hook, Garment, Double, SS, Surface Mounted	2	A	A	A	.	.	.	.	.	.
A5170	Rod, Shower Curtain, 1" Diameter, W/Curtain & Hooks	1	A	A	A	.	.	.	.	.	.
A5175	Soap Dish, With Bar, SS, Recessed	1	A	A	A	.	.	.	.	.	.
A5200	Dispenser, Toilet Tissue, SS, 2-Roll, Surface Mounted	1	A	A	A	.	.	.	.	.	.
A5205	Bar, Towel, 1" Diameter, SS, Surface Mounted	1	A	A	A	.	.	.	.	.	.
F2000	Basket, Wastepaper, Round, Metal	1	C	C	C	.	.	.	.	.	.
P3070	Lavatory, Vitreous China, Under or Countertop Mounted	1	A	A	A	D	.	.	.	.	.
P5040	Shower, Single, Hand-Held	1	A	A	A	D	.	.	.	.	.
P9050	Toilet, Wall Hung, Siphon Jet	1	A	.	.	B	.	.	.	.	.