

DESIGN NOTES

1. Construct all walls of masonry and GW and extend to the structure above.
2. Locate emergency flashing light(s) for the hearing impaired person(s).
3. Provide heavy gauge metal mesh door on Bulk Storage side with Keypad access.
4. Provide a visual alarm on the narcotics locker in the vault.
5. Provide a motion detector, wall mounted and facing the entry to the vault.
6. Provide touch key pad access to unit from adjacent corridor(s).

LEGEND

	Fire Blanket
	Fire Extinguisher
	Eye Wash
	Thermostat
	Multiplex Comm/ Data System
	Security Key Pad
	Security Alarm
	Security Motion Detector
	Duplex Electrical Outlet
	Quadruplex Electrical Outlet
	Electrical Panel
	Power Entry
	Heavy Gauge Metal Mesh Door

SMALL LAB URINALYSIS (LMUO2)

MILCARE

FLOOR/EQUIPMENT PLAN


DATE: 11/26/2002

10.99 NSM (118 NSF) MIN.

0 1000 2000



1:50 SCALE (MILLIMETERS)



NOTES:

1. Use duplex receptacle computer isolation, on separate circuit when service not located in rail at all computer stations.
2. 2' x 4' (610mm x 1219mm) recessed floor. w/4 - F40 CW lamps
3. 2' x 2' (610mm x 610mm) recessed floor. w/2 - F20 CW lamps
4. 2' x 4' (610mm x 1219mm) recessed floor. w/3 - F40 CW lamps
5. 2' x 4' (610mm x 1219mm) recessed floor. w/2 - F40 CW lamps
6. Motorized Ceiling HEPA Filters, Class 10, 47 5/8" x 23 5/8" (1219mm x 609mm)

LEGEND

	Light Fixture Emergency On Power. Clinic Requires Battery Ballast		Fixture Type a_2 (see note 3) Control Switch a_3
	Fixture Type a_1 (see note 2) Control Switch a		Ceiling Air Diffuser
	Fixture Type a_1 (see note 2) Control Switch a_3		Ceiling Air Return
	Fixture Type b_1 (see note 5) Control Switch a		Switch Fixture a
	Fixture Type c_1 (see note 4) Control Switch a		Switch Fixture a_3
	Fixture Type a_1 (see note 4) Control Switch a_4		Switch Fixture a_4
	Ceiling HEPA Filter (see note 6)		Ionization Smoke Detectors

SMALL LAB URINALYSIS (LMUO2)

MILCARE

CEILING PLAN

DATE: 11/26/2002

10.99 NSM (118 NSF) MIN.

0 1000 2000



1:50 SCALE (MILLIMETERS)

Project Rooms (User Contents Only)

As of 07/27/2005

Page 1

Room Code: LMU02 Room Qty: 1 Room Area: 118.24 Room Description: SMALL LAB URINALYSIS

JSN	NOMENCLATURE	Qty	UNIT ISSUE	LOG CAT	Utl 1	Utl 2	Utl 3	Utl 4	Utl 5	Utl 6
-----	--------------	-----	---------------	------------	----------	----------	----------	----------	----------	----------

Equipment per Room:

A5075	Dispenser, Soap, Disposable	1	EA	C	.	.	.	.	.	.
A5080	Dispenser, Paper Towel, SS, Surface Mounted	1	EA	A	.	.	.	.	.	.
A5106	Waste Disposal Unit, Sharps w/Glove Dispenser	1	EA	C	.	.	.	.	.	.
E0580	Workstation, Urinalysis Lab, Small	1	EA	F	D	A	.	.	.	.
F0230	Chair, Drafting, Rotary	1	EA	C	.	.	.	.	.	.
F2010	Basket, Wastepaper, Step-On	1	EA	C	.	.	.	.	.	.
L0100	Microscope, Binocular	1	EA	C	.	A	.	.	.	.
L0990	Analyzer, Urine, Basic	1	EA	C	.	A	.	.	.	.
L1182	Refractometer	1	EA	C	.	A	.	.	.	.
L1200	Cabinet, Specimen, Pass Thru, CRS	2	EA	A	.	.	.	.	.	.
L1502	Centrifuge, Tabletop	1	EA	C	.	C	.	.	.	.
M1800	Computer, Microprocessing, w/CRT Monitor	1	EA	C	.	A	.	.	.	.
M1825	Printer, Computer	1	EA	C	.	A	.	.	.	.
P5210	Shower, Safety, Freestanding, With Eye/Face Wash	1	EA	A	B	.	.	.	.	.
R7000	Refrigerator, 14 Cubic Feet, 64x28x29	1	EA	C	.	A	.	.	.	.

=====

GRAND TOTAL

16