




LEGEND

- Fire Extinguisher
- Eye Wash
- Thermostat
- Multiplex Comm/Data System
- Security Key Pad
- Security Alarm
- Security Motion Detector
- Duplex Electrical Outlet
- Quadruplex Electrical Outlet
- Electrical Panel
- Power Entry
- Heavy Gauge Metal Mesh Door

DESIGN NOTES

1. Construct all walls of masonry and GW and extend to the structure above.
2. Locate emergency flashing light(s) for the hearing impaired person(s).
3. Provide heavy gauge metal mesh door on Bulk Storage side with Keypad access.
4. Provide a visual alarm on the narcotics locker in the vault.
5. Provide a motion detector, wall mounted and facing the entry to the vault.
6. Provide touch key pad access to unit from adjacent corridor(s).

HIGH VOLUME PHARMACY BULK STORAGE (PHBS3)

MILCARE


FLOOR/EQUIPMENT PLAN

DATE: 11/26/2002

146.24 NSM (1574 NSF) MIN.

0 1000 2000

1:50 SCALE (MILLIMETERS)



LEGEND



Light Fixture Emergency
On Power, Clinic Requires
Battery Ballast



Fixture Type a_1 (see note 2)
Control Switch a



Fixture Type a_1 (see note 2)
Control Switch a_3



Fixture Type b_1 (see note 5)
Control Switch a



Fixture Type c_1 (see note 4)
Control Switch a



Fixture Type a_1
Control Switch a_4



Ceiling HEPA Filter
(see note 6)



Fixture Type a_2 (see note 3)
Control Switch a_3



Ceiling Air
Diffuser



Ceiling Air
Return



Switch Fixture a



Switch Fixture a_3



Switch Fixture a_4



Ionization Smoke
Detectors

NOTES:

1. Use duplex receptacle computer isolation, on separate circuit when service not located in rail at all computer stations.
2. 2' x 4' (610mm x 1219mm) recessed floor. w/4 - F40 CW lamps
3. 2' x 2' (610mm x 610mm) recessed floor. w/2 - F20 CW lamps
4. 2' x 4' (610mm x 1219mm) recessed floor. w/3 - F40 CW lamps
5. 2' x 4' (610mm x 1219mm) recessed floor. w/2 - F40 CW lamps
6. Motorized Ceiling HEPA Filters, Class 10, 47 5/8" x 23 5/8" (1219mm x 609mm)

HIGH VOLUME PHARMACY BULK STORAGE (PHBS3)

MILCARE

CEILING PLAN

DATE: 11/26/2002

146.24 NSM (1574 NSF) MIN.

0 1000 2000

1:50 SCALE (MILLIMETERS)

Project Rooms (User Contents Only)

As of 08/22/2005

Page 1

Room Code: PHBS3 Room Qty: 1 Room Area: ***** Room Description: HIGH VOLUME PHARMACY BULK STORAGE

JSN	NOMENCLATURE	Qty	UNIT ISSUE	LOG CAT	Ut1 1	Ut1 2	Ut1 3	Ut1 4	Ut1 5	Ut1 6
-----	--------------	-----	---------------	------------	----------	----------	----------	----------	----------	----------

Equipment per Room:

A1015	Telephone, Desk, Multiple Line	3	EA	A	.	.	.	.	.	.
A5075	Dispenser, Soap, Disposable	1	EA	C	.	.	.	.	.	.
A5080	Dispenser, Paper Towel, SS, Surface Mounted	1	EA	A	.	.	.	.	.	.
A5106	Waste Disposal Unit, Sharps w/Glove Dispenser	1	EA	C	.	.	.	.	.	.
E0685	Pharmacy Bulk Storage High Volume	1	EA	C	D	F	.	.	.	.
F0230	Chair, Drafting, Rotary	2	EA	C	.	.	.	.	.	.
F0280	Chair, Swivel, Low Back	2	EA	C	.	.	.	.	.	.
F0530	Cart, Trash	2	EA	C	.	.	.	.	.	.
F2000	Basket, Wastepaper, Round, Metal, 18 H x 16 Dia.	7	EA	C	.	.	.	.	.	.
F2020	Can, Trash, 44 Gallon	5	EA	C	.	.	.	.	.	.
F3105	Safe, F/S , Class 5	1	EA	C	.	.	.	.	.	.
F3200	Clock, Battery, 12" Diameter	1	EA	C	.	.	.	.	.	.
M1800	Computer, Microprocessing, w/CRT Monitor	5	EA	C	.	A	.	.	.	.
M1825	Printer, Computer	2	EA	C	.	A	.	.	.	.
M1830	Printer, Label, Pharmacy	1	EA	C	.	A	.	.	.	.
M3072	Frame, Infectious Waste Bag w/Lid	1	EA	C	.	.	.	.	.	.
R6060	Refrigerator, Biological, SS, 2 Door, 40 Cu Ft	2	EA	C	.	A	.	.	.	C
R6100	Freezer, Food, Upright, CRS, 23 Cu Ft, 84x27x37	1	EA	A	.	A	.	.	.	.
R7100	Refrigerator, 50 Cubic Feet, 84x53x37	1	EA	C	.	A	.	.	.	.

=====

GRAND TOTAL

40