


LOW VOLUME PHARMACY MANUFACTURING AND PREPACK

DESIGN NOTES

1. Construct all walls of masonry and GW and extend to the structure above.
2. Locate emergency flashing light(s) for the hearing impaired person(s).
3. Provide heavy gauge metal mesh door on Bulk Storage side with Keypad access.
4. Provide a visual alarm on the narcotics locker in the vault.
5. Provide a motion detector, wall mounted and facing the entry to the vault.
6. Provide touch key pad access to unit from adjacent corridor(s).



LEGEND

	Fire Extinguisher
	Eye Wash
	Thermostat
	Multiplex Comm/ Data System
	Security Key Pad
	Security Alarm
	Security Motion Detector
	Duplex Electrical Outlet
	Quadruplex Electrical Outlet
	Electrical Panel
	Power Entry
	Heavy Gauge Metal Mesh Door

LOW VOLUME PHARMACY MANUF & PREPACK (PHMP1)

MILCARE

FLOOR/EQUIPMENT PLAN

DATE: 11/26/2002


5.45 NSM (59 NSF) MIN.

0 1000 2000

1:50 SCALE (MILLIMETERS)

LEGEND

	Light Fixture Emergency On Power. Clinic Requires Battery Ballast		Fixture Type a_2 (see note 3) Control Switch a_3
	Fixture Type a_1 (see note 2) Control Switch a		Ceiling Air Diffuser
	Fixture Type a_1 (see note 2) Control Switch a_3		Ceiling Air Return
	Fixture Type b_1 (see note 5) Control Switch a	S_a	Switch Fixture a
	Fixture Type c_1 (see note 4) Control Switch a	S_{a_3}	Switch Fixture a_3
	Fixture Type a_1 (see note 2) Control Switch a_4	S_{a_4}	Switch Fixture a_4
	Ceiling HEPA Filter (see note 6)		Ionization Smoke Detectors



NOTES:

1. Use duplex receptacle computer isolation, on separate circuit when service not located in rail at all computer stations.
2. 2' x 4' (610mm x 1219mm) recessed floor. w/4 - F40 CW lamps
3. 2' x 2' (610mm x 610mm) recessed floor. w/2 - F20 CW lamps
4. 2' x 4' (610mm x 1219mm) recessed floor. w/3 - F40 CW lamps
5. 2' x 4' (610mm x 1219mm) recessed floor. w/2 - F40 CW lamps
6. Motorized Ceiling HEPA Filters, Class 10, 47 5/8" x 23 5/8" (1219mm x 609mm)

LOW VOLUME PHARMACY MANUF & PREPACK (PHMP1)

MILCARE

CEILING PLAN

DATE: 11/26/2002

5.45 NSM (59 NSF) MIN.

0 1000 2000



1:50 SCALE (MILLIMETERS)

Project Rooms (User Contents Only)

As of 08/22/2005

Page 1

Room Code: PHMP1 Room Qty: 1 Room Area: 58.64 Room Description: LOW VOLUME PHARMACY MANUFACTURING AND PREPACK

JSN	NOMENCLATURE	Qty	UNIT ISSUE	LOG CAT	Ut1 1	Ut1 2	Ut1 3	Ut1 4	Ut1 5	Ut1 6
-----	--------------	-----	---------------	------------	----------	----------	----------	----------	----------	----------

Equipment per Room:

A1015	Telephone, Desk, Multiple Line	1	EA	A	.	.	.	.	.	.
A5075	Dispenser, Soap, Disposable	1	EA	C	.	.	.	.	.	.
A5080	Dispenser, Paper Towel, SS, Surface Mounted	1	EA	A	.	.	.	.	.	.
A5106	Waste Disposal Unit, Sharps w/Glove Dispenser	1	EA	C	.	.	.	.	.	.
E0666	Pharmacy Manufacturing & Prepack Low Volume	1	EA	F	D	.	.	.	.	.
F0230	Chair, Drafting, Rotary	1	EA	C	.	.	.	.	.	.
F2000	Basket, Wastepaper, Round, Metal, 18 H x 16 Dia.	1	EA	C	.	.	.	.	.	.
K4210	Mixer, Table Mounted, 5 Quart	1	EA	C	.	A	.	.	.	.
M1210	Balance, Electronic, Laboratory/Pharmacy	1	EA	C	.	A	.	.	.	.
M1800	Computer, Microprocessing, w/CRT Monitor	1	EA	C	.	A	.	.	.	.
M2015	Cabinet, Storage, Flammable, Freestanding	1	EA	C	.	.	.	.	.	.
M7265	Counter, Pill/Tablet, Automated, Counter Mounted	1	EA	C	.	A	.	.	.	.
R7100	Refrigerator, 50 Cubic Feet, 84x53x37	1	EA	C	.	A	.	.	.	.

=====

GRAND TOTAL

13