

KEY NOTES

1. SLAB SHALL BE RECESSED AT THE AUDIO BOOTH LOCATION IN ORDER TO COMPLY WITH ADA.
2. MOUNT A5245, HOOK, AT 2372 [4'-6"] AFF. PROVIDE 2-A5245'S FOR NAVY PROJECTS ONLY.
MOUNT 1-A5145 AT 1372 [4'-6"] AFF AND 1-A5145 AT 1524 [5'-0"] AFF.
3. PROVIDE M4200, OTOSCOPE/OPHTHALMOSCOPE, FOR AIR FORCE AND NAVY PROJECTS.
4. M0025, AUDIOMETER, IS FOR NAVY PROJECTS AND IS OPTIONAL.
5. F3200, CLOCK, IS FOR NAVY PROJECTS AND IS OPTIONAL.
6. PROVIDE CD PLAYER AND VISUAL REINFORCEMENT ACCESSORIES FOR M0030, AUDIOMETER.
7. COORDINATE LOCATION OF M1620, PATIENT CHART HOLDER, AND ROOM SIGNAGE.
8. VERIFY THIS DIMENSION WITH MANUFACTURER'S VENTING REQUIREMENTS FOR THE M0041, AUDIO BOOTH.
9. COORDINATED ELECTRICAL REQUIREMENTS FOR AUDIO BOOTH WITH ACTUAL EQUIPMENT PROVIDED.

PHYSICAL EVALUATION,
HEARING SUITE, 2 ROOM (PEHS4)

AUDIOLOGY/SPEECH PATHOLOGY/ENT


FLOOR/EQUIPMENT PLAN 34.75 NSM (374 NSF)

DATE: 07/12/2001

0 1000 2000



1:50 SCALE (MILLIMETERS)



KEY NOTES

1. VERIFY REQUIRED CEILING HEIGHT WITH MANUFACTURER OF M0041, AUDIO BOOTH.

PHYSICAL EVALUATION,
HEARING SUITE, 2 ROOM (PEHS4)

AUDIOLOGY/SPEECH PATHOLOGY/ENT

CEILING PLAN

34.75 NSM (374 NSF)

0 1000 2000



DATE: 07/12/2001

1:50 SCALE (MILLIMETERS)

Project Rooms (User Contents Only)

As of 08/22/2005

Page 1

Room Code: PEHS4 Room Qty: 1 Room Area: 374.06 Room Description: PHYSICAL EVAL, HEARING SUITE, 2 ROOM

JSN	NOMENCLATURE	Qty	UNIT	LOG	Utl	Utl	Utl	Utl	Utl	Utl
			ISSUE	CAT	1	2	3	4	5	6

Equipment per Room:

A5145	Hook, Garment, Double, SS, Surface Mounted	1	EA	A
E0042	Workcenter, Computer, Free Standing, 48" W	1	EA	C
F0280	Chair, Swivel, Low Back	1	EA	C
F0295	Chair, Stacking, 34 X 21 X 24	1	EA	C
F0860	Table, Mobile	1	EA	C
F3200	Clock, Battery, 12" Diameter	1	EA	C
M0010	Recorder, Tape, w/Delayed Audio Feedback	1	EA	C	.	A
M0025	Audiometer, Diagnostic, Middle Ear, Impedance	1	EA	C	.	A
M0030	Audiometer, Diagnostic	1	EA	C	.	A
M0041	Booth, Audio, Double Wall, Suite	1	EA	A	.	F
M1620	Holder, Chart, Patient, Wall or Door Mounted	1	EA	A
M1800	Computer, Microprocessing, w/CRT Monitor	1	EA	C	.	A
M1825	Printer, Computer	1	EA	C	.	A
M4200	Otoscope/Ophthalmoscope, Wall Mounted	1	EA	C	.	A

=====

GRAND TOTAL

14