

\*\*\*\*\*  
USACE / NAVFAC / AFCEA UFGS-01830 (August 2004)  
-----  
Preparing Activity: USACE Superseding  
UFGS-01830A (August 2001)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 22 December 2004

Latest change indicated by CHG tags

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 01 - GENERAL REQUIREMENTS

##### SECTION 01830

#### OPERATION, MAINTENANCE, AND PROCESS MONITORING FOR SOIL VAPOR EXTRACTION (SVE) SYSTEMS

08/04

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 MEASUREMENT AND PAYMENT
  - 1.2.1 Operation of the SVE System, Maintenance and Process Monitoring
    - 1.2.1.1 Unit Pricing
  - 1.2.2 Training
  - 1.2.3 Disposal and Replacement of Vapor Phase Activated Carbon
  - 1.2.4 Pneumatic Flow Meter Testing
  - 1.2.5 Completion Testing
- 1.3 SUBMITTALS
- 1.4 ASSISTANCE IN PREPARATION OF O & M MANUALS
- 1.5 OPERATOR QUALIFICATIONS
- 1.6 REGULATORY REQUIREMENTS
  - 1.6.1 Permits and Licenses
  - 1.6.2 Air Emissions
  - 1.6.3 Noise Control
- 1.7 PROJECT/SITE CONDITIONS
- 1.8 CHEMICAL TESTING
- 1.9 SEQUENCING AND SCHEDULING

#### PART 2 PRODUCTS

- 2.1 SPILL RESPONSE MATERIALS

#### PART 3 EXECUTION

- 3.1 OPERATION OF THE SVE SYSTEM
  - 3.1.1 Period of Operation
  - 3.1.2 Hours of Operation and Reliability
  - 3.1.3 Operational Airflow Rates
  - 3.1.4 Intermittent Operation of Wells
  - 3.1.5 Adjustments to Mode of Operation

- 3.1.6 Operations Reports
- 3.1.7 Operations Log
- 3.2 MAINTENANCE
- 3.3 PROCESS MONITORING
  - 3.3.1 Meteorological and Subsurface Monitoring
    - 3.3.1.1 Meteorological Monitoring
    - 3.3.1.2 Vadose Zone Pressure Monitoring
    - 3.3.1.3 Groundwater Levels
    - 3.3.1.4 Pneumatic Flow Meter Testing
  - 3.3.2 Process Air Stream and Equipment Monitoring
    - 3.3.2.1 Combustible Organic Vapor Monitoring
    - 3.3.2.2 Airflow Rate Monitoring
    - 3.3.2.3 Air/Water Separator and Condensate
    - 3.3.2.4 Blower and Particulate Filter
  - 3.3.3 Vapor Stream Contaminant Level Monitoring
    - 3.3.3.1 Field Analysis
    - 3.3.3.2 Laboratory Analysis
  - 3.3.4 Vapor Stream Treatment System
    - 3.3.4.1 Vapor Stream Heating
    - 3.3.4.2 Pressure and Temperature
    - 3.3.4.3 Change-Out of Adsorption Vessels
- 3.4 CONTAMINATED MATERIAL STORAGE AND DISPOSAL
  - 3.4.1 Liquid Storage
  - 3.4.2 Sampling Liquid
  - 3.4.3 SPILLS
  - 3.4.4 DISPOSAL REQUIREMENTS
- 3.5 COMPLETION OF PERIOD OF CONTRACT
  - 3.5.1 Training
  - 3.5.2 CONTRACT COMPLETION REPORT
- 3.6 COMPLETION TESTING
  - 3.6.1 Soil Boring Sampling
  - 3.6.2 Groundwater Sampling
  - 3.6.3 Rebound Testing
  - 3.6.4 Soil Gas Monitoring

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEA UFGS-01830 (August 2004)  
-----  
Preparing Activity: USACE Superseding  
UFGS-01830A (August 2001)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 22 December 2004

Latest change indicated by CHG tags

\*\*\*\*\*

### SECTION 01830

OPERATION, MAINTENANCE, AND PROCESS MONITORING FOR SOIL VAPOR EXTRACTION  
(SVE) SYSTEMS  
08/04

\*\*\*\*\*

NOTE: This guide specification covers the requirements for operation, maintenance, and process monitoring for soil vapor extraction (SVE) systems.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

Use of electronic communication is encouraged.

Brackets are used in the text to indicate designer choices or locations where text must be supplied by the designer.

\*\*\*\*\*

## PART 1 GENERAL

\*\*\*\*\*

NOTE: This guide specification covers the initial period of operations (usually a 12 month period following completion of construction, commissioning and demonstration), or periods of operation beyond the initial period. Requirements for start-up and prove-out of SVE systems are covered by Section 01810A COMMISSIONING AND DEMONSTRATION FOR SOIL VAPOR EXTRACTION SYSTEMS.

Operations, Maintenance and Process Monitoring covers requirements to be followed by the operations staff to ensure proper operation of the SVE system equipment (e.g., monitoring vacuum levels and air flow rates, vapor stream monitoring, and performing

preventative maintenance). The operations and maintenance manual should be completed during the initial period of operation (see paragraph, Assistance in Preparation of O & M Manuals). Additional guidance on design and operation of SVE systems can be found in EM 1110-1-4001, Soil Vapor Extraction and Bioventing, Nov 1995.

The following information should be shown on the project drawings:

a. Individual site plans of each area of contamination with site features such as buildings, roads, utilities, trees, surface covers, locations of extraction wells, vadose zone pressure monitoring points, and groundwater monitoring wells. Depths of screened intervals for wells should also be shown in cross-section.

b. Process flow diagram of above-ground process equipment and, piping diagrams showing the locations of devices for monitoring pressure, temperature, flow. Locations of sampling ports and valves should also be shown.

\*\*\*\*\*

#### 1.1 REFERENCES

\*\*\*\*\*

NOTE: Issue (date) of references included in project specifications need not be more current than provided by the latest guide specification. Use of SpecsIntact automated reference checking is recommended for projects based on older guide specifications.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM D 4750 (1987; R 2001) Determining Subsurface Liquid Levels in a Borehole or Monitoring Well (Observation Well)

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

40 CFR 302 Designation, Reportable Quantities, and Notification

#### 1.2 MEASUREMENT AND PAYMENT

\*\*\*\*\*

NOTE: If there is a separate Measurement and Payment Section, edited versions of these paragraphs should be inserted in that section. Coordinate requirements of these paragraphs with the bidding

schedule. The bid schedule should include separate unit price items for laboratory analysis of samples for chemical data. Under the pricing structure shown below, costs for laboratory analysis of samples for chemical data are not covered by this section; these costs are typically covered by Section 01450A CHEMICAL DATA QUALITY CONTROL. Unit pricing should also be considered for replacement of granular activated carbon (GAC), if GAC vapor stream treatment will be required.

These paragraphs should be coordinated with Sections 11226A VAPOR PHASE ACTIVATED CARBON ADSORPTION UNITS, 01450A CHEMICAL DATA QUALITY CONTROL, and 11215 FANS/BLOWERS/PUMPS; OFF-GAS.

The bid sheet should include separate, optional items for tasks such as: training, pneumatic flow meter testing, and completion testing.

\*\*\*\*\*

Measurement shall be based on completion of contract requirements. Payment will be at the respective contract prices in the bidding schedule.

#### 1.2.1 Operation of the SVE System, Maintenance and Process Monitoring

##### 1.2.1.1 Unit Pricing

\*\*\*\*\*

NOTE: Incentives for the Contractor to complete remedial action in a timely manner should be incorporated into the pricing structure, if possible. Unit pricing alternatives for payment include: hours of operation, volume of air extracted, and mass of contaminants removed.

Although pricing by mass of contaminants removed creates incentive, mass of contaminants removed is more difficult to accurately measure than time or air volumes. Also there is typically a high degree of uncertainty in predicting mass removal rates, which will make it difficult for bidders to assign reasonable prices when preparing bids.

Another performance based payment option is to make periodic payments to the Contractor based on the degree of reduction in contaminant levels. For example, partial payment to the Contractor is made based on the percentage reduction in contaminant levels. However this type of payment scheme should be used with caution, since removal rates typically decrease as contaminant levels decrease; e.g., it may take 3 times as long to go from 25 to 10 mg/kg as it takes to go from 100 to 25 mg/kg.

Lump sum pricing, with performance requirements (see paragraph Operation of the SVE System), is generally recommended for Operations, Maintenance and Process Monitoring. Under this pricing structure, the

Contractor receives periodic payments (e.g., monthly) so long as performance requirements are being met. If performance requirements are not met, then the Contracting Officer may withhold payment until the Contractor demonstrates that performance requirements are being met.

If it is expected that large volumes of condensate will be generated, and that treatment or offsite disposal will be required; then a separate paragraph should be added to cover treatment and disposal of condensate. A unit pricing structure would be appropriate to pay for treatment or offsite disposal of condensate.

\*\*\*\*\*

Compensation shall be a lump sum price for Operation of the SVE System, Maintenance, and Process Monitoring. [Costs for Contaminated Material Storage and Disposal shall also be included in this price.] [Costs for replacement adsorption media for the vapor stream treatment system is covered under a separate paragraph and is not included in this price.] Physical and chemical testing performed in the field, and sampling shall be included in this price. Costs for laboratory analysis of samples is covered in Section 01450A CHEMICAL DATA QUALITY CONTROL and is not included in this price.

#### 1.2.2 Training

\*\*\*\*\*

NOTE: If it is expected that close out of the site will be completed within the period of the contract, then Training should be listed as an optional item on the bid sheet.

\*\*\*\*\*

Compensation shall be a lump sum price for Training.

#### 1.2.3 Disposal and Replacement of Vapor Phase Activated Carbon

\*\*\*\*\*

NOTE: This paragraph should be deleted if any of the following conditions apply: vapor steam treatment will not be required; the vapor stream treatment system does not use activated carbon; or payment for activated carbon is covered under a separate Section.

\*\*\*\*\*

Compensation for disposal of spent vapor phase activated carbon shall be by the contract unit price schedule for each [\_\_\_\_\_] [kilogram pound], based on [the dry weight of the spent activated carbon] [\_\_\_\_\_]. Compensation for replacement of spent vapor phase activated carbon shall be by the contract unit price schedule for each [\_\_\_\_\_] [kilogram pound], based on [invoices from the supplier of the replacement activated carbon] [\_\_\_\_\_].

#### 1.2.4 Pneumatic Flow Meter Testing

\*\*\*\*\*

NOTE: This paragraph should be deleted if pneumatic

flow meter testing will not be required. If this paragraph is retained, the bid sheet should include a separate, optional item for pneumatic flow meter testing.

\*\*\*\*\*

Compensation for pneumatic flow meter testing shall be by the contract unit price schedule on a per well basis. Physical and chemical testing performed in the field, and sampling shall be included in this price. Costs for laboratory analysis of samples is covered in Section 01450A CHEMICAL DATA QUALITY CONTROL, and is not included in this price.

#### 1.2.5 Completion Testing

\*\*\*\*\*

NOTE: Completion testing is defined as testing that is performed determine if regulatory requirements have been met, so that the SVE system can be permanently shut down.

This paragraph should be deleted if completion testing will not be included in the contract. If this paragraph is retained, the bid sheet should include a separate, optional item for completion testing.

\*\*\*\*\*

Compensation shall be a lump sum price for Completion Testing. Physical and chemical testing performed in the field, and sampling shall be included in this price. Costs for laboratory analysis of samples is covered in Section 01450A CHEMICAL DATA QUALITY CONTROL, and is not included in this price.

#### 1.3 SUBMITTALS

\*\*\*\*\*

NOTE: Submittals must be limited to those necessary for adequate quality control. The importance of an item in the project should be one of the primary factors in determining if a submittal for the item should be required.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the

District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy projects.

Submittal items not designated with a "G" are considered as being for information only for Army projects and for Contractor Quality Control approval for Navy projects.

Specific testing procedures should be addressed in the Sampling and Analysis Plan required by Section 01450A.

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for [Contractor Quality Control approval.] [information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

Submittals shall be provided in both hard copy, and electronic files on disc. Electronic files shall be compatible with the following software: [\_\_\_\_]. If a part of a submittal is not available in electronic format, then a note shall be included describing which items were not provided in electronic format and explaining why the items could not be provided in electronic format.

#### SD-03 Product Data

Operation of the SVE System[; G][; G, [\_\_\_\_]], [\_\_\_\_]

A plan for Operation of the SVE System not more than [30] [\_\_\_\_] calendar days after notice to proceed. A period of not less than [30] [\_\_\_\_] calendar days shall be allowed in the schedule for Government review. The plan shall include an outline of the Operations Reports.

Maintenance[; G][; G, [\_\_\_\_]]

A plan for Maintenance of the SVE System not more than [30] [\_\_\_\_] calendar days after notice to proceed. A period of not less than [30] [\_\_\_\_] calendar days shall be allowed in the schedule for Government review.

Process Monitoring[; G][; G, [\_\_\_\_]]

A plan for Process Monitoring not more than [30] [\_\_\_\_] calendar days after notice to proceed. A period of not less than [30] [\_\_\_\_] calendar days shall be allowed in the schedule for Government review. The plan shall include physical and chemical monitoring requirements, including test parameters, frequency of sampling, number of samples, and sampling locations; and laboratory turn-around-time. Test methods, and other sampling and analysis requirements shall be covered by submittals specified in Section 01450A CHEMICAL DATA QUALITY CONTROL.

Contaminated Material Storage and Disposal[; G][; G, [\_\_\_\_]]



A plan for Contaminated Material Storage and Disposal not more than [30] [\_\_\_\_\_] calendar days after notice to proceed. A period of not less than [30] [\_\_\_\_\_] calendar days shall be allowed in the schedule for Government review. The plan shall include testing requirements, including test parameters, frequency of sampling, number of samples, and sampling locations; laboratory turn-around-time. Test methods, and other sampling and analysis requirements shall be covered by submittals specified in Section 01450A CHEMICAL DATA QUALITY CONTROL.

Completion Testing[; G][; G, [\_\_\_\_\_] ]

A plan for Completion Testing not more than [14] [\_\_\_\_\_] calendar days after requested. A period of not less than [30] [\_\_\_\_\_] calendar days shall be allowed in the schedule for Government review. The plan shall address testing requirements for determining if regulatory clean-up criteria have been met, and for determining if the SVE system can be permanently shut down. Test methods, and other sampling and analysis requirements shall be covered by submittals specified in Section 01450A CHEMICAL DATA QUALITY CONTROL.

#### SD-06 Test Reports

Laboratory Analysis Reports[; G][; G, [\_\_\_\_\_] ]

Results from laboratory analysis not more than [40] [\_\_\_\_\_] calendar days after collecting samples. A period of not less than [30] [\_\_\_\_\_] calendar days shall be allowed in the schedule for Government review. A table comparing field data to the laboratory data, for samples collected at the same time and from the same sampling port, shall be provided with each set of laboratory analysis results. The reports shall be signed and dated by the Contractors Quality Control representative.

Completion Testing Report[; G][; G, [\_\_\_\_\_] ]

Completion testing report not more than [45] [\_\_\_\_\_] calendar days after finishing Completion Testing. A period of not less than [30] [\_\_\_\_\_] calendar days shall be allowed in the schedule for Government review. The report shall include narrative descriptions of each type of testing that was performed, and scaled drawings showing: [type of sample; sampling locations (and depths, if applicable); and sample identification numbers] [\_\_\_\_\_] . Results of testing shall be organized according to category, and shown chronologically within each category. The report shall be signed and dated by the Contractors Quality Control representative.

#### SD-07 Certificates

Operator Qualifications[; G][; G, [\_\_\_\_\_] ]

Operator Qualifications not more than [21] [\_\_\_\_\_] calendar days prior to initiating the first period of operation. A period of not less than [14] [\_\_\_\_\_] calendar days shall be allowed in the schedule for Government review. Resume of each member of the operations staff shall be provided including a chronology of

education, state licenses, and relevant work experience.

#### SD-10 Operation and Maintenance Data

Operations Reports[; G][; G, [\_\_\_\_]]

Reports as specified.

Operations Log[; G][; G, [\_\_\_\_]]

Copies of operations log as specified.

Maintenance Log[; G][; G, [\_\_\_\_]]

Maintenance log sheets attached to each Operations Report for the period covered by the Operations Report. The original log sheets shall be kept in notebooks organized in chronological order, and shall be submitted with the Contract Completion Report not more than [14] [\_\_\_\_] calendar days after completing work at the site.

Contract Completion Report[; G][; G, [\_\_\_\_]]

[\_\_\_\_] copies of Contract Completion Report not more than [14] [\_\_\_\_] calendar days after completing work at the site. A period of not less than [30] [\_\_\_\_] calendar days shall be allowed in the schedule for Government review.

#### 1.4 ASSISTANCE IN PREPARATION OF O & M MANUALS

\*\*\*\*\*

**NOTE:** Traditionally, O & M manuals are prepared by the designers of the treatment system, e.g. under Title II services. The draft O & M manual should be required after completing construction of the treatment system. Since unanticipated events often occur during the period of operation (e.g., changes in levels of contaminants), it is not uncommon for operating procedures to deviate from the procedures set out in the draft O & M manual. The authors should seek input from the operators of the treatment system during preparation of the final O & M Manual. The final O & M manual should be required before the period of the operations contract expires.

The amount of time required of the Contractor to assist with preparation of the O & M Manual should be proportional to the scale and complexity of the SVE system.

On some projects (e.g., under TERC), it may be more expedient to have the Contractor prepare the O & M Manuals. If the Contractor will be tasked to prepare the O & M Manuals, this paragraph should be rewritten, and submittal requirements for draft and final O & M Manuals should be added.

\*\*\*\*\*

The Contractor shall provide assistance to the team tasked to prepare the

Draft and Final O & M Manuals. Assistance shall include: [providing equipment manufacture's literature, as requested; 24 hours worth of demonstrating operation, maintenance, and monitoring protocols during facility tours; and 4 hours worth of answering follow-up questions] [\_\_\_\_].

## 1.5 OPERATOR QUALIFICATIONS

\*\*\*\*\*

NOTE: Some states may already have licensing or certification requirements for operators at sites where an air pollution control permit is required (e.g., on most RCRA projects). If the project does not require an air pollution control permit (e.g., on some CERCLA projects), then there are usually not any state licensing requirements for operators.

If remediation is not being performed under CERCLA authority (this includes both National Priority List (NPL) and non-NPL sites under Defense Environmental Restoration Program (DERP), Installation Restoration Program (IRP), Formerly Used Defense Sites (FUDS), or Base Realignment and Closure (BRAC) programs), the operator must comply with applicable state or local requirements for certification and training for operation of the SVE system. As some states have these requirements and others do not, the designer must research the state or local requirements and include them in this paragraph.

\*\*\*\*\*

The chief operator shall have at least [2] [\_\_\_\_] years of experience in operating air emissions control equipment, and at least [3] [\_\_\_\_] years of experience working on projects involving clean-up of CERCLA hazardous substances, or RCRA hazardous wastes. Each member of the operations staff shall possess a [high school diploma or equivalent] [\_\_\_\_].

## 1.6 REGULATORY REQUIREMENTS

### 1.6.1 Permits and Licenses

\*\*\*\*\*

NOTE: It is important for the designer to become familiar with the appropriate state and local requirements to determine if there is a need to obtain an operating permit for the system and to include those requirements in these paragraphs. The designer should also bear in mind that any SVE system operated as part of site remediation under CERCLA authority does not require federal, state or local permits. This includes all NPL and non-NPL sites being remediated under CERCLA authority such as DERP, IRP, FUDS, or BRAC program projects. Permits that have already been acquired should be attached to the specifications and referenced.

These paragraphs should be coordinated with Sections 01355A ENVIRONMENTAL PROTECTION and 11226A VAPOR PHASE ACTIVATED CARBON ADSORPTION UNITS (if used).

\*\*\*\*\*

The Contractor shall obtain required federal, state, and local permits for operation of the SVE system.

#### 1.6.2 Air Emissions

\*\*\*\*\*

NOTE: An air pathway analysis should be performed during design to determine if air monitoring will be required. Guidance on air pathway analyses is provided in EP 1110-1-21 - Air Pathway Analysis for the Design of Hazardous, Toxic, and Radioactive Waste (HTRW) Remedial Action Projects

Appropriate federal, state, and local permits should be identified in this paragraph, and site specific permit requirements should also be provided. For projects where a permit is required, usually the State agency will issue an air pollution control permit (or permit equivalent) that will specify emissions control requirements. The following requirement is an example from a State air pollution control permit equivalent, "The maximum emission rate of total VOC shall not exceed 0.092 lbs/hr".

\*\*\*\*\*

Air emissions shall be monitored, controlled, and reported in accordance with the following regulatory requirements: [\_\_\_\_]. [The air pollution control permit equivalent has been acquired and is shown in Appendix [\_\_\_\_]].

#### 1.6.3 Noise Control

\*\*\*\*\*

NOTE: In the equipment specifications there should be a requirement for the blower not to exceed a specified noise level. This paragraph is intended to ensure that the Contractor maintains noise control throughout the period of operation, during all site activities. Ensuring that noise levels are adequately controlled is especially important for projects near residential areas.

\*\*\*\*\*

The SVE system shall [meet state and local noise pollution control regulations.] [not exceed [\_\_\_\_] decibels at any site boundary.]

#### 1.7 PROJECT/SITE CONDITIONS

\*\*\*\*\*

NOTE: Include any pertinent information regarding project/site conditions in this paragraph and on the drawings.

\*\*\*\*\*

Approximate locations of contaminated zones are shown on the drawings. Chemical analysis of contaminated material and soil gas testing [has not been performed] [has been performed and is shown in Appendix [\_\_\_\_]]. Boring logs are shown [on the drawings] [in Appendix [\_\_\_\_]]. Ground

water is approximately [\_\_\_\_\_] meters feet below ground surface. [A pilot-scale SVE demonstration has been performed and the report is shown in Appendix [\_\_\_\_\_]].

## 1.8 CHEMICAL TESTING

Chemical sampling and analysis required in this section shall be conducted in accordance with SECTION 01450A CHEMICAL DATA QUALITY CONTROL.

## 1.9 SEQUENCING AND SCHEDULING

\*\*\*\*\*  
NOTE: The initial period of operation should not begin until the Contractor has fulfilled the requirements for commissioning and demonstration of the full-scale SVE system.  
\*\*\*\*\*

The first period of operation of the full-scale system shall not be initiated until after test and inspection reports in Section 01810 COMMISSIONING AND DEMONSTRATION FOR SOIL VAPOR EXTRACTION (SVE) SYSTEMS have been submitted and approved. The Contractor shall notify the Contracting Officer not less than [14] [\_\_\_\_\_] calendar days prior to initiating the first period of operation.

## PART 2 PRODUCTS

### 2.1 SPILL RESPONSE MATERIALS

The Contractor shall keep the following spill response materials on site: [containers, adsorbents, shovels, and personal protective equipment] [\_\_\_\_\_]. Spill response materials shall be available at all times in which hazardous materials/wastes are being handled or transported. Spill response materials shall be compatible with the type of materials being handled, and shall located [as shown on drawings] [\_\_\_\_\_].

## PART 3 EXECUTION

### 3.1 OPERATION OF THE SVE SYSTEM

\*\*\*\*\*  
NOTE: The length of the initial period of operation should be defined in the bid schedule, typically the construction Contractor is required to operate the treatment system for a period of about 12 months, after completion of the prove-out period. Contracts may also be written to include options for additional periods of operation. The length of the periods of operation should be based on the expected time to complete the remedial action. Use of optional periods of operation makes for a more flexible contract. Once clean-up goals have been reached, any remaining options for additional periods of operation would not be exercised.  
\*\*\*\*\*

The period of operation shall not be initiated until the following plans have been approved, and written approval has been received from the Contracting Officer: Operation of SVE System, Maintenance, Process

Monitoring, and Contaminated Material Storage and Disposal.

#### 3.1.1 Period of Operation

The Contractor shall operate the SVE system for a period of [365] [\_\_\_\_\_] calendar days. Time required to complete commissioning and demonstration shall not be included in the period of operation.

#### 3.1.2 Hours of Operation and Reliability

\*\*\*\*\*  
**NOTE: The reliability requirement should allow enough downtime for the Contractor to perform scheduled maintenance.**  
\*\*\*\*\*

Unless otherwise directed by the Contracting Officer, the SVE system shall remain in operation [24 hours per day, 7 days a week] [\_\_\_\_\_] . Reliability is the percent of time that the system is on, and minimum airflow rates are being maintained. The reliability of the system shall be at least [95%] [\_\_\_\_\_] of the total hours available in each 28 calendar day period. Hours of operation and downtime shall be recorded in the Operations Log, at least once every [14] [\_\_\_\_\_] calendar days. The Operations Log shall be kept at the facility, and available for inspection.

#### 3.1.3 Operational Airflow Rates

For the SVE system to be considered in operation, the blower shall be on and air shall be flowing from those wells designated in Table 1 at the flow rates shown in Table 1, [except during off-cycle periods as designated in Table 2] [\_\_\_\_\_] .

TABLE 1 -AIRFLOW RATES

| WELL IDENTIFICATION | MINIMUM<br>AIRFLOW RATE |
|---------------------|-------------------------|
| [_____]             | [_____]                 |

TABLE 1 -AIRFLOW RATES

| WELL IDENTIFICATION | MINIMUM<br>AIRFLOW RATE |
|---------------------|-------------------------|
| [_____]             | [_____]                 |

#### 3.1.4 Intermittent Operation of Wells

\*\*\*\*\*  
**NOTE: This paragraph should be deleted unless there are wells that will be operated intermittently.**

Periodic shutdown of selected SVE wells can be used to allow time for subsurface VOC levels to rebound, and to thereby maintain higher recovery rates from active wells. The length of the shut down period is site specific, and should be based on soil gas monitoring at the site. At some sites soil gas VOC levels will increase very slowly after shutdown, and a longer shutdown period may be required.

The frequency of vapor stream monitoring should be increased immediately after bringing SVE wells back on line, in order to measure the rebound spike. Periodic rebound testing is a useful tool for assessing the progress of SVE operations. See paragraph, Rebound Testing.

\*\*\*\*\*

Operation of designated wells shall be cycled in accordance with Table 2.

TABLE 2 -SCHEDULE FOR CYCLICAL OPERATION OF WELLS

| WELL IDENTIFICATION | ON-CYCLE<br>PERIOD | OFF-CYCLE<br>PERIOD |
|---------------------|--------------------|---------------------|
| [_____]             | [_____]            | [_____]             |

### 3.1.5 Adjustments to Mode of Operation

\*\*\*\*\*

NOTE: After the system has been in continuous operation for a few months (and vapor stream data has been reviewed), strategies that may hasten completion of the project (and reduce operating costs) should be considered. Such strategies may include: installing impermeable surface covers; increasing, decreasing or stopping air flow from certain wells; and periodic cycling of designated wells. In extremely arid climates, controlled irrigation may improve contaminant removal rates. Also see paragraph, Pneumatic Flow Meter Testing. Any changes may require that the contract be modified

Value Engineering (VE) Clauses are usually included in contracts to provide incentive for the Contractor to identify areas where savings can be realized. If there are clearly areas that show a strong potential for substantial cost savings, then it may be worthwhile to request that the Contractor submit a VE proposal to change the mode of operation. The Design Team should verify that a VE Clause is included in the contract.

Remedial System Evaluations (RSE) offer another way to assess the performance of the system, and to determine if changes should be made to hasten completion of the project, and reduce operating costs. A description of RSEs and RSE checklists can be found at the following internet site: <http://www.environmental.usace.army.mil/library/guide/rsechk/rsechk.html>. RSEs are typically performed after a treatment system has been in operation for at least one year. If RSE recommendations will require costly modifications to the treatment system equipment, and the period of the Contract is nearly over, then it may be best to build these recommendations into a future contract. The Contractor tasked to make substantial changes to the treatment system should be responsible for a minimum period of operation after the changes have been implemented.

\*\*\*\*\*

The Contractor shall receive written approval from the Contracting officer before implementing any changes to the mode of operation.

#### 3.1.6 Operations Reports

The Contractor shall submit reports scheduled as follows: [weekly for the 1<sup>st</sup> two weeks; every 4 weeks for the 3<sup>rd</sup> through the 10<sup>th</sup> week; and every 3 months thereafter] [\_\_\_\_]. A period of not less than [30] [\_\_\_\_] calendar days shall be allowed in the schedule for Government review. For the period covered by each Operations Report, the following data shall be provided: [hours of operation and hours of downtime; the amount of time that each SVE well was in use; and the cumulative total hours of operation] [\_\_\_\_]. Results of Process Monitoring shall be organized according to category, and shown chronologically within each category. Meteorological and Subsurface Monitoring data, and Process Air Stream and Equipment Monitoring data shall be included in each report. The following graphs shall be provided with each Operations Report. For each SVE well, plots of: volume of air extracted versus time, cumulative volume of air extracted versus time, concentration of [contaminants of concern] [\_\_\_\_] versus time, mass removal rate of [contaminants of concern] [\_\_\_\_] versus time, and cumulative mass of [contaminants of concern] [\_\_\_\_] removed versus time. For the SVE system as a whole, plots of: the concentration of [contaminants of concern] [\_\_\_\_] versus time, mass removal rate of [contaminants of concern] [\_\_\_\_] versus time, and cumulative mass of [contaminants of concern] [\_\_\_\_] removed versus time. The reports shall be signed and dated by the Contractors Quality Control representative. If warranted, the reports shall also provide recommendations for changing airflow rates from individual wells, and other proposed adjustments to the mode of operation.

#### 3.1.7 Operations Log

The Contractor shall submit copies of operations log sheets with each Operations Report for the period covered by the Operations Report. The original log sheets shall be kept in notebooks organized in chronological order, and shall be submitted with the Contract Completion Report not more than [14] [\_\_\_\_] calendar days after completing work at the site.



### 3.2 MAINTENANCE

\*\*\*\*\*  
NOTE: Proper servicing of equipment is especially important for equipment that will remain onsite after the contract expires. Maintenance oversight for equipment that will be retained by the Contractor may not be necessary.  
\*\*\*\*\*

Maintenance of equipment shall be performed in accordance with manufacture's recommendations. The Contractor shall submit a preventative maintenance schedule for inspecting equipment, and a schedule for servicing of major equipment items. Maintenance shall be performed according to schedule, and in response to monitoring data. Maintenance logs shall be kept for each of the following units of equipment: [air/water separator, particulate filters, blower, motor, instrumentation and control system, and vapor stream treatment system] [\_\_\_\_\_]. Each time one of these units is serviced, an entry shall be made in the maintenance log. Maintenance log entries shall include: date, reason for servicing, description of service performed, a list of the parts that were replaced, name of the service organization and technician performing the maintenance, and signature of the Contractor's Quality Control Representative. The Maintenance Log shall be kept at the facility, and available for inspection.

### 3.3 PROCESS MONITORING

\*\*\*\*\*  
NOTE: Periodically the monitoring parameters, and the frequency of monitoring should be re-evaluated to determine if monitoring requirements should be changed. For most projects, the frequency of monitoring can be decreased as more operational data is generated.

Labor costs and the accessibility of the site should be factored into the monitoring schedule. For small-scale SVE systems that are designed to operate with minimal operator attention, the frequency of monitoring should be less than that of a large-scale, more complex SVE system.

\*\*\*\*\*

The Contractor shall evaluate the monitoring schedule every [6 months] [\_\_\_\_\_]. The Contractor shall propose recommended changes to the monitoring schedule, if warranted. The Contractor shall receive written approval from the Contracting officer before implementing any changes to the monitoring schedule.

#### 3.3.1 Meteorological and Subsurface Monitoring

Meteorological and subsurface monitoring shall be performed to assess the response of the subsurface to the SVE system.

##### 3.3.1.1 Meteorological Monitoring

\*\*\*\*\*  
NOTE: Automated monitoring equipment can be used to collect meteorological data. Meteorological data

may also be available from a monitoring site in the immediate vicinity (e.g., an airport).

\*\*\*\*\*

The following data shall be recorded at least once every [Monday, Tuesday, Wednesday, Thursday, and Friday] [\_\_\_\_]: ambient temperature, and daily amount of precipitation. The barometric pressure shall be recorded each time that airflow rate monitoring is performed.

#### 3.3.1.2 Vadose Zone Pressure Monitoring

\*\*\*\*\*

NOTE: Vadose zone pressure should be monitored periodically, and each time that changes are made to the air extraction rates, or to the configuration of active extraction wells. Ideally, the site should be equipped with nested pressure monitoring points, placed at discrete depth intervals (corresponding to the depths of contaminated zones), and at several locations within the contaminated zones. It is also important to monitor from locations in the contaminated zone that are mid-way between SVE wells, and at relatively long distances from SVE wells, since "stagnant zones" (or reduced airflow rates) may occur at these locations.

Vadose zone pressure monitoring should be performed as part of the assessment of the zone of influence. Determination of air velocity (or travel time), rather than just vacuum levels, at vadose zone monitoring points should be used to assess the zone of influence. If vadose zone modeling will be performed, then data requirements for the model should be consistent with the monitoring procedures.

\*\*\*\*\*

Vadose zone pressure monitoring shall be performed at least once every [28] [\_\_\_\_] calendar days, and each time that changes are made to the configuration of active SVE wells. Monitoring shall be performed at the following locations: [\_\_\_\_].

#### 3.3.1.3 Groundwater Levels

\*\*\*\*\*

NOTE: Groundwater level monitoring may be necessary to determine if operation of the SVE system results in upwelling of the water table, or if fluctuations in the water table (not related to SVE operations) are limiting the effective depth of SVE. If upwelling is occurring, then soils that were previously part of the lower vadose zone may become saturated and thus will not be treated via operation of the SVE system. Upwelling is usually localized around extraction wells (especially in porous soils), but some monitoring may be necessary to determine the extent of upwelling. If the contaminated zones are well above the water table then groundwater level monitoring may not be necessary.

Site-specific considerations should be incorporated into the monitoring schedule. Water levels may be influenced by factors such as tidal cycles, and seasonal pumping from irrigation wells.

\*\*\*\*\*

Groundwater levels shall be measured at least once every [90] [\_\_\_\_\_] calendar days at the following monitoring wells: [\_\_\_\_\_] . Water level measurement shall be performed in accordance with ASTM D 4750. Water level readings shall be recorded to the nearest 3.0 mm 0.01 foot. The part of the measuring device that was wetted shall be decontaminated after each measurement.

#### 3.3.1.4 Pneumatic Flow Meter Testing

\*\*\*\*\*

NOTE: This paragraph should be deleted if pneumatic flow meter testing will not be required. If it has not already been performed, pneumatic flow meter testing of the SVE wells should be considered. Ideally, pneumatic flow meter testing should be performed during design investigations. However, information gained from these tests can be used as part of a systematic plan to optimize operation of an SVE system.

Pneumatic logging of SVE wells is analogous to borehole flow meter testing of groundwater wells. A probe accurately measures the incremental increases in airflow as it moves up from the bottom of the well while air is extracted from the well. A sampling port on the probe allows the determination of the soil gas concentration in the well at the depth of the probe. The sampling data, coupled with the flow data, allows a determination of the contaminant mass input at different depths.

Pneumatic logging data is useful for producing vertical air permeability profiles, evaluating the distribution of contaminants, tailoring well construction, and changing operating strategy. Pneumatic logging data may also be used to define input values for vadose zone modeling.

\*\*\*\*\*

Pneumatic flow meter testing shall be performed at the following SVE wells [\_\_\_\_\_] . The following parameters shall be continuously monitored during testing: [airflow rate, vacuum, probe depth, and total volatile hydrocarbons] [\_\_\_\_\_] .

#### 3.3.2 Process Air Stream and Equipment Monitoring

Process air stream and equipment monitoring shall be performed as part of the overall assessment of the SVE system, and to monitor operation of SVE system equipment.

### 3.3.2.1 Combustible Organic Vapor Monitoring

\*\*\*\*\*

NOTE: Some SVE systems are designed to handle vapor stream contaminant levels that are above the lower explosive limit. However, even if an explosion-proof blower and motor are being used, ignition of an organic-laden vapor stream is still possible (e.g., static electricity may build up inside piping that is not grounded, and a spark may be released). Combustible organic vapor monitoring should be performed to reduce the risk of a fire or explosion during operation of SVE systems.

A flame ionization detector (FID) is usually recommended for this type of monitoring. Combustible gas indicators (CGI) can also be used, but only if oxygen levels are also being monitored. Combustible gas indicators can produce false readings if the level of oxygen in the sample is less than the minimum level of oxygen required for the instrument to function properly.

Site-specific action levels should be established prior to initiating the first period of operation. Action levels should be based on the types of volatile organic compounds present in the vadose zone, and the specific monitoring instrument and calibration gas being used. The action levels may require modification as more monitoring data is generated.

\*\*\*\*\*

After opening the valves to begin extracting air from an extraction well that is being brought on-line for the first time, monitoring shall be initiated during the following time intervals: [0-1 minute, 30-45 minutes, 60-75 minutes, and 120-135 minutes] [\_\_\_\_]. In addition, monitoring shall be performed at least one time daily during the first [\_\_\_\_] [200 hours] of operation of the SVE system, and at least one time daily until each extraction well has been in continuous operation for a minimum of [\_\_\_\_] [72 hours]. During each monitoring event, [at least 3 readings, separated by 1 minute increments,] [\_\_\_\_] shall be recorded. Monitoring shall be performed at the following location: [in the combined piping manifold (upstream from the inlet bleed line)] [\_\_\_\_]. If the [flame ionization detector] [\_\_\_\_] indicates that the vapor stream has reached [5000 ppmV as isobutylene] [\_\_\_\_], then the Contractor shall immediately make adjustments to decrease the level of organic compounds in the vapor stream. Such adjustments may include increasing and / or decreasing airflow rates from selected wells. The monitoring and adjustment procedure shall be repeated until the organic vapor level of the vapor stream has been decreased to less than [5000 ppmV as isobutylene] [\_\_\_\_].

### 3.3.2.2 Airflow Rate Monitoring

\*\*\*\*\*

NOTE: To accurately determine volumetric airflow rates the density of the air stream should be calculated. Air density is dependent on relative humidity, temperature and barometric pressure. The

Contractor's measurement of airflow rates should periodically be independently verified by a NEEB or AABC certified Testing, Adjusting, and Balancing specialist.

\*\*\*\*\*

Pressures, temperatures, and airflow rates shall be monitored at the following locations at least once every [14] [\_\_\_\_\_] calendar days: [in piping from each individual SVE well being used; in the combined piping manifold (upstream from the inlet bleed line); in the inlet bleed line; and at the discharge stack] [\_\_\_\_\_]. Airflow rate monitoring shall be in accordance with manufacturer's instructions for the airflow monitoring devices. The Contractor shall record instrument readings, and shall provide, in each Operations Report, any assumed values that were used to calculate airflow rates. Measurement of airflow rates shall be independently verified by a NEEB or AABC certified Testing, Adjusting, and Balancing specialist at least once every [90] [\_\_\_\_\_] calendar days, and shall be performed in accordance with Section 15990A TESTING, ADJUSTING AND BALANCING OF HVAC SYSTEMS. A copy of the airflow rates determined and signed by the NEEB or AABC certified Testing, Adjusting, and Balancing specialist shall be attached to the Operations Report for the period when the airflow rate was verified.

#### 3.3.2.3 Air/Water Separator and Condensate

\*\*\*\*\*

NOTE: During cold weather, greater volumes of condensate may accumulate than during warm weather. More frequent monitoring may be necessary during periods of cold weather.

\*\*\*\*\*

The volume of condensate in the air/water separator shall be recorded at least once every [14] [\_\_\_\_\_] calendar days. The volume of condensate generated since the previous monitoring event and cumulative total volume of condensate shall also be recorded.

#### 3.3.2.4 Blower and Particulate Filter

The following parameters shall be recorded at least once every [14] [\_\_\_\_\_] calendar days: hour meter readings from the totalizing hour meter on the blower; pressures and temperatures immediately upstream from the blower and immediately downstream from the blower; and pressures immediately upstream and downstream from the inlet air filter.

#### 3.3.3 Vapor Stream Contaminant Level Monitoring

\*\*\*\*\*

NOTE: Real-time vapor monitoring instruments are sensitive to the gasoline, or light fuel fraction contaminants such as benzene, toluene, ethyl benzene, and xylene (BTEX). A photo-ionization detector (PID) or flame-ionization detector (FID) may be used to detect constituents normally found in gasoline such as BTEX. For some types of contaminants (e.g., PCE and TCE), use of an FID is preferred over a PID. For SVE applications, an FID is usually recommended over a PID because the vapor stream is commonly moist, and an FID is less

sensitive to moisture.

Vapor stream monitoring requirements are site specific, and must be in accordance with regulatory requirements. Regulatory representatives should be provided the opportunity to provide input on vapor stream monitoring requirements in the early stages of remedial design. The monitoring protocol shown below is provided as an example only, and has no regulatory basis.

\*\*\*\*\*

Vapor stream contaminant level monitoring shall be performed within [2] [\_\_\_\_\_] hours of airflow rate monitoring to allow mass removal rates to be determined. Monitoring shall be performed in accordance with regulatory requirements.

#### 3.3.3.1 Field Analysis

Vapor stream monitoring shall be performed at least once every [14] [\_\_\_\_\_] calendar days. During each monitoring event, [at least 3 readings, separated by 2 minute increments,] [\_\_\_\_\_] shall be recorded. Data collected each monitoring event shall include [flame ionization detector readings] [\_\_\_\_\_] from the following locations: [each individual SVE well being used; in the combined piping manifold (upstream from the inlet bleed line); the inlet of the vapor stream treatment system; between the lead and lag vapor stream treatment units; and from the discharge stack] [\_\_\_\_\_] .

#### 3.3.3.2 Laboratory Analysis

Laboratory analysis of vapor stream samples shall be performed as follows: [weekly for the first 2 weeks, every 4 weeks for week 3 through 11, and at least once every 90 calendar days thereafter.] [\_\_\_\_\_] . One air stream sample shall be collected for laboratory analysis from each of the following locations: [in the combined piping manifold (upstream from the inlet bleed line); the inlet of the vapor stream treatment system; and from the discharge stack] [\_\_\_\_\_] . The sample for laboratory analysis shall be taken immediately after collecting the sample for field analysis at each sample port. Samples shall be tested for the following analytes: [\_\_\_\_\_] .

#### 3.3.4 Vapor Stream Treatment System

\*\*\*\*\*

**NOTE:** These paragraphs should be deleted if vapor stream treatment will not be required. If the vapor stream treatment system involves a process other than granular activated carbon adsorption, then these paragraphs should be revised accordingly.

\*\*\*\*\*

Whenever soil vapor is being extracted, the vapor stream shall be continuously routed through [2 adsorption vessels, configured in series,] [\_\_\_\_\_] before being released to the atmosphere.

#### 3.3.4.1 Vapor Stream Heating

\*\*\*\*\*

**NOTE:** If granular activated carbon is being used for vapor stream treatment, then the relative

humidity of the vapor stream should be less than 50% before entering the carbon vessels. Adsorption efficiency will be reduced, and carbon consumption will increase as the relative humidity increases. The heat generated by the blower can often be used to decrease the relative humidity of the vapor stream. A temperature rise of about 20 degrees F is usually sufficient to reduce the relative humidity of the vapor stream to about 50%. If the temperature and pressure of the vapor stream are being monitored at locations upstream and downstream of the blower, then the change in relative humidity across the blower can be calculated.

\*\*\*\*\*

Before entering the lead adsorption vessel, the vapor stream shall be heated to at least [11.1 degrees C 20 degrees F] [\_\_\_\_\_] higher than the temperature coming out of the extraction wells.

#### 3.3.4.2 Pressure and Temperature

Pressures, and temperatures of the vapor stream shall be monitored at the following locations at least once every [14] [\_\_\_\_\_] calendar days: [at the inlet to the lead adsorption vessel; between the lead and lag adsorption vessels; and at the outlet of the lag adsorption vessel] [\_\_\_\_\_].

#### 3.3.4.3 Change-Out of Adsorption Vessels

\*\*\*\*\*

NOTE: Site-specific action levels should be established prior to initiating the first period of operation. Action levels should be based on the types of volatile organic compounds present in the vadose zone, and the specific monitoring instrument and calibration gas being used. The action levels may require modification as more monitoring data is generated.

\*\*\*\*\*

Not more than [72] [\_\_\_\_\_] hours after detection of breakthrough, the lead vessel shall be replaced by the lag vessel and a fresh vessel shall be placed in the lag position. Breakthrough is defined as follows: [when field analysis indicates that contaminant levels at the outlet of the lead vessel has reached the level that corresponds to the permitted maximum emission rate, see paragraphs Field Analysis and Air Emissions] [\_\_\_\_\_]. The volume of air that was treated from the time that the vessel was placed in the upstream position until breakthrough was consistently determined shall be recorded as the breakthrough volume. The Contractor shall provide the Contracting Officer with a written record of the field analysis data, and the breakthrough volume, not more than [24] [\_\_\_\_\_] hours after breakthrough was detected.

#### 3.4 CONTAMINATED MATERIAL STORAGE AND DISPOSAL

\*\*\*\*\*

NOTE: For SVE systems, the most common type of potentially-contaminated media that may require collection and disposal is condensate from the air/water separator. However, the level of volatile

contaminants in the condensate will be limited by the continuous flow of air through the piping. If significant volumes of condensate accumulate in the air/water separator, periodic testing may be necessary to determine storage and disposal requirements.

If activated carbon is being used for vapor stream treatment, then spent activated carbon will have to be regenerated or sent to a disposal facility.

For RCRA sites, hazardous waste can be stored in a drum or roll-off unit for up to 90 days without a permit. For temporary storage of more than 90 days, dual containment of hazardous liquid and some hazardous solids is required. Containment system requirements are described in 40 CFR 264.175 - Containment.

Storage requirements will depend on factors such as whether the contaminated material is determined to be hazardous waste. If there are site-specific factors that dictate the need for dual containment, this paragraph should be revised accordingly.

\*\*\*\*\*

Methods of contaminated material storage shall be in accordance with regulatory requirements. If multiple storage units are required, each unit shall be clearly labeled with an identification number and a written log shall be kept to track the source of contaminated material in each temporary storage unit.

#### 3.4.1 Liquid Storage

Liquid collected shall be temporarily stored in [220 L 55 gallon barrels] [2000] [\_\_\_\_\_] L [500] [\_\_\_\_\_] gallon tanks]. Liquid storage containers shall have no leaks and shall be located [as shown on the drawings] [\_\_\_\_\_] .

#### 3.4.2 Sampling Liquid

\*\*\*\*\*

NOTE: The frequency of testing should be based on the rate of liquid generation, the size of the storage containers, and regulatory requirements. Offsite disposal may require additional testing and analysis prior to disposal. NPDES requirements must be considered for onsite disposal of liquids.

\*\*\*\*\*

Liquid collected shall be sampled at a frequency of at least once every [2,000] [\_\_\_\_\_] L [500] [\_\_\_\_\_] gallons of liquid collected. Samples shall be tested for the following analytes: [\_\_\_\_\_] .

a. Chemical Parameter: [\_\_\_\_\_] .

b. Regulatory Limit: [\_\_\_\_\_] .

Liquid with contaminant levels that exceed regulatory limits shall be treated [offsite. Analyses for contaminated liquid to be taken to an



offsite treatment facility shall conform to local, state, and federal criteria as well as to the requirements of the treatment facility. Documentation of all analyses performed shall be furnished to the Contracting Officer. Additional sampling and analysis required by the receiving off-site treatment, storage or disposal (TSD) facility shall be the responsibility of the Contractor] [onsite. Treatment shall be in accordance with Section [\_\_\_\_]].

#### 3.4.3 SPILLS

\*\*\*\*\*  
**NOTE: Regarding pre-established spill reporting procedures, the designer should consult CEMP-RT memorandum of 20 July 1995, Subject: Spill Reporting Procedures for USACE Personnel Involved in HTRW Projects.**  
\*\*\*\*\*

In the event of a spill or release of a hazardous substance (as designated in 40 CFR 302), pollutant, contaminant, or oil (as governed by the Oil Pollution Act (OPA), 33 U.S.C. 2701 et seq.), the Contractor shall notify the Contracting Officer immediately. If the spill exceeds the reporting threshold, the Contractor shall follow the pre-established procedures for immediate reporting to the Contracting Officer. Immediate containment actions shall be taken to minimize the effect of any spill or leak. Clean-up shall be in accordance with applicable federal, state, and local regulations. Additional sampling and testing may be required to verify spills have been cleaned up. Spill clean-up and testing shall be done at no additional cost to the Government.

#### 3.4.4 DISPOSAL REQUIREMENTS

Offsite disposal of contaminated material shall be in accordance with SECTION 02120 TRANSPORTATION AND DISPOSAL OF HAZARDOUS MATERIALS.

#### 3.5 COMPLETION OF PERIOD OF CONTRACT

##### 3.5.1 Training

\*\*\*\*\*  
**NOTE: If continued operation of the treatment system will be required after the contract expires, then the outgoing Contractor should be required to train the incoming Contractor. This paragraph should be coordinated with training prescribed in Sections 11215A FANS/BLOWERS/PUMPS; OFF-GAS and 11226A VAPOR PHASE ACTIVATED CARBON ADSORPTION UNITS.**  
\*\*\*\*\*

The Contractor shall provide a minimum of [32 hours] [\_\_\_\_] of training to the incoming Contractor prior to completion of the contract. Scheduling of training shall subject to approval by the Contracting Officer. Training shall include: [familiarizing the incoming contractor with the O & M Manual; touring the treatment facility; demonstrating the use of each piece of equipment; demonstrating the use all interlocks and system controls; demonstrating start-up and shut-down of system; demonstrating maintenance procedures; demonstrating process monitoring requirements and sampling procedures during a scheduled monitoring event; providing written inventory and showing the locations of materials and spare parts that will be left

on-site; and answering questions] [\_\_\_\_].

### 3.5.2 CONTRACT COMPLETION REPORT

\*\*\*\*\*  
NOTE: In addition to progress photos, video tapes  
have been used at some sites to record site  
activities.  
\*\*\*\*\*

[\_\_\_\_] copies of a Contract Completion Report shall be prepared and submitted within [14] [\_\_\_\_] calendar days of completing work at the site. The report shall be labeled with the contract number, project name, location, date, name of general contractor, and the Corps of Engineers District Contracting for the work. The report shall include the following information as a minimum:

- a. A cover letter signed by a [responsible Contractor representative] [Professional Engineer registered in the State of [\_\_\_\_] who is a responsible Contractor representative] certifying that all services involved have been performed in accordance with the terms and conditions of the contract specifications.
- b. A narrative report including but not limited to the following:
  - (1) site conditions, ground water elevation, and clean-up criteria;
  - (2) monitoring locations and methods;
  - (3) dates of the last 3 monitoring events; and
- c. Copies of the most recent test results and the final Operations Report.
- d. Copies of manifests.
- e. For materials that required offsite disposal, copies of certifications of final disposal signed by the responsible disposal facility official, and waste profile sheets.

### 3.6 COMPLETION TESTING

\*\*\*\*\*  
NOTE: This paragraph should be deleted if completion testing will not be included in the contract. There is often a great deal of uncertainty regarding how long the treatment system will be required to operate. At some sites, completion testing may not be appropriate until after the contract for construction and the initial period of operation of the treatment system has been completed. However, it may be advantageous to include a separate, optional item in the contract for completion testing. If it is not possible to determine the completion testing requirements when this contract is being written, then a contract modification may be required as soon as the completion testing requirements have been determined.  
\*\*\*\*\*

Many military facilities have base-wide sampling and analysis plans that have been approved by the applicable regulatory agencies. However these plans may not specify the number of confirmation samples which must be taken. The number of confirmation samples should be based on the depth and areal extent of the contaminated zone and regulatory requirements. The following reference provides guidance on the design of statistically based sampling intervals: EPA 230/02-89-042 - Methods of Evaluation and Attainment of Cleanup Standards.

Some of the samples used for completion testing should be collected from locations that are mid-way between SVE wells, and near the perimeter of the area of concern, to determine if SVE operations have adequately remediated the contaminated zone. One or more lines of evidence may be required as part of completion testing. The following reference includes guidance for obtaining closure of SVE operations: Evaluation of Mass Flux to and from Groundwater Using a Vertical Flux Model (VFLUX): Application to the Soil Vapor Extraction Closure Problem; DiGiulio, et al., Groundwater Monitoring and Remediation, Spring 1999, Vol. 19, No. 2.

Completion testing requirements are site specific, and must be in accordance with regulatory requirements. Regulatory representatives should be provided the opportunity to provide input on completion testing requirements during design. If attainment of the original completion requirements is later determined to be technically impractical, then regulatory input will be required to explore the possibility of revising the completion testing requirements. The requirements shown below are provided as examples only, and have no regulatory basis.

\*\*\*\*\*

Completion testing is defined as testing to determine whether continue, or shutdown, operation of the SVE system. The Contractor shall provide written notification to the Contracting Officer not less than [14] [\_\_\_\_\_] calendar days prior to performing completion testing. The notification shall include: the type of testing to be performed, the date and time of testing, and the names of the Contractor's representatives who will be present. The Contractor shall submit a Completion Testing Report as specified in the Submittals paragraph.

### 3.6.1 Soil Boring Sampling

\*\*\*\*\*

NOTE: This paragraph should be deleted if soil boring sampling will not be a required component of completion testing. Immunoassay field kits are available that are sensitive to light fuel fractions. EM 200-1-2, Appendix G, provides additional guidance on field analysis methods. See

ASTM D 4700, Standard Guide for Soil Sampling from the Vadose Zone, for additional information on sampling methods.

\*\*\*\*\*

Soil boring samples shall be collected from the following locations and depth intervals: [\_\_\_\_]. Locations of samples shall be recorded in the field, and documented on the as-built drawings. Soil boring sampling shall be performed in accordance with Section 02210 SUBSURFACE DRILLING, SAMPLING, AND TESTING. Samples shall be tested for the following analytes: [\_\_\_\_].

### 3.6.2 Groundwater Sampling

\*\*\*\*\*

NOTE: This paragraph should be deleted if groundwater testing will not be a required component of completion testing. Groundwater monitoring may be necessary after the levels of volatile organics in the vapor stream have dropped to asymptotic levels. If high levels of volatile organics are present in groundwater, then VOCs from groundwater may be continually migrating into, and re-contaminating, the vadose zone.

\*\*\*\*\*

Groundwater sampling shall be performed as part of an assessment of the mass transfer rate of volatile organic contaminants from groundwater to the vadose zone. Sampling shall be performed at the following monitoring wells: [\_\_\_\_]. Samples shall be tested for the following analytes: [\_\_\_\_].

### 3.6.3 Rebound Testing

\*\*\*\*\*

NOTE: This paragraph should be deleted if rebound (or equilibrium) testing will not be a required component of completion testing. If the level of contaminants represented by the "rebound spike" is less than about ten times the level of the initial contaminant level spike (from when the system was first started up), this may indicate that recovery of volatiles has become diffusion limited and that continued operation of the SVE system will be of limited value. However, it still may be possible to increase contaminant removal rates through other means, see Analysis of Selected Enhancements for Soil Vapor Extraction, EPA-542-R-97-007, Sept. 1997.

Periodic rebound testing is a useful tool for assessing the progress of SVE operations. On some projects rebound testing is performed on a regularly scheduled basis (e.g., every 4 months). Comparison of the initial contaminant level spike to subsequent rebound spikes should play into the decision on whether to continue SVE operations.

The length of the shut down period is site specific, and should be based on soil gas monitoring at the

site. At some sites soil gas VOC levels will increase very slowly after shutdown, and a longer shutdown period may be required.

\*\*\*\*\*

After the level of contaminants in the vapor stream have reached asymptotic levels, and written approval has been received from the Contracting Officer, the SVE system shall be shut down for a period of [28] [\_\_\_\_\_] calendar days. After the SVE system has remained idle for the prescribed time period, the system shall be turned back on. Vapor stream monitoring shall commence immediately after turning the SVE system back on. Vapor stream monitoring shall be performed [every 30 minutes for the first 4 hours, every hour for the 4<sup>th</sup> through the 24<sup>th</sup> hour, and every 4 hours for the 24<sup>th</sup> through the 60<sup>th</sup> hour] [\_\_\_\_\_] . During each monitoring event, [at least 3 readings, separated by 2 minute increments,] [\_\_\_\_\_] shall be recorded. Data collected each monitoring event shall include [flame ionization detector readings] [\_\_\_\_\_] from the following locations: [each individual SVE well being used; and in the combined piping manifold (upstream from the inlet bleed line)] [\_\_\_\_\_] . The Contractor shall submit Laboratory Analysis Reports for the vapor stream contaminant as specified in the Submittals paragraph.

#### 3.6.4 Soil Gas Monitoring

\*\*\*\*\*

NOTE: This paragraph should be deleted if soil gas monitoring will not be a required component of completion testing. Use of passive soil gas sampling devices is generally not recommended at SVE sites; i.e., air should be withdrawn from the vadose zone to collect soil gas samples. If levels of volatile organics in whole air samples are below detection limits, they can be concentrated by passing a known volume of extracted soil gas through an adsorption device. See ASTM D 5314, Standard Guide for Soil Gas Monitoring in the Vadose Zone, for additional information.

\*\*\*\*\*

Soil gas monitoring shall be performed by extracting air from the following soil vapor extraction wells and vadose zone monitoring points: [\_\_\_\_\_] . [In addition, a soil gas survey shall be performed to collect samples from the following locations and depth intervals: [\_\_\_\_\_] .] Soil gas sampling shall be performed by either collecting whole-air samples, or by passing a known volume of extracted soil gas through an adsorption device. Samples shall be tested for the following analytes: [\_\_\_\_\_] .

-- End of Section --