





specification when you choose to reconcile  
references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM B 1	(2001) Standard Specification for Hard-Drawn Copper Wire
ASTM B 232/B 232M	(2001e1) Standard Specification for Concentric-Lay-Stranded Aluminum Conductors, Coated Steel-Reinforced (ACSR)
ASTM B 398/B 398M	(2002) Specification for Aluminum-Alloy 6201-T81 Wire for Electrical Purposes
ASTM B 399/B 399M	(1999) Specification for Concentric-Lay-Stranded Aluminum-Alloy 6201-T81 Conductors
ASTM B 8	(1999) Standard Specification for Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

IEEE C2	(2002) National Electrical Safety Code
---------	--

1.2 SUBMITTALS

\*\*\*\*\*

NOTE: Review Submittal Description (SD) definitions in Section 01330 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for

Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01330 SUBMITTAL PROCEDURES:

#### SD-03 Product Data

Manufacturer's product data shall be submitted for the following items:

Conductors  
Splices  
Hardware  
Clamps  
Stringing Sheaves

#### SD-08 Manufacturer's Instructions

Overhead Medium-Voltage Wiring Systems

### 1.3 GENERAL REQUIREMENTS

\*\*\*\*\*

NOTE: If Section 16003S GENERAL ELECTRICAL PROVISIONS is not included in the project specification, applicable requirements therefrom should be inserted and the following paragraph deleted.

\*\*\*\*\*

Section 16003S GENERAL ELECTRICAL PROVISIONS applies to work specified in this section.

## PART 2 PRODUCTS

### 2.1 CONDUCTORS

Line conductors shall be bare [hard-drawn stranded copper of the sizes indicated, conforming to ASTM B 1 ASTM B 8.] [aluminum conductors, steel reinforced, (ACSR), of the sizes indicated, conforming to ASTM B 232/B 232M ASTM B 232/B 232M.] [All Aluminum-Alloy Conductor (AAAC), of the sizes indicated, conforming to ASTM B 398/B 398M and ASTM B 399/B 399M]

### 2.2 SPLICES

Splicing material shall be UL approved.

Splices under tension shall be the compression type with strength not less

than that of the conductor spliced and made of suitable noncorrosive materials.

## 2.3 HARDWARE

Hardware shall be UL approved.

Tie wires shall be 4.12 millimeter diameter No. 6 AWG [medium-hard drawn bare copper.] [strong aluminum alloy or 5.19 millimeter diameter No. 4 AWG annealed aluminum;] armor shall be as recommended by the manufacturer.

## PART 3 EXECUTION

### 3.1 MANUFACTURER'S INSTRUCTIONS

Manufacturer's instructions shall be submitted for Overhead Medium-Voltage Wiring Systems indicating the manufacturer's recommended operation instructions.

### 3.2 INSTALLATION

\*\*\*\*\*  
**NOTE: For installations in California, use  
California Public Utilities Commission, Dgs Gen.  
Ord. 95, "Rules for Overhead Electric Line  
Construction," in lieu of IEEE C2.**  
\*\*\*\*\*

Installation shall comply with the requirements and recommendations of IEEE C2 for medium loading conditions, Grade B construction.

[Tie] [Clamp] conductors to insulators in accordance with insulator manufacturer written installation instructions.

\*\*\*\*\*  
**NOTE: Delete the following paragraph if aluminum  
conductors are not used.**  
\*\*\*\*\*

Conductors shall be armored at all points of support. For spans less than 60 meter 200 feet, flat armor may be used.

Dead ends shall be made with clamps designed for the purpose, with a strength not less than that of the conductor.

Care shall be taken in handling and stringing conductors to prevent cuts, scratches, and kinks. Conductors shall not be drawn over rough or rocky ground or around sharp bends. When drawn by machine power, conductors shall be drawn from the mounted reels through stringing sheaves in approximately straight lines and clear of all obstructions.

Where conductors pass through trees, the trees shall be trimmed at least 2400 millimeter 8-feet clear of conductors vertically and horizontally, and no branch shall overhang the horizontal clearance. A climbing space at least 1200 millimeter 48-inches square shall be provided.

Initial stringing sags and tensions shall be in accordance with approved values for the conductors furnished. Indicated clearances shall be maintained.

\*\*\*\*\*  
NOTE: Omit the following paragraph if a static wire  
is not required.  
\*\*\*\*\*

A static wire of stranded copper-coated steel, of size as indicated, shall be installed above the conductors to afford a 30-degree cone of lightning protection. Static wires shall be grounded at each pole and structure.

A neutral conductor of material the same as phase conductors, of size as indicated, shall be installed at an elevation equal to or below phase conductors in accordance with clearance requirements of IEEE C2.

-- End of Section --