
USACE / NAVFAC / AFCEA UFGS-15751N (September 1999)

Preparing Activity: NAVFAC Replacing without revision
NFGS of same number and date

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 22 December 2004

SECTION TABLE OF CONTENTS

DIVISION 15 - MECHANICAL

SECTION 15751N

DESICCANT DEHUMIDIFICATION EQUIPMENT

09/99

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 RELATED REQUIREMENTS
- 1.3 SUBMITTALS

PART 2 PRODUCTS

- 2.1 DESICCANT DEHUMIDIFICATION UNIT
 - 2.1.1 Air Handling Components
 - 2.1.2 Hot Water Heater
 - 2.1.3 Sensible Heat Recovery Devices
 - 2.1.3.1 Rotary Wheel
 - 2.1.3.2 Heat Pipe
 - 2.1.4 Desiccant Wheel
 - 2.1.5 Evaporative Chiller

PART 3 EXECUTION

- 3.1 PREPARATION
- 3.2 INSTALLATION
- 3.3 FIELD QUALITY CONTROL
 - 3.3.1 Preliminary Tests
 - 3.3.2 Testing and Balancing
- 3.4 FIELD TRAINING

-- End of Section Table of Contents --

USACE / NAVFAC / AFCESA UFGS-15751N (September 1999)

Preparing Activity: NAVFAC Replacing without revision
NFGS of same number and date

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 22 December 2004

SECTION 15751N

DESICCANT DEHUMIDIFICATION EQUIPMENT 09/99

NOTE: This guide specification covers the requirements for natural gas or waste heat fired rotary wheel type dehumidifier utilizing an adsorbing material for a desiccant.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

Use of electronic communication is encouraged.

Brackets are used in the text to indicate designer choices or locations where text must be supplied by the designer.

NOTE: Desiccant dehumidifiers are delivered from the manufacturer as a complete air handling unit consisting of the casing, fan, sensible heat recovery device and a desiccant wheel. The unit may or may not also include heating and/or cooling coils, evaporative cooling pad, etc. This guide specification covers all components that may make up a complete desiccant dehumidification unit.

PART 1 GENERAL

1.1 REFERENCES

NOTE: Issue (date) of references included in project specifications need not be more current than provided by the latest guide specification. Use of SpecsIntact automated reference checking is

recommended for projects based on older guide
specifications.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING
ENGINEERS (ASHRAE)

ASHRAE 15 (2001; Errata 2002) Safety Standard for
Refrigeration Systems

ASHRAE 84 (1991) Method of Testing Air-to-Air Heat
Exchangers

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2005) National Electrical Code

NFPA 90A (2002) Installation of Air Conditioning
and Ventilating Systems

1.2 RELATED REQUIREMENTS

Section 15050, "Basic Mechanical Materials and Methods, applies to this section with the addition and modifications specified herein.

1.3 SUBMITTALS

NOTE: Submittals must be limited to those necessary for adequate quality control. The importance of an item in the project should be one of the primary factors in determining if a submittal for the item should be required.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy projects.

Submittal items not designated with a "G" are considered as being for information only for Army projects and for Contractor Quality Control approval for Navy projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

SD-03 Product Data

Note: Indicate sound ratings or loudness level of equipment in the Equipment Schedule on the drawings.

Desiccant Dehumidification Unit

SD-06 Test Reports

Filter sections

Preliminary tests

Dampers leakage test

SD-07 Certificates

Desiccant dehumidification unit

SD-10 Operation and Maintenance Data

Desiccant dehumidification unit, Data Package 5

Submit in accordance with Section 01781 OPERATION MAINTENANCE DATA.

PART 2 PRODUCTS

2.1 DESICCANT DEHUMIDIFICATION UNIT

2.1.1 Air Handling Components

All air handling components of the desiccant dehumidification unit ([casing,] [dampers,] [fans] [vibration isolation,] [filter sections,] [mixing boxes,] [outside air intake,] [[heating] [cooling] sections] [roof curbs] [and] corrosion criteria as applicable) shall meet the requirements of Section 15720N AIR HANDLING UNITS. Units shall include humidity controls (humidistat) and temperature controls (thermostat).

[2.1.2 Hot Water Heater

Hot water heater shall meet the requirements of Section 15514N LOW PRESSURE WATER HEATING BOILERS UNDER 800,000 BTU/HR OUTPUT, with an atmospheric-type

gas burner.

]2.1.3 Sensible Heat Recovery Devices

[2.1.3.1 Rotary Wheel

NOTE: Select minimum acceptable energy transfer effectiveness and maximum acceptable cross-contamination. Delete moisture resistance and chain drive if not required.

Unit shall be a factory fabricated and tested assembly for air-to-air energy recovery by transfer of sensible heat from exhaust air to supply air stream. Device performance shall be according to ASHRAE 84. Device shall deliver energy transfer effectiveness of not less than [70] [85] [_____] percent with cross-contamination not in excess of [0.1] [1.0] [_____] percent of exhaust airflow rate at system design differential pressure. Exchange media shall be chemically inert, moisture resistant, fire-retardant, laminated, nonmetallic material which complies with NFPA 90A. Exhaust and supply stream shall be isolated by seals which are static, field adjustable, and replaceable. Chain drive mechanisms shall be fitted with ratcheting torque limiter or slip-clutch protective device. Enclosure shall include maintenance access provisions. Recovery control and rotational failure provisions shall be as indicated.

] [2.1.3.2 Heat Pipe

NOTE: Schedule should include face air velocity, static pressure drop, temperature requirements for entering and leaving air or exhaust streams. Delete flexible connectors if not required.

Device shall be a factory fabricated, assembled and tested, counterflow arrangement, air-to-air heat exchanger for transfer of sensible heat between exhaust and supply airstreams. Device shall deliver an energy transfer effectiveness not less than that indicated without cross-contamination. Heat exchanger tube core shall be [15] [18] [25] mm [1/2] [5/8] [one] inch nominal diameter, seamless aluminum or copper tube with extended surfaces, utilizing wrought aluminum Alloy 3003 or Alloy 5052, temper to suit. Maximum fins per unit length and number of tube rows shall be as indicated. Tubes shall be fitted with internal capillary wick, filled with an ASHRAE 15, Group 1 refrigerant working fluid, selected for system design temperature range, and hermetically sealed. Heat exchanger frame shall be constructed of not less than 1.6 mm 16 gage galvanized steel intermediate tube supports, and flange connections. Tube end-covers and a partition of galvanized steel to separate exhaust and supply air streams without cross-contamination shall be provided. [A drain pan constructed of welded Type 300 series stainless shall be provided.] Heat recovery regulation shall be provided by [system face and bypass dampers and related control system as indicated] [interfacing with manufacturer's standard tilt-control mechanism for summer/winter operation, regulating the supply air temperature and frost prevention on weather face of exhaust side at temperature indicated]. Coil shall be fitted with pleated flexible connectors.

]2.1.4 Desiccant Wheel

Supply and regeneration airstreams shall be counterflow. The dehumidifier shall be a rotary type designed for continuous operation. The wheel structure shall be of the extended surface type in the axial flow direction and the geometry shall provide for laminar flow over the operating range for minimum air pressure differentials. The dehumidifier shall be complete with a drive system utilizing a fractional-horsepower electric motor and speed reducer assembly driving the rotor. A slack-side tensioner shall be included for automatic take-up for belt-driven wheels. The desiccant material shall be an adsorbing type. The desiccant material shall be applied to the wheel such that the entire surface is active as a desiccant and the desiccant material does not degrade or detach from the surface of the wheel. The wheel shall be fitted with full-face, low-friction contact seals on both sides to prevent cross leakage. The rotary structure shall have underheat, overheat and rotation fault circuitry. The wheel assembly shall be warranted for a minimum of five years.

[2.1.5 Evaporative Chiller

Evaporative chiller shall meet the requirements of Section 15721N
EVAPORATIVE COOLING SYSTEMS.

]PART 3 EXECUTION

3.1 PREPARATION

Provide storage for equipment and materials at the project site. Parts shall be readily accessible for inspection, repair, and renewal. Protect materials and equipment from weather.

3.2 INSTALLATION

Install desiccant dehumidification equipment as indicated and in accordance with the manufacturer's instructions. Provide clearance for inspection, repair, replacement, and service. Electrical work shall conform with NFPA 70 and Division 16, "Electrical". Provide overload protection in the operating disconnect switches and magnetic starters. Locate outside air intake at a minimum of 8 meters 25 feet from industrial stacks, bathroom vents, and sanitary risers. Prevailing wind direction shall not be used as justification for placing air intake closer than 8 meters 25 feet of exhaust stacks. Install assembled units on vibration isolators. Bolt sections together in high pressure units. Pipe drain pan to nearest floor drain.

3.3 FIELD QUALITY CONTROL

Schedule and administer specified tests. Provide personnel, instruments and equipment for such tests. Correct defects and repeat the respective inspection and tests. Give the Contracting Officer ample notice of the dates and times scheduled for tests and trial operations. Conduct inspection and testing in the presence of the Contracting Officer.

Inspection

Prior to initial operation, inspect equipment installation for conformance with drawings and specifications.

3.3.1 Preliminary Tests

For each item of air handling and distribution equipment and its components, perform an operational test for a minimum period of [4] [_____] hours.

3.3.2 Testing and Balancing

After preliminary tests, perform air handling and distribution equipment tests adjustment, and balancing in accordance with Section 15950N HVAC TESTING/ADJUSTING/BALANCING.

3.4 FIELD TRAINING

The contractor shall conduct a training course for operating and maintenance personnel as designated by the Contracting Officer. Training shall be provided for a period of [4] [_____] hours of normal working time and shall start after the system is functionally complete but prior to the performance of tests. The field instruction shall cover all of the items contained in the approved Operating and Maintenance Instructions.

-- End of Section --