

Preparing Activity: NAVFAC

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 22 December 2004

SECTION TABLE OF CONTENTS

DIVISION 15 - MECHANICAL

SECTION 15702N

COMPUTER ROOM AIR CONDITIONING UNITS

2/02

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SYSTEM DESCRIPTION
- 1.3 SUBMITTALS
- 1.4 OZONE DEPLETION FACTOR

PART 2 PRODUCTS

- 2.1 COMPUTER ROOM AIR CONDITIONING UNITS (CRACU)
 - 2.1.1 Cabinet and Frame
 - 2.1.1.1 Unit Cabinet
 - 2.1.1.2 Cabinet Interiors Sound Attenuation
 - 2.1.2 Fan Section
 - 2.1.3 Cooling Coil
 - 2.1.4 Filters
 - 2.1.5 Reheat Coil
 - 2.1.6 Humidifier
 - 2.1.7 Refrigeration System
 - 2.1.7.1 Compressors
 - 2.1.7.2 Refrigerant Tubing
 - 2.1.8 Condenser
 - 2.1.8.1 Air-cooled Condenser
 - 2.1.8.2 Liquid-cooled Condenser
 - 2.1.8.3 Dry Coolers
 - 2.1.9 Space Temperature Control System
 - 2.1.10 Alarm Panel System
 - 2.1.11 Air Return and Delivery Orientation
 - 2.1.12 Floorstand
- 2.2 Corrosion Protection For Coastal Installations
 - 2.2.1 Polyelastomer Finish Coating System
 - 2.2.1.1 Heat Exchanger Coil (Including Evaporator Coil) Surfaces
 - 2.2.1.2 Uninsulated Interior Surfaces and Exterior Surfaces
 - 2.2.1.3 Insulated Interior Surfaces
 - 2.2.2 Phenolic Finish Coating System
 - 2.2.2.1 Heat Exchanger Coil (Including Evaporator Coil) Surfaces
 - 2.2.2.2 Uninsulated Interior Surfaces and Exterior Surfaces

- 2.2.2.3 Insulated Interior Surfaces
- 2.3 ELECTRICAL
 - 2.3.1 Electrical Motors, Controllers, Contactors, and Disconnects
 - 2.3.2 Electrical Control Wiring
- 2.4 [HVAC WATER PIPING] [AND] [METAL DUCTWORK]
- 2.5 FIRE PROTECTION DEVICES
- 2.6 SOURCE QUALITY CONTROL
 - 2.6.1 Manufacturer's Factory Test Plans
 - 2.6.1.1 Test Procedure
 - 2.6.1.2 Performance Variables
 - 2.6.1.3 Test Configuration
 - 2.6.1.4 Tested Variables
 - 2.6.1.5 Thermal Testing
 - 2.6.1.6 Specialized Components
 - 2.6.1.7 Factory Test For Sound Pressure Level
 - 2.6.1.8 Factory Tests Reporting Forms
 - 2.6.2 CRACU Production Schedule and Factory Test Schedule
 - 2.6.3 Factory Tests
 - 2.6.4 Deficiency Resolution
 - 2.6.5 Factory Test Reports

PART 3 EXECUTION

- 3.1 INSTALLATION
 - 3.1.1 CRACU System
 - 3.1.2 Installation Instructions
 - 3.1.3 Connections to Existing Systems
- 3.2 FIELD QUALITY CONTROL
- 3.3 FIELD TESTING
 - 3.3.1 Manufacturer's Field Test Plans
 - 3.3.1.1 Coordinated Testing
 - 3.3.1.2 Prerequisite Testing
 - 3.3.1.3 Test Procedure
 - 3.3.1.4 Performance Variables
 - 3.3.1.5 Test Configuration
 - 3.3.1.6 Tested Variables
 - 3.3.1.7 Thermal Testing
 - 3.3.1.8 Specialized Components
 - 3.3.1.9 Field Test Reporting Forms
 - 3.3.2 Field Test Schedule
 - 3.3.3 Manufacturer's Test Representative
 - 3.3.4 Field Tests
 - 3.3.5 Deficiency Resolution
 - 3.3.6 Field Test Reports

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA UFGS-15702N (February 2002)

Preparing Activity: NAVFAC

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 22 December 2004

SECTION 15702N

COMPUTER ROOM AIR CONDITIONING UNITS

2/02

NOTE: This guide specification covers the requirements for heating, ventilating, and cooling (HVAC) equipment for computer room air conditioning Units (CRACUs)..

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

Use of electronic communication is encouraged.

Brackets are used in the text to indicate designer choices or locations where text must be supplied by the designer.

NOTE: Equipment includes cooling equipment less than 211 KW 720,000 Btuh, and heating equipment less than 117 KW 400,000 Btuh.

Use the most efficient, competitively available CRACU for which there are at least two products available for the indicated ranges of comparability. Design parameters for each item of equipment shall be indicated on the drawings including capacity, efficiency, sound ratings, motor speeds, electrical characteristics, and special features.

System requirements must conform to NAVFAC MIL-HDBK-1003/3, "Heating, Ventilating, Air Conditioning, and Dehumidifying Systems."

PART 1 GENERAL

1.1 REFERENCES

NOTE: Issue (date) of references included in
project specifications need not be more current than
provided by the latest guide specification. Use of
SpecsIntact automated reference checking is
recommended for projects based on older guide
specifications.

The publications listed below form a part of this specification to the
extent referenced. The publications are referred to within the text by the
basic designation only.

AIR-CONDITIONING AND REFRIGERATION INSTITUTE (ARI)

ARI 410 (2001; Addendum 2002) Forced-Circulation
Air-Cooling and Air-Heating Coils

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING
ENGINEERS (ASHRAE)

ASHRAE 15 (2001; Errata 2002) Safety Standard for
Refrigeration Systems

ASHRAE 52.1 (1992) Gravimetric and Dust-Spot
Procedures for Testing Air-Cleaning
Devices Used in General Ventilation for
Removing Particulate Matter

ASME INTERNATIONAL (ASME)

ASME B16.22 (2002) Wrought Copper and Copper Alloy
Solder Joint Pressure Fittings

ASME B16.26 (1988) Cast Copper Alloy Fittings for
Flared Copper Tubes

ASME B31.1 (2004) Power Piping

ASME B31.5 (2001) Refrigeration Piping and Heat
Transfer Components

ASME BPVC SEC (1998) Boiler and Pressure Vessel Codes

ASTM INTERNATIONAL (ASTM)

ASTM B 280 (2003) Seamless Copper Tube for Air
Conditioning and Refrigeration Field
Service

ETL TESTING LABORATORIES (ETL)

ETL DLP (updated continuously) Directory of ETL
Listed Products

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

| | |
|----------|--|
| NFPA 70 | (2005) National Electrical Code |
| NFPA 90A | (2002) Installation of Air Conditioning and Ventilating Systems |

UNDERWRITERS LABORATORIES (UL)

| | |
|-------------------|--|
| UL Elec Equip Dir | (2003) Electrical Appliance and Utilization Equipment Directory |
|-------------------|--|

1.2 SYSTEM DESCRIPTION

Provide [new] [and modify existing] computer room air conditioning unit[s] (CRACU) complete and ready for operation.

1.3 SUBMITTALS

NOTE: Submittals must be limited to those necessary for adequate quality control. The importance of an item in the project should be one of the primary factors in determining if a submittal for the item should be required.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy projects.

Submittal items not designated with a "G" are considered as being for information only for Army projects and for Contractor Quality Control approval for Navy projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] The following shall be submitted in accordance with

Section 01330 SUBMITTAL PROCEDURES:

NOTE: For LANTNAVFACENGCOM projects, Contractor submittals for the CRACU's shall be Contracting Officer approved by LANTNAVFACENGCOM Mechanical Design Branch, in spite of who is the Designer of Record. Ensure that Section 01330 SUBMITTAL PROCEDURES, paragraph "Submittals Reserved for LANTNAVFACENGCOM Approval" covers this submittal requirement.

SD-03 Product Data

Computer room air conditioning units; G

Space temperature control system drawings; G

SD-06 Test Reports

NOTE: Specify factory tests for CRACU's with a capacity greater than 52,700 W 180,000 Btuh

[CRACU production schedule and factory test schedule; G

Manufacturer's factory test plans; G

Factory test reports; G]

Field test schedule; G

Manufacturer's field test plans; G

Field test reports; G

SD-07 Certificates

Certificate of Specification Compliance; G

Credentials of the manufacturer's field test representative; G

SD-08 Manufacturer's Instructions

Installation manual for each type of CRACU

SD-10 Operation and Maintenance Data

Submit in accordance with Section 01781 OPERATION AND MAINTENANCE DATA.

Computer room air conditioning units, Data Package 4; G

1.4 OZONE DEPLETION FACTOR

Equipment using refrigerants R-11, R-12, R-113, R-114, R-115, R-500, or refrigerants with ozone depletion factor (ODF) greater than 0.05 shall not

be permitted.

PART 2 PRODUCTS

2.1 COMPUTER ROOM AIR CONDITIONING UNITS (CRACU)

NOTE: The indoor components of CRACU are inherently noisy. In noise sensitive areas, designers should take steps to attenuate CRACU generated sound. Determine the maximum acceptable sound level limit for the application in NC level or dbA and add the limit to the CRACU equipment schedule. This sound level compliance may be verified by the CRACU factory and field tests.

NOTE: Designers should locate the floor registers in a raised floor system as far from the CRACU as possible to reduce direct sound transmission from the unit to the conditioned space.

NOTE: Designers should indicate the mandatory routing of piping around the floor stand of a downflow CRACU in their piping plan view and piping details. Ensure, by dimensioning of piping details, that no piping interferes with the air flow performance of the CRACU.

ASHRAE 15. Provide self-contained units, designed, [and] factory assembled[, and factory tested]. Unit shall be listed in UL Elec Equip Dir or ETL DLPfor computer room application. Unit shall include room cabinet and frame, [floor stand,]fan section, filter section, cooling coil, reheat coil, humidifier, [compressors], [condensers], controls, and, interconnecting piping internal to the CRACU.

2.1.1 Cabinet and Frame

2.1.1.1 Unit Cabinet

Unit frame shall be minimum 14 gage 2.0 millimeter welded steel tubes or steel angles and shall be mill-galvanized or coated with an epoxy finish, or an approved manufacturer's standard finish, if equivalent.

Exterior panels shall be furniture grade steel sheet, minimum of 20 gage 1.0 mm, mill-galvanized or coated with a corrosion-inhibiting epoxy finish, or an approved equivalent finish. Mill galvanized sheet metal shall be coated with not less than 1.25 ounces of zinc per square foot 380 gram of zinc per square meter of two-sided surface. Mill rolled structural steel shall be hot-dip galvanized or primed and painted. Cut edges, burns and scratches in hot-dip galvanized surfaces shall be coated with galvanizing repair coating.

Provide removable panel for access to controls without interrupting airflow. Panels shall be gasketed to prevent air leakage under system

operating pressure and shall be removable for service access without the use of special tools. Condensate pans shall be minimum 22 gage 1.0 millimeter Type 304 stainless steel and shall be piped to drain.

Exterior surfaces of cabinets constructed of mill-galvanized steel shall be finished by the manufacturer's standard enamel finish in [the specified] [the indicated] color.

CRACU manufacturer's standard cabinet materials and finishes will be acceptable if considered equivalent to the above requirements by the Contracting Officer.

[2.1.1.2 Cabinet Interiors Sound Attenuation

NOTE: For CRACU interior cabinets located in spaces which require low sound levels because of interaction requirements of the operating personnel, select desired sound attenuation methods specified in this paragraph. In noise sensitive areas, specifiers should take special steps to attenuate CRACU generated sound, such as using the two inch foam requirement, in lieu of the fiber glass insulation.

Provide a factory-installed sound attenuation system in the interior of the CRACU cabinet.

[CRACU cabinet panels interior shall be provided with 25 millimeters of 24 kilogram per cubic meter one inch of 1 1/2 pound per cubic foot neoprene-coated fiber glass insulation on interior of cabinet panels. Insulation shall be applied to the cabinet panels with 100 percent adhesive coverage and both the insulation and the adhesive shall conform to NFPA 90A].

[CRACU cabinet panels interior shall be provided with minimum 50 millimeters two inchthick acoustical sound absorbing foam with a minimum Noise Reduction Coefficient (NRC) of 0.85].

[Compressors located in CRACU interior cabinets shall be either wrapped in a sound absorbing insulating blanket or enclosed in it's own sound absorbing insulated mini-cabinet inside of the larger CRACU interior cabinet.]

[Fans and compressors located in the CRACU interior cabinet shall be provided with vibration isolators between their respective support frames and the cabinet framing.]

CRACU manufacturer's standard interior cabinet sound attenuation materials and finishes will be acceptable if considered equivalent to the above requirements by the Contracting Officer.

]2.1.2 Fan Section

NOTE: For CRACU units of sizes 6 tons and more, specify dual V-belt fan drives.

Fans which force air through coils into computer room[s] shall have belt drives and adjustable sheaves sized to ensure achievement of design air flow by field adjustments. Fan system design shall be such that design air flow shall be achieved at the midpoint of sheave adjustment.

The supply air fan shall be AMCA certified, double-inlet/double-width, and equipped with forward-curved blades wheel. The supply air fan shall be statically and dynamically balanced and equipped with V-belt drive. The fan shall have self-aligning, permanently lubricated ball bearings with a minimum life span of 100,000 hours.

Provide [V-belt drive][dual V-belt drive] sized for 200 percent of the motor nameplate rating. Fan speed shall be adjustable with cast iron variable pitch pulleys. Sheaves shall be within the middle one third of the sheave adjustment range.

The fan motor shall be drip-proof with NEMA rated frame, inherent overload protection, and sliding adjustable motor base. The maximum vibrations shall not exceed 2 mils (0.05 mm) in any plane.

2.1.1.3 Cooling Coil

**NOTE: Indicate on the design drawings the minimum
required head for the coil condensate pump.**

Provide ARI 410 coils and slope for drainage. Coil shall be constructed of seamless copper tubes with plate aluminum fins. Each coil, in the production process, shall be individually tested at 2200 kPa 320 psi with compressed air under water and verified to be air tight. [Provide DX coil complete with a distributor and thermostatic expansion valve with external equalizer.] [Provide hydronic coils complete with drain and vent connections.] [Provide condensate drain pan of stainless steel construction with nonferrous connections and internal trap, and a condensate pump system complete with integral pump discharge check valve, integral float switch, reservoir, and pump and motor assembly.]

2.1.1.4 Filters

Provide UL listed[2] [4] [_____] inches [50] [100] [_____] mm thick deep pleated fiberglass throwaway type filters. [Additionally, provide [2] [_____] inches [50] [_____] mm thick deep pleated fiberglass throwaway type pre-filters.] Efficiency of filter bank shall be a minimum of [30 percent][__ percent] efficiency based on ASHRAE 52.1 requirements. Provide one complete spare filter bank set for installation prior to final acceptance testing covered in Part 3 of this section.

2.1.1.5 Reheat Coil

[Provide ARI 410 reheat coils and slope for drainage. Provide coil constructed of seamless copper tubes with plate aluminum fins. Each coil, in the production process, shall be individually tested at 2200 kPa 320 psi with compressed air under water and verified to be air tight.]

[Provide electric reheat coils with low watts density. The electric reheat coils shall be enclosed in 304 stainless steel tubes and 304 stainless steel fins. Provide modulating control of the electric reheat coils by

[multiple stages] [or] [Silicon Controlled Rectifier (SCR).] Provide UL or ETL listed safety switches to protect system from overheating.]

2.1.6 Humidifier

Humidifier section shall include liquid-level control, emergency overflow and automatic water supply system factory pre-piped for final connection. Provide stainless steel evaporator pan with water high level and low level alarms. Arrange system to be cleanable and serviceable.

[Provide infrared type humidifier, including high intensity quartz lamps mounted above and out of water supply.]

[Provide low-watts density electric heater immersion type humidifier. Provide entire assembly and removable pan of stainless steel construction. Protect elements with high temperature limit cutout.]

[Provide steam generator type humidifier. Provide steam generator humidifier cutout. Controls shall include steam generation, and flush cycle. Furnish two extra cannisters.]

2.1.7 Refrigeration System

Provide compressor[s] complete with vibration isolation, suction and discharge service valves, high and low pressure safety switches, and built-in overload protection. Provide refrigeration circuits including hot gas mufflers, liquid-line filter-drier, refrigerant sight glass and moisture indicator, externally equalized expansion valve, and liquid-line solenoid valve factory connected with refrigeration copper tubing. [Crankcase heaters are required.] [Provide hot gas bypass.]

2.1.7.1 Compressors

NOTE: The purpose of the paragraph below is to prevent the acquisition of a refrigerant compressor design that is inferior from an energy efficiency or control standpoint. Delete this paragraph if there is no probability of acquisition of high energy users or inferior controls at a given capacity. However, if such an acquisition is probable, use the selections below to prohibit the acquisition of inferior designs.

Provide [single] or [dual], [hermetic] or [semi-hermetic] or [scroll] compressors. [If dual compressors are provided, the refrigeration system shall be equipped with two independent refrigeration circuits.] [Dual semi-hermetic compressors shall be provided complete with unloading system.]

] 2.1.7.2 Refrigerant Tubing

Field-installed refrigerant tubing for split systems shall be ASTM B 280, cleaned, dehydrated, and sealed. Further, provide ASME B16.22 solder joint refrigerant fittings and adapters with silver brazing alloy solder and silver brazing alloy flux. During brazing operations bleed a small amount of dry oil-free nitrogen continuously through the refrigerant tubing. If required for connections to equipment, provide ASME B16.26 flared fittings.

]2.1.8 Condenser

NOTE: Insert minimum temperature at which the
mechanical cooling equipment will be required to
operate.

Provide condenser circuit pre-piped with start-up and head pressure controls to maintain system operation at ambient temperatures down to [4.4 degrees C 40 degrees F] [minus 6.6 degrees C 20 degrees F] [_____] degrees C degrees F.

[2.1.8.1 Air-cooled Condenser

Provide remote air-cooled condenser arranged for vertical air discharge. The direct-driven propeller fans shall have factory balanced aluminum blades and shall be equipped with fan guards. The coils shall be constructed from seamless copper tubes with plate type aluminum fins. The coils, in the production process, shall be pressure tested with compressed air 300 psig 2068 kPa under water and verified to be leak-free. The air-cooled condensers casings and other components shall be suitable for outdoor location and constructed from aluminum with manufacturer's standard corrosion-resistant finish, or galvanized steel. [An integral factory wired and tested control panel shall be provided for the condenser.]

] [2.1.8.2 Liquid-cooled Condenser

Provide cleanable, cast iron or steel shell and copper tubes, [counterflow type] [or] [water-cooled] [or] [glycol-cooled] condenser with removable cast iron or steel heads. The condenser shall be constructed in accordance with ASME BPVC SEC. As an option, a coaxial (copper tube-in-copper tube) type water-cooled condenser may be provided.

] [2.1.8.3 Dry Coolers

The dry cooler shall be factory fabricated and shall comprise of casing, coil, and fan sections. The casing shall be constructed of aluminum sheets with aluminum legs, casing and legs provided with manufacturer's standard corrosion resistant finish.

The cooling fluid (water or water/glycol solution) shall flow through a coil made up of copper tubes and aluminum fins. The coils shall be leak tested at factory at 300 psi 2068 kPa.

The fan section of the dry cooler shall comprise of factory balanced, direct driven metal propeller fan(s) complete with slow speed motor(s) and fan guard(s). The fan(s) shall be arranged for vertical discharge. The electrical connections and control connections shall be provided in a weatherproof enclosure mounted integral with the dry cooler.

As indicated on the drawings, the dry cooler shall be equipped with a centrifugal pump [single pump] [double pump] package complete with an open expansion tank. The pump package shall be mounted in a weatherproof enclosure.

Provide special corrosion protection in accordance with the requirements specified in this section in the paragraph, "Corrosion Protection For Coastal Installations".

]2.1.9 Space Temperature Control System

[Provide microprocessor control system integral with unit including electronic control center, control valves, sensors, wiring, and other appurtenances for workable system. Provide access panel or door in front of unit.

Isolate electronic control center from conditioned airstream to allow service while system is in operation. Provide control sensors in unit for cooling, dehumidifying, and humidifying. High-voltage circuits in system shall have individual leg overload protection. Starters, contactors, and relays shall be controlled by 24 volt control circuit.

High-voltage circuit components shall be protected by safety lock, dead-front panel. Mount nonautomatic, molded-case circuit breaker in high-voltage section of electrical panel. Operating mechanism shall prevent access to high-voltage electrical components until switched to "OFF" position.]

[Include the following control capabilities:

- [a. Capable of changing the set points and sensitivity of the space and humidity along with their low and high alarm points.]
- [b. Logging capability of the last 10 alarms and run time.]
- [c. Diagnostics]
- [d. Refrigerant compressor sequencing]]

[Provide controls under Section 15901N SPACE TEMPERATURE CONTROL SYSTEMS.]
[Provide controls under Section 15910N DIRECT DIGITAL CONTROL SYSTEMS.] [Provide a controls interface on CRACU to enable the DDC system to monitor the following operating parameters and alarm conditions: high and low computer room temperature, relative humidity, CRACU status, [____].]

2.1.10 Alarm Panel System

Provide unit with cabinet-mounted alarm panel which shall monitor high and low space temperature, high and low space humidity, dirty filters, loss of airflow, [loss of [water][or glycol] flow,] compressor high head pressure, and humidifier problems. Provide underfloor water detector. Provide field accessible local audible alarm with silence pushbutton. Provide push-to-test lamps or all-lamp test pushbutton. [CRACUs shall have local devices which provide signals for remote audible and visual alarming capability for the above specified alarm conditions.]

2.1.11 Air Return and Delivery Orientation

NOTE: Select one of the following two paragraphs to specify air delivery and air return orientation.
Indicate the extent of the acoustical lining in the downflow discharge duct.

[Computer room air conditioning unit[s] shall be downflow discharge, top return, draw-thru cooling coil, and shall discharge air [into a raised

floor plenum] with through an acoustically-lined sweep or acoustically-lined multiple turning vane elbows provided to direct the flow of air away from the back of the unit. Provide acoustical lining on the interior of [the discharge air devices] [and] [the return air plenum] in compliance with with requirements specified hereinafter in paragraph "Cabinet Interiors Sound Attenuation".]

[Computer room air conditioning unit[s] shall be upflow discharge, [bottom return,] [front return,] [rear return,] draw-thru cooling coil, and shall be fitted with collars for top supply duct connections. Upflow discharge shall discharge air with a acoustical lined sweep or acoustically-lined multiple turning vane elbows provided to direct the flow of air away from the back of the unit. Supply (discharge air) ducting from the upflow units shall be off of each blower discharge outlet, that is, one duct and duct collar per blower. Provide acoustical lining on the interior of [the supply air devices] in compliance with with requirements specified hereinafter in paragraph "Cabinet Interiors Sound Attenuation".]

[2.1.12 Floorstand

Unit shall be provided with elevating [225] [300] [450] [600] mm [9] [12] [18] [24] inches high floorstand or jacks for freestanding installation on the main building floor. Floorstand or jacks shall elevate the unit to the height of the raised computer floor and shall allow for leveling and locking at the desired height. Floorstand or jacks shall be retractable, or removable, for installing the unit directly on the raised floor. Unit shall be fully gasketed (rubber or neoprene) to prevent air leakage at the raised floor penetration.

] [2.2 Corrosion Protection For Coastal Installations

NOTE: Specify corrosion protection for exterior HVAC equipment, including air handling units, heat exchanger coil surfaces, equipment casings, that is exposed to the weather within 5 miles of a sea (salt) water coast.

At these coastal locations, this corrosion protection is also required on HVAC equipment within buildings that are subject to the outside weather conditions. Specifically, equipment requiring protection is defined as the first HVAC equipment (excluding louvers) met by the outside air in the supply air ductwork system.

Specifier shall survey the HVAC equipment market place, find and specify the manufacturer's standard off-the-shelf anti-corrosion options for "coastal" or "sea coast" installations. Specify the various systems (utilizing the word "or") offered by three competitive equipment selections. This approach is by far less costly than specifying the custom corrosion protection requirements below.

After thorough investigation, if standard off-the-shelf anti-corrosion options are not available, include the corrosion protection requirements specified herein.

NOTE: For installations in MCAS Cherry Point and
MCB Camp LeJeune, including New River, specify
corrosion protection for all outside, and specific
inside HVAC equipment exposed to the weather.
Follow the guidance specified in the criteria NOTE
above.

Provide either the polyelastomer finish coating system or the phenolic finish coating system on the interior and the exterior surfaces of HVAC heat exchanging equipment, The coating system shall not reduce the HVAC equipment's performance rating.

Finish coating shall be applied at the premises of the HVAC equipment manufacturer or at the premises of the coating manufacturer or his authorized applicator. Provide finish coating in colors gray, or aluminum, or ivory. All components of the special finish coating systems, including primers and intermediate coats, shall be applied by immersion dip-coating or spray-coating in accordance with coating manufacturer's written procedures.

If special finish coatings are applied at the finish coating manufacturer's (or his authorized applicator's) premises, the equipment to be finish coated shall be transported to and from the finish coating manufacturer's premises by the Contractor. The finish-coating manufacturer shall be responsible for necessary disassembly of the HVAC equipment and re-assembly of final finish coated equipment.

Submit for approval a Certificate of Specification Compliance furnished by the finish coating system manufacturer. Requirements for certificate include:

- a. Name of firm that provided the finish coating system.
- b. Project title and Navy construction contract number.
- c. Listing of the pieces of equipment that were finish coated by this firm.
- d. Certificate shall certify that the finish coating materials and application procedures employed conform to the contract specifications.
- e. Date of final inspection by this firm and printed name and signature of the inspector.
- f. Printed name and signature of the officer of the firm that is responsible for firm's certification program .

2.2.1 Polyelastomer Finish Coating System

2.2.1.1 Heat Exchanger Coil (Including Evaporator Coil) Surfaces

- a. Acrylic polymer resin primer: 0.025 mm (1 mil) minimum dry film thickness.
- b. Polyelastomer resin top coating: 3 coats, 0.038 mm (1.5 mils) minimum total dry film thickness.
- c. In lieu of coating, provide copper tubes and copper fins

2.2.1.2 Uninsulated Interior Surfaces and Exterior Surfaces

Polyelastomer resin: 3 coats, 0.100 to 0.150 mm (4 to 6 mils) minimum total dry film thickness.

2.2.1.3 Insulated Interior Surfaces

Vinyl: 0.050 to 0.250 mm (2 to 10 mils) minimum dry film thickness

2.2.2 Phenolic Finish Coating System

Provide a resin base thermosetting phenolic finish.

2.2.2.1 Heat Exchanger Coil (Including Evaporator Coil) Surfaces

- a. Apply phenolic finish to the entire coil. Provide a minimum of two coats. Total minimum dry film thickness shall be 0.075 mm (3 mils).
- b. In lieu of coating, provide coil of copper tubes and copper fins

2.2.2.2 Uninsulated Interior Surfaces and Exterior Surfaces

Amine cured epoxy phenolic finish: 0.150 to 0.175 mm (6 to 7 mils) minimum total dry film thickness.

2.2.2.3 Insulated Interior Surfaces

Polyester or Vinyl Ester finish: 0.050 to 0.250 mm (2 to 10 mils) minimum dry film thickness.

]2.3 ELECTRICAL

2.3.1 Electrical Motors, Controllers, Contactors, and Disconnects

Furnish with respective pieces of equipment. Motors, controllers, contactors, and disconnects shall conform to Section 16402 INTERIOR DISTRIBUTION SYSTEM, as modified and supplemented by this section. Provide electrical connections under Section 16402 INTERIOR DISTRIBUTION SYSTEM. Provide controllers and contactors with maximum of 120-volt control circuits, and auxiliary contacts for use with controls furnished. When motors and equipment furnished are larger than sizes indicated, the cost of providing additional electrical service and related work shall be included under this section.

2.3.2 Electrical Control Wiring

[Provide control wiring under Section 15901N SPACE TEMPERATURE CONTROL SYSTEMS.] [Provide control wiring under Section 15910N DIRECT DIGITAL CONTROL SYSTEMS.] [Provide control wiring under this section in accordance with NFPA 70 and Section 16402 INTERIOR DISTRIBUTION SYSTEM.] Provide Space temperature control system drawings which include point-to-point electrical wiring diagrams.

2.4 [HVAC WATER PIPING] [AND] [METAL DUCTWORK]

NOTE: LANTNAVFACENGCOM Projects should use

**LANTNAVFACENGCOM Section 15700 HEATING, VENTILATING,
AND COOLING SYSTEM.**

Requirements for HVAC water piping and metal ductwork is specified in [Section 15181N CHILLED, CONDENSER, AND DUAL SERVICE WATER PIPING] [and] [Section 15810N DUCTWORK AND DUCTWORK ACCESSORIES].

[2.5 FIRE PROTECTION DEVICES

The requirements for duct smoke detectors are specified in [Section 15910N DIRECT DIGITAL CONTROL SYSTEMS] [Section 15901N SPACE TEMPERATURE CONTROL SYSTEMS].

] [2.6 SOURCE QUALITY CONTROL

**NOTE: Specify factory acceptance tests (source
quality control) for CRACU's with a capacity greater
than 52,700 W 180,000 Btuh**

Provide factory test plan[s], factory test schedule[s], factory test[s] and factory test report[s] on [each of the CRACU[s]]; [CRACU-1 through CRACU-[_]].

2.6.1 Manufacturer's Factory Test Plans

For each CRACU, submit a factory test plan which when followed during factory testing shall verify that the performance scheduled on the drawings is met by the produced CRACU models.

The manufacturer shall perform factory tests on the actual CRACU[s] produced for this project. The test reports shall document the performance tests conducted on the factory assembled computer room air conditioning units. Performance testing on the individual computer room air conditioning unit components, not factory assembled, is not acceptable.

Submit the required test plans for review and approval to the Contracting Officer at least [90][_] calendar days before scheduled factory test date.

2.6.1.1 Test Procedure

Indicate in each test plan the factory acceptance test procedures. Procedures shall be structured to test all modes of operation to confirm that the controls through all modes of control to confirm that the controls are performing in accordance with the intended sequence of control.

Controllers shall be verified to be properly calibrated and have the proper set point to provide stable control of their respective equipment.

Include in each test plan a detailed step-by-step procedure for testing automatic controls provided by the manufacturer.

2.6.1.2 Performance Variables

Each test plan shall list performance variables that are required to be measured or tested as part of the field test. Include in the listed performance indicated on the equipment schedules on the contract design

drawings.

Manufacturer shall furnish with each test procedure a description of acceptable performance results that shall be verified. Manufacturer shall identify the acceptable limits or tolerances within which each tested performance variable shall acceptably operate.

2.6.1.3 Test Configuration

Plans shall indicate that tests are to be performed for a minimum of four continuous hours in a wet coil condition. If test period is interrupted, the four hour test period shall be started over. Each test plan shall be job specific and shall address the particular CRACU[s] and particular conditions which exist with this contract. Generic or general preprinted test procedures are not acceptable. [Tests shall include [a pressurized raised floor discharge configuration at the specified or indicated height above the floor,] [with or without the air discharge elbows;] [or a top air discharge configuration] [and phenolic coated coils].]

2.6.1.4 Tested Variables

Plans shall provide for air side testing which includes verification of the airflow, total static pressure; fan drive motor KW, amperage and RPM; and fan RPM. Provide entering air temperatures equal to those indicated on the CRACU schedules.

2.6.1.5 Thermal Testing

Plans shall provide thermal testing utilizing [chilled water] [40 percent ethylene glycol and 60 percent water solution] [and] [hot water] with temperatures equal to those indicated on the CRACU schedules. Thermal testing shall verify CRACU heating, sensible cooling, total cooling, and humidifying performance scheduled on the contract drawings.

2.6.1.6 Specialized Components

Include procedures for field testing and field adjusting specialized components, such as hot gas bypass control valves, or pressure valves.

[2.6.1.7 Factory Test For Sound Pressure Level

NOTE: Do not include the following sound rating tests in the specification without written permission from the Engineering Field Division's Mechanical Design Branch for a particular project. Prior to including the following sound testing paragraph, coordinate the following aspects of the requirements:

1. Determining the sound ratings of CRACU's requires specific factory testing. This testing may need to be witnessed by a representative of the Contracting Officer to verify compliance since no manufacturer to date has performed these sound rating tests.

2. Sound rating testing will add significant cost to each CRACU and therefore must be covered by the

project cost estimate.

3. Ensure that acceptable sound ratings for each CRACU is indicated.

Determine the A-weighted sound pressure level for the indoor portion of each of the CRACU's; [CRACU-1 through CRACU-[_]].

Each unit shall be mounted on a [raised] floor duplicating of the installation configuration indicated on the contract drawings. Unit shall be located at least 1.5 meters 150 mm5 feet 6 inches from test room walls. No other equipment shall be operating in the test room during sound level testing of subject unit. Background sound levels shall be at least 10 dB below lowest sound pressure level measured on subject unit. Testing shall be conducted by using an ANSI Type 1 or 2 sound level meter located 1.0 meter 3.3 feet from the unit under test and 1.0 meter 3.3 feet above raised floor. Measure and record A-weighted sound pressure level on all four sides of unit.

]2.6.1.8 Factory Tests Reporting Forms

Each test plan shall include the required test reporting forms to be completed by the Contractor's testing representatives. Submit factory test reports, referencing each tested CRACU serial number, and receive approval before delivery of CRACU to the project site.

2.6.2 CRACU Production Schedule and Factory Test Schedule

The Government [will][reserves the right to] witness factory tests for [CRACU-1,][and CRACU-[_____] through CRACU-[_____]].

Provide the CRACU production schedule and factory test schedule for tests to be performed at the manufacturer's test facility. Submit planned production schedule, and factory test schedule and test location, to the Contracting Officer as soon as it is scheduled but not less than 60 calendar days prior to the scheduled factory test date. Track this schedule through the production phases and if a scheduled factory test date changes, give advanced notice to Contracting Officer as soon as possible but at least 15 calendar days in advance of the scheduled test dates.

2.6.3 Factory Tests

Conduct the factory testing in compliance with the Contracting Officer approved manufacturer's field test plan, and in accordance with additional field testing requirements specified herein. Record the required data using the test reporting forms approved of the approved field test plan. Conduct the test for each CRACU for the continuous test period in the approved test plan. A CRACU shutdown before the continuous test period is completed shall result in the test period being started again and run for the required duration.

2.6.4 Deficiency Resolution

The test requirements shall be acceptably met; deficiencies identified during the tests shall be corrected in compliance with the manufacturer's recommendations and corrections tested as specified in the paragraph

"Factory Test Plans".

2.6.5 Factory Test Reports

Use the test reporting forms approved in the factory test plan. Final test report forms shall be typed including data entries and remarks. Completed test report forms for each CRACU shall be reviewed, approved, and signed by the Manufacturer's test director.

] PART 3 EXECUTION

3.1 INSTALLATION

3.1.1 CRACU System

Installation of each CRACU system including equipment, materials, installation, workmanship, fabrication, assembly, erection, examination, inspection, and testing, shall be in accordance with ASME B31.1, ASME B31.5, NFPA 70, as modified and supplemented by the requirements of this section and the CRACU manufacturer's recommendations.

3.1.2 Installation Instructions

Provide a manufacturer's installation manual for each type of CRACU.

3.1.3 Connections to Existing Systems

Notify the Contracting Officer in writing at least 15 calendar days prior to the date the connections are required. Obtain approval before interrupting service. Furnish materials required to make connections into existing systems and perform excavating, backfilling, compacting, and other incidental labor as required. Furnish labor and tools for making actual connections to existing systems.

3.2 FIELD QUALITY CONTROL

Upon completion and before final acceptance of work, test each CRACU subsystem in service to demonstrate compliance with the contract requirements, including field testing specified below. Adjust controls and balance systems prior to final acceptance of completed systems. Test controls through every cycle of operation. Test safety controls to demonstrate performance of required function. Correct defects in work provided by Contractor and repeat tests. Furnish steam, fuel, water, electricity, instruments, connecting devices, and personnel for tests. Flush and clean piping before placing in operation. Clean equipment, piping, strainers, and ducts. Prior to commencement of field testing, remove all filters and provide new filters.

3.3 FIELD TESTING

Provide field test plan[s], field test schedule[s], field test[s] and field test report[s] on each of the CRACU[s]. Field test each CRACU for Contracting Officer acceptance in accordance with the CRACU manufacturer's approved field test plan.

3.3.1 Manufacturer's Field Test Plans

Submit field test plans developed by the manufacturer for each CRACU; [submit the field test plans along with the factory test plans specified

herein before][submit the field test plans at least 90 calendar days prior to planned date of the field test]. Field test plans developed by the installing Contractor, or the equipment sales agency furnishing the CRACU, will not be acceptable.

The Contracting Officer will review and approve the field test plan for each of the listed CRACU's prior to commencement of field testing of the equipment. The approved field test plans shall be followed for the field tests of the CRACU and test reporting.

3.3.1.1 Coordinated Testing

Indicate in each field test plan when work required by this section requires coordination with test work required by other specification sections. Furnish test procedures for the simultaneous or integrated testing of: CRACU controls which interlock and interface with controls factory prewired[; and external controls for the CRACU provided under [Section 15901N SPACE TEMPERATURE COTROL SYSTEMS] [Section 15910N DIRECT DIGITAL CONTROL SYSTEMS]].

3.3.1.2 Prerequisite Testing

Each CRACU for which performance testing is dependent upon the completion of the work covered by Section 15950N HVAC TESTING/ADJUSTING/BALANCING must have that work completed as a prerequisite to testing work under this section. Indicate in each field test plan when such prerequisite work is required.

3.3.1.3 Test Procedure

Indicate in each field test plan the CRACU manufacturer's published start-up, and field acceptance test procedures. Include in each test plan a detailed step-by-step procedure for testing automatic controls provided by the manufacturer.

Procedures shall be structured to test the controls through all modes of control to confirm that the controls are performing with the intended sequence of control.

Controllers shall be verified to be properly calibrated and have the proper set point to provide stable control of their respective equipment.

3.3.1.4 Performance Variables

Each test plan shall list performance variables that are required to be measured or tested as part of the field test.

Include, in the listed performance variables, requirements indicated on the CRACU schedules on the design drawings. Manufacturer shall furnish, with each test procedure, a description of acceptable results that have been verified.

Manufacturer shall identify the acceptable limits or tolerances within which each tested performance variable shall acceptably operate.

3.3.1.5 Test Configuration

Plans shall indicate that tests are to be performed for a minimum of four continuous hours in a wet coil condition. If test period is interrupted,

the four hour test period shall be started over. Each test plan shall be job specific and shall address the particular CRACU[s] and particular conditions which exist with this contract. Generic or general preprinted test procedures are not acceptable. [Tests shall include [a pressurized raised floor discharge configuration at the specified or indicated height above the floor,] [with or without the air discharge elbows;] [or a top air discharge configuration] [and corrosion protection.]]

3.3.1.6 Tested Variables

Plans shall provide for air side testing which includes verification of the airflow, total static pressure; fan drive motor KW, amperage and RPM; and fan RPM. Provide entering air temperatures equal to those indicated on the CRACU schedules.

3.3.1.7 Thermal Testing

Plans shall provide thermal testing utilizing [chilled water] [40 percent ethylene glycol and 60 percent water solution] [and] [hot water] with temperatures equal to those indicated on the CRACU schedules. Thermal testing shall verify CRACU heating, sensible cooling, total cooling, and humidifying performance scheduled on the contract drawings.

3.3.1.8 Specialized Components

Include procedures for field testing and field adjusting specialized components, such as hot gas bypass control valves, or pressure valves.

3.3.1.9 Field Test Reporting Forms

Each test plan shall include the required test reporting forms to be completed by the Contractor's testing representatives.

3.3.2 Field Test Schedule

Notify the Contracting Officer in writing at least 30 calendar days prior to the testing. Within 30 calendar days after acceptable completion of testing, submit each test report for the review and approval of the Contracting Officer.

3.3.3 Manufacturer's Test Representative

Furnish a factory trained field test representative authorized by the CRACU manufacturer to oversee the complete execution of the field testing. This test representative shall also review, approve, and sign the completed field test report. Signatures shall be accompanied by the person's name typed.

Submit credentials of the manufacturer's field test representative proposed, including current telephone number, to the Contracting Officer for review and approval. Submit these credentials with the written advance notice of the field tests

3.3.4 Field Tests

Conduct the field testing in compliance with the Contracting Officer approved manufacturer's field test plan, and in accordance with additional field testing requirements specified herein. Record the required data using the test reporting forms approved of the approved field test plan.

Conduct the test for each CRACU for a continuous 24-hour test period. A CRACU shutdown before the continuous 24-hour test period is completed shall result in the 24-hour test period being started again and run for the required duration.

3.3.5 Deficiency Resolution

The test requirements shall be acceptably met; deficiencies identified during the tests shall be corrected in compliance with the manufacturer's recommendations. Corrections shall be tested again in compliance with the requirements specified in the paragraph "Field Test Plans".

3.3.6 Field Test Reports

Use the test reporting forms approved in the field test plan. Final test report forms shall be typed, including data entries and remarks. Completed test report forms for each CRACU shall be reviewed, approved, and signed by the Contractor's test director and the QC manager.

-- End of Section --