

2.7 COATINGS

- 2.7.1 Outdoor Vapor-Barrier Finishing
 - 2.7.2 Indoor Vapor-Barrier Finishing
 - 2.7.3 Outdoor and Indoor Nonvapor-Barrier Finishing (NBF)
 - 2.7.4 Cellular-Elastomer Insulation Coating
 - 2.7.5 Coating Color
- ## 2.8 TAPE
- 2.9 DUAL-TEMPERATURE (HOT- AND CHILLED-) WATER PIPING
 - 2.10 HOT-WATER, STEAM, AND CONDENSATE-RETURN PIPING
 - 2.11 COLD-WATER AND CONDENSATE-DRAIN PIPING
 - 2.12 REFRIGERANT SUCTION PIPING
 - 2.13 COOLING-TOWER CIRCULATING WATER PIPING
 - 2.14 STEAM AND CONDENSATE PIPING, 2.4 MEGAPASCAL 350 PSIG
 - 2.15 HOT WATER HEATING CONVERTER
 - 2.16 CHILLED-WATER AND DUAL-TEMPERATURE PUMPS
 - 2.17 LOW-PRESSURE STEAM AND CONDENSATE, WEATHER-EXPOSED
 - 2.18 STEAM & CONDENSATE, WEATHER-EXPOSED, 861 KILOPASCAL 125 PSIG
 - 2.19 STEAM & CONDENSATE, WEATHER-EXPOSED, 2.4 MEGAPASCAL 350 PSIG

PART 3 EXECUTION

3.1 INSTALLATION OF INSULATION SYSTEMS

3.2 SYSTEM TYPES

- 3.2.1 Type T-1, Mineral Fiber with Vapor-Barrier Jacket
- 3.2.2 Type T-2, Mineral Fiber with Glass Cloth Jacket
- 3.2.3 Type T-3, Cellular Elastomer
- 3.2.4 Type T-4, Cellular Glass with Vapor-Barrier Jacket
- 3.2.5 Type T-5, Calcium Silicate with Glass Cloth Jacket (Piping)
- 3.2.6 Type T-6, Mineral Fiber with Aluminum Jacket
- 3.2.7 Type T-7, Calcium Silicate with Glass Cloth Jacket (Surfaces)
- 3.2.8 Type T-9, Cellular Elastomer
- 3.2.9 Type T-10, Mineral-Fiber Fill
- 3.2.10 Type T-17, Calcium Silicate Weatherproof Jacket

3.3 ACCEPTANCE

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-22 07 19.00 40 (February 2011)

Preparing Activity: NASA Superseding
UFGS-22 07 19 (May 2010)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated January 2012

SECTION 22 07 19.00 40

PLUMBING PIPING INSULATION 02/11

NOTE: This specification covers the requirements for field-applied insulation for hot and cold water and steam piping, exterior condensate piping including aboveground piping, piping on piers, piping under piers, piping in trenches on piers, piping in tunnels, and piping in manholes but does not cover cryogenic piping.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the

reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM A167	(2011) Standard Specification for Stainless and Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and Strip
ASTM A240/A240M	(2011a) Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications
ASTM B209	(2010) Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate
ASTM B209M	(2010) Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate (Metric)
ASTM C1136	(2010) Standard Specification for Flexible, Low Permeance Vapor Retarders for Thermal Insulation
ASTM C195	(2007) Standard Specification for Mineral Fiber Thermal Insulating Cement
ASTM C449	(2007) Standard Specification for Mineral Fiber Hydraulic-Setting Thermal Insulating and Finishing Cement
ASTM C533	(2011) Standard Specification for Calcium Silicate Block and Pipe Thermal Insulation
ASTM C534/C534M	(2008) Standard Specification for Preformed Flexible Elastomeric Cellular Thermal Insulation in Sheet and Tubular Form
ASTM C547	(2011) Standard Specification for Mineral Fiber Pipe Insulation
ASTM C552	(2007) Standard Specification for Cellular Glass Thermal Insulation
ASTM C553	(2011) Standard Specification for Mineral Fiber Blanket Thermal Insulation for

Commercial and Industrial Applications

ASTM C591	(2011) Standard Specification for Unfaced Preformed Rigid Cellular Polyisocyanurate Thermal Insulation
ASTM C592	(2010) Standard Specification for Mineral Fiber Blanket Insulation and Blanket-Type Pipe Insulation (Metal-Mesh Covered) (Industrial Type)
ASTM C795	(2008) Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel
ASTM C916	(1985; R 2007) Standard Specification for Adhesives for Duct Thermal Insulation
ASTM C920	(2011) Standard Specification for Elastomeric Joint Sealants
ASTM C921	(2010) Standard Practice for Determining the Properties of Jacketing Materials for Thermal Insulation
ASTM D226	(2009) Standard Specification for Asphalt-Saturated Organic Felt Used in Roofing and Waterproofing
ASTM D579	(2010) Standard Specification for Greige Woven Glass Fabrics
ASTM E84	(2011b) Standard Test Method for Surface Burning Characteristics of Building Materials
ASTM E96/E96M	(2010) Standard Test Methods for Water Vapor Transmission of Materials

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 220	(2012) Standard on Types of Building Construction
NFPA 255	(2006) Standard Method of Test of Surface Burning Characteristics of Building Materials

SOCIETY OF AUTOMOTIVE ENGINEERS INTERNATIONAL (SAE)

SAE AMS 3779	(1990; Rev A; R 1994) Tape Adhesive, Pressure Sensitive Thermal Radiation Resistant, Aluminum Foil/Glass Cloth
--------------	--

U.S. GENERAL SERVICES ADMINISTRATION (GSA)

FED-STD-595	(Rev C) Colors Used in Government Procurement
-------------	---

U.S. GREEN BUILDING COUNCIL (USGBC)

LEED

(2002; R 2005) Leadership in Energy and
Environmental Design(tm) Green Building
Rating System for New Construction
(LEED-NC)

1.2 SYSTEM DESCRIPTION

NOTE: If Section 23 00 00 AIR SUPPLY, DISTRIBUTION,
VENTILATION AND EXHAUST SYSTEMS is not included in
the project specification, applicable requirements
therefrom should be inserted and the following
paragraph deleted.

Section 23 00 00 AIR SUPPLY, DISTRIBUTION, VENTILATION AND EXHAUST SYSTEMS
applies to work specified in this section.

1.3 PERFORMANCE REQUIREMENTS

Provide noncombustible thermal-insulation system materials, as defined by
NFPA 220. Provide adhesives, coatings, sealants, facings, jackets, and
thermal-insulation materials, except cellular elastomers, with a
flame-spread classification (FSC) of [25 or less] [____], and a
smoke-developed classification (SDC) of [50 or less] [____]. Determine
these maximum values in accordance with [ASTM E84] [NFPA 255]. Provide
coatings and sealants that are nonflammable in their wet state.

Provide adhesives, coatings, and sealants with published or certified
temperature ratings suitable for the entire range of working temperatures
normal for the surfaces to which they are to be applied.

1.4 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions
in Section 01 33 00 SUBMITTAL PROCEDURES and edit
the following list to reflect only the submittals
required for the project.

The Guide Specification technical editors have
designated those items that require Government
approval, due to their complexity or criticality,
with a "G." Generally, other submittal items can be
reviewed by the Contractor's Quality Control
System. Only add a "G" to an item, if the submittal
is sufficiently important or complex in context of
the project.

For submittals requiring Government approval on Army
projects, a code of up to three characters within
the submittal tags may be used following the "G"
designation to indicate the approving authority.
Codes for Army projects using the Resident
Management System (RMS) are: "AE" for
Architect-Engineer; "DO" for District Office
(Engineering Division or other organization in the

District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Installation Drawings

SD-03 Product Data

Adhesives[; G][; G, [____]] [LEED]

Coatings[; G][; G, [____]] [LEED]

Insulating Cement

Insulation Materials[; G][; G, [____]] [LEED]

Jacketing

Tape

SD-07 Certificates

Recycled Materials

SD-08 Manufacturer's Instructions

Installation Manual

[1.5 RECYCLED MATERIALS

Provide thermal insulation containing recycled materials [LEED] to the extent practicable, provided that the material meets all other requirements of this section. The minimum recycled material content of the following insulation types are:

- a. Rock Wool - 75 percent slag by weight
- b. Fiberglass - 20-25 percent glass cullet by weight
- c. Plastic Rigid Foam - 9 percent recovered material
- d. Polyisocyanurate/Polyurethane - 9 percent recovered material
- e. Rigid Foam - 9 percent recovered material

Submit [recycled materials](#) documentation indicating percentage of post-industrial and post-consumer recycled content per unit of product. Indicate relative dollar value of recycled content products to total dollar value of products included in project.

]1.6 PRE-INSTALLATION REQUIREMENTS

Within [30] [_____] days of Contract Award, submit [installation drawings](#) for pipe insulation, conforming with the adhesive manufacturer's written instructions for installation. Submit [installation manual](#) clearly stating the manufacturer's instructions for insulation materials

PART 2 PRODUCTS

Submit manufacturer's catalog data for the following items:

- a. [Adhesives](#)
- b. [Coatings](#)
- c. [Insulating Cement](#)
- d. [Insulation Materials](#)
- e. [Jacketing](#)
- f. [Tape](#)

Provide compatible materials which do not contribute to corrosion, soften, or otherwise attack surfaces to which applied, in either the wet or dry state. Meet [ASTM C795](#) requirements for materials to be used on stainless steel surfaces. Provide materials that are asbestos free and conform to the following.

2.1 INSULATION MATERIALS

NOTE: Select the applicable types of insulating materials to be used in your project and delete those which are not applicable.

Provide materials with maximum value conductances as tested at any point, not an average. Replace or augment insulation conductance found by test to exceed the specified maximum by an additional thickness to bring it to the required maximum conductance and a complete finishing system.

[2.1.1 Mineral Fiber Insulation

Provide mineral fiber insulation conforming to [[ASTM C592](#)] [[ASTM C553](#)] [[ASTM C547](#)] and be suitable for surface temperatures up to 188 degrees C 370 degrees F, and not less than [_____] [[64.1 kilograms per cubic meter](#)] [[4-pound per cubic foot](#)] density with thermal conductivity not greater than [_____] [[0.037 watt per meter per degree Kelvin](#)] [[0.26 Btu per hour per square foot square per degree F](#)] at 66 degrees C 150 degrees F mean.

[Mineral fiber pipe wrap insulation having an insulating efficiency not less

than that of the specified thickness of fibrous glass pipe insulation may be provided in lieu of fibrous glass pipe insulation for pipe sizes 250 mm 10 inches and larger.

] [2.1.2 Cellular Elastomer Insulation

Provide cellular elastomer insulation conforming to ASTM C534/C534M, ensuring the water vapor permeability does not exceed [_____] [0.44] nanogram per second per pascal [_____] [0.30] perms per foot per inch per hour per square foot mercury pressure difference for 25 millimeter 1 inch thickness of cellular elastomer.

] [2.1.3 Cellular Glass Insulation

Conform to ASTM C552, Type II, Grade 2, pipe covering for Cellular Glass. Substitutions for this material are not permitted. Ensure minimum thickness is not less than 38 mm 1-1/2 inches.

] [2.1.4 Calcium Silicate Insulation

Conform to ASTM C533. Ensure the apparent thermal conductivity does not exceed [_____] [0.078] watt per meter per degree K [_____] [0.54] Btu-inch per hour per square foot per degree F [_____] at 93 degrees C 200 degrees F mean.

] [2.1.5 Fiberglass Insulation

Conform to ASTM C547. Ensure the apparent thermal conductivity does not exceed [_____] [0.078] watt per meter per degree K [_____] [0.54] Btu-inch per hour per square foot per degree F at 93 degrees C 200 degrees F mean.

Fiber glass pipe insulation having an insulating efficiency not less than that of the specified thickness of mineral fiber pipe insulation may be provided in lieu of mineral fiber pipe insulation for aboveground piping.

] [2.1.6 Polyisocyanurate Pipe Insulation

Conform to ASTM C591 for polyisocyanurate, minimum density of 27.20 kilograms per cubic meter (kg/cu m) 1.7 pcf.

] [2.1.7 Pipe Barrel

Pipe barrel insulation shall be Type II, Molded, Grade A or Type III, Precision V-Groove, Grade A for use at temperatures up to and including 650 degrees C 1200 degrees F.

] 2.1.8 Pipe Fittings

Provide molding pipe fitting insulation covering for use at temperatures up to and including 650 degrees C 1200 degrees F.

2.1.9 Flexible Blankets

Provide flexible blankets and felts for use at temperatures up to and including 177 degrees C 350 degrees F minimum 16 kilogram per cubic meter 1 pound per cubic foot density. Ensure thermal conductivity is no greater than [_____] [0.26] [_____] [0.038] watt per meter per degree K Btu per hour per square foot per degree F at 24 degrees C 75 degrees F mean.

2.2 ADHESIVES

2.2.1 Cloth Adhesives

Provide adhesives for adhering, sizing, and finishing lagging cloth, canvas, and open-weave glass cloth with a pigmented polyvinyl acetate emulsion conforming to the requirements of **ASTM C916**, Type I.

2.2.2 Vapor-Barrier Material Adhesives

Provide adhesives for attaching laps of vapor-barrier materials and presized glass cloth for attaching insulation to itself, to metal, and to various other substrates, of nonflammable solvent-base, synthetic-rubber type conforming to the requirements of **ASTM C916**, Type I, for attaching fibrous-glass insulation to metal surfaces.

2.2.3 Cellular Elastomer Insulation Adhesive

For cellular elastomer insulation adhesive, provide a solvent cutback chloroprene elastomer conforming to **ASTM C916**, Type I, and be of a type approved by the manufacturer of the cellular elastomer for the intended use.

2.3 INSULATING CEMENT

2.3.1 General Purpose Insulating Cement

Provide general purpose insulating cement, [diatomaceous silica] [mineral fiber], conforming to **ASTM C195**. Ensure composite is rated for **982 degrees C** **1800 degrees F** service, with a thermal-conductivity maximum of **[] [.123] [] [0.85] [] watt per meter per degree Kelvin** **[] Btu by inch per hour per square foot for each degree F** temperature differential at **93 degrees C** **200 degrees F** mean temperature for **25 millimeter 1 inch** thickness.

2.3.2 Finishing Insulating Cement

Provide finishing insulating cement of a mineral-fiber, hydraulic-setting type conforming to **ASTM C449**.

2.4 CALKING

Provide elastomeric joint sealant for calking specified insulation materials in accordance with **ASTM C920**, Type S, Grade NS, Class 25, Use A.

2.5 CORNER ANGLES

Provide nominal **0.41 millimeter 0.016 inch** aluminum **25 by 25 millimeter 1 by 1 inch** corner angle piping insulation with factory applied kraft backing. Ensure aluminum conforms to **ASTM B209M ASTM B209**, Alloy [3003] [3105] [5005].

2.6 JACKETING

NOTE: Select the following aluminum jackets for all weather exposed piping insulation, except system T-3. Stainless steel jackets should be considered for corrosive atmospheres. Aluminum or pvc should be specified for mechanical equipment rooms.

[2.6.1 Aluminum Jacket

NOTE: Use bracketed sentence for Naval Base Norfolk.

Provide aluminum jackets conforming to **ASTM B209M** **ASTM B209**, Temper H14, minimum thickness of **0.41 mm** **0.016 inch**, with factory-applied polyethylene and kraft paper moisture barrier on inside surface. Provide smooth surface jackets for jacket outside diameters less than **200 mm** **8 inches**. Provide corrugated surface jackets for jacket outside diameters **200 mm** **8 inches** and larger. Provide stainless steel bands, minimum width of **13 mm** **0.5 inch**. Provide factory prefabricated aluminum covers for insulation on fittings, valves, and flanges.[Provide aboveground jackets and bands with factory-applied baked-on semigloss brown color conforming to Federal Standard **FED-STD-595**, "Colors," color chip number 20062.]

] [2.6.2 Asphalt-Saturated Felt

Provide asphalt-saturated felt conforming to **ASTM D226**, without perforations, minimum weight of **0.49 kilograms per square meter** **10 pounds per 100 square feet**.

] [2.6.3 Stainless Steel Jacket

Provide stainless steel jackets conforming to **ASTM A167** or **ASTM A240/A240M**; Type 304, minimum thickness of **0.25 mm** **0.010 inch**, smooth surface with factory-applied polyethylene and kraft paper moisture barrier on inside surface. Provide stainless steel bands, minimum width of **13 mm** **0.5 inch**. Provide factory prefabricated stainless steel covers for insulation on fittings, valves, and flanges.

] [2.6.4 Glass Cloth Jacket

Provide plain-weave glass cloth conforming to **ASTM D579**, Style 141, weighing not less than **0.25 kilogram/square meter** [_____] [7.23] **ounces per square yard** before sizing. Factory apply cloth wherever possible.

Provide leno weave glass reinforcing cloth, 26-end and 12-pick thread conservation, with a warp and fill tensile strength of **7.9 and 5.3 kilonewton per meter** **45 and 30 pounds per inch** of width, respectively, and a weight of not less than [_____] **0.51 kilogram per square meter** [_____] [1.5] **ounces per square yard**. [At the Contractor's option, Style 191 leno-weave glass cloth conforming to **ASTM D579** may be provided.]

] [2.6.5 PVC Jacket

Provide **0.25 millimeter** **0.010 inch** thick, factory-premolded, [one-piece fitting] [pipe-barrel sheeting vapor-barrier jacketing] polyvinylchloride that is self-extinguishing, high-impact strength, moderate chemical resistance with a permeability rating of **0.574 nanogram per pascal per second per square meter** **0.01 grain per hour per square foot per inch** of mercury pressure difference, determined in accordance with **ASTM E96/E96M**. Provide manufacturer's standard solvent-weld type vapor-barrier joint adhesive.

Conform to **ASTM C1136** for, Type I, low-vapor transmission, high-puncture

resistance vapor barrier for use on insulation for piping, ducts, and equipment.

] 2.7 COATINGS

[2.7.1 Outdoor Vapor-Barrier Finishing

For coatings for outdoor vapor-barrier finishing of insulation surfaces, such as fittings and elbows, provide a nonasphaltic, hydrocarbon polymer, solvent-base mastic containing a blend of nonflammable solvents. Conform to the requirements of [ASTM C1136](#) and [ASTM C921](#) for coatings.

] [2.7.2 Indoor Vapor-Barrier Finishing

Provide pigmented resin and solvent compound coatings for indoor vapor-barrier finishing of insulation surfaces conforming to [ASTM C1136](#), Type II.

] [2.7.3 Outdoor and Indoor Nonvapor-Barrier Finishing (NBF)

Provide pigmented polymer-emulsion type NBF recommended by the insulation material manufacturer for outdoor and indoor NBF coating of insulation surfaces for the surface to be coated and applied to specified dry-film thickness.

] 2.7.4 Cellular-Elastomer Insulation Coating

Provide a polyvinylchloride lacquer approved by the manufacturer of the cellular elastomer finish coating.

2.7.5 Coating Color

[Provide white] [Conform to the color code specified] [Blend with background of surrounding area] [Provide as specified by the Contracting Officer] for the coating color.

2.8 TAPE

Provide a knitted elastic cloth glass lagging specifically suitable for continuous spiral wrapping of insulated pipe bends and fittings and produce a smooth, tight, wrinkle-free surface. Conform to requirements of [SAE AMS 3779](#), [SAE AMS 3779](#), [ASTM D579](#), and [ASTM C921](#) for tape, weighing not less than [_____] [0.339] kilogram per square meter [_____] [10] ounces per square yard.

[2.9 DUAL-TEMPERATURE (HOT- AND CHILLED-) WATER PIPING

Provide [mineral fiber with vapor barrier jacket, Type T-1] [cellular class with vapor barrier jacket, Type T-4] insulation, with a thickness of not less than [_____] . Insulate aboveground pipes, valve bodies, fittings, unions, and flanges.

] [2.10 HOT-WATER, STEAM, AND CONDENSATE-RETURN PIPING

Provide mineral fiber insulation with glass cloth jacket, Type T-2, with a thickness of not less than [_____] . Insulate aboveground pipes, valve bodies, fittings, unions, flanges, and miscellaneous surfaces.

] [2.11 COLD-WATER AND CONDENSATE-DRAIN PIPING

Insulate aboveground pipes, valve bodies, fittings, unions, flanges, and miscellaneous surfaces.

[Provide 10 millimeter 3/8 inch mineral fiber insulation with glass cloth jacket, Type T-2, with a thickness of not less than [____].

] [Provide cellular-elastomer insulation conforming to ASTM C534/C534M, with water-vapor permeability not exceeding 5.74 nanograms per pascal per second per square meter 0.1 grain per square foot per hour per inch mercury pressure-differential for 25 millimeter 1 inch thickness.

] [Provide flexible unicellular-elastomeric thermal insulation for cold water piping, Type T-3, with a thickness of [10][15] millimeter [3/8][1/2] inch per calculation. Use expanded, closed-cell pipe insulation only aboveground, not for underground piping.

] [2.12 REFRIGERANT SUCTION PIPING

Provide cellular-elastomer insulation, Type T-3, with a nominal thickness of 20 millimeter 3/4 inch. Insulate surfaces, including valve, fittings, unions, and flanges.

] [2.13 COOLING-TOWER CIRCULATING WATER PIPING

NOTE: Normally, cooling-tower circulating water piping will not require insulation.

Provide cellular-elastomer insulation, Type T-3, with a thickness of not less than [____]. Insulate aboveground pipes, valve bodies, fittings, unions, flanges, and miscellaneous surfaces.

NOTE: Type T-6 is normally specified for exterior use.

Provide mineral fiber insulation with aluminum jacket, Type T-6, with a thickness of not less than [____]. Insulate aboveground pipes, valve bodies, fittings, unions, flanges, and miscellaneous surfaces.

] [2.14 STEAM AND CONDENSATE PIPING, 2.4 MEGAPASCAL 350 PSIG

Provide calcium silicate insulation with glass cloth jacket, Type T-5, with a thickness of not less than [____] which is based on an 27 degrees C 80 degrees F ambient temperature in still air with an insulation "K" factor of 0.37 at 93 degrees C 200 degrees F mean temperature:

] [2.15 HOT WATER HEATING CONVERTER

Provide calcium silicate insulation with glass cloth jacket, Type T-7, with a thickness of 40 millimeter 1-1/2 inches.

] [2.16 CHILLED-WATER AND DUAL-TEMPERATURE PUMPS

Provide cellular elastomer insulation, Type T-9, with a thickness of 25

millimeter 1 inch. Cover surfaces subject to condensation, and provide a vapor-barrier coating.

] [2.17 LOW-PRESSURE STEAM AND CONDENSATE, WEATHER-EXPOSED

Provide calcium silicate insulation with weatherproof jacket, Type T-17, with a thickness of not less than [____]. Insulate all systems.

] [2.18 STEAM & CONDENSATE, WEATHER-EXPOSED, 861 KILOPASCAL 125 PSIG

Provide calcium silicate insulation with weatherproof jacket, Type T-17, with a thickness not less than [____]. Insulate all system surfaces.

] [2.19 STEAM & CONDENSATE, WEATHER-EXPOSED, 2.4 MEGAPASCAL 350 PSIG

Provide calcium silicate insulation with weatherproof jacket, Type T-17, with a thickness not less than [____]. Insulate all system surfaces.

] PART 3 EXECUTION

3.1 INSTALLATION OF INSULATION SYSTEMS

Install smooth and continuous contours on exposed work. Smoothly and securely paste down cemented laps, flaps, bands, and tapes. Apply adhesives on a full-coverage basis.

Apply insulation only to system or component surfaces that have been tested and approved.

Install insulation lengths tightly butted against each other at joints. Where lengths are cut, provide smooth and square and without breakage of end surfaces. Where insulation terminates, neatly taper and effectively seal ends, or finish as specified. Direct longitudinal seams of exposed insulation away from normal view.

Apply materials in conformance with the recommendations of the manufacturer.

Clean surfaces free of oil and grease before insulation adhesives or mastics are applied. Provide solvent cleaning required to bring metal surfaces to such condition.

Submit installation drawings for pipe insulation, conforming with the adhesive manufacturer's written instructions for installation. Submit installation manual clearly stating the manufacturer's instructions for insulation materials.

3.2 SYSTEM TYPES

[3.2.1 Type T-1, Mineral Fiber with Vapor-Barrier Jacket

Cover piping with mineral-fiber pipe insulation with factory-and field-attached vapor-barrier jacket. Maintain vapor seal. Securely cement jackets, jacket laps, flaps, and bands in place with vapor-barrier adhesive. Provide jacket overlaps not less than [____] [40] millimeter [____] [1-1/2] inches and jacketing bands for butt joints 75 millimeter 3 inches wide.

Cover exposed-to-view fittings and valve bodies with preformed mineral-fiber pipe-fitting insulation of the same thickness as the

pipe-barrel insulation. Temporarily secure fitting insulation in place with light cord ties. Apply a 1.52 millimeter 60-mil coating of white indoor vapor-barrier coating and, while still wet, wrap with glass lagging tape with 50 percent overlap, and smoothly blend into the adjacent jacketing. Apply additional coating as needed and rubber-gloved to smooth fillet or contour coating, then allowed to fully cure before the finish coating is applied. On-the-job fabricated insulation for concealed fittings and special configurations, build up from mineral fiber and a special mastic consisting of a mixture of insulating cement and lagging adhesive diluted with 3 parts water. Where standard vapor-barrier jacketing cannot be used, make the surfaces vapor tight by using coating and glass lagging cloth or tape as previously specified.

In lieu of materials and methods previously specified, fittings may be wrapped with a twine-secured, mineral-wool blanket to the required thickness and covered with premolded polyvinylchloride jackets. Make seams vapor tight with a double bead of manufacturer's standard vapor-barrier adhesive applied in accordance with the manufacturer's instructions. Hold all jacket ends in place with AISI 300 series corrosion-resistant steel straps, [] [0.381] millimeter [] [15] mils thick by [] [15] millimeter [] [1/2] inch wide.

Set pipe insulation into an outdoor vapor-barrier coating for a minimum of [] [150] millimeter [] [6] inches at maximum [] [3500]-millimeter [] [12]-foot spacing and the ends of the insulation sealed to the jacketing with the same material to provide an effective vapor-barrier stop.

Do not use staples in applying insulation. Install continuous vapor-barrier materials over all surfaces, including areas inside pipe sleeves, hangers, and other concealments.

Provide piping insulation at hangers consisting of 208 kilogram per cubic meter 13-pounds per cubic foot density, fibrous-glass inserts or expanded, rigid, closed-cell, polyvinylchloride. Seal junctions with vapor-barrier jacket where required, glass-cloth mesh tape, and vapor-barrier coating.

Expose white-bleached kraft paper side of the jacketing to view.

Finish exposed-to-view insulation with not less than a [0.152]-millimeter [6]-mil [] dry-film thickness of nonvapor-barrier coating suitable for painting.

] [3.2.2 Type T-2, Mineral Fiber with Glass Cloth Jacket

Cover piping with a mineral-fiber, pipe insulation with factory-attached, presized, white, glass cloth. Securely cement jackets, jacket laps, flaps, and bands in place with vapor-barrier adhesive with jacket overlap not less than 40 millimeter 1-1/2 inches and jacketing bands for butt joints 75 millimeter 3 inches wide.

Cover exposed-to-view fittings with preformed mineral-fiber fitting insulation of the same thickness as the pipe insulation and temporarily secured in place with light cord ties. Install impregnated glass lagging tape with indoor vapor-barrier on 50 percent overlap basis and the blend tape smoothly into the adjacent jacketing. Apply additional coating as needed, and rubber gloved to a smooth contour. Tape ends of insulation to the pipe at valves DN50 2 inches and smaller. Build up on-the-job fabricated insulation for concealed fittings and special configurations

from mineral fiber and a mixture of insulating cement and lagging adhesive, diluted with 3 parts water. Finish surfaces with glass cloth or tape lagging.

[Cover all valves 65 millimeter 2-1/2 inches and larger and all flanges with preformed insulation of the same thickness as the adjacent insulation.

] [Finish exposed-to-view insulation with a minimum [_____] [0.152] -millimeter [_____] [6] -mil dry-film thickness of nonvapor-barrier coating suitable for painting.

] [In lieu of materials and methods specified above, fittings may be wrapped with a twine-secured, mineral-wool blanket to the required thickness and covered with premolded polyvinylchloride jackets. Hold all jacket ends in place with AISI 300 series corrosion-resistant steel straps, [_____] [0.381] millimeter [_____] [15] mils thick by 15 millimeter [_____] [1/2] inch [_____] wide. Provide fitting insulation, thermally equivalent to pipe-barrel insulation to preclude surface temperatures detrimental to polyvinylchloride.

]] [3.2.3 Type T-3, Cellular Elastomer

Cover piping-system surfaces with flexible cellular-elastomer sheet or preformed insulation. Maintain vapor seal. Cement insulation into continuous material with a solvent cutback chloroprene adhesive recommended by the manufacturer for the specific purpose. Apply adhesive to both of the surfaces on a 100-percent coverage basis to a minimum thickness of 0.254 millimeter 10 mils wet or approximately 4 square meter per liter 150 square feet per gallon of undiluted adhesive.

Seal insulation on cold water piping to the pipe for a minimum of 150 millimeter [6] inches at maximum intervals of 3500 millimeter 12 feet to form an effective vapor barrier. At piping supports, ensure insulation is continuous through using outside-carrying type clevis hangers with insulation shield. Install [Cork] [Wood dowel] load-bearing inserts between the pipe and insulation shields to prevent insulation compression.

Insulate hot-water, cold-water, and condensate drain pipes to the extent shown with nominal [10] [15] millimeter [3/8] [1/2] inch thick, fire retardant (FR), cellular elastomer, preformed pipe insulation. Seal joints with adhesive.

At pipe hangers or supports where the insulation rests on the pipe hanger strap, cut the insulation with a brass cork borer and a [No. 3] [_____] superior grade cork inserted. Seal seams with approved adhesive. Insulate sweat fitting with miter-cut pieces of cellular elastomer insulation of the same nominal pipe size and thickness as the insulation on the adjacent piping or tubing. Joint miter-cut pieces with approved adhesive. Slit and snap covers over the fitting, and seal joints with approved adhesive.

Insulate screwed fittings with sleeve-type covers formed from miter-cut pieces of cellular elastomer thermal insulation having an inside diameter large enough to overlap adjacent pipe insulation. Butt pipe insulation against fittings, and overlap not less than [_____] [25] millimeter [_____] [1] inch. Use adhesive to join cover pieces and cement the cover to the pipe insulation.

Finish surfaces exposed to view or ultraviolet light with a [_____] [0.051] millimeter [_____] [2] -mil minimum dry-film thickness application of a

polyvinylchloride lacquer recommended by the manufacturer, and applied in not less than [two] [_____] coats.

] [3.2.4 Type T-4, Cellular Glass with Vapor-Barrier Jacket

Cover piping with cellular glass insulation and factory- and field-attached vapor-barrier jacket. Maintain vapor seal. Securely cement jackets, jacket laps, flaps, and bands in place with vapor-barrier adhesive, and overlap jacket not less than [_____] [40] millimeter [_____] [1-1/2] inches. Provide jacket bands for butt joints of not less than [_____] [75] millimeter [_____] [3] inches width. Provide insulation continuous through hangers. Bed insulation in an outdoor vapor-barrier coating applied to all piping surfaces.

Insulate flanges, unions, valves, anchors, and fittings with factory premolded or prefabricated or field fabricated segments of insulation of the same material and thickness as the adjoining pipe insulation. When segments of insulation are used, provide elbows with not less than three segments. For other fittings and valves, cut segments to the required curvature or nesting size.

Secure segments of the insulation in place with twine or copper wire. After the insulation segments are firmly in place, apply a vapor-barrier coating over the insulation in two coats with glass tape imbedded between coats. First coat, tinted, the second, white to ensure application of two coats. Apply coating to a total dry-film thickness of 1.6 millimeter 1/16 inch minimum. Overlap glass tape seams not less than [_____] [25] millimeter [_____] [1] inch and the tape end not less than [_____] [100] millimeter [_____] [4] inches.

In lieu of materials and methods specified above, fittings may be wrapped with 10 millimeter 3/8 inch thick, vapor-barrier, adhesive-coated strips of cellular elastomer insulation. Insulation shall be under tension, compressed to 25 percent of original thickness, and wrapped until overall thickness is equal to adjacent insulation. Secure cellular elastomer in place with twine and sealed with vapor-barrier coating applied to produce not less than [_____] [1.6] millimeter [_____] [1/16] inch dry-film thickness. Cover fittings with premolded polyvinylchloride jackets. Make seams vapor-tight with a double bead of manufacturer's standard vapor-barrier adhesive applied in accordance with the manufacturer's instructions. Hold jacket ends in place with AISI 300 series corrosion-resistant steel straps, [_____] [0.381] millimeter [_____] [15] mils thick by [_____] [15] millimeter [_____] [1/2] inch wide.

Insulate anchors secured directly to piping, to prevent condensation, for not less than [_____] [150] millimeter [_____] [6] inches from the surface of the pipe insulation.

Install white-bleached kraft paper side of jacket exposed to view. Finish exposed-to-view insulation with not less than a [_____] [0.152] millimeter [_____] [6]-mil dry-film thickness of nonvapor-barrier coating suitable for painting.

] [3.2.5 Type T-5, Calcium Silicate with Glass Cloth Jacket (Piping)

Cover piping with a calcium-silicate pipe insulation with factory attached and presized, white, glass cloth. Field apply jackets when required. Securely cement jackets, jacket laps, flaps, and bands in place with vapor-barrier adhesive. Jacket overlap shall be not less than [_____] [40]

millimeter [_____] [1-1/2] inches. Jacketing bands for butt joints shall be 100 millimeter 4-inches wide. Fabricate fittings from segmented pipe barrel sections bedded in general purpose insulating cement and wired in place. Fill voids with general purpose insulating cement with not less than [_____] [6] millimeter [_____] [1/4] inch thick, final coating. Impregnate glass lagging tape with lagging adhesive, wrapped with a 50-percent overlap, and be blended smoothly into adjacent jacketing. Apply additional adhesive as needed and rubber-gloved to a smooth contour.

] [3.2.6 Type T-6, Mineral Fiber with Aluminum Jacket

Cover piping with mineral-fiber pipe insulation with factory-attached or field-applied aluminum jacketing.

Cover fittings and valve bodies with preformed mineral-fiber pipe-fitting insulation of the same thickness as the pipe-barrel insulation. Temporarily secure fitting insulation in place with light cord ties. Apply a 1.52 millimeter 60-mil coating of vapor-barrier mastic, and while still tacky, wrapped with glass lagging tape.

Apply additional mastic as needed and rubber-gloved to smooth fillets or contours. Build up on-the-job fabricated insulation for special configurations from mineral fiber and a mixture of insulating cement and lagging adhesive diluted with 3 parts water. Only where standard aluminum jacketing cannot be used, make the surfaces vapor-tight by using mastic and glass lagging cloth or tape as specified above with an added finish coat of mastic.

Set pipe insulation into outdoor vapor-barrier coating for a minimum of [_____] [150] millimeter [_____] [6] inches at maximum [_____] [3500] millimeter [_____] [12]-foot spacing. Seal ends of the insulation to the jacketing with the same material to provide effective vapor barrier stops.

Install continuous vapor barrier over all surfaces, including areas inside pipe sleeves, hangers, and other concealment.

Apply piping insulation to both sides of pipe hangers. Insulate junctions with a special mastic mixture, glass cloth mesh tape, and mastic as previously specified.

Securely cement jacket laps, flaps, and bands in place with aluminum jacket sealant. Provide 150 millimeter 6 inch wide minimum jacketing bands for butt joints.

Lap joints, wherever possible, against the weather so that the water will run off the lower edge and in accordance with the pipe drainage pitch. Locate longitudinal laps on horizontal lines 45 degrees below the horizontal centerline and alternately staggered 25 millimeter 1 inch. Lap jacketing material a minimum of [_____] [50] millimeter [_____] [2] inches, circumferentially sealed with mastic, and strapped to provide a waterproof covering throughout. Locate straps 200 millimeter 8 inches on center and pull up tight to hold jacketing securely in place. Use screws in addition to straps when necessary to obtain a waterproof covering. Place extra straps on each side of supporting devices and at openings. Where flanging access occurs, strap a chamfer sheet to the pipe at jacketing.

Stiffen exposed longitudinal edges of aluminum jacketing by bending a 25 millimeter 1 inch hem on one edge.

Provide expansion joints for maximum and minimum dimensional fluctuations.

To prevent corrosion, do not allow the aluminum jacketing to come in direct contact with other types of metal.

At openings in jacket, apply an outdoor vapor-barrier coating for [_____] [50] millimeter [_____] [2] inches in all directions. Apply jacketing while waterproofing is tacky.

Use screws at each corner of each sheet, at fitting jackets, and as necessary for the service. Place number 7, 10 millimeter 3/8 inch long, binding-head aluminum sheet metal screws through the mastic seal.

] [3.2.7 Type T-7, Calcium Silicate with Glass Cloth Jacket (Surfaces)

Cover surfaces with insulation block bedded in an insulating cement and covered with glass cloth jacketing.

Clean surfaces with a chlorinated solvent. Mix general purpose insulating cement with 3 parts water to 1 part nonvapor-barrier adhesive to bring to application consistency. Set block into bedding and joints and fill spaces with a bedding mix and wrap with galvanized chicken wire mesh well laced into an envelope. Trowel a 10 millimeter 3/8 inch thick coating of bedding mix jacket on with nonvapor-barrier adhesive and glass cloth. Finish surfaces with not less than a [_____] [0.152] millimeter [_____] [6]-mil dry-film thickness of nonvapor-barrier coating.

[At the Contractor's option, aluminum sheet jacketing may be used in lieu of glass cloth.]

] [3.2.8 Type T-9, Cellular Elastomer

Clean pump surfaces with solvent. Apply not less than 25 millimeter [_____] [1] inch of general purpose insulating cement, mixed with nonvapor-barrier adhesive diluted with 3 parts water, to achieve smooth surface and configuration contours. After all water has been removed, cover surfaces with 13 millimeter 1/2 inch thick cellular elastomer insulation attached and joined into a continuous sheet with an outdoor vapor-barrier coating recommended by the insulation manufacturer for the specific purpose. Apply coating to both of the surfaces on a 100-percent coverage basis with a minimum thickness of [_____] [0.254] millimeter [_____] [10] mils wet, or approximately 3.7 square meter per liter 150 square feet per gallon of undiluted coating. Blend coating into the adjacent flange insulation and the joint covered with a band of cellular elastomer equal to the flange assembly width. Use same coating to seal insulation to the casing at penetrations and terminations. Insulate pumps in a manner that permits insulation to be removed to repair or replace pumps.

Finish insulation with a [_____] [0.051] millimeter [_____] [2]-mil minimum dry-film application of a polyvinylchloride lacquer coating recommended by the manufacturer and applied in not less than [two] [_____] coats.

] [3.2.9 Type T-10, Mineral-Fiber Fill

Pack voids surrounding pipe with mineral-fiber fill.

NOTE: Insulation system Type T-17 may be used as is

written for drained shallow trenches or by
modification to eliminate all thermoplastic
references and requiring only standard aluminum
jackets.

] 3.2.10 Type T-17, Calcium Silicate Weatherproof Jacket

Cover piping system surfaces with calcium silicate insulation. Cover fittings and valve bodies with preformed insulation of the same material and thickness as the adjoining pipe insulation.

] 3.3 ACCEPTANCE

NOTE: Following a minimum of 90 calendar days operation (or installation), but no later than one year, the Systems Engineer/Condition Monitoring Office/Predictive Testing Group should inspect the installation using Infrared Imaging. This technology can identify insulation voids, insulation settling, and areas of insufficient insulation. Identification of insulation materials and locations is required to effectively identify these types of problems. The Systems Engineer/Condition Monitoring Office/Predictive Testing Group needs to know the warranty expiration date, if there is a warranty, in order to perform the inspections within the prescribed time frame.

Final acceptance is dependent upon providing construction (Record Drawings) details to the Contracting Officer. Include construction details, by building area, the insulation material type, amount, and installation method. An illustration or map of the duct routing locations may serve this purpose. With data, provide a cover letter/sheet clearly marked with the system name, date, and the words "Record Drawings insulation/material." Forward to the Systems Engineer/Condition Monitoring Office/Predictive Testing Group for inclusion in the Maintenance Database."

-- End of Section --