

\*\*\*\*\*  
USACE / NAVFAC / AFCEC / NASA UFGS-26 56 19.00 40 (May 2013)  
-----  
Preparing Activity: NASA Superseding  
UFGS-26 56 19.00 40 (November 2008)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UML dated January 2014

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 26 - ELECTRICAL

#### SECTION 26 56 19.00 40

#### ROADWAY LIGHTING

05/13

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 ADMINISTRATIVE REQUIREMENTS

#### PART 2 PRODUCTS

- 2.1 SYSTEM DESCRIPTION
- 2.2 STREET-LIGHTING LUMINAIRES
  - 2.2.1 Roadway Luminaire Components
  - 2.2.2 End-Mounted High-Intensity-Discharge (HID) Luminaires
  - 2.2.3 Side-Mounted (HID) Luminaires
  - 2.2.4 Lamp Ballasts
    - 2.2.4.1 Multiple-Circuit Ballasts
    - 2.2.4.2 Series Circuit Transformers
  - 2.2.5 Lamps
    - 2.2.5.1 (HID) Lamps and Ballasts
    - 2.2.5.2 Low Pressure Sodium
  - 2.2.6 Side-Mounted Incandescent Luminaires
  - 2.2.7 Incandescent Lamps

#### PART 3 EXECUTION

- 3.1 INSTALLATION
  - 3.1.1 End-Mounted High-Intensity-Discharge (HID) Luminaires
  - 3.1.2 Side-Mounted (HID) Luminaires
  - 3.1.3 Side-Mounted Incandescent Luminaires
- 3.2 FIELD TESTING

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEC / NASA UFGS-26 56 19.00 40 (May 2013)  
-----  
Preparing Activity: NASA Superseding  
UFGS-26 56 19.00 40 (November 2008)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated January 2014

\*\*\*\*\*

### SECTION 26 56 19.00 40

#### ROADWAY LIGHTING

05/13

\*\*\*\*\*

NOTE: This guide specification covers the requirements for highway and roadway lighting luminaires.

Drawings should show details of each street lighting fixture with letter designation keyed to the drawings and electrical symbols describing the type, style, class, kind, and size of fixture as follows:

Roadway lighting fixtures including luminaires for IES as listed in IES RP-8, "Lighting Distribution Patterns."

Coordinate this section with UFGS Section  
26 09 23.00 40 LIGHTING CONTROL DEVICES and UFGS  
Section 26 56 13.00 40 LIGHTING POLES AND STANDARDS.

Roadway-lighting standards and fixture details on drawings should describe, in plan and elevation, the type and kind of pole, bracket, luminaire, base, and foundation required for installation at the location indicated. Elevation details should indicate height of pole, bracket-spread length, luminaire, depth of foundation, anchor bolts, underground conduit connections, ground rods, and ground connections. Plan views should indicate foundation configuration, conduit stub-ups, base dimensions, and bolt circles. Foundation detail drawings should accurately describe the nature and properties of soil surrounding foundations for the support of lighting standards.

Foundations for installation of area, flood lighting, roadway lighting, and security lighting standards and fixtures in filled locations may require modification to resist horizontal movement without permanent set under stipulated wind loads.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project

specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

\*\*\*\*\*

\*\*\*\*\*

NOTE: TO DOWNLOAD UFGS GRAPHICS

Go to <http://www.wbdg.org/ccb/NAVGRAPH/graphdoc.pdf>.

\*\*\*\*\*

\*\*\*\*\*

NOTE: This section contains the following sketches (Graphics) and are available in metric (SI) and U.S. Customary (IP) system dimensions. Sketch titles and style numbers are unchanged for both types. The metric values indicated are a conversion of U.S. Customary (IP) system dimensions.

Do not include list of sketches, or sketches themselves, in project specifications. Use luminaire sketches as details on drawings whenever possible. If special features are required, do not modify sketches, but indicate these changes as notes in fixture schedule. The "XL" style numbers and dates should remain on the drawing details.

<u>Sketch No.</u>	<u>Title</u>
XL-1	Roadway and Area Light
XL-4	Roadway and Area Light
XL-6	Area and Street Lighting Cutoff Luminaire
XL-13 thru 19	Reserved for Future Exterior Luminaires

NOTE: Do not include this index in project specification.

\*\*\*\*\*

\*\*\*\*\*

NOTE: Show the following information on the drawings or specify in the project specifications:

a. Luminaire schedule and indicate pertinent information; i.e., mounting, lamps, ballasts, and voltage.

1. Type of luminaire;

2. Voltage, wattage, and frequency rating required;

3. Accessories required, such as photocell, time switches, and auxiliary lamps;
4. Location of poles or standards;
5. Referenced sketch; and
6. Extent and location of the work to be accomplished and wiring and equipment necessary for a complete installation.

\*\*\*\*\*

\*\*\*\*\*

NOTE: Demolition work that involves disposal of fluorescent and HID lamps and ballasts requires the use of Section 02 84 16 HANDLING OF LIGHTING BALLASTS AND LAMPS CONTAINING PCBs AND MERCURY.

\*\*\*\*\*

## PART 1 GENERAL

\*\*\*\*\*

NOTE: If Section 26 00 00.00 20 BASIC ELECTRICAL MATERIALS AND METHODS is not included in the project specification, applicable requirements there from should be inserted and the following paragraph deleted.

\*\*\*\*\*

Section 26 00 00.00 20 BASIC ELECTRICAL MATERIALS AND METHODS applies to work specified in this section.

### 1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ILLUMINATING ENGINEERING SOCIETY OF NORTH AMERICA (IES)

IES RP-8 (2000; Errata 2004; R 2005; Errata 2007)  
Roadway Lighting

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

ANSI ANSLG C78.42 (2009) For Electric Lamps: High-Pressure  
Sodium Lamps

ANSI C136.11 (2006) American Standard for Roadway  
Lighting Equipment Series Sockets and  
Series Sockets Receptacles

ANSI C136.15 (2011) American National Standard for  
Roadway Lighting Equipment -  
High-Intensity-Discharge and Low-Pressure  
Sodium Lamps in Luminaires - Field  
Identification

ANSI C136.2 (2004; R 2009) American National Standard  
for Roadway and Area Lighting Equipment:  
Luminaires Voltage Classification

ANSI C136.3 (2005; R 2009) American National Standard  
for Roadway and Area Lighting Equipment  
Luminaire Attachments

ANSI C136.6 (2004) American National Standard for  
Roadway Lighting Equipment - Metal Heads  
and Reflector Assemblies - Mechanical and  
Optical Interchangeability

ANSI C136.9 (2003) American National Standard for  
Roadway and Area Lighting Equipment -  
Socket Support Assemblies for Metal Heads  
- Mechanical Interchangeability

ANSI C82.4 (2002) American National Standard for  
Ballasts for High-Intensity-Discharge and  
Low-Pressure Sodium (LPS) Lamps  
(Multiple-Supply Type)

NEMA ANSLG C82.9 (2010) American National Standard for Lamp  
Ballasts- High-Intensity Discharge and  
Low-Pressure Sodium Lamps- Definitions

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

21 CFR 1040 Performance Standards for Light-Emitting  
Products

1.2 SUBMITTALS

\*\*\*\*\*

**NOTE: Review Submittal Description (SD) definitions  
in Section 01 33 00 SUBMITTAL PROCEDURES and edit  
the following list to reflect only the submittals  
required for the project. Keep submittals to the**

minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

#### SD-01 Preconstruction Submittals

Material, Equipment, and Fixture Lists.

Equipment and Performance Data

#### SD-02 Shop Drawings

Street-Lighting Luminaires

Installation Drawings

#### SD-03 Product Data

Street-Lighting Fixtures

Street-Lighting Luminaires

#### SD-06 Test Reports

Operational Tests

#### SD-07 Certificates

## Lighting-Distribution Certificates

### 1.3 ADMINISTRATIVE REQUIREMENTS

Submit the following information at the Preconstruction Meeting:

- a. **Material, Equipment, and Fixture Lists** for highway and roadway lighting fixtures including manufacturer's style or catalog numbers, specification and drawing reference numbers, warranty information, and fabrication site information
- b. **Equipment and Performance Data** for highway and roadway lighting systems consisting of life test, system functional flows, safety features, mechanical automated details, automatic interlocks, and such features as electrical system protective device ratings
- c. **Lighting-distribution Certificates** showing compliance with the following requirement: lighting-distribution curves for each type of fixture prepared, utilizing the fixture manufacturer's own facilities or those of an independent nationally recognized laboratory, in accordance with the standard procedure developed by the Illuminating Engineering Society.

### PART 2 PRODUCTS

\*\*\*\*\*  
**NOTE: Revise as necessary to meet project requirements.**  
\*\*\*\*\*

#### 2.1 SYSTEM DESCRIPTION

Provide **street-lighting fixtures**, equipped with lamps. Furnish fixtures complete with wiring and mounting devices ready for installation at the locations indicated.

Submit **Installation Drawings** for the highway and roadway lighting systems. Indicate on drawings overall physical features, dimensions, ratings, service requirements, and weight of equipment.

#### 2.2 STREET-LIGHTING LUMINAIRES

Provide enclosed and gasketed vaportight street-lighting luminaires in accordance with **IES RP-8** for Types I, II, III, IV, and V lighting-distribution patterns.

\*\*\*\*\*  
**NOTE: Select street-lighting luminaires, ballasts, and lamps from the following parts to suit project requirements.**

**Factors affecting the selection of luminaire types include the following:**

**Fixture efficiency is the percent of available lumens from the light source that emits from the fixture. The most efficient fixture should be selected commensurate with the other design**

requirements.

The spacing to mounting height ratio (S/MH) indicates how far apart the fixtures can be placed in relation to their mounting height. This ratio should be available in the fixture manufacturer's literature. A medium-to-wide distribution of light from the fixture should be selected. Fewer fixtures are required using the larger, more efficient light sources. Overlapping light patterns provide greater uniformity of illumination and increase light on vertical surfaces.

High power factor ballasts should be selected.

\*\*\*\*\*

#### 2.2.1 Roadway Luminaire Components

Provide roadway luminaire components conforming to the following standards:

- a. Attachments, ANSI C136.3
- b. Voltage classification, ANSI C136.2
- c. Field identification marking, ANSI C136.15
- d. Interchangeability, ANSI C136.6 and ANSI C136.9
- e. Sockets, ANSI C136.11

#### 2.2.2 End-Mounted High-Intensity-Discharge (HID) Luminaires

Provide end-mounted HID luminaires with a horizontal lamp-burning position. Include with the luminaire; a hinged two- or three-piece housing, reflector, refractor, refractor holding ring, lampholder, fuses, fuseholders, terminal block, ballast, and lamp in a completely sealed optical system for end-mounting to street-lighting standards. Ensure wiring is concealed in street-lighting standards and luminaires.

Provide with cast aluminum upper housing with fixture-leveling pad, integral slip fitter, pipe stop, and clamps with provision for vertical adjustments of plus or minus 3 degrees for leveling purposes.

Provide a reflector formed from anodized sheet aluminum with a specular finish. Provide molded prismatic heat-resistant borosilicate glass refractor. Ensure the design generates the lighting-distribution pattern indicated. Ensure the refractor cover allows for expansion and contraction of the refractor for ambient temperature changes between 0 to 105 degrees F.

Provide a cast aluminum refractor holding ring and ballast cover which forms the lower housing. Equip lower housing with corrosion-resistant steel hinge and hinge pin, spring-loaded safety catch, and refractor latching mechanism.

#### 2.2.3 Side-Mounted (HID) Luminaires

Provide side-mounted (HID) luminaires with base-up vertical lamp-burning position. Include a universal head with built-in ballast, lamp, porcelain lampholder, and reflector assembly in a completely sealed optical system



for bracket mounting to street-lighting standards. Conceal wiring in street-lighting standards and luminaires.

Provide cast aluminum universal head with integral side-mounting slip fitter, pipe stop, and clamps with provisions for vertical adjustments of plus or minus 3 degrees for leveling purposes.

Include in reflector assembly a reflector, refractor, and clamping band. Form reflector from anodized sheet aluminum with a specular finish. Include molded prismatic heat-resistant borosilicate glass refractor designed to provide the lighting-distribution pattern indicated. Provide clamping band formed from sheet aluminum or corrosion-resistant steel.

Provide a complete assembly which latches the reflector directly to the universal head with aluminum or corrosion-resistant steel latches. Include a seating flange to provide a seal against moisture, dirt, and insects.

#### 2.2.4 Lamp Ballasts

##### 2.2.4.1 Multiple-Circuit Ballasts

\*\*\*\*\*  
**NOTE: Select solid-state ballasts, if available and most efficient.**  
\*\*\*\*\*

Multiple-circuit ballasts include a two-winding core-and-coil assembly with a saturated-iron regulating element and capacitors impregnated with an insulating material in accordance with ANSI C82.4 and NEMA ANSLG C82.9.

Provide ballasts which maintain correct lamp operation over a voltage-input range of plus or minus 13 percent of rated voltage. Include capacitors providing a power factor lamp load of not less than 95 percent.

Provide ballasts with a voltage rated for operation on 120- or 277-volt, single-phase, 60-hertz lighting-distribution systems as indicated.

Design ballasts for a minimum lamp starting temperature of minus 29 degrees C 20 degrees F and a maximum ambient temperature of 41 degrees C 105 degrees F.

##### 2.2.4.2 Series Circuit Transformers

Provide series transformers with a two-winding core-and-coil assembly designed for connection to constant-current supply circuits in accordance with NEMA ANSLG C82.9.

Design the primary winding of the transformer for connection to 6.6-or 20-ampere constant-current street-lighting circuits, providing the proper starting voltage and operating current for the lamp indicated.

Design transformers for a maximum ambient temperature of 41 degrees C 105 degrees F.

#### 2.2.5 Lamps

Provide lamps, if used in a populated area, certified to be automatically self-extinguishing, conforming to 21 CFR 1040, Section 30.

\*\*\*\*\*  
NOTE: Select one of the following two paragraphs.  
Add watt requirements on the drawings.  
\*\*\*\*\*

#### 2.2.5.1 (HID) Lamps and Ballasts

Furnish compatible (HID) lamps and ballasts, as specified on drawings. Provide high pressure sodium lamps in compliance with the following industry standards:

1,000 watts	ANSI ANSLG C78.42
400 watts	ANSI ANSLG C78.42
150 watts	ANSI ANSLG C78.42
70 watts	ANSI ANSLG C78.42

#### 2.2.5.2 Low Pressure Sodium

Provide lamps certified by manufacturer as meeting the requirements defined by the contract drawings.

#### 2.2.6 Side-Mounted Incandescent Luminaires

Provide side-mounted incandescent-lamp luminaires with base-up vertical lamp-burning position including a universal head with lamp and porcelain lampholders. Ensure the reflector assembly is in a completely sealed optical system suitable for bracket mounting to street-lighting standards.

Provide cast aluminum universal head with integral side-mounting slip fitter, pipe stop, and clamps with provision for vertical adjustments of plus or minus 3 degrees for leveling purposes.

Include in reflector assembly a reflector, refractor, and clamping band. Form reflector from anodized sheet aluminum with a specular finish. Provide a molded prismatic heat-resistant borosilicate glass refractor. Ensure the design generates the type of lighting-distribution pattern indicated. Form a clamping band from sheet aluminum or corrosion-resistant steel to completely seal the joint between reflector and refractor.

Provide reflector assembly which latches directly to the universal head with aluminum or corrosion-resistant steel latches, with latches and seating flange to provide a seal against moisture, dirt, and insects.

#### 2.2.7 Incandescent Lamps

Provide the following incandescent lamps:

- a. General-purpose incandescent lamps - clear or inside frosted.
- b. Lamps with wattage ratings up to and including 300 watts- medium brass screw bases.
- c. Lamps with wattage ratings in excess of 300 watts- mogul brass screw bases.

Provide special-purpose lamps, including PAR and R lamps as follows:

- a. PAR lamps - clear molded heat-resistant hard-glass bulbs with parabolic aluminized inner-bulb wall reflectors for spotlighting or floodlighting applications.
- b. R lamps - clear soft blown-glass bulbs with silver-deposited, inner-bulb wall reflector for spotlighting or floodlighting applications.

Provide lamps designed for operation on 120-volt, 60-hertz circuits unless otherwise specified.

### PART 3 EXECUTION

#### 3.1 INSTALLATION

Install a street-lighting fixture at each location indicated, with lamps of the proper type, voltage, and wattage in each fixture.

Install new lamps immediately prior to completion of the project. Install lamps with the light center at the focal point of the reflector and in the proper burning position.

##### 3.1.1 End-Mounted High-Intensity-Discharge (HID) Luminaires

Conceal wiring in street-lighting standards and luminaires. Mount porcelain lampholder on an adjustable supporting bracket that permits vertical and horizontal positioning of the lamp. Ensure the upper housing overlaps the lower housing with a heat-resistant gasket providing a seal against moisture, dirt, and insects.

##### 3.1.2 Side-Mounted (HID) Luminaires

Conceal wiring in street-lighting standards and luminaires. Install clamping band to completely seal the joint between reflector and refractor against moisture, dirt, and insects.

##### 3.1.3 Side-Mounted Incandescent Luminaires

Conceal wiring in street-lighting standards and luminaires. Install clamping band to completely seal the joint between reflector and refractor against moisture, dirt, and insects.

#### 3.2 FIELD TESTING

Perform [Operational Tests](#) in accordance with referenced standards within this section[, in the presence of the Contracting Officer].

Perform demonstration to verify street lighting operates satisfactorily in the presence of the Contracting Officer, after sunset.

-- End of Section --