
USACE / NAVFAC / AFCEC / NASA UFGS-01 78 00 (August 2011)

Preparing Activity: USACE Superseding
UFGS-01 78 00 (May 2010)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated January 2015

SECTION TABLE OF CONTENTS

DIVISION 01 - GENERAL REQUIREMENTS

SECTION 01 78 00

CLOSEOUT SUBMITTALS

08/11

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 PROJECT RECORD DOCUMENTS
 - 1.3.1 Record Drawings
 - 1.3.1.1 Government Furnished Materials
 - 1.3.1.2 Working Record and Final Record Drawings
 - 1.3.1.3 Drawing Preparation
 - 1.3.1.4 Computer Aided Design and Drafting (CADD) Drawings
 - 1.3.1.5 Manually Prepared Drawings
 - 1.3.1.6 Payment
 - 1.3.2 As-Built Record of Equipment and Materials
 - 1.3.3 Final Approved Shop Drawings
 - 1.3.4 Construction Contract Specifications
 - 1.3.5 Real Property Equipment
- 1.4 SPARE PARTS DATA
- 1.5 PREVENTATIVE MAINTENANCE
- 1.6 CERTIFICATION OF EPA DESIGNATED ITEMS
- 1.7 WARRANTY MANAGEMENT
 - 1.7.1 Warranty Management Plan
 - 1.7.2 Performance Bond
 - 1.7.3 Pre-Warranty Conference
 - 1.7.4 Contractor's Response to Construction Warranty Service Requirements
 - 1.7.5 Warranty Tags
- 1.8 COMMISSIONING
 - 1.8.1 Building Commissioning
 - 1.8.2 HVAC Commissioning
- 1.9 OPERATION AND MAINTENANCE MANUALS
 - 1.9.1 Configuration
 - 1.9.2 Training and Instruction
- 1.10 CLEANUP
 - 1.10.1 Extraordinary Cleanup Requirements
- 1.11 REAL PROPERTY RECORD
- 1.12 NAVFAC SUSTAINABLE & ENERGY DATA RECORD CARD

PART 2 PRODUCTS

PART 3 EXECUTION

ATTACHMENTS:

draft DD Form 1354

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEC / NASA UFGS-01 78 00 (August 2011)

Preparing Activity: USACE Superseding
UFGS-01 78 00 (May 2010)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated January 2015

SECTION 01 78 00

CLOSEOUT SUBMITTALS 08/11

NOTE: This guide specification covers the requirements for closeout submittals including: revised project documents, warranty management, testing, adjusting and balancing, O & M manuals, and final cleaning.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

PART 1 GENERAL

1.1 REFERENCES

NOTE: Issue (date) of references included in project specifications need not be more current than provided by the latest guide specification. Use of SpecsIntact automated reference checking is recommended for projects based on older guide specifications.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM E1971 (2005; R 2011) Stewardship for the
Cleaning of Commercial and Institutional
Buildings

GREEN SEAL (GS)

GS-37 (2012) Cleaning Products for Industrial
and Institutional Use

U.S. ARMY CORPS OF ENGINEERS (USACE)

TR-06-X (2006; Supplement 2009) A/E/C
(Architectural, Engineering, and
Construction) CADD Standard - Release 3.0

U.S. DEPARTMENT OF DEFENSE (DOD)

UFC 1-300-08 (2009, with Change 2) Criteria for
Transfer and Acceptance of DoD Real
Property

1.2 SUBMITTALS

NOTE: Review submittal description (SD) definitions
in Section 01 33 00 SUBMITTAL PROCEDURES and edit
the following list to reflect only the submittals
required for the project.

The Guide Specification technical editors have
designated those items that require Government
approval, due to their complexity or criticality,
with a "G." Generally, other submittal items can be
reviewed by the Contractor's Quality Control
System. Only add a "G" to an item, if the submittal
is sufficiently important or complex in context of
the project.

For submittals requiring Government approval on Army
projects, a code of up to three characters within
the submittal tags may be used following the "G"
designation to indicate the approving authority.
Codes for Army projects using the Resident
Management System (RMS) are: "AE" for
Architect-Engineer; "DO" for District Office
(Engineering Division or other organization in the
District Office); "AO" for Area Office; "RO" for
Resident Office; and "PO" for Project Office. Codes
following the "G" typically are not used for Navy,
Air Force, and NASA projects.

An "S" following a submittal item indicates that the
submittal is required for the Sustainability
Notebook to fulfill federally mandated sustainable
requirements in accordance with Section 01 33 29
SUSTAINABILITY REPORTING.

Choose the first bracketed item for Navy, Air Force
and NASA projects, or choose the second bracketed
item for Army projects.

Government approval is required for submittals with a "G" designation;
submittals not having a "G" designation are for [Contractor Quality Control
approval.][information only. When used, a designation following the "G"
designation identifies the office that will review the submittal for the
Government.] Submittals with an "S" are for inclusion in the
Sustainability Notebook, in conformance to Section 01 33 29 SUSTAINABILITY
REPORTING. Submit the following in accordance with Section 01 33 00
SUBMITTAL PROCEDURES:

SD-03 Product Data

As-Built Record of Equipment and Materials
Warranty Management Plan
Warranty Tags
Final Cleaning
Spare Parts Data

SD-08 Manufacturer's Instructions

Preventative Maintenance
Condition Monitoring (Predictive Testing)
Inspection
Posted Instructions

SD-10 Operation and Maintenance Data

Operation and Maintenance Manuals

SD-11 Closeout Submittals

Record Drawings
Certification of EPA Designated Items; G[, [____]]
Interim Form DD1354; G[, [____]]
Checklist for Form DD1354; G[, [____]]
NAVFAC Sustainable & Energy Data Record Card; G

1.3 PROJECT RECORD DOCUMENTS

1.3.1 Record Drawings

NOTE: The USACE policy on Record (As-Built)
drawings is as follows:

a. Method of Preparation for DoD Projects. The
construction Contractor will prepare the final
Record drawings, whether in manual or CADD format.

b. Method of Preparation for Civil Works
Projects. The preferred method of preparing the
final Record drawings is by the construction
Contractor. The management plan for the project
must justify the preparation of the final Record

drawings by any other method, such as by in-house personnel. Two such exceptions are "emergency construction" and operations work performed with hired labor. Revise the following specification paragraphs if as-builts are not to be done by the Contractor.

c. Customer Coordination. The method of producing the record drawings and their format will be discussed with the customer at the beginning of a project, reflected in the Memorandum of Understanding with the customer (if applicable) and the management plan for the project, and confirmed with the customer before issuing the construction solicitation.

Drawings showing final as-built conditions of the project. This paragraph covers record drawings complete, as a requirement of the contract. The terms "drawings," "contract drawings," "drawing files," "working record drawings" and "final record drawings" refer to contract drawings which are revised to be used for final record drawings showing as-built conditions. [The final CAD record drawings must consist of one set of electronic CAD drawing files in the specified format, 2 sets of prints, and one set of the approved working Record drawings.] [The manually prepared drawings must consist of 1 set of completed final as-built original transparency drawings, 2 sets of blue-line prints of the transparencies, and the approved marked working as-built prints.]

1.3.1.1 Government Furnished Materials

NOTE: Edit this paragraph to specify manually prepared drawings or CADD files compatible with the customers CADD system.

One set of [mylar drawings revised to reflect all bid amendments will be provided by the Government at the preconstruction conference for projects requiring manually prepared record drawings] [electronic CADD files in the specified software and format revised to reflect all bid amendments will be provided by the Government at the preconstruction conference for projects requiring CADD file record drawings].

1.3.1.2 Working Record and Final Record Drawings

Revise [2] [_____] sets of paper drawings by red-line process to show the as-built conditions during the prosecution of the project. Keep these working as-built marked drawings current on a weekly basis and at least one set available on the jobsite at all times. Changes from the contract plans which are made in the work or additional information which might be uncovered in the course of construction must be accurately and neatly recorded as they occur by means of details and notes. Prepare final record (as-built) drawings after the completion of each definable feature of work as listed in the Contractor Quality Control Plan (Foundations, Utilities, Structural Steel, etc., as appropriate for the project). The working as-built marked prints and final record (as-built) drawings will be jointly reviewed for accuracy and completeness by the Contracting Officer and the Contractor prior to submission of each monthly pay estimate. If the

Contractor fails to maintain the working and final record drawings as specified herein, the Contracting Officer will deduct from the monthly progress payment an amount representing the estimated cost of maintaining the record drawings. This monthly deduction will continue until an agreement can be reached between the Contracting Officer and the Contractor regarding the accuracy and completeness of updated drawings. Show on the working and final record drawings , but not limited to, the following information:

- a. The actual location, kinds and sizes of all sub-surface utility lines. In order that the location of these lines and appurtenances may be determined in the event the surface openings or indicators become covered over or obscured, show by offset dimensions to two permanently fixed surface features the end of each run including each change in direction on the record drawings. Locate valves, splice boxes and similar appurtenances by dimensioning along the utility run from a reference point. Also record the average depth below the surface of each run.
- b. The location and dimensions of any changes within the building structure.
- c. Correct grade, elevations, cross section, or alignment of roads, earthwork, structures or utilities if any changes were made from contract plans.
- d. Changes in details of design or additional information obtained from working drawings specified to be prepared and/or furnished by the Contractor; including but not limited to fabrication, erection, installation plans and placing details, pipe sizes, insulation material, dimensions of equipment foundations, etc.
- e. The topography, invert elevations and grades of drainage installed or affected as part of the project construction.
- f. Changes or modifications which result from the final inspection.
- g. Where contract drawings or specifications present options, show only the option selected for construction on the final as-built prints.
- h. If borrow material for this project is from sources on Government property, or if Government property is used as a spoil area, furnish a contour map of the final borrow pit/spoil area elevations.
- i. Systems designed or enhanced by the Contractor, such as HVAC controls, fire alarm, fire sprinkler, and irrigation systems.
- j. Modifications (include within change order price the cost to change working and final record drawings to reflect modifications) and compliance with the following procedures.
 - (1) Follow directions in the modification for posting descriptive changes.
 - (2) Place a Modification [Circle][Delta] at the location of each deletion.
 - (3) For new details or sections which are added to a drawing, place a Modification [Circle][Delta] by the detail or section title.

- (4) For minor changes, place a Modification [Circle][Delta] by the area changed on the drawing (each location).
- (5) For major changes to a drawing, place a Modification [Circle][Delta] by the title of the affected plan, section, or detail at each location.
- (6) For changes to schedules or drawings, place a Modification [Circle][Delta] either by the schedule heading or by the change in the schedule.
- (7) The Modification [Circle][Delta] size shall be 13 mm 1/2 inch diameter unless the area where the circle is to be placed is crowded. Smaller size circle shall be used for crowded areas.

1.3.1.3 Drawing Preparation

Modify the record drawings as may be necessary to correctly show the features of the project as it has been constructed by bringing the contract set into agreement with approved working as-built prints, and adding such additional drawings as may be necessary. These working as-built marked prints must be neat, legible and accurate. These drawings are part of the permanent records of this project and must be returned to the Contracting Officer after approval by the Government. Any drawings damaged or lost by the Contractor must be satisfactorily replaced by the Contractor at no expense to the Government.

1.3.1.4 Computer Aided Design and Drafting (CADD) Drawings

NOTE: Edit this paragraph to specify CADD drawings compatible with the costumer's CADD system, providing the version where applicable.

Omit this paragraph if manually prepared drawings are required for the project.

Only employ personnel proficient in the preparation of CADD drawings to modify the contract drawings or prepare additional new drawings. Additions and corrections to the contract drawings must be equal in quality and detail to that of the originals. Line colors, line weights, lettering, layering conventions, and symbols must be the same as the original line colors, line weights, lettering, layering conventions, and symbols. If additional drawings are required, prepare them using the specified electronic file format applying [the same graphic standards specified for original drawings][TR-06-X]. The title block and drawing border to be used for any new final record drawings must be identical to that used on the contract drawings. Accomplish additions and corrections to the contract drawings using CADD files. The Contractor will be furnished "as-designed" drawings in [AutoCad Release [14] [2000i] [2004] [____]] [Microstation [J] [V8] [____]] format compatible with a [[Windows XP] [Windows NT] [____]] operating system. The electronic files will be supplied on optical disk. Provide all program files and hardware necessary to prepare final record drawings. The Contracting Officer will review final record drawings for accuracy and return them to the Contractor for required corrections, changes, additions, and deletions.

- a. Provide CADD "base" colors of red, green, and blue. Color code for changes as follows:
 - (1) Deletions (Red) - Over-strike deleted graphic items (lines), lettering in notes and leaders.
 - (2) Additions (Green) - Added items, lettering in notes and leaders.
 - (3) Special (Blue) - Items requiring special information, coordination, or special detailing or detailing notes.
- b. Rename the Contract Drawing files in a manner related to the contract number (i.e., 98-C-10.DGN) as instructed in the Pre-Construction conference. Use only those renamed files for the Marked-up changes. All changes shall be made on the layer/level as the original item.
- c. When final revisions have been completed, show the wording "RECORD DRAWINGS / AS-BUILT CONDITIONS" followed by the name of the Contractor in letters at least 5 mm 3/16 inch high on the cover sheet drawing. Mark all other contract drawings either "Record" drawing denoting no revisions on the sheet or "Revised Record" denoting one or more revisions. Date original contract drawings in the revision block.
- d. Within [[10] [_____] days for contracts less than \$5 million] [20 days for contracts \$5 million and above] after Government approval of all of the working record drawings for a phase of work, prepare the final CADD record drawings for that phase of work and submit two sets of blue-lined prints of these drawings for Government review and approval. The Government will promptly return one set of prints annotated with any necessary corrections. Within [[7] [_____] days for contracts less than \$5 million] [10 days for contracts \$5 million and above] revise the CADD files accordingly at no additional cost and submit one set of final prints for the completed phase of work to the Government. Within [[10] [_____] days for contracts less than \$5 million] [20 days for contracts \$5 million and above] of substantial completion of all phases of work, submit the final record drawing package for the entire project. Submit one set of electronic files on optical disk, one set of mylars, two sets of blue-line prints and one set of the approved working record drawings. They must be complete in all details and identical in form and function to the contract drawing files supplied by the Government. Any transactions or adjustments necessary to accomplish this is the responsibility of the Contractor. The Government reserves the right to reject any drawing files it deems incompatible with the customer's CADD system. Paper prints, drawing files and storage media submitted will become the property of the Government upon final approval. Failure to submit final record drawing files and marked prints as specified will be cause for withholding any payment due the Contractor under this contract. Approval and acceptance of final record drawings must be accomplished before final payment is made to the Contractor.

][1.3.1.5 Manually Prepared Drawings

NOTE: Edit this paragraph to specify manually prepared drawings.

Omit this paragraph if CADD drawings are required for the project.

Employ only personnel proficient in the preparation of manually prepared drawings to modify the original contract drawing or prepare additional new drawings. Additions and corrections to the contract drawings must be neat, clean and legible, shall be done to the same level of detail, and match the adjacent existing line work, and lettering being annotated in type, density, size and style. Drafting work must be done using the same medium (pencil, plastic lead or ink) that was employed on the original contract drawings and with graphite lead on paper base material. The Contracting Officer will review record drawings for accuracy and conformance to the above specified drafting standards. Corrections, changes, additions, and deletions required must meet these standards. The title block to be used for any new record drawings must be similar to that used on the original drawings.

- a. When final revisions have been completed, Letter or stamp each drawing with the words "RECORD DRAWINGS / AS-BUILT CONDITIONS" followed by the name of the Contractor in letters at least 5 mm 3/16 inch high. Mark original contract drawings either "Record" drawings denoting no revisions on the sheet or "Revised Record" denoting one or more revisions Date all original contract drawings in the revision block.
- b. Within [[10] [_____] days for contracts less than \$5 million] [20 days for contracts \$5 million and above] after Government approval of all of the working record drawings for a phase of work, prepare the final record drawings for that phase of work and submit two sets of blue-line prints of these drawings for Government review and approval. The Government will promptly return one set of prints annotated with any necessary corrections. Within [[7] [_____] days for contracts less than \$5 million] [10 days for contracts \$5 million and above] revise the drawings accordingly at no additional cost and submit one set of final prints for the completed phase of work to the Government. Within [[10] [_____] days for contracts less than \$5 million] [20 days for contracts \$5 million and above] of substantial completion of all phases of work, submit the final record drawing package for the entire project. Submit two blue-line prints of these drawings and the return of the approved marked record prints, complete in all details. Paper prints and reproducible drawings will become the property of the Government upon final approval. Failure to submit final record drawings and marked prints, as required herein, will be cause for withholding any payment due the Contractor under this contract. Approval and acceptance of final record drawings must be accomplished before final payment is made to the Contractor.

1.3.1.6 Payment

No separate payment will be made for record drawings required under this contract, and all costs accrued in connection with such drawings are considered a subsidiary obligation of the Contractor.

1.3.2 As-Built Record of Equipment and Materials

NOTE: This paragraph is intended to provide data on equipment and materials incorporated in the construction of the project that cannot readily be determined after completion of construction. The data is expected to be of value for future

maintenance, alteration, and repair work. The designer should predetermine the items on which data is required and list them in the DESCRIPTION column of the following form. A typical list of items would include such things as: roofing, insulation, and special wall coverings.

Furnish [one copy] [[_____]copies] of preliminary record of equipment and materials used on the project [15] [_____] days prior to final inspection. This preliminary submittal will be reviewed and returned [2] [_____] days after final inspection with Government comments. Submit [Two] [_____] sets of final record of equipment and materials [10] [_____] days after final inspection. Key the designations to the related area depicted on the contract drawings. List the following data:

RECORD OF DESIGNATED EQUIPMENT AND MATERIALS DATA				
Description	Specification Section	Manufacturer and Catalog, Model, and Serial Number	Composition and Size	Where Used

1.3.3 Final Approved Shop Drawings

Furnish final approved project shop drawings [30] [_____] days after transfer of the completed facility.

1.3.4 Construction Contract Specifications

Furnish final record (as-built) construction contract specifications, including modifications thereto, [30] [_____] days after transfer of the completed facility.

1.3.5 Real Property Equipment

Furnish a list of installed equipment furnished under this contract. Include all information usually listed on manufacturer's name plate. In the "EQUIPMENT-IN-PLACE LIST" include, as applicable, the following for each piece of equipment installed: description of item, location (by room number), model number, serial number, capacity, name and address of manufacturer, name and address of equipment supplier, condition, spare parts list, manufacturer's catalog, and warranty. Furnish a draft list at time of transfer. Furnish the final list [30] [_____] days after transfer of the completed facility.

1.4 SPARE PARTS DATA

Submit [two] [four] [_____] copies of the Spare Parts Data list.

- Indicate manufacturer's name, part number, nomenclature, and stock level required for maintenance and repair. List those items that may be standard to the normal maintenance of the system.
- Supply [_____] items of each part for spare parts inventory. Provision of spare parts does not relieve the Contractor of responsibilities listed under the contract guarantee provisions.

1.5 PREVENTATIVE MAINTENANCE

Submit Preventative Maintenance, Condition Monitoring (Predictive Testing) and Inspection schedules with instructions that state when systems should be retested.

- a. Define the anticipated length of each test, test apparatus, number of personnel identified by responsibility, and a testing validation procedure permitting the record operation capability requirements within the schedule. Provide a signoff blank for the Contractor and Contracting Officer for each test feature; e.g., liter per second, rpm, kilopascal gpm, rpm, psi. Include a remarks column for the testing validation procedure referencing operating limits of time, pressure, temperature, volume, voltage, current, acceleration, velocity, alignment, calibration, adjustments, cleaning, or special system notes. Delineate procedures for preventative maintenance, inspection, adjustment, lubrication and cleaning necessary to minimize corrective maintenance and repair.
- b. Repair requirements must inform operators how to check out, troubleshoot, repair, and replace components of the system. Include electrical and mechanical schematics and diagrams and diagnostic techniques necessary to enable operation and troubleshooting of the system after acceptance.

1.6 CERTIFICATION OF EPA DESIGNATED ITEMS

Submit the Certification of EPA Designated Items as required by FAR 52.223-9, "Certification and Estimate of Percentage of Recovered Material Content for EPA Designated Items". Include on the certification form the following information: project name, project number, Contractor name, license number, Contractor address, and certification. The certification will read as follows and be signed and dated by the Contractor. ["I hereby certify the information provided herein is accurate and that the requisition/procurement of all materials listed on this form comply with current EPA standards for recycled/recovered materials content. The following exemptions may apply to the non-procurement of recycled/recovered content materials: 1) The product does not meet appropriate performance standards; 2) The product is not available within a reasonable time frame; 3) The product is not available competitively (from two or more sources); 4) The product is only available at an unreasonable price (compared with a comparable non-recycled content product)."] [_____] Record each product used in the project that has a requirement or option of containing recycled [or biobased] content in accordance with Section 01 33 29 SUSTAINABILITY REPORTING, noting total price, total value of post-industrial recycled content, total value of post-consumer recycled content, [total value of biobased content,] exemptions (1, 2, 3, or 4, as indicated), and comments. Recycled [and biobased] content values may be determined by weight or volume percent, but must be consistent throughout.

1.7 WARRANTY MANAGEMENT

NOTE: A warranty package based on a cost/benefit determination will be established with the customer at the beginning of a project. Coordinate with the customer regarding special warranty requirements and options.

1.7.1 Warranty Management Plan

Develop a warranty management plan which contains information relevant to the clause Warranty of Construction in [_____]. At least 30 days before the planned pre-warranty conference, submit [one set] [[four] [_____] sets] of the warranty management plan. Include within the warranty management plan all required actions and documents to assure that the Government receives all warranties to which it is entitled. The plan must be in narrative form and contain sufficient detail to render it suitable for use by future maintenance and repair personnel, whether tradesmen, or of engineering background, not necessarily familiar with this contract. The term "status" as indicated below must include due date and whether item has been submitted or was accomplished. Warranty information made available during the construction phase must be submitted to the Contracting Officer for approval prior to each monthly pay estimate. Assemble approved information in a binder and turn over to the Government upon acceptance of the work. The construction warranty period will begin on the date of project acceptance and continue for the full product warranty period. A joint 4 month and 9 month warranty inspection will be conducted, measured from time of acceptance, by the Contractor, Contracting Officer and the Customer Representative. Include within the warranty management plan , but not limited to, the following:

- a. Roles and responsibilities of all personnel associated with the warranty process, including points of contact and telephone numbers within the organizations of the Contractors, subContractors, manufacturers or suppliers involved.
- b. Furnish with each warranty the name, address, and telephone number of each of the guarantor's representatives nearest to the project location.
- c. Listing and status of delivery of all Certificates of Warranty for extended warranty items, to include roofs, HVAC balancing, pumps, motors, transformers, and for all commissioned systems such as fire protection and alarm systems, sprinkler systems, lightning protection systems, etc.
- d. A list for each warranted equipment, item, feature of construction or system indicating:
 - (1) Name of item.
 - (2) Model and serial numbers.
 - (3) Location where installed.
 - (4) Name and phone numbers of manufacturers or suppliers.
 - (5) Names, addresses and telephone numbers of sources of spare parts.
 - (6) Warranties and terms of warranty. Include one-year overall warranty of construction, including the starting date of warranty of construction. Items which have extended warranties must be indicated with separate warranty expiration dates.
 - (7) Cross-reference to warranty certificates as applicable.
 - (8) Starting point and duration of warranty period.
 - (9) Summary of maintenance procedures required to continue the warranty in force.
 - (10) Cross-reference to specific pertinent Operation and Maintenance manuals.
 - (11) Organization, names and phone numbers of persons to call for warranty service.

(12) Typical response time and repair time expected for various warranted equipment.

- e. The Contractor's plans for attendance at the 4 and 9 month post-construction warranty inspections conducted by the Government.
- f. Procedure and status of tagging of all equipment covered by extended warranties.
- g. Copies of instructions to be posted near selected pieces of equipment where operation is critical for warranty and/or safety reasons.

1.7.2 Performance Bond

The Contractor's Performance Bond [must remain effective throughout the construction period] [_____].

- a. In the event the Contractor fails to commence and diligently pursue any construction warranty work required, the Contracting Officer will have the work performed by others, and after completion of the work, will charge the remaining construction warranty funds of expenses incurred by the Government while performing the work, including, but not limited to administrative expenses.
- b. In the event sufficient funds are not available to cover the construction warranty work performed by the Government at the Contractor's expense, the Contracting Officer will have the right to recoup expenses from the bonding company.
- c. Following oral or written notification of required construction warranty repair work, respond in a timely manner. Written verification will follow oral instructions. Failure of the Contractor to respond will be cause for the Contracting Officer to proceed against the Contractor.

1.7.3 Pre-Warranty Conference

Prior to contract completion, and at a time designated by the Contracting Officer, meet with the Contracting Officer to develop a mutual understanding with respect to the requirements of this section. Communication procedures for Contractor notification of construction warranty defects, priorities with respect to the type of defect, reasonable time required for Contractor response, and other details deemed necessary by the Contracting Officer for the execution of the construction warranty will be established/reviewed at this meeting. In connection with these requirements and at the time of the Contractor's quality control completion inspection, furnish the name, telephone number and address of a licensed and bonded company which is authorized to initiate and pursue construction warranty work action on behalf of the Contractor. This point of contact will be located within the local service area of the warranted construction, be continuously available, and be responsive to Government inquiry on warranty work action and status. This requirement does not relieve the Contractor of any of its responsibilities in connection with other portions of this provision.

1.7.4 Contractor's Response to Construction Warranty Service Requirements

Following oral or written notification by the Contracting Officer, respond to construction warranty service requirements in accordance with the

"Construction Warranty Service Priority List" and the three categories of priorities listed below. Submit a report on any warranty item that has been repaired during the warranty period. Include within the report the cause of the problem, date reported, corrective action taken, and when the repair was completed. If the Contractor does not perform the construction warranty within the timeframes specified, the Government will perform the work and backcharge the construction warranty payment item established.

- a. First Priority Code 1. Perform onsite inspection to evaluate situation, and determine course of action within 4 hours, initiate work within 6 hours and work continuously to completion or relief.
- b. Second Priority Code 2. Perform onsite inspection to evaluate situation, and determine course of action within 8 hours, initiate work within 24 hours and work continuously to completion or relief.
- c. Third Priority Code 3. All other work to be initiated within 3 work days and work continuously to completion or relief.
- d. The "Construction Warranty Service Priority List" is as follows:

Code 1-Life Safety Systems

- (1) Fire suppression systems.
- (2) Fire alarm system(s) in place in the building.

Code 1-Air Conditioning Systems

- (1) Recreational support.
- (2) Air conditioning leak in part of building, if causing damage.
- (3) Air conditioning system not cooling properly.

Code 1-Doors

- (1) Overhead doors not operational, causing a security, fire, or safety problem.
- (2) Interior, exterior personnel doors or hardware, not functioning properly, causing a security, fire, or safety problem.

Code 3-Doors

- (1) Overhead doors not operational.
- (2) Interior/exterior personnel doors or hardware not functioning properly.

Code 1-Electrical

- (1) Power failure (entire area or any building operational after 1600 hours).
- (2) Security lights
- (3) Smoke detectors

Code 2-Electrical

- (1) Power failure (no power to a room or part of building).
- (2) Receptacle and lights (in a room or part of building).

Code 3-Electrical

Street lights.

Code 1-Gas

- (1) Leaks and breaks.
- (2) No gas to family housing unit or cantonment area.

Code 1-Heat

- (1) Area power failure affecting heat.
- (2) Heater in unit not working.

Code 2-Kitchen Equipment

- (1) Dishwasher not operating properly.
- (2) All other equipment hampering preparation of a meal.

Code 1-Plumbing

- (1) Hot water heater failure.
- (2) Leaking water supply pipes.

Code 2-Plumbing

- (1) Flush valves not operating properly.
- (2) Fixture drain, supply line to commode, or any water pipe leaking.
- (3) Commode leaking at base.

Code 3 -Plumbing

Leaky faucets.

Code 3-Interior

- (1) Floors damaged.
- (2) Paint chipping or peeling.
- (3) Casework.

Code 1-Roof Leaks

Temporary repairs will be made where major damage to property is occurring.

Code 2-Roof Leaks

Where major damage to property is not occurring, check for location of leak during rain and complete repairs on a Code 2 basis.

Code 2-Water (Exterior)

No water to facility.

Code 2-Water (Hot)

No hot water in portion of building listed.

Code 3-All other work not listed above.

1.7.5 Warranty Tags

At the time of installation, tag each warranted item with a durable, oil and water resistant tag approved by the Contracting Officer. Attach each tag with a copper wire and spray with a silicone waterproof coating. Also, submit [two] [four] [_____] record copies of the warranty tags showing the layout and design. The date of acceptance and the QC signature must remain blank until the project is accepted for beneficial occupancy. Show the following information on the tag.

Type of product/material	
Model number	
Serial number	
Contract number	

Warranty period from/to	
Inspector's signature	
Construction Contractor	
Address	
Telephone number	
Warranty contact	
Address	
Telephone number	
Warranty response time priority code	
WARNING - PROJECT PERSONNEL TO PERFORM ONLY OPERATIONAL MAINTENANCE DURING THE WARRANTY PERIOD.	

[1.8 COMMISSIONING

**NOTE: Use for projects as directed by the
Government.**

1.8.1 Building Commissioning

All contract requirements for building commissioning shall be completed prior to contract completion.

1.8.2 HVAC Commissioning

All contract requirements of Section 23 08 00.00 10 COMMISSIONING OF HVAC SYSTEMS must be fully completed, including all testing concurrent with Building Commissioning. All contract requirements of Section 23 05 93 TESTING, ADJUSTING AND BALANCING must be fully completed, including testing and inspection, prior to HVAC commissioning, except as noted otherwise in Section 23 05 93. All contract requirements of Section [23 09 53.00 20 SPACE TEMPERATURE CONTROL SYSTEMS] [23 09 23 LONWORKS DIRECT DIGITAL CONTROL FOR HVAC AND OTHER BUILDING CONTROL SYSTEMS] [23 09 23.13 20 BACnet DIRECT DIGITAL CONTROL SYSTEMS FOR HVAC] must be fully completed, including all testing, prior to HVAC commissioning. The time required to complete all work and testing as prescribed by Sections [23 08 00.00 10] [23 09 53.00 20] [23 09 23.13 20], 23 05 93 and [_____] is included in the allotted calendar days for completion.

]1.9 OPERATION AND MAINTENANCE MANUALS

Submit [6] [_____] copies of the project operation and maintenance manuals 30 calendar days prior to testing the system involved. Update and resubmit data for final approval no later than 30 calendar days prior to contract completion.

1.9.1 Configuration

Operation and Maintenance Manuals must be consistent with the manufacturer's standard brochures, schematics, printed instructions, general operating procedures, and safety precautions. Bind information in manual format and grouped by technical sections. Test data must be legible and of good quality. Light-sensitive reproduction techniques are acceptable provided finished pages are clear, legible, and not subject to fading. Pages for vendor data and manuals must have 10 millimeter 0.3937-inch holes and be bound in 3-ring, loose-leaf binders. Organize data by separate index and tabbed sheets, in a loose-leaf binder. Binder must lie flat with printed sheets that are easy to read. Caution and warning indications must be clearly labeled.

1.9.2 Training and Instruction

Submit classroom and field instructions in the operation and maintenance of systems equipment where required by the technical provisions. These services must be directed by the Contractor, using the manufacturer's factory-trained personnel or qualified representatives. Contracting Officer will be given 7 calendar days written notice of scheduled instructional services. Instructional materials belonging to the manufacturer or vendor, such as lists, static exhibits, and visual aids, must be made available to the Contracting Officer.

1.10 CLEANUP

NOTE: Natural cleaning materials include:

- a. abrasive cleaners: substitute 1/2 lemon dipped in borax.**
- b. ammonia: substitute vinegar, salt and water mixture, or baking soda and water.**
- c. disinfectants: substitute 1/2 cup borax in gallon water.**
- d. drain cleaners: substitute 1/4 cup baking soda and 1/4 cup vinegar in boiling water.**
- e. upholstery cleaners: substitute dry cornstarch.**

Provide final cleaning in accordance with ASTM E1971 and submit [two] [four] [_____] copies of the listing of completed final clean-up items. Leave premises "broom clean." Comply with GS-37 for general purpose cleaning and bathroom cleaning. Use only nonhazardous cleaning materials, including natural cleaning materials, in the final cleanup. Clean interior and exterior glass surfaces exposed to view; remove temporary labels, stains and foreign substances; polish transparent and glossy surfaces; vacuum carpeted and soft surfaces. Clean equipment and fixtures to a sanitary condition. [Clean] [Replace] filters of operating equipment and comply with the Indoor Air Quality (IAQ) Management Plan. Clean debris from roofs, gutters, downspouts and drainage systems. Sweep paved areas and rake clean landscaped areas. Remove waste and surplus materials, rubbish and construction facilities from the site. Recycle, salvage, and return construction and demolition waste from project in accordance with the Waste Management Plan. Promptly and legally transport and dispose of any trash. Do not burn, bury, or otherwise dispose of trash on the project site.

1.10.1 [Extraordinary Cleanup Requirements

NOTE: Do not add information related to facility regulations which are of a routine nature. Include unusual cleanup requirements.

The following cleanup requirements apply: [_____].

]1.11 REAL PROPERTY RECORD

NOTE: All DoD projects require Form DD1354 to be completed, made final, and submitted for entry into the applicable service database of real property. The Designer of Record must complete and attach a draft version of Form DD1354 (with cost data deleted) to the end of this section for subsequent revision by the construction Contractor, or US Naval Construction Forces, whichever is appropriate. Complete procedural instructions for design and construction government forces are provided at the checklist URL below.

NOTE: Modify paragraph below if Command requires the activity contracting office to complete the form instead of the Contractor.

Near the completion of Project, but a minimum of 60 days prior to final acceptance of the work, complete[, update draft DD Form 1354 attached to this section,] and submit an accounting of all installed property with Interim Form DD1354 "Transfer and Acceptance of Military Real Property." Include any additional assets/improvements/alterations from the Draft DD Form 1354. Contact the Contracting Officer for any project specific information necessary to complete the DD Form 1354. Refer to UFC 1-300-08 for instruction on completing the DD Form 1354. For information purposes, a blank DD Form 1354 (fill-able) in ADOBE (PDF) may be obtained at the following web site:

<http://www.dtic.mil/whs/directives/infomgt/forms/eforms/dd1354.pdf>

Submit the completed Checklist for Form DD1354 of Installed Building Equipment items. Attach this list to the updated DD Form 1354.

1.12 NAVFAC SUSTAINABLE & ENERGY DATA RECORD CARD

NOTE: All NAVFAC projects require this Form to be completed and submitted to NAVFAC for records keeping.

Within 60 days of the completion of Project, complete an electronic copy of the NAVFAC Sustainable & Energy Data Record Card, and submit to the Contracting Officer. Draft Record card for this project should be available from Designer of Record (DOR) or Contracting Officer.

Instructions and a blank DD Form (fill-able) in ADOBE (PDF) may be obtained at the Whole Building Design Guide web site by navigating:
Home > Participating Agencies > Department of Defense (DoD) > NAVFAC Sustainable Development Program > Contract Documents > NAVFAC Sustainable & Energy Data Record Card; or directly at
http://www.wbdg.org/pdfs/navfac_sustainable_energy_data_record_card.pdf.

PART 2 PRODUCTS

Not Used

PART 3 EXECUTION

Not Used

-- End of Section --