
USACE / NAVFAC / AFCEA / NASA UFGS-09 23 82.00 40 (April 2006)

Preparing Activity: NASA Superseding
 NASA-09212S (December 2005)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are NOT in agreement with UMRL dated 01 April 2006

Revised throughout - changes not indicated by CHG tags

SECTION TABLE OF CONTENTS

DIVISION 09 - FINISHES

SECTION 09 23 82.00 40

FIREPROOFING PLASTER

04/06

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 DELIVERY, HANDLING, AND STORAGE

PART 2 PRODUCTS

- 2.1 MATERIALS
 - 2.1.1 Fireproof Plaster
 - 2.1.2 Water

PART 3 EXECUTION

- 3.1 INSTALLATION
 - 3.1.1 General Requirements
 - 3.1.2 Application
- 3.2 ACCEPTANCE PROVISIONS

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-09 23 82.00 40 (April 2006)

Preparing Activity: NASA Superseding
 NASA-09212S (December 2005)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are NOT in agreement with UMRL dated 01 April 2006

Revised throughout - changes not indicated by CHG tags

SECTION 09 23 82.00 40

FIREPROOFING PLASTER 04/06

NOTE: Delete, revise, or add to the text in this section to cover project requirements. Notes are for designer information and will not appear in the final project specification.

This section covers fireproofing, complete.

Associated work found in other sections includes metal framing, furring systems, and metal lath.

Drawings must show areas of application and installation details.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

Use of electronic communication is encouraged.

Brackets are used in the text to indicate designer choices or locations where text must be supplied by the designer.

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date,

and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM E 119 (2000a) Standard Test Methods for Fire Tests of Building Construction and Materials

ASTM E 84 (2005e1) Standard Test Method for Surface Burning Characteristics of Building Materials

INTERNATIONAL CODE COUNCIL (ICC)

ICC IBC (2003) International Building Code

1.2 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the

District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Installation drawings shall be submitted for Fireproof Plaster in accordance with the paragraph entitled, "Application," of this section.

SD-03 Product Data

Manufacturer's catalog data shall be submitted for Fireproof Plaster showing flame spread classification, fuel contribution, and smoke developed.

SD-04 Samples

Not less than 0.2 kilogram 1/2 pound of Fireproofing Plaster Mix.

SD-07 Certificates

Certificates shall be submitted for Fireproof Plaster showing conformance with the ICC IBC, "Uniform Building Code," Volume I, "Requirements for Four-Hour Construction."

SD-08 Manufacturer's Instructions

Manufacturer's instructions shall be submitted for Fireproof Plaster including special provisions required to install equipment components and system packages. Special notices shall detail impedances, hazards and safety precautions.

1.3 DELIVERY, HANDLING, AND STORAGE

Materials shall be delivered in original unopened packages bearing the name of the product, manufacturer's name, and the Underwriters Laboratories, Inc. label.

Materials shall be stored off the ground, under cover, and away from damp surfaces and shall be kept dry until ready to use. Materials that have been exposed to water before use shall be discarded.

PART 2 PRODUCTS

2.1 MATERIALS

2.1.1 Fireproof Plaster

Fireproof plaster shall be gypsum-vermiculite mix. Consisting of one part gypsum to two parts vermiculite. Plaster shall comply with ICC IBC, "International Building Code," "Requirements for 4-Hour Construction."

Cohesion of the dry set material shall be such that the fireproofing coat will not crack or delaminate when the structural steel element is subjected to a downward deflection of 1/120 of the span.

Compressive strength shall be not less than 485 kilopascal 70 pounds per square inch.

When tested in accordance with ASTM E 84, the set and dry material shall show the following characteristics:

Flame spread	10
Fuel contributed	5
Smoke developed	0

2.1.2 Water

Water shall be potable.

PART 3 EXECUTION

3.1 INSTALLATION

3.1.1 General Requirements

Fireproofing plaster shall be applied as specified to those areas indicated. Details shall be as indicated.

3.1.2 Application

Application of fireproofing plaster shall be [pneumatic] [or] [and] [trowelled] in accordance with material manufacturer's written recommendations. Thickness of application shall be as indicated and in compliance with the applicable codes to provide rated fireproofing when tested in accordance with ASTM E 119.

Framing and furring shall be as recommended by manufacturer for the installation of the fireproofing plaster thickness required or as indicated.

3.2 ACCEPTANCE PROVISIONS

After completion of fireproofing work, application equipment shall be removed. Areas of ceilings, walls, and floors, adjacent or exposed to the operations of application of the fireproofing material, and other surfaces and finishes that may have been soiled shall be cleaned of fireproofing materials.

Damaged or unacceptable portions of the fireproofing plaster shall be removed and replaced with new work at no additional cost to the Government.

-- End of Section --