
USACE / NAVFAC / AFCEA / NASA UFGS-26 56 36.00 40 (April 2006)

Preparing Activity: NASA Superseding
 NASA-16522S (December 2005)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are NOT in agreement with UMRL dated 01 April 2006

Revised throughout - changes not indicated by CHG tags

SECTION TABLE OF CONTENTS

DIVISION 26 - ELECTRICAL

SECTION 26 56 36.00 40

FLOOD LIGHTING

04/06

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 GENERAL REQUIREMENTS
- 1.3 SUBMITTALS

PART 2 PRODUCTS

- 2.1 PRODUCT STANDARDS
- 2.2 FLOODLIGHTING LUMINAIRES
- 2.3 HIGH-INTENSITY-DISCHARGE (HID) LUMINAIRES
- 2.4 QUARTZ-IODINE LUMINAIRES, SPECIAL PURPOSE
- 2.5 SUBSTATION-YARD LIGHTING LUMINAIRES
- 2.6 LIGHTING STANDARDS
- 2.7 SERIES CIRCUIT TRANSFORMERS
- 2.8 LAMPS
 - 2.8.1 HID Lamps
 - 2.8.2 Low-Pressure Sodium
 - 2.8.3 High-Pressure Sodium
 - 2.8.4 Metal Halide
 - 2.8.5 Incandescent Lamps

PART 3 EXECUTION

- 3.1 INSTALLATION
- 3.2 FIELD TESTING

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-26 56 36.00 40 (April 2006)

Preparing Activity: NASA Superseding
 NASA-16522S (December 2005)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are NOT in agreement with UMRL dated 01 April 2006

Revised throughout - changes not indicated by CHG tags

SECTION 26 56 36.00 40

FLOOD LIGHTING 04/06

NOTE: Delete, revise, or add to the text in this section to cover project requirements. Notes are for designer information and will not appear in the final project specification.

This section covers floodlighting fixtures and energy efficient lamps.

Drawings should show a three-dimensional detail of each fixture, with letter designation keyed to the drawings and electrical symbols describing the type, style, class, kind, and size of fixture as follows:

Floodlighting fixtures, including lighting standards, pole-top adapters, foundations, and luminaires for NEMA Type 2, 3, 4, 5, 6, and 7 beam-spread distribution patterns.

All fixture drawings should indicate the materials and finishes for reflectors, refractors, diffusers, and shielding; fixture mounting details; the number, size, and description of lamps; and electrical characteristics of branch-circuit or feeder connections.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

Use of electronic communication is encouraged.

Brackets are used in the text to indicate designer choices or locations where text must be supplied by the designer.

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)

ANSI C82.5 (1990; R 1995) Reference Ballasts - and Low Pressure Sodium Lamps

ANSI C82.9 (1996) Standard for High-Intensity-Discharge and Low-Pressure Sodium Lamps, Ballasts, and Transformers - Definitions

ILLUMINATING ENGINEERING SOCIETY OF NORTH AMERICA (IESNA)

IESNA HB-9 (2000) IES Lighting Handbook

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

ANSI/IEEE C136.3 (1995) Roadway Lighting Equipment - Luminaire Attachments

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

ANSI/NEMA C78.388 (1990; R 1994) High Pressure Sodium Lamps-Methods of Measuring Characteristics

ANSI/NEMA C78.41 (2001) Guidelines for Low Pressure Sodium Lamps

ANSI/NEMA LSD 25 (2004) Best Practices for Metal Halide

Lighting Systems, Plus Questions and
Answers about Lamp Ruptures in Metal
Halide Lighting Systems

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2005) National Electrical Code

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

21 CFR 1040 (1995) Performance Standards for
Light-Emitting Products

UNDERWRITERS LABORATORIES (UL)

UL 1571 (1995e4) Standard for Incandescent
Lighting Fixtures

1.2 GENERAL REQUIREMENTS

NOTE: If Section 26 00 00.00 40 GENERAL ELECTRICAL
PROVISIONS is not included in the project
specification, applicable requirements therefrom
should be inserted and the following paragraph
deleted.

Section 26 00 00.00 40 GENERAL ELECTRICAL PROVISIONS applies to work
specified in this section.

Certificates shall be submitted showing compliance with the following
requirements:

Lighting-distribution curves for each type of fixture shall be in
accordance with the Illuminating Engineering Society.

Certification that Floodlighting Fixtures conform to structural,
electrical, and photometric requirements.

Equipment and Performance Data shall be submitted for floodlighting systems
consisting of life, test, system functional flows, safety features,
mechanical automated details, automatic interlocks, and such features as
electrical system protective device ratings.

1.3 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions
in Section 01 33 00 SUBMITTAL PROCEDURES and edit
the following list to reflect only the submittals
required for the project. Submittals should be kept
to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the
submittal requires Government approval. Some
submittals are already marked with a "G". Only
delete an existing "G" if the submittal item is not
complex and can be reviewed through the Contractor's

Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-03 Product Data

Equipment and Performance Data shall be submitted for floodlighting systems in accordance with paragraph entitled, "General Requirements," of this section.

Manufacturer's catalog data shall be submitted for the following items:

Floodlighting Fixtures
Floodlighting Luminaires
High-Intensity-Discharge (HID) Luminaires
Quartz-Iodine Luminaires
Substation-Yard Lighting Luminaires
Lighting Standards
Series Circuit Transformers
Lamp Ballasts

SD-02 Shop Drawings

Installation Drawings shall be submitted for the Floodlighting Systems in accordance with the paragraph entitled "Installation," of this section.

SD-06 Test Reports

Test reports shall be submitted for Operational Tests on incandescent lighting fixtures in accordance with the paragraph entitled, "Field Testing," of this section.

SD-07 Certificates

Certificates shall be submitted in accordance with paragraph entitled, "General Requirements," of this section.

Floodlighting Fixtures

PART 2 PRODUCTS

2.1 PRODUCT STANDARDS

Floodlighting fixtures shall conform to IESNA HB-9.

Floodlighting fixtures shall be furnished complete with wiring and mounting devices ready for installation at the locations. Fixtures shall be equipped with the proper lamps.

2.2 FLOODLIGHTING LUMINAIRES

Floodlighting luminaires shall be enclosed and gasketed vaportight fixtures in accordance with IESNA HB-9.

2.3 HIGH-INTENSITY-DISCHARGE (HID) LUMINAIRES

NOTE: The following paragraph shall be used when
low- or high-pressure sodium or metal halide lamps
are used.

HID luminaires with base-down vertical-lamp burning positions shall include a housing with glass lens and cover, reflector, lampholder, ballast compartment, terminal block, fuses, fuseholders, and fixture mounting devices in a completely sealed optical system.

Housing shall be cast aluminum with hinged cast-aluminum cover, heat-resistant clear plain glass lens not less than 5 millimeter 3/16-inch thick, gasket, and cover clamps. Housing shall provide a weatherproof seal against moisture and foreign material. Housing shall include an integral cast-aluminum ballast compartment with built-in ballast and terminal block.

Reflector shall be detachable, formed anodized sheet aluminum with diffuse or specular finish designed for a rectangular wide-beam spread.

Fixture mounting devices shall include a galvanized-steel trunnion adaptable to pole, wall, pipe, or crossarm mounting as indicated and required, with fixture positioning devices that will permit horizontal and vertical adjustment over a 180-degree range.

Fixture shall have lamp focusing adjustments, fixture aiming and leveling devices, fuses, and fuseholders accessible from the outside of the fixture. Lamps shall be replaceable from the top or front.

Electrical connections shall be made with Type AFS cord.

2.4 QUARTZ-IODINE LUMINAIRES, SPECIAL PURPOSE

Quartz-iodine lamp luminaires, Class HD, with horizontal lamp-burning position shall include a housing with glass lens and cover, reflector,

lampholders, fuses, fuseholders, lamp, and fixture mounting devices in a completely sealed optical system for pole-top mounting. Wiring shall be concealed in floodlighting luminaires.

Housing shall be cast aluminum with hinged cast-aluminum cover, heat-resistant plain glass lens, gasket, and cover clamps. Housing shall seal against moisture and foreign material.

Reflectors shall be formed anodized sheet aluminum in a [parabolic] [elliptical] shape with diffuse or specular finish for a rectangular beam spread with narrow, medium, or wide light distribution. Beam spread shall be not less than 10 percent of the maximum **illuminance candlepower**. Fixture shall have lamp focusing, positioning, and leveling adjustments that will permit horizontal and vertical adjustment over a 180-degree range, fixture leveling and aiming devices, and fuses with fuseholders accessible from the outside of the fixture. Lamps shall be replaceable from the front and rear.

Fixture shall be designed to accommodate the appropriate lamp.

2.5 SUBSTATION-YARD LIGHTING LUMINAIRES

[Substation-yard lighting luminaires shall be enclosed and gasketed vaportight fixtures especially designed for substations to illuminate overhead vertical and horizontal surfaces of the substation structure.

Luminaires shall include cast-aluminum fittings with pole-top slip fitters and supports for lampholder and reflector assemblies. Lampholder shall be porcelain with mogul base and shall support the lamp in a vertical base-down burning position. Slip fitter shall secure the fixture to the pole with corrosion-resistant steel setscrews. Collar of the reflector assembly shall engage threads in the cast-aluminum fitting with corrosion-resistant steel setscrews that will prevent rotation of the luminaire after beam adjustment.

Reflector assembly shall include a reflector with cast-aluminum threaded collar, refractor, and top access cover. Reflector and refractor shall be sealed at the joint with a clamping band formed from sheet aluminum or corrosion-resistant steel. Refractor and access cover shall be sealed with a heat-resistant weatherproof gasket and secured with spring-loaded corrosion-resistant steel latches.

Reflector and access cover shall be formed from anodized sheet aluminum. Reflecting surfaces shall have a specular finish. Refractor shall be molded prismatic heat-resistant borosilicate glass designed to provide not less than 60 percent of the total lamp lumens in the upward direction. Maximum **illuminance candlepower** of the lighting-distribution curve shall be adjustable plus or minus 5 degrees.

Wiring shall be concealed in lighting standards and luminaires.]

2.6 LIGHTING STANDARDS

[Lighting requirements shall be in accordance with Section **26 56 19.00 40 ROADWAY LIGHTING**.]

Lighting standards, including poles, anchor base, transformer base, brackets, and accessories, shall conform to **ANSI/IEEE C136.3**. Lighting standards shall be designed to withstand vertical and horizontal loading on

the entire structure and supported equipment without damage or permanent deformation to any component of the lighting standard. Standards shall be set in a concrete base. Installations provided with photocell devices shall operate at 320 lux on and 650 lux off 30 foot-candles (fc) on and 60 fc off.

Lamp ballasts shall maintain correct lamp operation over a voltage-input range of plus or minus 13 percent of rated voltage. Capacitors shall provide a power-factor lamp load of not less than 95 percent.

Ballasts shall be voltage rated for operation on [120] [277]-volt, single-phase, 60-hertz lighting-distribution systems.

Ballasts shall be designed for a minimum lamp starting temperature of minus 29 degrees C 20 degrees F and a maximum ambient temperature of 40 degrees C 105 degrees F.

2.7 SERIES CIRCUIT TRANSFORMERS

Series type transformers shall include a two-winding core-and-coil assembly designed for connection to constant-current supply circuits in accordance with ANSI C82.5 and ANSI C82.9.

Primary winding of the transformer shall be designed for connection to [6.6] [20]-ampere constant-current street-lighting circuits. Transformer shall provide the proper starting voltage and operating current for the appropriate lamp.

Transformers shall be designed for a maximum ambient temperature of 40 degrees C 105 degrees F.

2.8 LAMPS

2.8.1 HID Lamps

High Intensity Discharge (HID) lamps shall be automatically self-extinguishing and shall conform to 21 CFR 1040, Section 30, when used in a populated area.

2.8.2 Low-Pressure Sodium

Low-Pressure Sodium (LPS) lamps shall be in accordance with ANSI/NEMA C78.41.

2.8.3 High-Pressure Sodium

High-Pressure Sodium (HPS) lamps shall be in accordance with ANSI/NEMA C78.388.

2.8.4 Metal Halide

Metal Halide lamps shall be in accordance with ANSI/NEMA LSD 25.

2.8.5 Incandescent Lamps

Incandescent Lamps shall be in accordance with UL 1571.

General-purpose incandescent lamps up to 300 watts shall have medium screw bases.

Lamps with wattage ratings above 300 watts shall have mogul screw bases.

Special-purpose PAR and R lamps shall have wall reflector. R lamps shall have clear soft-blown-glass bulbs with silver-deposited inner-bulb wall reflector.

Lamps shall be designed for operation on 120-volt, 60-hertz circuits.

PART 3 EXECUTION

3.1 INSTALLATION

Floodlighting fixtures shall be installed in accordance with NFPA 70, and lamps of the proper type, voltage, and wattage shall be installed in each fixture.

New lamps shall be installed immediately prior to completion of the project. Lamps shall be installed with the light center at the focal point in the reflector and in the proper burning position. Fixtures shall be aimed at night to provide optimum light coverage.

Installation Drawings shall be submitted for Floodlighting Systems. Drawings shall indicate overall physical features, dimensions, ratings, service requirements, and weights of equipment.

3.2 FIELD TESTING

Floodlighting fixtures installation shall be demonstrated to operate satisfactorily in the presence of the Contracting Officer.

Operational Tests shall be performed in accordance with referenced standards in this section.

-- End of Section --