

\*\*\*\*\*  
USACE / NAVFAC / AFCEA UFGS-11330 (February 2005)  
-----  
Preparing Activity: USACE Superseding  
UFGS-11330 (August 2004)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMLR dated 22 December 2004

Latest change indicated by CHG tags

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 11 - EQUIPMENT

##### SECTION 11330

##### SEWAGE BAR SCREEN AND MECHANICAL SHREDDER

02/05

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 GENERAL REQUIREMENTS
  - 1.2.1 Standard Products
  - 1.2.2 Nameplates
  - 1.2.3 Protection from Moving Parts
  - 1.2.4 Verification of Dimensions
- 1.3 SUBMITTALS
- 1.4 DELIVERY AND STORAGE
- 1.5 MANUFACTURER'S SERVICES

#### PART 2 PRODUCTS

- 2.1 MATERIALS AND EQUIPMENT
  - 2.1.1 Bearings
  - 2.1.2 Iron, Steel, and Miscellaneous Metal
    - 2.1.2.1 Miscellaneous Metal
    - 2.1.2.2 Malleable Iron
    - 2.1.2.3 Structural Steel
  - 2.1.3 Motors, Electric
  - 2.1.4 Motor Controls
  - 2.1.5 Switches, Enclosed
- 2.2 ELECTRICAL WORK
  - 2.2.1 Electric Motors
  - 2.2.2 Motor Controls
- 2.3 HYDRAULIC WORK
  - 2.3.1 Fluid Motors
  - 2.3.2 Hydraulic Controls
  - 2.3.3 Fluid Power Valves
  - 2.3.4 Fluid Tubing
  - 2.3.5 Hydraulic Fluid
- 2.4 MECHANICALLY-CLEANED BAR SCREEN
  - 2.4.1 Bar Screen

- 2.4.2 Screen Rake
  - 2.4.2.1 Rake Mechanism
  - 2.4.2.2 Revolving-Frame-Type
  - 2.4.2.3 Automatic-Hoist-Type
  - 2.4.2.4 Endless-Chain-Type
  - 2.4.2.5 Screw-Drive Type
  - 2.4.2.6 Rake Mechanism Control Equipment
- 2.5 MECHANICAL SHREDDER, CUTTER, OR GRINDER
  - 2.5.1 Operation Requirements
  - 2.5.2 Control Equipment
  - 2.5.3 Cutter Mechanism
  - 2.5.4 Bearings
  - 2.5.5 Stuffing Boxes
  - 2.5.6 Lubrication

### PART 3 EXECUTION

- 3.1 INSTALLATION
- 3.2 CONCRETE FOUNDATIONS
- 3.3 SPECIAL TOOLS
- 3.4 PAINTING
- 3.5 FRAMED INSTRUCTIONS
- 3.6 TESTS
- 3.7 TRAINING

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEA UFGS-11330 (February 2005)  
-----  
Preparing Activity: USACE Superseding  
UFGS-11330 (August 2004)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated 22 December 2004

Latest change indicated by CHG tags

\*\*\*\*\*

### SECTION 11330

#### SEWAGE BAR SCREEN AND MECHANICAL SHREDDER 02/05

\*\*\*\*\*

NOTE: This guide specification covers the requirements for sewage bar screen and mechanical shredder for use in sewage treatment plants normally handling domestic sewage.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

Use of electronic communication is encouraged.

Brackets are used in the text to indicate designer choices or locations where text must be supplied by the designer.

\*\*\*\*\*

#### PART 1 GENERAL

\*\*\*\*\*

NOTE: Refer to TM 5-814-3 for design requirements. This guide specification is written for one bar screen and mechanical shredder.

\*\*\*\*\*

#### 1.1 REFERENCES

\*\*\*\*\*

NOTE: Issue (date) of references included in project specifications need not be more current than provided by the latest guide specification. Use of SpecsIntact automated reference checking is recommended for projects based on older guide specifications.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN BEARING MANUFACTURERS ASSOCIATION (ABMA)

ABMA 11 (1990; R 1999) Load Ratings and Fatigue Life for Roller Bearings

ABMA 9 (1990; R 2000) Load Ratings and Fatigue Life for Ball Bearings

ASTM INTERNATIONAL (ASTM)

ASTM A 153/A 153M (2004) Zinc Coating (Hot-Dip) on Iron and Steel Hardware

ASTM A 36/A 36M (2004) Carbon Structural Steel

ASTM A 47/A 47M (1999) Ferritic Malleable Iron Castings

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA 250 (2003) Enclosures for Electrical Equipment (1000 Volts Maximum)

NEMA ICS 1 (2000) Industrial Control and Systems: General Requirements

NEMA ICS 2 (2000) Industrial Controls and Systems: Controllers, Contactors, and Overload Relays Rated Not More than 2000 Volts AC or 750 Volts DC

NEMA ICS 3 (1993; R 2000) Industrial Control and Systems: Medium Voltage Controllers Rated 2001 to 7200 Volts AC

NEMA ICS 4 (2000) Industrial Control and Systems: Terminal Blocks

NEMA ICS 6 (1993; R 2001) Industrial Control and Systems: Enclosures

NEMA MG 1 (2003) Motors and Generators

NATIONAL FLUID POWER ASSOCIATION (NFLPA)

NFLPA T2.13.1 R3 (1998) Practice for the Use of Fire Resistant Fluids in Industrial Hydraulic Fluid Power Systems

SOCIETY OF AUTOMOTIVE ENGINEERS INTERNATIONAL (SAE)

SAE J1677 (2004) Tests and Procedures for Steel and Copper Nickel Tubing

UNDERWRITERS LABORATORIES (UL)

UL 98

(2004) Enclosed and Dead-Front Switches

1.2 GENERAL REQUIREMENTS

1.2.1 Standard Products

Material and equipment shall be the standard products of a manufacturer regularly engaged in the manufacture of the products.

1.2.2 Nameplates

Each major item of equipment shall have manufacturer's name, address, and catalog or model number on a plate securely attached to item. In lieu of nameplate on the shredder and bar screen, manufacturer's name or trademark may be cast integrally with shredder, stamped, or otherwise permanently marked.

1.2.3 Protection from Moving Parts

Moving parts of the equipment, such as drive chains and sprockets, shall be fully enclosed in removable guards. Equipment above the level of the sewage-carrying channel shall be fully enclosed in a cast iron or 1.897 mm (14 gauge) 14 gauge sheet steel or wrought-iron housing. Housing shall be provided with a sufficient number of doors or removable panels to ensure ready access to any part of equipment for repairs, replacements, or cleaning. Joint between the housing and the concrete foundation shall be made leakproof.

1.2.4 Verification of Dimensions

The Contractor shall become familiar with all details of the work, verify all dimensions in the field, and shall advise the Contracting Officer of any discrepancy before performing the work.

1.3 SUBMITTALS

\*\*\*\*\*

NOTE: Submittals must be limited to those necessary for adequate quality control. The importance of an item in the project should be one of the primary factors in determining if a submittal for the item should be required.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident

Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy projects.

Submittal items not designated with a "G" are considered as being for information only for Army projects and for Contractor Quality Control approval for Navy projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for [Contractor Quality Control approval.] [information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] The following shall be submitted in accordance with Section 01330 SUBMITTAL PROCEDURES:

#### SD-02 Shop Drawings

Installation[; G][; G, [\_\_\_\_\_]]

Detail drawings shall consist of a complete list of equipment and materials, including manufacturer's descriptive and technical literature, catalog cuts; and installation instructions. Detail drawings shall also contain complete wiring and schematic diagrams, equipment layout and anchorage, and any other details required to demonstrate that the system has been coordinated and will properly function as a unit.

#### SD-03 Product Data

##### Spare Parts

Spare parts data for each different item of material and equipment specified, after approval of the detail drawings, and not later than [\_\_\_\_\_] months prior to the date of beneficial occupancy. The data shall include a complete list of parts and supplies, with current unit prices and source of supply, and a list of the parts recommended by the manufacturer to be replaced after [1] [and] [3] year(s) of service.

##### Framed Instructions

Framed instructions under glass or in laminated plastic, as specified.

#### SD-06 Test Reports

##### Tests

Upon completion and testing of the installed system, test reports shall be submitted in booklet form showing all field tests performed to adjust each component and all field tests performed to prove compliance with the specified performance criteria. Each test report shall indicate the final position of controls.

## SD-10 Operation and Maintenance Data

### Operating and Maintenance Instructions

[Six] [\_\_\_\_\_] complete copies of operating instructions outlining the step-by-step procedures required for system startup, operation and shutdown. The instructions shall include the manufacturer's name, model number, service manual, parts list, and brief description of all equipment and their basic operating features. [Six] [\_\_\_\_\_] complete copies of maintenance instructions listing routine maintenance procedures, possible breakdowns and repairs, and troubleshooting guides. The instructions shall include simplified diagrams for the system as installed.

#### 1.4 DELIVERY AND STORAGE

All equipment delivered and placed in storage shall be stored with protection from the weather, humidity and temperature variation, dirt and dust, or other contaminants.

#### 1.5 MANUFACTURER'S SERVICES

The Contractor shall obtain the services of the manufacturer's representative who is experienced in the installation, adjustment, and operation of the equipment specified. The representative shall supervise the installation, adjustment, and testing of the equipment.

### PART 2 PRODUCTS

#### 2.1 MATERIALS AND EQUIPMENT

Materials and equipment shall conform to the respective publications and other requirements specified and shall be the standard products of a manufacturer regularly engaged in the manufacture of the products. Items of equipment shall essentially duplicate equipment that has been in satisfactory use at least 2 years prior to bid opening. Equipment shall be supported by a service organization that is, in the opinion of the Contracting Officer, reasonably convenient to the site.

##### 2.1.1 Bearings

ABMA 9 and ABMA 11.

##### 2.1.2 Iron, Steel, and Miscellaneous Metal

###### 2.1.2.1 Miscellaneous Metal

Bolts, nuts, anchors, washers, and other types of supports necessary for the installation of equipment shall be of steel or wrought iron, galvanized according to the requirements of ASTM A 153/A 153M.

###### 2.1.2.2 Malleable Iron

ASTM A 47/A 47M, grade No. 32510, minimum.

#### 2.1.2.3 Structural Steel

ASTM A 36/A 36M.

#### 2.1.3 Motors, Electric

NEMA 250, NEMA ICS 1, NEMA ICS 3, NEMA ICS 4, NEMA ICS 6 and NEMA MG 1.

#### 2.1.4 Motor Controls

NEMA ICS 2.

#### 2.1.5 Switches, Enclosed

UL 98.

### 2.2 ELECTRICAL WORK

Electrical equipment and wiring shall be in accordance with Section 16402 INTERIOR DISTRIBUTION SYSTEM. Electrical characteristics shall be as indicated. Manual or automatic control and protective or signal devices required for the operation specified, and any control wiring required for controls and devices but not shown on electrical plans, shall be provided under this section of the specification.

#### 2.2.1 Electric Motors

Equipment shall be provided complete with motors of the [open] [totally enclosed] ball-bearing squirrel-cage induction type, with a maximum speed not to exceed 1800 rpm. Motors shall be of sufficient capacity to drive equipment at the specified capacity without exceeding rating shown on nameplate attached to the motor.

#### 2.2.2 Motor Controls

Motor controls shall be provided to control the motor in the manner indicated or specified. Motor controls shall be coordinated with the associated motor and shall have properly sized thermal-overload protective elements. Except where otherwise indicated, starters shall be provided in [general-purpose] [weatherproof] enclosures. Where manual control is specified, starter shall be provided with a start-stop pushbutton in the cover. Where automatic control is specified, starter shall be provided with a hand-off-automatic selector switch in the cover. Each starter shall bear an appropriate nameplate or stencil identifying equipment controlled.

### 2.3 HYDRAULIC WORK

Hydraulic equipment and application shall be in accordance with Section 15495 HYDRAULIC FLUID POWER SYSTEMS. Manual or automatic control and protective or signal devices required for the operation specified, and any control wiring or hydraulic connections required for controls and devices but not shown on electrical or hydraulic plans, shall be provided under this section of the specification.

#### 2.3.1 Fluid Motors

Equipment shall be provided complete with fluid motors of the [vane] [piston] type. Motors shall be of sufficient capacity to drive equipment at the specified rating without exceeding rating shown on the nameplate



attached to the motor.

#### 2.3.2 Hydraulic Controls

Controls shall be provided in the manner indicated or specified, shall be coordinated with the associated equipment, and shall have properly sized overload protective elements.

#### 2.3.3 Fluid Power Valves

SAE J1677.

#### 2.3.4 Fluid Tubing

SAE J1677.

#### 2.3.5 Hydraulic Fluid

NFLPA T2.13.1 R3.

### 2.4 MECHANICALLY-CLEANED BAR SCREEN

Bar screen shall consist of a stationary bar screen, a screen rake, a rake mechanism operated by [an electric] [a hydraulic] drive unit, and a dead plate and rake-cleaning device, where required. Equipment shall be installed so as not to obstruct the flow of sewage to bar screen. Unless otherwise specified, metal that is submerged in the sewage-carrying channel or that comes in contact with sewage shall be of wrought iron, steel, cast iron, or other equally corrosion-resistant metal.

#### 2.4.1 Bar Screen

Each bar screen shall be suitable for installation in a rectangular channel [\_\_\_\_\_] m [\_\_\_\_\_] -feet [\_\_\_\_\_] -inches wide by [\_\_\_\_\_] m [\_\_\_\_\_] -feet [\_\_\_\_\_] -inches deep, and shall be designed for handling sewage flows as follows:

Minimum, [\_\_\_\_\_] cubic meters/day MGD.

Average, [\_\_\_\_\_] cubic meters/day MGD.

Maximum, [\_\_\_\_\_] cubic meters/day MGD.

#### 2.4.2 Screen Rake

Rake shall be designed to rake up screenings collected on the bar screen and in the openings between bars, and to convey screenings to a [drain platform] [collection trough] [grinder]. Rake shall be of cast iron, steel, or other suitable material not less than [\_\_\_\_\_] mm inch thick. Rake teeth shall be spaced so as to pass between bars of the screen. Rake teeth plate shall be easily removable and replaceable.

##### 2.4.2.1 Rake Mechanism

Mechanism shall be revolving-frame, automatic-hoist, endless-chain type, or screw-drive type and shall include parts and accessories necessary for a complete operating unit. Parts of the mechanism shall be amply proportioned for stresses that may occur during fabrication, erection, and operation. Individual parts that are alike in each unit shall be

interchangeable. Shearing pins or an overload-release mechanism shall be provided for overload protection. Rake speed shall not exceed [\_\_\_\_\_] m/second feet per minute. Rake mechanism shall be provided with a complete and adequate system of lubrication to moving parts subject to wear. Bearings shall be grease- or oil-lubricated except submerged bearings which shall be of alloy-bearing metal designed to operate without any lubrication and to prevent accumulation of deposits.

#### 2.4.2.2 Revolving-Frame-Type

Revolving-frame-type rake mechanism shall consist of two pairs of structural-steel-angle rake arms mounted on a horizontal shaft. Screen rakes shall be attached to steel crossbars mounted on the outer end of each pair of rake arms. Entire rake mechanism shall revolve about the horizontal shaft.

#### 2.4.2.3 Automatic-Hoist-Type

Automatic-hoist-type rake mechanism shall consist of a reciprocating rake mounted on a horizontal shaft or frame and guided by steel channels or angles at each end of the frame. Rake and frame shall be pulled up the slope of the guide rails by two or more cables operating over motor-propelled grooved drums. After screenings are discharged, rake frame shall be automatically tilted and lowered to the bottom of screen.

#### 2.4.2.4 Endless-Chain-Type

Endless-chain-type rake mechanism shall consist of a drive chain, drive sprockets, and sprocket wheels mounted on a drive shaft, and an idler shaft where required, operating two endless chains with rakes securely attached.

- a. Drive chain connecting motor sprocket with the drive shaft and the endless chain shall be of malleable iron with heat-treated-steel pins or rivets. A chain tightener or takeup bracket shall be provided for drive chain. Chains shall be of suitable size and design to withstand strains imposed.
- b. Sprockets for the drive and endless chains shall be of semi-steel or cast iron with chilled teeth and rims. Rims and teeth of the sprockets shall be accurately ground to fit chains. Sprockets shall be of size recommended by the equipment manufacturer. Shafting shall be of cold-rolled steel, straight and true, and of ample diameter to transmit the power required without undue deflection. Keyways where required shall be accurately cut. Malleable iron or bronze safety collars shall be provided where required to keep shafting and sprockets in alignment.

#### 2.4.2.5 Screw-Drive Type

Screw-drive type rake mechanism shall consist of a reversing threaded screw-drive and bearing nut attached to rake. Rake shall have reciprocating action.

#### 2.4.2.6 Rake Mechanism Control Equipment

Starting of motor shall be actuated by means of [automatic time switch for intermittent operation, adjustable to give 3 to 60 minutes between cycles] [float switch for automatic operation at predetermined levels] [float switch for automatic operation at predetermined rise in head of sewage on

the upstream side of the screen bar]. [Floats shall be constructed of corrosion-resistant metal.]

- a. Endless-Chain-Type-Rake Mechanism: A motor-reversing switch shall be provided so that direction of travel of the rake mechanism can be reversed in the event of jamming. The motor-reversing switch shall be a double-throw externally operable switch enclosed in a [raintight] [watertight] enclosure. The switch shall be marked: "Forward," "Off," "Reverse."
- b. Automatic Hoist-Type Rake Mechanism: Starters for this type of rake mechanism shall be of the reversing type. Control devices shall be so arranged that on completion of upward travel of the rake mechanism, motor will be stopped and then reversed, and rake will travel to the lower position, at which point motor will again stop and be automatically adjusted for the next automatic operation.
- c. Revolving Frame-Type Rake Mechanism: An emergency stop push-button and a rake limit switch, to always stop the rake out of water after discharge of screenings, shall be provided in a weatherproof enclosure.
- d. Bearing Type Rake Mechanism: Travel of the rake in a downward or upward direction shall be controlled by proximity switches. Frequency of raking shall be adjustable. Rake delay shall be on the [top] [bottom]. Rake drive shall be [hydraulic] [electric]. Overload protection shall be provided for down and up stroke. Drive shall have a control panel (minimum NEMA ICS 2) mounted.
- e. Rake Wiper: Where required to remove screenings from rake, a rake wiping or scraping device shall be provided at the discharge point of rake. Device shall consist of either a plate attached to swinging hinged arms or a continuous hinged plate actuated by motion of the rake. Wiper shall be so designed that after cleaning of the rake is completed, wiper will fall into the proper place ready for the next scraping operation. Fall of wiper shall be controlled either mechanically or hydraulically to absorb any shock.
- f. Dead Plate or Apron: A wrought iron or steel dead plate shall be provided where required to prevent any deposited screenings from falling into the downstream side of rake. Dead plate shall be not less than 2.657 mm (12 gauge) 12 gauge metal if required by the design and type of rake mechanism installed, and shall be rigidly braced if required.

## 2.5 MECHANICAL SHREDDER, CUTTER, OR GRINDER

### 2.5.1 Operation Requirements

Shredder, cutter, or grinder unit shall be suitable to receive screenings from screening unit specified and to discharge resulting pulp into the sewage flow. Machine shall be operated by an electric drive unit and shall be designed to cut sewage solids, including sticks, rags, and stringy material without clogging, jamming, or stalling moving parts. Grinder and drive unit shall be direct connected by a flexible or friction-type coupling and integrally mounted on a structural steel or cast iron base. Grinder shall be provided with a water-flushing system where required to

flush ground solids through the machine. Machine shall have a capacity of grinding [\_\_\_\_\_] kg pounds of sewage screening per hour.

#### 2.5.2 Control Equipment

Control shall be so arranged that shredder motor will automatically start when the rake-mechanism motor starts. A relay shall be provided to allow the shredder to continue to run for a predetermined time after rake mechanism has stopped, and to automatically stop the shredder motor.

#### 2.5.3 Cutter Mechanism

Cutter shall consist of cutting blades or impellers mounted on a revolving shaft or drum in contact with a stationary cutter screen or blade. Cutting devices shall be of tool steel or other material equally suitable for cutting tools, and shall be accurately cut and ground to size to provide sharp cutting edges having extreme resistance to wear.

#### 2.5.4 Bearings

Bearings shall be of the self-aligning ball or roller type. Bearings and bearing supports shall be designed to safely carry and withstand the stresses imposed by the disintegrating action of the grinder.

#### 2.5.5 Stuffing Boxes

Wherever the drum shaft passes through the machine housing, stuffing boxes of proper depth and construction shall be provided.

#### 2.5.6 Lubrication

Moving parts, subject to wear, and bearings shall be provided with adequate devices for grease or oil lubrication.

### PART 3 EXECUTION

#### 3.1 INSTALLATION

All materials and equipment shall be installed as shown and in accordance with the approved written recommendations of the equipment manufacturer.

#### 3.2 CONCRETE FOUNDATIONS

Concrete for foundations shall be as specified in Section 03300A CAST-IN-PLACE STRUCTURAL CONCRETE. Concrete foundations shall be integral with, and of same strength as the building floor, unless otherwise specified. Concrete used in foundations that are entirely separated from the surrounding floor shall be 17 MPa 2500 psi. When new foundations are constructed on existing concrete, new concrete shall be bonded to old as specified in Section 03300A CAST-IN-PLACE STRUCTURAL CONCRETE. Foundation bolts, as required, shall be furnished for proper positioning during placement of concrete.

#### 3.3 SPECIAL TOOLS

Special tools shall be furnished for the proper operation and maintenance of equipment, and shall be installed in a wall-mounted hardwood or metal container. The Contractor shall furnish a complete set of manufacturer's recommended spare parts including cutting teeth and combs or other cutting

elements, fasteners, screens, seals or bearings, etc.

#### 3.4 PAINTING

Equipment shall be thoroughly cleaned, primed, and given two finish coats of paint at the factory in accordance with the recommendations of the manufacturer. Field painting is specified in Section 09900 PAINTS AND COATINGS.

#### 3.5 FRAMED INSTRUCTIONS

The Contractor shall provide framed instructions, including wiring and control diagrams, showing the complete layout of the entire system, posted where directed. The framed instructions shall be posted before acceptance testing of the systems. Condensed operating instructions explaining preventive maintenance procedures, methods of checking the system for normal safe operation and procedures for safely starting and stopping the system shall be prepared in typed form, framed as specified above for the wiring and control diagrams and posted beside the diagrams. Proposed diagrams, instructions, and other sheets, prior to posting.

#### 3.6 TESTS

After installation of the sewage bar screen and mechanical shredder is complete, Contractor shall conduct operational tests required to demonstrate that the sewage bar screen and mechanical shredder will operate in accordance with the requirements of this section of the specifications.

#### 3.7 TRAINING

A field training course shall be provided for designated operating and maintenance staff members. Training shall be provided for a total period of [\_\_\_\_\_] hours of normal working time and shall start after the system is functionally complete but prior to final acceptance tests. Field training shall cover all of the items contained in the Operating and Maintenance Instructions.

-- End of Section --