
USACE / NAVFAC / AFCEA / NASA UFGS-31 31 16.19 (April 2006)

Preparing Activity: NAVFAC Replacing without change
 UFGS-02363 (August 2004)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2011

SECTION TABLE OF CONTENTS

DIVISION 31 - EARTHWORK

SECTION 31 31 16.19

TERMITE CONTROL BARRIER SYSTEM

04/06

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SYSTEM DESCRIPTION
- 1.3 SUBMITTALS
- 1.4 QUALITY ASSURANCE
 - 1.4.1 QUALIFICATIONS OF SYSTEM INSTALLERS
 - 1.4.2 PREINSTALLATION MEETING
- 1.5 DELIVERY, STORAGE AND HANDLING
- 1.6 WARRANTY

PART 2 PRODUCTS

- 2.1 MATERIALS
 - 2.1.1 Asbestos Prohibition
 - 2.1.2 Barrier Mesh
 - 2.1.3 Accessories

PART 3 EXECUTION

- 3.1 SURFACE EXAMINATION
 - 3.1.1 Examination
 - 3.1.2 Verification
- 3.2 INSTALLATION
 - 3.2.1 Instructions
 - 3.2.2 Installation Sequence
- 3.3 PROTECTION
- 3.4 VISUAL INSPECTION GUIDE
- 3.5 FIELD QUALITY CONTROL

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-31 31 16.19 (April 2006)

Preparing Activity: NAVFAC Replacing without change
 UFGS-02363 (August 2004)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2011

SECTION 31 31 16.19

TERMITE CONTROL BARRIER SYSTEM 04/06

NOTE: This guide specification covers the requirements for termite control barrier system.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

NOTE: This specification consists of furnishing and installing a complete stainless steel mesh system at all penetrations, joints and perimeter foundations as a physical barrier below the concrete slabs and foundations of a structure to prevent the entry of Formosan and other ground termites into wood components of the structure, similar to laying down a chemical barrier of soil termiticide treatments.

The use of this material does not preclude the use of other preventive measures such as chemical treatment, basaltic termite barrier system and pressure treated lumber for construction to provide maximum protection to the structure. In fact, it is recommended that this material be used in conjunction with chemical treatment at all vulnerable areas such as penetration areas around electrical conduits and plumbing pipes that penetrate the slab as well as the foundation

perimeter and shoulder portions of the barrier.
This termite physical protection system must comply
with all codes. It is also recommended that
pressure treated lumber be used to provide maximum
protection to the structure.

PART 1 GENERAL

NOTE: Termite infestation exists throughout the
United States and overseas areas with the exception
of Alaska. Mesh termite barriers can be prescribed
for installation at all sites where termites are
likely to establish colonies and make concealed
entries to wood construction, when it is deemed
appropriate and cost effective.

1.1 REFERENCES

NOTE: This paragraph is used to list the
publications cited in the text of the guide
specification. The publications are referred to in
the text by basic designation only and listed in
this paragraph by organization, designation, date,
and title.

Use the Reference Wizard's Check Reference feature
when you add a RID outside of the Section's
Reference Article to automatically place the
reference in the Reference Article. Also use the
Reference Wizard's Check Reference feature to update
the issue dates.

References not used in the text will automatically
be deleted from this section of the project
specification when you choose to reconcile
references in the publish print process.

The publications listed below form a part of this specification to the
extent referenced. The publications are referred to within the text by the
basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM A478 (1997; R 2008) Standard Specification for
Chromium-Nickel Stainless Steel Weaving
and Knitting Wire

ASTM A580/A580M (2008) Standard Specification for
Stainless Steel Wire

1.2 SYSTEM DESCRIPTION

NOTE: A complete termite control barrier system
encompasses a fine steel mesh placed across all

termite entry points to the building. Principal entry points include all cracks, joints, penetrations and other termite entry points within the concrete slabs and cavities in walls. The steel mesh and fastening system physically prevents the termites from entering the building. The mesh is too fine for the termites to squeeze through, too hard to chew through, and highly corrosion resistant for future break down.

Place the stainless steel termite mesh barrier across all openings, joints, penetrations and other termite entry points to the building (including all shrinkage cracks in concrete slabs and built penetrations in slabs and walls that termites may use for access point) and as per manufacturer's recommendations. Clamp, parge adhere, bond and/or embed the termite mesh to the material surrounding the opening as per the manufacturer's recommendations. Install with no gaps, penetrations or damage to the mesh system.

1.3 SUBMITTALS

NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the

"G" designation identifies the office that will review the submittal for the Government.] The following shall be submitted in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Barrier Mesh

Shop drawings of the termite barrier mesh system installation at all perimeter foundations, joint and penetration conditions.

SD-03 Product Data

Barrier Mesh

Accessories

System Description

Catalog cuts, illustrations, schedules, diagrams, performance charts, instructions and brochures illustrating size, physical appearance and other characteristics of materials or equipment.

Manufacturer's Guidance[; G][; G, [_____]]

Visual Inspection Guide[; G][; G, [_____]]

SD-04 Samples

Barrier Mesh[; G][; G, [_____]]

Samples of stainless steel mesh to be used in this work, 102 x 102 mm 4 x 4 inches.

SD-07 Certificates

System Installers[; G][; G, [_____]]

Certification that installers meet the requirements specified under paragraph entitled "Qualifications of System Installers.

Materials

Statements signed by responsible officials of manufacturer of product, system or material attesting that product, system or material meets specification requirements. Must be dated after award of project contract and clearly name the project.

SD-08 Manufacturer's Instructions

Manufacturer's Installation Instruction Manual.

Preprinted material describing installation of a product, system or material, including special notices and Material Safety Data sheets concerning impedances, hazards and safety precautions.

SD-09 Manufacturer's Field Reports

Site Conditions

Documentation of the testing and verification actions taken by manufacturer's representative to confirm compliance with manufacturer's standards or instructions.

Written verification that site conditions are as required and other site work will not disturb the installation.

SD-11 Closeout Submittals

Warranty

Written warranty required in paragraph entitled "Warranty" and signed jointly by an officer of the Contractor and the supplier.

1.4 QUALITY ASSURANCE

1.4.1 QUALIFICATIONS OF SYSTEM INSTALLERS

- a. The installer shall be trained and accredited by the system supplier.
- b. The installer shall employ only workers trained and accredited at the appropriate level by the system supplier.

1.4.2 PREINSTALLATION MEETING

Convene a preinstallation meeting at least one week prior to beginning installation, to review conditions of preparation, storage and handling, installation procedures, sequencing, protection and coordination with other related work. Attendance by the project superintendent, installer, installer's crew leader, and representatives of the trades affected by this work is required. Notify the Contracting Officer at least 10 calendar days before meeting.

1.5 DELIVERY, STORAGE AND HANDLING

Deliver materials to the site in original unbroken packaging and containers, with original labels in place. Store materials in conformance with system supplier's recommendations.

1.6 WARRANTY

NOTE: Use 5 years for family housing and 3 years for
other types of facilities.

Furnish a [3] [5] year written warranty against infestations or reinfestation by subterranean termites of the buildings or building additions constructed under this contract. Perform annual inspections of the building[s] or building addition[s]. If live subterranean termite infestation or subterranean termite damage is discovered during the warranty period, and building conditions have not been altered in the interim, the Contractor shall:

- a. Correct defective stainless steel mesh installation and perform other treatment as may be necessary for elimination of subterranean termite infestation;

- b. Repair damage caused by termite infestation; and
- c. Reinspect the building approximately 180 calendar days after the repair.

PART 2 PRODUCTS

NOTE: Check with local agencies to determine the
local building code requirements and specifications
to ensure conformance where required.

2.1 MATERIALS

2.1.1 Asbestos Prohibition

No asbestos containing materials or equipment are permitted at the job site. The contractor shall ensure that materials proposed for the project are asbestos free.

2.1.2 Barrier Mesh

Stainless steel mesh shall conform to ASTM A478 and ASTM A580/A580M, Type A1AA marine grade 316 stainless steel mesh of 0.18 mm 0.007 in. diameter wire with mesh openings of 0.66 x 0.45 mm. 0.026 x 0.018 inches.

2.1.3 Accessories

Parging adhesives, bonding cement, high grade stainless steel clamps, ties, and other accessories as recommended by system supplier.

PART 3 EXECUTION

NOTE: The stainless steel mesh must be installed in
a manner to provide maximum protection to the
dwelling. The material provides a physical barrier
to the termites, thus, preventing entry. A range of
techniques and material widths may be required to
meet site conditions. The designer is required to
determine the extent of openings to be covered to
provide quantity estimates for the material
installed.

3.1 SURFACE EXAMINATION

3.1.1 Examination

Examine the substrates and conditions under which work of this section will be performed. Do not proceed until unsatisfactory conditions detrimental to timely and proper completion of the work have been corrected.

3.1.2 Verification

Provide written verification that the site conditions under the proposed slab(s) are proper for the installation of termite barrier system as per

manufacturer's recommendations. Perform work related to final grades, landscape plantings, foundations, or any other operations that might alter the condition of the site, in accordance with this specification. Before installation, ensure that:

- a. The ground has been cleared of wood scraps such as ground stakes, forms and other termite food sources.
- b. The work area has been filled with finely graded soil consisting of particle sizes no larger than 25 mm 1 in and compacted to eliminate soil movement. The condition of the site shall meet the manufacturer's recommendations for installing the mesh barrier.
- c. Footings and foundations, and outer forms are in place.
- d. Communications, electrical and plumbing penetrating pipes are in place.

3.2 INSTALLATION

3.2.1 Instructions

Strictly follow the manufacturer's instructions published in [Manufacturer's Installation Instruction Manual](#).

3.2.2 Installation Sequence

- a. Install mesh as required, fit and clamp mesh around all pipe penetrations, and terminate at perimeters as appropriate for the building construction as described in installation manual.
- b. Install special fittings appropriate to construction as described in installation manual.
- c. Following installation of mesh, vapor barrier, install reinforcing steel and concrete specified under other sections.
- d. Where required, integrate mesh into subsequent construction as described in installation manual.

3.3 PROTECTION

Protect the installed termite mesh system, attachments and accessories before, during and after the work of all trades as required by the system supplier or directed by the Contracting Officer.

Do not place dissimilar metals in contact with the stainless steel mesh to avoid an electrolytic reaction.

3.4 [VISUAL INSPECTION GUIDE](#)

To maintain resistance to termites, complete the system and do not disturb, penetrate or damage during the remaining contract time period. Provide [Manufacturer's Guidance](#) for performing a visual assessment of the installed mesh barrier to ensure the mesh barrier provides the designed termite physical barrier.

3.5 FIELD QUALITY CONTROL

In the event following trades on the site move or damage the mesh, clamps or parging mix, immediately contact the mesh installer, for recommendation of necessary repairs.

-- End of Section --