
USACE / NAVFAC / AFCEA / NASA UFGS-10 44 16 (May 2012)

Preparing Activity: NASA Superseding
UFGS-10 44 16 (May 2009)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2012

SECTION TABLE OF CONTENTS

DIVISION 10 - SPECIALTIES

SECTION 10 44 16

FIRE EXTINGUISHERS

05/12

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 DELIVERABLES
 - 1.3.1 Samples
- 1.4 DELIVERY, HANDLING, AND STORAGE
- 1.5 WARRANTY

PART 2 PRODUCTS

- 2.1 TYPES
- 2.2 MATERIAL
- 2.3 SIZE
- 2.4 ACCESSORIES
- 2.5 CABINETS
 - 2.5.1 Material
 - 2.5.2 Type
 - 2.5.3 Size
- 2.6 WALL BRACKETS

PART 3 EXECUTION

- 3.1 INSTALLATION
- 3.2 ACCEPTANCE PROVISIONS
 - 3.2.1 Repairing
 - 3.2.2 Cleaning

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-10 44 16 (May 2012)

Preparing Activity: NASA Superseding
UFGS-10 44 16 (May 2009)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2012

SECTION 10 44 16

FIRE EXTINGUISHERS

05/12

NOTE: This guide specification covers the requirements for portable fire extinguishers, including wall brackets, accessories, maintenance servicing and inspection tagging requirements.

Associated work found in other sections includes non-portable fire protection systems, alarms and related accessories.

Consult with the local AHJ (Authority Having Jurisdiction) during design stage. Indicate on drawings the locations for proper placement and each type of portable extinguisher located within the installation.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in

the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

INTERNATIONAL CODE COUNCIL (ICC)

ICC IFC (2009) International Fire Code

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 1 (2012) Fire Code

NFPA 10 (2010) Standard for Portable Fire Extinguishers

NFPA 101 (2012; Amendment 1 2012) Life Safety Code

NFPA 303 (2011) Fire Protection Standards for Marinas and Boatyards

NFPA 385 (2012) Standard for Tank Vehicles for Flammable and Combustible Liquids

NFPA 409 (2011; Errata 11-1) Standard on Aircraft Hangars

NFPA 418 (2011) Standard for Heliports

NFPA 505 (2011) Fire Safety Standard for Powered Industrial Trucks Including Type Designations, Areas of Use, Conversions, Maintenance, and Operations

NFPA 99 (2012) Health Care Facilities Code

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

29 CFR 1910.106 Flammable and Combustible Liquids

29 CFR 1910.157 (2003) Portable Fire Extinguishers

UNDERWRITERS LABORATORIES (UL)

UL 154	(2005; Reprint Nov 2010) Carbon-Dioxide Fire Extinguishers
UL 2129	(2005; Reprint Jul 2011) Halocarbon Clean Agent Fire Extinguishers
UL 299	(2002; Reprint Apr 2009) Dry Chemical Fire Extinguishers
UL 626	(2005; Reprint Nov 2010) 2-1/2 Gallon Stored-Pressure, Water-Type Fire Extinguishers
UL 8	(2005; Reprint Jun 2011) Water Based Agent Fire Extinguishers

1.2 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project.

The Guide Specification technical editors have designated those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-01 Preconstruction Submittals

Manufacturer's Data

SD-02 Shop Drawings

Fire Extinguishers

Accessories

Cabinets

Wall Brackets

SD-03 Product Data

Fire Extinguishers

Accessories

Cabinets

Wall Brackets

Replacement Parts

SD-04 Samples

Fire Extinguisher

Cabinet

Wall Brackets

Accessories

SD-07 Certificates

Fire Extinguishers

Manufacturer's Warranty with Inspection Tag

1.3 DELIVERABLES

1.3.1 Samples

Provide the following samples: One of each type of [Fire Extinguisher](#) being installed; one full-sized sample of each type of [Cabinet](#) being installed; three samples of [Wall Brackets](#) and [Accessories](#) of each type being used.

Approved samples may be used for installation, with proper identification and storage.

1.4 DELIVERY, HANDLING, AND STORAGE

Protect materials from weather, soil, and damage during delivery, storage, and construction.

Deliver materials in their original packages, containers, or bundles bearing the brand name and the name and type of the material.

[Provide portable fire extinguishers in compliance with NFPA 505 for all ancillary vehicles where Fire Safety Standard for Powered Industrial Trucks, including type designations, special conditions relating to areas of use, conversions, maintenance, or specific operations apply.

]1.5 WARRANTY

Guarantee that Fire Extinguishers are free of defects in materials, fabrication, finish, and installation and that they will remain so for a period of not less than [_____] years after completion.

PART 2 PRODUCTS

Submit fabrication drawings consisting of fabrication and assembly details performed in the factory and product data for the following items: Fire Extinguishers; Accessories, Cabinets, Wall Brackets.

2.1 TYPES

NOTE: Select one or more of the following types of pressurized fire extinguishers, as required:

Water and Foam - Water extinguishers are for Class A fires only (paper, wood, cloth).

Foam extinguishers are for Class A and B fires only (common combustibles, flammable liquids and gases).

Carbon Dioxide - Carbon Dioxide extinguishers can be used on Class B and C fires (flammable liquids and gases, live electrical equipment).

Dry Chemical - Dry Chemical extinguishers can be used on Class A, B, and C fires (all the above elements) (not recommended for computers or sensitive electrical equipment - use clean agent or Carbon Dioxide).

Wet Chemical - Wet chemical extinguishers are primarily for cooking media fires (high temperature oils and fats) (some may also be used on Class A fires in commercial kitchens).

Clean Agent - Newer Clean Agent extinguishers have replaced former halogenated extinguishers with less ozone depleting halocarbon agents, for Class B and C fires, with some larger units available for use on Class A, B, and C fires.

Dry Powder - Dry Powder extinguishers are for Class D or combustible metal fires only.

Water Mist - Water Mist extinguishers are primarily for Class A fires, although they are also safe for use in Class C fires.

Submit certificates that show **Fire Extinguishers** comply with local codes and regulations.

Provide Fire Extinguishers conforming to **NFPA 10**. Provide quantity and placement in compliance with the applicable sections of **ICC IFC**, Section 1414 and **ICC IFC**, Section 906, **NFPA 1**, **NFPA 101**, [**NFPA 99**], [**NFPA 303**], [**NFPA 385**], [**NFPA 409**], [**NFPA 418**], [**29 CFR 1910.106**] and **29 CFR 1910.157**.

[Provide [stored-pressure] [cartridge] [hand-pump] water type fire extinguishers.

] [Provide [foam] type fire extinguishers.

] [Provide carbon-dioxide type fire extinguishers compliant with **UL 154**.

] [Provide dry chemical type fire extinguishers compliant with **UL 299**.

] [Provide wet chemical type fire extinguishers compliant with **UL 8**.

] [Provide clean agent type fire extinguishers compliant with **UL 2129**.

] [Provide dry powder type fire extinguishers.

] [Provide water mist type fire extinguishers compliant with **UL 626**.

] Submit **Manufacturer's Data** for each type of Fire Extinguisher required, detailing all related Cabinet, Wall Mounting and Accessories information, complete with **Manufacturer's Warranty with Inspection Tag**.

2.2 MATERIAL

NOTE: Select one or more of the following for the shell material. Check manufacturers to ensure that the material and extinguisher type are compatible.

Provide [corrosion-resistant steel] [aluminum] [enameled steel] [_____] extinguisher shell.

2.3 SIZE

NOTE: Select one or more of the following for the size of the extinguisher. Size as indicated.

[**9.5 liter 2-1/2 gallons** extinguishers.

] [**1.1 kilogram 2-1/2 pounds** extinguishers.

] [**[2.3] [4.5] [6.8] [9] [13.6] kilogram [5] [10] [15] [20] [30] pounds** extinguishers.

] 2.4 ACCESSORIES

NOTE: Select items as applicable. Indicate appropriate UL rating.

[Forged brass valve
][Fusible plug
][Safety release
][Antifreeze
][Pressure gage
]2.5 CABINETS

NOTE: Include the following paragraphs if fire extinguishers are designated as cabinet mounted. If fire extinguishers are to be hung on wall brackets only, then delete cabinet requirements.

2.5.1 Material

NOTE: Select one of the following materials for cabinets.

Provide [enameled steel] [corrosion-resistant steel] [aluminum] cabinets.

2.5.2 Type

NOTE: Select one of the following types.

[Provide [recessed] [trimless] [surface] type cabinets.
] [Provide semi-recessed cabinet for a [150] [100] millimeter [6-inch] [4-inch] wall.
] [Provide [recessed] [trimless] [surface] bubble type cabinets.

2.5.3 Size

Dimension cabinets to accommodate the specified fire extinguishers.

2.6 WALL BRACKETS

NOTE: Delete the paragraph heading and the following paragraphs if cabinets are specified. Select one of the following.

Provide[running-board] [spring-clip] [wall-hook] fire extinguisher wall brackets.

Provide wall bracket and accessories as approved.

PART 3 EXECUTION

3.1 INSTALLATION

NOTE: For Class A light-hazard occupancies, such as office buildings, use a Class A extinguisher within a 25 meter 75-foot travel distance with one unit of 1A rating for every 280 square meter 3,000 square feet of floor area; ordinary hazard occupancies such as warehouses and department stores: 25 meter 75-foot travel distance with one unit of 2A rating for every 280 square meter 3,000 square feet; and extra hazard occupancies such as woodworking and spray painting locations: 25 meter 75-foot travel distance with one unit of 3A rating for every 280 square meter 3,000 square feet.

For Class B light-hazard occupancies, use a Class B extinguisher within 15 meter 50-foot travel distance with one unit of 4B rating; ordinary hazard occupancies: 15 meter 50-foot travel distance with one unit of 8B rating; extra hazard occupancies: 15 meter 50-foot travel distance with one unit of 12B rating. For deep-layer flammable-liquid fire hazards such as dip tanks, one unit of Class B extinguishing potential is required for each 0.1 square meter square foot of the largest individual hazard unless an approved automatic system is installed.

Class C extinguishers, where there are electrical hazards, are distributed on the same basis as Class B extinguishers.

Install Fire Extinguishers where indicated on the drawings. Verify exact locations prior to installation.

Comply with the manufacturer's recommendations for all installations.

Provide extinguishers which are fully charged and ready for operation upon installation. Provide extinguishers complete with Manufacturer's Warranty with Inspection Tag attached.

3.2 ACCEPTANCE PROVISIONS

3.2.1 Repairing

Remove and replace damaged and unacceptable portions of completed work with new work at no additional cost to the Government.

Submit Replacement Parts list indicating specified items replacement part, replacement cost, and name, address and contact for replacement parts distributor.

3.2.2 Cleaning

Clean all surfaces of the work, and adjacent surfaces which are soiled as a result of the work. Remove from the site all construction equipment, tools, surplus materials and rubbish resulting from the work.

-- End of Section --