

\*\*\*\*\*  
USACE / NAVFAC / AFCEC / NASA UFGS-32 92 26 (April 2006)  
-----  
Preparing Activity: NAVFAC Replacing without change  
UFGS-02923 (May 2004)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2014

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 32 - EXTERIOR IMPROVEMENTS

#### SECTION 32 92 26

#### SPRIGGING

04/06

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 DEFINITIONS
  - 1.2.1 Stand of Turf
- 1.3 RELATED REQUIREMENTS
- 1.4 SUBMITTALS
- 1.5 DELIVERY, STORAGE, AND HANDLING
  - 1.5.1 Delivery
    - 1.5.1.1 Sprig Protection
    - 1.5.1.2 [Fertilizer] [Gypsum] [Sulfur] [Iron] [and] [Lime] Delivery
  - 1.5.2 Storage
    - 1.5.2.1 Sprig Storage
    - 1.5.2.2 Seed, [Fertilizer] [Gypsum] [Sulfur] [Iron] [and] [Lime] Storage
    - 1.5.2.3 Topsoil
    - 1.5.2.4 Handling
- 1.6 TIME RESTRICTIONS AND PLANTING CONDITIONS
  - 1.6.1 Restrictions
- 1.7 TIME LIMITATIONS
  - 1.7.1 Sprigging

#### PART 2 PRODUCTS

- 2.1 SPRIGS
  - 2.1.1 Classification
  - 2.1.2 Composition
  - 2.1.3 Planting Dates
- 2.2 SEED
  - 2.2.1 Seed Classification
  - 2.2.2 Temporary Seed Species Composition
- 2.3 TOPSOIL
  - 2.3.1 On-Site Topsoil
  - 2.3.2 Off-Site Topsoil
  - 2.3.3 Composition
- 2.4 pH ADJUSTERS AND SOIL CONDITIONERS

- 2.4.1 Lime
- 2.4.2 Aluminum Sulfate
- 2.4.3 Sulfur
- 2.4.4 Iron
- 2.4.5 Peat
- 2.4.6 Sand
- 2.4.7 Perlite
- 2.4.8 Composted Derivatives
  - 2.4.8.1 Particle Size
  - 2.4.8.2 Nitrogen Content
- 2.4.9 Gypsum
- 2.4.10 Calcined Clay
- 2.5 FERTILIZER
  - 2.5.1 Granular Fertilizer
  - 2.5.2 Hydrosprigging Fertilizer
- 2.6 MULCH
  - 2.6.1 Straw
  - 2.6.2 Hay
  - 2.6.3 Wood Cellulose Fiber Mulch
- 2.7 WATER
- 2.8 EROSION CONTROL MATERIALS
  - 2.8.1 Erosion Control Blanket
  - 2.8.2 Erosion Control Fabric
  - 2.8.3 Erosion Control Net
  - 2.8.4 Hydrophilic Colloids
  - 2.8.5 Erosion Control Material Anchors

### PART 3 EXECUTION

- 3.1 PREPARATION
  - 3.1.1 EXTENT OF WORK
  - 3.1.2 Soil Preparation
    - 3.1.2.1 Soil Conditioner Application Rates
    - 3.1.2.2 Fertilizer Application Rates
- 3.2 SPRIGGING INSTALLATION
  - 3.2.1 Installing Sprigs
    - 3.2.1.1 Broadcast Sprigging
    - 3.2.1.2 Hydroplanting
    - 3.2.1.3 Row Sprigging
  - 3.2.2 Mulching
    - 3.2.2.1 Hay or Straw Mulch
    - 3.2.2.2 Mechanical Anchor
    - 3.2.2.3 Wood Cellulose Fiber, Paper Fiber and Recycled Paper
  - 3.2.3 Applying Seed Over Sprigs
    - 3.2.3.1 Broadcast Seeding
    - 3.2.3.2 Hydroseeding
  - 3.2.4 Rolling
  - 3.2.5 Finishing
  - 3.2.6 Erosion Control Material
  - 3.2.7 Watering Sprigs
- 3.3 PROTECTION OF TURF AREAS
- 3.4 RESTORATION

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEC / NASA UFGS-32 92 26 (April 2006)  
-----  
Preparing Activity: NAVFAC Replacing without change  
UFGS-02923 (May 2004)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2014

\*\*\*\*\*

### SECTION 32 92 26

SPRIGGING  
04/06

\*\*\*\*\*

NOTE: This guide specification covers the requirements for sprigging.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

\*\*\*\*\*

\*\*\*\*\*

NOTE: The following information shall be shown on the project drawings:

1. Clearly indicate all areas to be turfed and if more than one type of turf is specified, delineate areas for each type.

2. All draft turf specifications shall be submitted to the cognizant Landscape Architect/Natural Resources Specialist for review to ensure that the specifications are in accordance with environmental conditions peculiar to the project areas.

\*\*\*\*\*

## PART 1 GENERAL

### 1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

ASTM INTERNATIONAL (ASTM)

ASTM C602	(2013a) Agricultural Liming Materials
ASTM D4427	(2013) Peat Samples by Laboratory Testing
ASTM D4972	(2013) pH of Soils

TURFGRASS PRODUCERS INTERNATIONAL (TPI)

TPI GSS	(1995) Guideline Specifications to Turfgrass Sodding
---------	--

U.S. DEPARTMENT OF AGRICULTURE (USDA)

AMS Seed Act	(1940; R 1988; R 1998) Federal Seed Act
DOA SSIR 42	(1996) Soil Survey Investigation Report No. 42, Soil Survey Laboratory Methods Manual, Version 3.0

1.2 DEFINITIONS

1.2.1 Stand of Turf

95 percent ground cover of the established species.

1.3 RELATED REQUIREMENTS

[Section 31 00 00 EARTHWORK], [Section 32 84 24 IRRIGATION AND SPRINKLER SYSTEMS], [Section 32 96 00 TRANSPLANTING EXTERIOR PLANTS], [Section 32 92 19 SEEDING], [Section 32 92 23 SODDING], [Section 32 93 00 EXTERIOR PLANTS], and Section 32 05 33 LANDSCAPE ESTABLISHMENT applies to this section for pesticide use and plant establishment requirements, with additions and modifications herein.

## 1.4 SUBMITTALS

\*\*\*\*\*

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project.

The Guide Specification technical editors have designated those items that require Government approval, due to their complexity or criticality, with a "G". Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.] [for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] The following shall be submitted in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

### SD-03 Product Data

Wood cellulose fiber mulch

Fertilizer

Include physical characteristics, and recommendations.

### SD-06 Test Reports

\*\*\*\*\*

NOTE: In states that require certification, adjust testing requirements to suit local conditions.

\*\*\*\*\*

Topsoil composition tests (reports and recommendations).

## SD-07 Certificates

State certification and approval for **seed**

[Nursery] [Sod farm] certification for **sprigs**. Indicate type of sprig in accordance with **TPI GSS**.

## SD-08 Manufacturer's Instructions

### Erosion Control Materials

#### 1.5 DELIVERY, STORAGE, AND HANDLING

##### 1.5.1 Delivery

###### 1.5.1.1 Sprig Protection

\*\*\*\*\*  
**NOTE: If sprigs are to be delivered in quantity over considerable distance, specify trucking in vans equipped with temperature control.**  
\*\*\*\*\*

Protect from drying out and from contamination during delivery, on-site storage, and handling.

###### 1.5.1.2 [Fertilizer] [Gypsum] [Sulfur] [Iron] [and] [Lime] Delivery

Deliver to the site in original, unopened containers bearing manufacturer's chemical analysis, name, trade name, trademark, and indication of conformance to state and federal laws. Instead of containers, [fertilizer] [gypsum] [sulphur] [iron] [and] [lime] may be furnished in bulk with certificate indicating the above information.

##### 1.5.2 Storage

###### 1.5.2.1 Sprig Storage

\*\*\*\*\*  
**NOTE: Check with the local Agriculture County Extension Service Office to determine if specie used requires more water than is average for the geographical area.**  
\*\*\*\*\*

Lightly sprinkle with water, cover with moist burlap, straw, or other approved covering; and protect from exposure to wind and direct sunlight until planted. Provide covering that will allow air to circulate so that internal heat will not develop. Do not store longer than 24 hours. Do not store directly on concrete or bituminous surfaces.

###### 1.5.2.2 Seed, [Fertilizer] [Gypsum] [Sulfur] [Iron] [and] [Lime] Storage

Store in cool, dry locations away from contaminants.

###### 1.5.2.3 Topsoil

Prior to stockpiling topsoil, treat growing vegetation with application of

appropriate specified non-selective herbicide. Clear and grub existing vegetation three to four weeks prior to stockpiling topsoil.

#### 1.5.2.4 Handling

Do not drop or dump materials from vehicles.

### 1.6 TIME RESTRICTIONS AND PLANTING CONDITIONS

#### 1.6.1 Restrictions

Do not plant when the ground is [frozen,] [snow covered,] muddy, or when air temperature exceeds [32] [\_\_\_\_\_] degrees Celsius [90] [\_\_\_\_\_] degrees Fahrenheit.

### 1.7 TIME LIMITATIONS

#### 1.7.1 Sprigging

Perform sprigging a maximum of twenty four hours after initial harvesting.

## PART 2 PRODUCTS

### 2.1 SPRIGS

\*\*\*\*\*  
NOTE: The specific species and varieties used  
should be based on recommendations of the local  
Agriculture County Extension Service Office.  
\*\*\*\*\*

#### 2.1.1 Classification

Healthy living stems, stolons, or rhizomes and attached roots of locally adapted grass without adhering soil, including two to three nodes and from 100 to 150 mm 4 to 6 inches long. Obtain from heavy, dense certified sod as classified in the TPI GSS. [Obtain sprigs from designated areas on the project site.] Provide sprigs which have been grown under climatic conditions similar to those in the locality of the project. Coordinate harvesting and planting operations to prevent exposure of sprigs to the sun for more than 30 minutes before covering and moistening. Sprigs containing weeds or other detrimental material or that are heat damaged will be rejected.

#### 2.1.2 Composition

Botanical and Common Name	Percent
[_____]	[_____]

#### 2.1.3 Planting Dates

Sow sprigs from [\_\_\_\_\_] to [\_\_\_\_\_] for warm season planting and from [\_\_\_\_\_] to [\_\_\_\_\_] for cool season planting.

### 2.2 SEED

\*\*\*\*\*

NOTE: When applying seed over sprigs as a specified method of establishing sprigs, select the annual seed species to be installed. State-certified seed is more stringently monitored than State-approved seed; and therefore, more expensive.

\*\*\*\*\*

#### 2.2.1 Seed Classification

[State-certified] [State-approved] seed of the latest season's crop shall be provided in original sealed packages bearing the producer's guaranteed analysis for percentages of mixture, purity, germination, hard seed, weed seed content, and inert material. Labels shall be in conformance with **AMS Seed Act** and applicable state seed laws.

#### 2.2.2 Temporary Seed Species Composition

Botanical Name	Common Name	Minimum Percent Pure Seed	Minimum Percent Germination	Maximum Percent Weed Seed
[_____]	[_____]	[_____]	[_____]	[_____]

#### 2.3 TOPSOIL

\*\*\*\*\*

NOTE: If topsoil properties are included in another section of Division 2, delete this paragraph and include a cross-reference to the appropriate section. Otherwise, select appropriate paragraphs on topsoil. Check with the local Agriculture County Extension Service Office for soil properties appropriate for the plant materials to be planted. Where suitable topsoil is available within limits of the work area, stripping and stockpiling of topsoil should be included in the applicable section of Division 2 of the specification. If suitable topsoil is not available within the limits of the work area, it should generally be the Contractor's option to either treat the soil of the graded areas with fertilizer and supplements so as to be conducive to turf establishment and maintenance, or to transport topsoil to the project site. Modify pH range for specified turf and geographical requirements.

\*\*\*\*\*

##### 2.3.1 On-Site Topsoil

Surface soil stripped and stockpiled on site and modified as necessary to meet the requirements specified for topsoil in paragraph entitled "Composition." When available topsoil shall be existing surface soil stripped and stockpiled on-site in accordance with Section [31 00 00 EARTHWORK] [31 23 00.00 20 EXCAVATION AND FILL].



### 2.3.2 Off-Site Topsoil

Conform to requirements specified in paragraph entitled "Composition." Additional topsoil shall be [furnished by the Contractor] [obtained from topsoil borrow areas indicated].

### 2.3.3 Composition

Containing from 5 to 10 percent organic matter as determined by the [topsoil composition tests](#) of the Organic Carbon, 6A, Chemical Analysis Method described in [DOA SSIR 42](#). Maximum particle size, [19 mm 3/4 inch](#), with maximum 3 percent retained on [6 mm 1/4 inch](#) screen. The pH shall be tested in accordance with [ASTM D4972](#). Topsoil shall be free of sticks, stones, roots, and other debris and objectionable materials. Other components shall conform to the following limits:

Silt	[25-50] [7 to 17] [_____] percent
Clay	[10-30] [4 to 12] [_____] percent
Sand	[20-35] [70 to 82] [_____] percent
pH	[5.5 to 7.0] [_____]
Soluble Salts	[600] [_____] ppm maximum

## 2.4 pH ADJUSTERS AND SOIL CONDITIONERS

\*\*\*\*\*  
NOTE: Prior to including these provisions in project specifications, perform tests of on-site topsoil to determine its suitability and the possible need of pH adjusters or soil conditioners.  
\*\*\*\*\*

Add conditioners to topsoil as required to bring into compliance with "composition" standard for topsoil as specified herein.

### 2.4.1 Lime

\*\*\*\*\*  
NOTE: Use ASTM C602 calcium carbonate equivalent (C.C.E.) as specified in Table 1: for burnt lime, C.C.E. shall not be less than 140 percent; for hydrated lime, C.C.E. shall not be less than 110 percent; and for limestone, C.C.E. shall not be less than 80 percent.  
\*\*\*\*\*

Commercial grade [hydrate] [or] [burnt] limestone containing a calcium carbonate equivalent (C.C.E.) as specified in [ASTM C602](#) of not less than [\_\_\_\_\_] percent.

### 2.4.2 Aluminum Sulfate

Commercial grade.

#### 2.4.3 Sulfur

100 percent elemental

#### 2.4.4 Iron

100 percent elemental

#### 2.4.5 Peat

Natural product of [peat moss] derived from a freshwater site and conforming to [ASTM D4427] [as modified herein]. Shred and granulate peat to pass a 12.5 mm 1/2 inch mesh screen and condition in storage pile for minimum 6 months after excavation.

#### 2.4.6 Sand

Clean and free of materials harmful to plants.

#### 2.4.7 Perlite

Horticultural grade.

#### 2.4.8 Composted Derivatives

Ground bark, nitrolized sawdust, humus or other green wood waste material free of stones, sticks, and soil stabilized with nitrogen and having the following properties:

##### 2.4.8.1 Particle Size

Minimum percent by weight passing:

4.75 mm	No. 4 mesh screen	95
2.36 mm	No. 8 mesh screen	80

##### 2.4.8.2 Nitrogen Content

Minimum percent based on dry weight:

Fir Sawdust	0.7
Fir or Pine Bark	1.0

#### 2.4.9 Gypsum

Coarsely ground gypsum comprised of calcium sulfate dihydrate 91 percent, calcium 22 percent, sulfur 17 percent; minimum 96 percent passing through 850 micrometers 20 mesh screen, 100 percent passing thru 970 micrometers 16 mesh screen.

#### 2.4.10 Calcined Clay

Calcined clay shall be granular particles produced from montmorillonite clay calcined to a minimum temperature of 650 degrees C 1200 degrees F. Gradation: A minimum 90 percent shall pass a 2.36 mm No. 8 sieve; a minimum 99 percent shall be retained on a 0.250 mm No. 60 sieve; and a maximum 2 percent shall pass a 0.150 mm No. 100 sieve. Bulk density: A maximum 640 kilogram per cubic meter 40 pounds per cubic foot.

## 2.5 FERTILIZER

\*\*\*\*\*  
NOTE: Check with the local Agriculture County  
Extension Service Office for recommended fertilizer  
mixture for local conditions.  
\*\*\*\*\*

### 2.5.1 Granular Fertilizer

[Organic][synthetic], granular controlled release fertilizer containing the following minimum percentages, by weight, of plant food nutrients:

[ ] percent available nitrogen  
[ ] percent available phosphorus  
[ ] percent available potassium  
[ ] percent sulfur  
[ ] percent iron

### 2.5.2 Hydrosprigging Fertilizer

Controlled release fertilizer, to use with hydrosprigging and composed of pills coated with plastic resin to provide a continuous release of nutrients for at least 6 months and containing the following minimum percentages, by weight, of plant food nutrients.

[ ] percent available nitrogen  
[ ] percent available phosphorus  
[ ] percent available potassium  
[ ] percent sulfur  
[ ] percent iron

## 2.6 MULCH

\*\*\*\*\*  
NOTE: Check with the local Agriculture County  
Extension Service Office to determine choice of  
mulch most suitable for the project area. Specify  
only one type of mulch.  
\*\*\*\*\*

Mulch shall be free from noxious weeds, mold, and other deleterious materials.

### 2.6.1 Straw

Stalks from oats, wheat, rye, barley, or rice. Furnish in air-dry condition and of proper consistency for placing with commercial mulch blowing equipment. Straw shall contain no fertile seed.

### 2.6.2 Hay

Air-dry condition and of proper consistency for placing with commercial mulch blowing equipment. Hay shall be sterile, containing no fertile seed.

### 2.6.3 Wood Cellulose Fiber Mulch

\*\*\*\*\*  
NOTE: Wood cellulose fiber mulches have been

successful on level areas or on slopes with slight grades where sufficient moisture is present to obtain a quick germination of grass seed. The material should be hydraulically applied at the following rates: Areas up to and including 3 to 1 slopes, at the rate of 1,120 kg per 10,000 sq. m 1,000 pounds per acre; areas steeper than 3 to 1 at the rate of 1,568 kg per 10,000 sq. m 1,400 pounds per acre. It should not be specified for slopes 2 to 1 or greater in areas where drought may prevent germination of the seed or where runoff from heavy rains may cut gullies through the fiber mulch. In these areas use erosion control materials such as specified in paragraph entitled "Erosion Control Material."

\*\*\*\*\*

Use recovered materials of either paper-based (100 percent) or wood-based (100 percent) hydraulic mulch. Processed to contain no growth or germination-inhibiting factors and dyed an appropriate color to facilitate visual metering of materials application. Composition on air-dry weight basis: 9 to 15 percent moisture, pH range from 5.5 to 8.2 [\_\_\_\_]. Use with hydraulic application of grass [seed] and fertilizer.

## 2.7 WATER

\*\*\*\*\*

NOTE: When water is Government furnished, locate the source. Recycled or reclaimed irrigation water may be available through a tertiary treatment plant on or off site. It is preferred that this type of water be used for irrigation whenever possible. Check project specific conditions.

Unless otherwise directed, water shall be the responsibility of the Contractor. Water source shall be potable or non-potable. If non-potable edit specification accordingly. Source of water shall be approved by the Contracting Officer and shall be of suitable quality for irrigation, containing no elements toxic to plant life.

Coordinate information presented here with Section 01 50 00 TEMPORARY CONSTRUCTION FACILITIES AND CONTROLS

\*\*\*\*\*

Source of water shall be approved by Contracting Officer and of suitable quality for irrigation containing no element toxic to plant life.

## 2.8 EROSION CONTROL MATERIALS

\*\*\*\*\*

NOTE: Provide all erosion and sediment control measures in Section 01 57 19.00 20 TEMPORARY ENVIRONMENTAL CONTROLS for Navy instead of here if used for project. The Contractor may propose other types of erosion control material, based on site conditions.

\*\*\*\*\*

Erosion control material shall conform to the following:

[2.8.1 Erosion Control Blanket

Blanket shall be machine produced mat of wood excelsior formed from a web of interlocking wood fibers; covered on one side with either knitted straw blanket-like mat construction; covered with biodegradable plastic mesh; or interwoven biodegradable thread, plastic netting, or twisted kraft paper cord netting.

] [2.8.2 Erosion Control Fabric

Fabric shall be knitted construction of polypropylene yarn with uniform mesh openings 19 to 25 mm 3/4 to 1 inch square with strips of biodegradable paper. Filler paper strips shall have a minimum life of 6 months.

] [2.8.3 Erosion Control Net

Net shall be heavy, twisted jute mesh, weighing approximately 605 grams per meter 1.22 pounds per linear yard and 1200 mm 4 feet wide with mesh openings of approximately 25 mm 1 inch square.

] [2.8.4 Hydrophilic Colloids

Hydrophilic colloids shall be physiologically harmless to plant and animal life without phytotoxic agents. Colloids shall be naturally occurring, silicate powder based, and shall form a water insoluble membrane after curing. Colloids shall resist mold growth.

] 2.8.5 Erosion Control Material Anchors

Erosion control anchors shall be as recommended by the manufacturer.

PART 3 EXECUTION

3.1 PREPARATION

3.1.1 EXTENT OF WORK

Provide soil preparation (including soil conditioners), fertilizing, and sprigging, [temporary seeding] of all newly graded finished earth surfaces, unless indicated otherwise, and at all areas inside or outside the limits of construction that are disturbed by the Contractor's operations.

3.1.2 Soil Preparation

\*\*\*\*\*  
NOTE: Choose one of the following options  
\*\*\*\*\*

\*\*\*\*\*  
NOTE: Elevation of subgrade will vary depending  
upon the needs for additional topsoil, sod, or other  
treatment.  
\*\*\*\*\*

Provide 102 mm 4 inches of [off-site topsoil] [on-site topsoil] [existing

soil] to meet indicated finish grade. After areas have been brought to indicated finish grade, incorporate [fertilizer] [pH adjusters] [soil conditioners] into soil a minimum depth of [100] [\_\_\_\_\_] mm [4] [\_\_\_\_\_] inches by disking, harrowing, tilling or other method approved by the Contracting Officer. Remove debris and stones larger than 19 mm 3/4 inch in any dimension remaining on the surface after finish grading. Correct irregularities in finish surfaces to eliminate depressions. Protect finished topsoil areas from damage by vehicular or pedestrian traffic.

#### 3.1.2.1 [Soil Conditioner Application Rates

Apply soil conditioners at rates as determined by laboratory soil analysis of the soils at the job site. For bidding purposes only apply at rates for the following:

[Lime [ [\_\_\_\_\_] kg per square meter [\_\_\_\_\_] pounds per acre] [ [\_\_\_\_\_] kg per 100 square meters [\_\_\_\_\_] pounds per 1000 square feet.]]

[Sulfur [ [\_\_\_\_\_] kg per square meter [\_\_\_\_\_] pounds per acre] [ [\_\_\_\_\_] kg per 100 square meters [\_\_\_\_\_] pounds per 1000 square feet.]]

[Iron [ [\_\_\_\_\_] kg per square meter [\_\_\_\_\_] pounds per acre] [ [\_\_\_\_\_] kg per 100 square meters [\_\_\_\_\_] pounds per 1000 square feet.]]

[Aluminum Sulfate [ [\_\_\_\_\_] kg per square meter [\_\_\_\_\_] pounds per acre] [ [\_\_\_\_\_] kg per 100 square meters [\_\_\_\_\_] pounds per 1000 square feet.]]

[Peat [ [\_\_\_\_\_] cubic meters per square meter [\_\_\_\_\_] cubic yard per acre] [ [\_\_\_\_\_] cubic meters per 100 square meters [\_\_\_\_\_] cubic yards per 1000 square feet.]]

[Sand [ [\_\_\_\_\_] cubic meters per square meter [\_\_\_\_\_] cubic yard per acre] [ [\_\_\_\_\_] cubic meters per 100 square meters [\_\_\_\_\_] cubic yards per 1000 square feet.]]

[Perlite [ [\_\_\_\_\_] cubic meters per square meter [\_\_\_\_\_] cubic yard per acre] [ [\_\_\_\_\_] cubic meters per 100 square meters [\_\_\_\_\_] cubic yards per 1000 square feet.]]

[Compost Derivatives [ [\_\_\_\_\_] cubic meters per square meter [\_\_\_\_\_] cubic yard per acre] [ [\_\_\_\_\_] cubic meters per 100 square meters [\_\_\_\_\_] cubic yards per 1000 square feet.]]

[Calcined Clay [ [\_\_\_\_\_] cubic meters per square meter [\_\_\_\_\_] cubic yard per acre] [ [\_\_\_\_\_] cubic meters per 100 square meters [\_\_\_\_\_] cubic yards per 1000 square feet.]]

[Gypsum [ [\_\_\_\_\_] cubic meters per square meter [\_\_\_\_\_] cubic yard per acre] [ [\_\_\_\_\_] cubic meters per 100 square meters [\_\_\_\_\_] cubic yards per 1000 square feet.]]

#### ]3.1.2.2 [Fertilizer Application Rates

\*\*\*\*\*

**NOTE: Check with the local Agriculture County Extension Service and specify amounts applicable for the project area. Two fertilizer applications may**

be required when hydroseeding with wood fiber mulch.

\*\*\*\*\*

Apply fertilizer at rates as determined by laboratory soil analysis of the soils at the job site. For bidding purposes only apply at rates for the following:

[Organic Granular Fertilizer [ [\_\_\_\_\_] kg per square meter [\_\_\_\_\_] pounds per acre] [ [\_\_\_\_\_] kg per 100 square meters [\_\_\_\_\_] pounds per 1000 square feet.]]

[Hydrosprigging Fertilizer [ [\_\_\_\_\_] kg per square meter [\_\_\_\_\_] pounds per acre] [ [\_\_\_\_\_] kg per 100 square meters [\_\_\_\_\_] pounds per 1000 square feet.]]

### ] 3.2 SPRIGGING INSTALLATION

\*\*\*\*\*

**NOTE: Allow the Contractor sprig installation options when installing areas larger than 1 acre. Define lawn areas and field areas on the drawings.**

\*\*\*\*\*

Prior to installing sprigs, any previously prepared surface compacted or damaged shall be reworked to meet the requirements of paragraph SOIL PREPARATION. Areas shall be sprigged as indicated.

#### 3.2.1 Installing Sprigs

The sprigging method shall be [Broadcast Sprigging] [Hydroplanting] [Row Sprigging] [applying seed-over-sprigs]. Sprigging procedure shall ensure even coverage.

##### 3.2.1.1 Broadcast Sprigging

Sprigs shall be broadcast uniformly by hand, with mechanical equipment, or other approved method. Sprigs shall be planted to provide a minimum number of 30 viable sprigs per square meter 25 viable sprigs per square yard. The distance between individual sprigs shall be a maximum 300 mm 12 inch space. Sprigs shall be forced into the soil to a minimum 25 mm 1 inch depth by disk-rolling, pressing with steel matting, or other approved method.

##### 3.2.1.2 Hydroplanting

Sprigs shall be mixed with water and uniformly applied under pressure over the entire area. Sprigs shall be covered by distributing a topdressing uniformly and evenly to a minimum 25 mm 1 inch depth. Topdressing shall conform to the paragraph TOPSOIL.

##### 3.2.1.3 Row Sprigging

Sprigs shall be planted in rows spaced a maximum of 300 mm 12 inches apart and to a minimum 25 mm 1 inch depth, with mechanical sprig planter or other methods. Sprigs shall be placed in the rows a maximum 150 mm 6 inch distance apart.

### 3.2.2 Mulching

#### 3.2.2.1 Hay or Straw Mulch

Hay or straw mulch shall be spread uniformly at the rate of 0.75 metric tons per hectare 2 tons per acre. Mulch shall be spread by hand, blower-type mulch spreader, or other approved method. Mulching shall be started on the windward side of relatively flat areas or on the upper part of steep slopes, and continued uniformly until the area is covered. The mulch shall not be bunched or clumped. Sunlight shall not be completely excluded from penetrating to the ground surface. All areas installed with seed shall be mulched on the same day as the seeding. Mulch shall be anchored immediately following spreading.

#### 3.2.2.2 Mechanical Anchor

Mechanical anchor shall be a V-type-wheel land packer; a scalloped-disk land packer designed to force mulch into the soil surface; or other suitable equipment.

#### 3.2.2.3 Wood Cellulose Fiber, Paper Fiber and Recycled Paper

Wood cellulose fiber, paper fiber, or recycled paper shall be applied as part of the hydroseeding operation. The mulch shall be mixed and applied in accordance with the manufacturer's recommendations.

### 3.2.3 [Applying Seed Over Sprigs

Seed shall be applied using either [broadcast] [or] [hydroseeding] equipment and methods. Seeding procedure shall ensure even coverage. Gravity feed applicators, which drop seed directly from a hopper onto the prepared soil, shall not be used.

#### 3.2.3.1 [Broadcast Seeding

Seed shall be uniformly broadcast at the rate of [\_\_\_\_\_] kilograms per hectare pounds per 1000 square feet using broadcast seeders. Half the total rate of seed application shall be broadcast in 1 direction, with the remainder of the seed rate broadcast at 90 degrees from the first direction. Seed shall be covered to a minimum 6 mm 1/4 inch depth by disk harrow, steel mat drag, cultipacker, or other approved device. Seed shall be broadcast and covered prior to sprigging operation.

#### ]3.2.3.2 [Hydroseeding

Seed shall be mixed to ensure broadcast at the rate of [\_\_\_\_\_] kilograms per hectare pounds per 1000 square feet. Seed and fertilizer shall be added to water and thoroughly mixed at the rates specified. The maximum time period for the seed to be held in the slurry shall be 24 hours. [Wood cellulose fiber mulch and tackifier shall be added at the rates recommended by the manufacturer after the seed, fertilizer, and water have been thoroughly mixed to produce a homogeneous slurry.] Slurry shall be uniformly applied under pressure over the entire area. The hydroseeded area shall not be rolled.

#### ]3.2.4 Rolling

The entire area shall be firmed with a roller not exceeding 130 kilograms per meter 90 pounds per foot roller width. Slopes over a maximum



3-horizontal-to-1 vertical shall not be rolled.

#### 3.2.5 Finishing

A minimum 25 percent of the installed sprigs shall extend above the ground surface upon completion of the sprigging operation.

#### 3.2.6 Erosion Control Material

Install in accordance with manufacturer's instructions, where indicated or as directed by the Contracting Officer.

#### 3.2.7 Watering Sprigs

Watering shall be started immediately after completing each day of sprigging. Water shall be applied at a rate sufficient to ensure moist soil conditions to a minimum 25 mm 1 inch depth. Run-off, puddling, and wilting shall be prevented. Unless otherwise directed, watering trucks shall not be driven over turf areas. Watering of other adjacent areas or plant material shall be prevented.

#### 3.3 PROTECTION OF TURF AREAS

Immediately after turfing, protect area against traffic and other use.

#### 3.4 RESTORATION

Restore to original condition existing turf areas which have been damaged during turf installation operations. Keep clean at all times at least one paved pedestrian access route and one paved vehicular access route to each building. Clean other paving when work in adjacent areas is complete.

-- End of Section --