
USACE / NAVFAC / AFCEC / NASA UFGS-06 82 14 (February 2015)

Preparing Activity: NASA

Superseding
UFGS-06 82 14 (May 2012)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2017

SECTION TABLE OF CONTENTS

DIVISION 06 - WOOD, PLASTICS, AND COMPOSITES

SECTION 06 82 14

FIBERGLASS REINFORCED PLASTIC (FRP) PIPE AND TUBE RAILINGS

02/15

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 QUALITY CONTROL
 - 1.3.1 Qualifications of Manufacturer
 - 1.3.2 Qualifications of Engineer of Record
- 1.4 DELIVERY, HANDLING, AND STORAGE

PART 2 PRODUCTS

- 2.1 SYSTEM DESCRIPTION
 - 2.1.1 Installation Drawings
 - 2.1.2 Product Data
 - 2.1.3 Design Requirements
 - 2.1.4 Performance Requirements
 - 2.1.4.1 Structural Performance of Pipe and Tube Railings
- 2.2 FABRICATION
- 2.3 MATERIALS
 - 2.3.1 Fasteners
 - 2.3.2 Anchors
 - 2.3.3 Grout And Anchoring Cement
 - 2.3.4 Component Connections
 - 2.3.4.1 Lag Screws and Bolts
 - 2.3.4.2 Toggle Bolts
 - 2.3.4.3 Bolts, Nuts, Studs and Rivets
 - 2.3.4.4 Powder Driven Fasteners
 - 2.3.4.5 Screws
 - 2.3.4.6 Washers

PART 3 EXECUTION

- 3.1 INSTALLATION
 - 3.1.1 Anchorage, Fastenings, and Connections
 - 3.1.2 Workmanship
- 3.2 CLOSEOUT ACTIVITIES

- 3.2.1 Warranty
- 3.2.2 Manufacturer's Instructions

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEC / NASA UFGS-06 82 14 (February 2015)

Preparing Activity: NASA Superseding
UFGS-06 82 14 (May 2012)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2017

SECTION 06 82 14

FIBERGLASS REINFORCED PLASTIC (FRP) PIPE AND TUBE RAILINGS 02/15

NOTE: This guide specification covers the requirements for fiberglass reinforced plastic (FRP) pipe and tube railings, customarily manufactured to meet specific requirements in building construction and fabricated FRP items, which are not a part of the structural FRP components or framework.

Adhere to UFC 1-300-02 Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a Criteria Change Request (CCR).

NOTE: Units of work normally included in this section should be FRP items which require specific fabrication to meet the desired project requirements.

NOTE: Include in drawings a complete design indicating the character of the work to be performed and showing the following:

a. Location and details of each fabricated FRP pipe and tube railings components showing all dimensions, shapes, and sizes of members, connections, and the relation of items to other building components.

- b. All sizes and dimensions.
- c. Special fastenings, attachments or anchoring, including anchorage devices embedded in other construction, including but not limited to, precast concrete wall panels, precast concrete structural members, precast concrete roof decking, brick and block masonry, and precast stone work; anchorage devices to structural steel framework, including, but not limited to, steel bar grating, steel floor plates, and structural steel roof or floor decking.
- d. Location and special details of expansion joint covers.
- e. Connection details, other than manufacturer's standard for pipe and tube railings.
- f. Locate and detail removable sections of handrails.

PART 1 GENERAL

This Section includes, but is not limited to, new fiberglass reinforced plastic (FRP) pipe and tube railing/guards, mounting systems and accessories.

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN SOCIETY OF CIVIL ENGINEERS (ASCE)

ASCE 7

(2010; Errata 2011; Supp 1 2013) Minimum

Design Loads for Buildings and Other
Structures

AMERICAN SOCIETY OF SAFETY ENGINEERS (ASSE/SAFE)

ASSE/SAFE A10.3 (2013) Operations - Safety Requirements
for Powder Actuated Fastening Systems

ASME INTERNATIONAL (ASME)

ASME B18.2.1 (2012; Errata 2013) Square and Hex Bolts
and Screws (Inch Series)

ASME B18.2.2 (2015) Nuts for General Applications:
Machine Screw Nuts, Hex, Square, Hex
Flange, and Coupling Nuts (Inch Series)

ASME B18.21.1 (2009; R 2016) Washers: Helical
Spring-Lock, Tooth Lock, and Plain Washers
(Inch Series)

ASME B18.21.2M (1999; R 2014) Lock Washers (Metric Series)

ASME B18.6.2 (1998; R 2010) Slotted Head Cap Screws,
Square Head Set Screws, and Slotted
Headless Set Screws: Inch Series

ASME B18.6.3 (2013) Machine Screws, Tapping Screws, and
Machine Drive Screws (Inch Series)

ASTM INTERNATIONAL (ASTM)

ASTM A307 (2014) Standard Specification for Carbon
Steel Bolts and Studs, 60 000 PSI Tensile
Strength

ASTM C1107/C1107M (2014a) Standard Specification for
Packaged Dry, Hydraulic-Cement Grout
(Nonshrink)

ASTM D1148 (2013) Standard Test Method for Rubber
Deterioration-Discoloration from
Ultraviolet (UV) and Heat Exposure of
Light-Colored Surfaces

ASTM D2344/D2344M (2016) Standard Test Method for Short-Beam
Strength of Polymer Matrix Composite
Materials and Their Laminates

ASTM D430 (2006; R 2012) Standard Test Methods for
Rubber Deterioration - Dynamic Fatigue

ASTM D638 (2014) Standard Test Method for Tensile
Properties of Plastics

ASTM D696 (2016) Standard Test Method for
Coefficient of Linear Thermal Expansion of
Plastics Between -30 degrees C and 30
degrees C With a Vitreous Silica

Dilatometer

ASTM D790 (2015; E 2016; E 2016) Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials

ASTM E488/E488M (2015) Standard Test Methods for Strength of Anchors in Concrete and Masonry Elements

ASTM E84 (2016) Standard Test Method for Surface Burning Characteristics of Building Materials

INTERNATIONAL CODE COUNCIL (ICC)

ICC IBC (2015) International Building Code

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 101 (2015; ERTA 2015) Life Safety Code

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

29 CFR 1910.23 Guarding Floor and Wall Openings and Holes

29 CFR 1926 Safety and Health Regulations for Construction

1.2 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project.

The Guide Specification technical editors have designated those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Use the "S" Classification only in SD-11 Closeout

Submittals. An "S" following a submittal item indicates that the submittal is required for the Sustainability eNotebook to fulfill federally mandated sustainable requirements in accordance with Section 01 33 29 SUSTAINABILITY REPORTING.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for Contractor Quality Control approval for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. Submittals with an "S" are for inclusion in the Sustainability eNotebook, in conformance to Section 01 33 29 SUSTAINABILITY REPORTING. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-01 Preconstruction Submittals

Qualifications of Manufacturer[; G[, [____]]]

Qualifications of Engineer of Record[; G[, [____]]]

Manufacturer's Sample Warranty[; G[, [____]]]

SD-02 Shop Drawings

Installation Drawings[; G[, [____]]]

SD-03 Product Data

FRP Pipe and Tube[; G[, [____]]]

Railings/Guards[; G[, [____]]]

Anchorage Materials[; G[, [____]]]

Adhesives[; G[, [____]]]

Resins[; G[, [____]]]

Hardeners[; G[, [____]]]

SD-06 Test Reports

Ultraviolet Test Reports[; G[, [____]]]

Thermal Expansion Test Reports[; G[, [____]]]

Flame Spread Test Reports[; G[, [____]]]

SD-07 Certificates

Manufacturer's Certification by the State of [____] Product Approval[; G[, [____]]]

Proof of Certification from a minimum of two quality assurance programs for its facilities or products (UL, DNV, ABS, USCG, AARR) [; G[, [____]]]

SD-08 Manufacturer's Instructions

Manufacturer's Instructions[; G[, [____]]]

SD-09 Manufacturer's Field Reports

Manufacturer's Certification of Installation[; G[, [____]]]

SD-11 Closeout Submittals

Manufacturer's Warranty[; G[, [____]]]

1.3 QUALITY CONTROL

1.3.1 Qualifications of Manufacturer

Submit Qualifications Of Manufacturer documentation certifying that the Fiberglass Reinforced Plastic (FRP) manufacturer has a minimum of [10][____] years experience in manufacturing FRP products.

Provide items within this section from manufacturers having a minimum of [5] [10] [____] years experience in the design and manufacture of similar products and systems.

[Submit documentation proving of a minimum of at least 5 previous, separate, similar installations within the last [5] [10] [____] years.

][Submit Proof of Certification from a minimum of two quality assurance programs for its facilities or products (UL, DNV, ABS, USCG, AARR).

][Submit Manufacturer's Certification by the state of [____] Product Approval.

] Provide Manufacturer's sample warranty for all FRP products against defects in material and workmanship for a minimum of [5] [____] years. Provide evidence of manufacturer's ISO 9001-2000 standard certification.

1.3.2 Qualifications of Engineer of Record

[Submit Qualifications of Engineer of Record documentation that the Engineer of Record is currently licensed within the jurisdiction of the project.

][Submit documentation that the Engineer of Record is approved, authorized, and currently licensed by the State of [____], and has a minimum of [5] years experience as an approved Engineer for manufacturers of similar ladder systems. Require the Engineer of Record to supply the name and location of [5] projects of similar size and scope for which he has provided engineering calculations using the manufacturer's products submitted for this project within the previous [3] [____] years. Provide certified and signed calculations prepared by Engineer for:

] a. ASCE 7,in accordance with International Building Code

b. Installation drawings

1.4 DELIVERY, HANDLING, AND STORAGE

Deliver all manufactured materials in original, unbroken pallets, packages, containers, or bundles bearing the label of the manufacturers, clearly marked and identified relative to the complete system. Provide all adhesives, resins and their catalysts and hardeners in clearly marked or noted crates or boxes to facilitate their safe movement to a dry indoor storage facility with a constant temperature range between 21.11 and 29.44 degrees C 70 and 85 degrees F until they are required.

Handle all materials to prevent abrasion, cracking, chipping, twisting, or other deformations and other types of damage.

PART 2 PRODUCTS

2.1 SYSTEM DESCRIPTION

2.1.1 Installation Drawings

Submit templates, erection and installation drawings indicating thickness, type, and dimensions. Show construction details, reinforcement, anchorage, and installation with relation to the building construction.

Include plans, elevations, sections, details, and attachments to other work. Indicate for installed products to comply with design loads. Include structural analysis data signed and sealed by the qualified professional engineer responsible for their preparation.

2.1.2 Product Data

Submit manufacturer's catalog data including two copies of manufacturer's specifications, load tables, dimension diagrams, and anchor details for the following items:

- a. FRP Pipe and Tube
- b. Railings/Guards
- c. Anchorage Materials
- d. Adhesives
- e. Resins
- f. Hardeners

2.1.3 Design Requirements

Ensure all posts and rails are FRP structural shapes manufactured by the pultrusion process. Compose structural shapes of fiberglass reinforcement and resin in qualities, quantities, properties, arrangements and dimensions as necessary to meet the design requirements in accordance with ASCE 7, 29 CFR 1910.23, NFPA 101, and dimensions specified.

Ensure fiberglass reinforcements a combination of continuous roving, continuous strand mat, and surfacing veil in sufficient quantities as needed by the application and/or physical properties required.

Provide resins, with appropriate hardeners, of isophthalic polyester with

chemical formulation necessary for corrosion resistance, strength and other physical properties as required.

Ensure all finished surfaces of FRP items, including FRP pipe and tube, railings/guards, anchorage materials, and fabrications are smooth, resin-rich, free of voids and without dry spots, cracks, and un-reinforced areas. Provide complete coverage of all glass fibers with resin to protect against their exposure due to wear or weathering.

Protect all pultruded structural shapes from ultraviolet (UV) attack with:

- a. Integral UV inhibitors within the resin
- b. Synthetic surfacing veil to help produce a resin rich surface
- c. UV resistant coating for outdoor exposures

Provide FRP products which have a flame spread rating of 25 or less as per ASTM E84, Tunnel Test. Submit [_____] copies of Flame Spread Test Reports to the Contracting Officer.

Ensure rails, posts, and kick plates are integrally pigmented yellow. Submit [_____] copies of Ultraviolet Test Reports for FRP material, similar to the requirements of ASTM D1148 for rubber deterioration, and ASTM D430, to the Contracting Officer. Submit testing data relating to Thermal Expansion Test Reports.

Provide structural shapes in the guardrail system to meet minimum longitudinal mechanical properties as follows:

Tensile Strength	ASTM D638	2.068427e+008 pascal
Tensile Modulus	ASTM D638	1.723689e+010 pascal
Flexural Strength	ASTM D790	2.068427e+008 pascal
Flexural Modulus	ASTM D790	1.241056e+010 pascal
Flexural Modulus-Full Section		1.930532e+010 pascal
Short Beam Shear	ASTM D2344/D2344M	3.102641e+007 pascal
Shear Modulus-Transverse		3.102641e+009 pascal
Coefficient of Thermal Expansion	ASTM D696	2.032e-005 cm/cm/m
Flame Spread	ASTM E84	2.032e-005 cm/cm/m

Tensile Strength	ASTM D638	30,000 psi
Tensile Modulus	ASTM D638	2,500,000 psi

Flexural Strength	ASTM D790	30,000 psi
Flexural Modulus	ASTM D790	1,800,000 psi
Flexural Modulus-Full Section		2,800,000 psi
Short Beam Shear	ASTM D2344/D2344M	4,500 psi
Shear Modulus-Transverse		450,000 psi
Coefficient of Thermal Expansion	ASTM D696	.000008 in/in/F
Flame Spread	ASTM E84	25 or less

2.1.4 Performance Requirements

2.1.4.1 Structural Performance of Pipe and Tube Railings

Provide a pipe and tube railing system capable of withstanding the effects of gravity loads in accordance with ASCE 7 and International Building Code, ICC IBC the state of [_____] Building Code with the following loads and stresses within limits and under conditions indicated:

a. Handrails:

- (1) Uniform load of 6.91 Kgf/m 50 lbf/ft. applied in any direction.
- (2) Concentrated load of 90.72 Kgf 200 lbf applied in any direction.
- (3) Uniform and concentrated loads need not be assumed to act concurrently.

b. Top Rails of Guards:

- (1) Uniform load of 6.91 Kgf/m 50 lbf/ft. applied in any direction.
- (2) Concentrated load of 90.72 Kgf 200 lbf applied in any direction.
- (3) Uniform and concentrated loads need not be assumed to act concurrently.

c. Infill of Guards:

- (1) Concentrated load of 6.91 Kgf/m 50 lbf applied horizontally on an area of 929 square centimeter 1 sq. ft.
- (2) Uniform load of 1.2 kilopascal 25 lbf/sq.ft. applied horizontally.
- (3) Infill load and other loads need not be assumed to act concurrently.

2.2 FABRICATION

Perform fabrication of the handrail post/rail connection such that the rails are unbroken and continuous through the post without the use of packs

or splices. Install the bottom rail through the post at a prepared hole made to fit the outside dimensions of the rail, and the top rail fit into a machined, u-shaped pocket formed into top of the post such that the rail is located at the center of the post. Radius all exposed corners to eliminate sharp edges. Join the rails to the post through a combination of bonding and riveting. No sharp, protruding edges are to remain after assembly of the handrail. Spacing of the posts are not to exceed 1.83 m 6'-0". Attach post base according to the construction contract drawings. Reinforce post base to a height of 22 cm 8-1/2-inches. All field and shop fabricated cuts are to be coated with a vinyl ester resin to provide maximum corrosion resistance.

2.3 MATERIALS

2.3.1 Fasteners

Provide Type 316 stainless-steel concealed fasteners, unless unavoidable or standard for railings indicated.

2.3.2 Anchors

Provide cast-in-place epoxy mechanical anchors, fabricated from corrosion-resistant materials with capability to sustain, without failure, a load equal to six times the design load imposed when installed in unit masonry and equal to four times the design load imposed when installed in concrete, as determined by testing per ASTM E488/E488M.

2.3.3 Grout And Anchoring Cement

Provide factory-packaged, non-shrink, nonmetallic grout complying with ASTM C1107/C1107M; or water-resistant, non-shrink anchoring cement; recommended by manufacturer for exterior use. Ensure all other adhesives conform to the manufacturer's recommendations and instructions.

2.3.4 Component Connections

2.3.4.1 Lag Screws and Bolts

Provide lag screws and bolts conforming to ASME B18.2.1, of the type and grade best suited for the purpose.

2.3.4.2 Toggle Bolts

Provide toggle bolts conforming to ASME B18.2.1.

2.3.4.3 Bolts, Nuts, Studs and Rivets

Provide bolts, nuts, studs, and rivets conforming to ASME B18.2.2 and ASTM A307.

2.3.4.4 Powder Driven Fasteners

Follow safety provisions of ASSE/SAFE A10.3.

2.3.4.5 Screws

Provide screws conforming to ASME B18.2.1, ASME B18.6.2, and ASME B18.6.3.

2.3.4.6 Washers

Provide plain washers conforming to ASME B18.21.1. Provide beveled washers for American Standard beams and channels, square or rectangular, tapered in thickness, and smooth. Provide lock washers conforming to ASME B18.21.2M and ASME B18.21.1.

PART 3 EXECUTION

3.1 INSTALLATION

Install items in accordance with 29 CFR 1910.23 and 29 CFR 1926 at locations indicated, according to manufacturer's instructions. Verify all measurements and take all field measurements necessary before fabrication. Materials and parts necessary to complete each item, even though such work is not definitely shown or specified, to be included. Perform cutting, drilling, and fitting required for installing railings. Set railings accurately in location, alignment, and elevation. Submit [_____] signed copies of Manufacturer's Certification of Installation

- a. Set posts plumb within a tolerance of 1.6 mm 1/16 inch in 0.91 meter three (3) feet.
- b. Align rails so variations from level for horizontal members and variations from parallel with rake of steps and ramps for sloping members do not exceed 6.4 mm 1/4 inch in 3.66 meter twelve (12) feet.

3.1.1 Anchorage, Fastenings, and Connections

Provide anchorage where necessary for fastening miscellaneous FRP items securely in place. Include for anchorage not otherwise specified or indicated slotted inserts, expansion shields, and powder-driven fasteners, when approved for concrete; toggle bolts and through bolts for masonry; machine and carriage bolts for steel; through bolts and screws. Conceal fastenings where practicable.

3.1.2 Workmanship

FRP work to be well formed to shape and size, with sharp lines and angles and true curves. Drilling and punching to produce clean true lines and surfaces. Exposed surfaces of work in place to have a smooth finish. Where tight fits are required, joints to be milled. Corner joints to be coped or mitered, well formed, and in true alignment. Accurately set work to established lines and elevations and securely fastened in place. Installation to be in accordance with manufacturer's installation instructions and approved drawings, cuts, and details.

3.2 CLOSEOUT ACTIVITIES

3.2.1 Warranty

Submit [_____] signed copies of the Manufacturer's Warranty 30 calendar days before final inspection.

3.2.2 Manufacturer's Instructions

Submit manufacturer's instructions for shipping, handling, erection procedures, and care and maintenance upon completion of installation.

-- End of Section --