

\*\*\*\*\*  
USACE / NAVFAC / AFCEC / NASA UFGS-33 77 36.00 40 (May 2017)  
-----  
Preparing Activity: NASA Superseding  
UFGS-33 77 36.00 40 (May 2014)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2021

\*\*\*\*\*

SECTION TABLE OF CONTENTS

DIVISION 33 - UTILITIES

SECTION 33 77 36.00 40

MEDIUM-VOLTAGE UTILITY FUSES

05/17

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS

PART 2 PRODUCTS

- 2.1 SYSTEM DESCRIPTION
- 2.2 EQUIPMENT
  - 2.2.1 Standards
  - 2.2.2 Fuse Cutouts

PART 3 EXECUTION

- 3.1 INSTALLATION

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEC / NASA UFGS-33 77 36.00 40 (May 2017)  
-----  
Preparing Activity: NASA Superseding  
UFGS-33 77 36.00 40 (May 2014)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated April 2021

\*\*\*\*\*

SECTION 33 77 36.00 40

### MEDIUM-VOLTAGE UTILITY FUSES 05/17

\*\*\*\*\*

NOTE: This guide specification covers the requirements for distribution fuse cutouts. Show on drawings current rating, load-break fuses if required, combination lightning arresters and fuse cutouts if required, and mounting details.

Adhere to [UFC 1-300-02](#) Unified Facilities Guide Specifications (UFGS) Format Standard when editing this guide specification or preparing new project specification sections. Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments, suggestions and recommended changes for this guide specification are welcome and should be submitted as a [Criteria Change Request \(CCR\)](#).

\*\*\*\*\*

## PART 1 GENERAL

### 1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a Reference Identifier (RID) outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature

to update the issue dates.

References not used in the text will automatically  
be deleted from this section of the project  
specification when you choose to reconcile  
references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the  
extent referenced. The publications are referred to within the text by  
the basic designation only.

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS (IEEE)

- IEEE 242 (2001; Errata 2003) Recommended Practice  
for Protection and Coordination of  
Industrial and Commercial Power Systems -  
Buff Book
- IEEE 399 (1997) Brown Book IEEE Recommended  
Practice for Power Systems Analysis
- IEEE C37.40 (2003; Errata 2003; R 2009) Service  
Conditions & Definitions for High-Voltage  
Fuses, Distribution Enclosed Single-Pole  
Air Switches, Fuse Disconnecting Switches,  
& Accessories
- IEEE C37.41 (2016; Corr 2017) Design Tests for  
High-Voltage (>1000 V) Fuses and  
Accessories
- IEEE C37.42 (2016) Specifications for High-Voltage (>  
1000 V) Fuses and Accessories
- IEEE C37.46 (2010) Standard for High Voltage Expulsion  
and Current-Limiting Type Power Class  
Fuses and Fuse Disconnecting Switches
- IEEE C37.47 (2011) Standard for High Voltage  
Distribution Class Current-Limiting Type  
Fuses and Fuse Disconnecting Switches

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

- NEMA ICS 3 (2005; R 2010) Medium-Voltage Controllers  
Rated 2001 to 7200 V AC
- NEMA ICS 6 (1993; R 2016) Industrial Control and  
Systems: Enclosures

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

- NFPA 70 (2020; ERTA 20-1 2020; ERTA 20-2 2020; TIA  
20-1; TIA 20-2; TIA 20-3; TIA 20-4)  
National Electrical Code

## 1.2 SUBMITTALS

\*\*\*\*\*

NOTE: Review Submittal Description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list, and corresponding submittal items in the text, to reflect only the submittals required for the project. The Guide Specification technical editors have classified those items that require Government approval, due to their complexity or criticality, with a "G." Generally, other submittal items can be reviewed by the Contractor's Quality Control System. Only add a "G" to an item, if the submittal is sufficiently important or complex in context of the project.

For Army projects, fill in the empty brackets following the "G" classification, with a code of up to three characters to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

The "S" classification indicates submittals required as proof of compliance for sustainability Guiding Principles Validation or Third Party Certification and as described in Section 01 33 00 SUBMITTAL PROCEDURES.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are [for Contractor Quality Control approval.][for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

### SD-02 Shop Drawings

Fabrication Drawings; G[, [\_\_\_\_]]

Installation Drawings; G[, [\_\_\_\_]]

### SD-03 Product Data

Distribution Fuse Cutouts; G[, [\_\_\_\_]]

### SD-07 Certificates

Testing Certificates

## SD-08 Manufacturer's Instructions

### Fuse Cutouts

### Manufacturer's Installation Instructions

## PART 2 PRODUCTS

### 2.1 SYSTEM DESCRIPTION

\*\*\*\*\*

**NOTE: Show the following information the drawings:**

**1. Conductor sizes, types, and materials.**

**2. Primary fused cutout; give voltage rating and state fusing (ampere rating) and "K" quick or "T" tardy required for coordination with existing upstream sectionalizing equipment.**

\*\*\*\*\*

Submit [fabrication drawings](#) for fuse cutouts consisting of fabrication and assembly details to be performed in the factory.

Submit equipment and performance data for [distribution fuse cutouts](#) including life, [testing certificates](#) verifying conformance to referenced standards, system functional flows, safety features, and mechanical automated details.

### 2.2 EQUIPMENT

#### 2.2.1 Standards

Ensure distribution fuse cutouts conform to the following standards:

- a. [IEEE C37.40](#)
- b. [IEEE C37.41](#)
- c. [IEEE C37.42](#)
- d. [IEEE C37.46](#)
- e. [IEEE C37.47](#)
- f. [IEEE 242](#)
- g. [IEEE 399](#)
- h. [NEMA ICS 3](#)
- i. [NEMA ICS 6](#)
- k. [NFPA 70](#)

#### 2.2.2 Fuse Cutouts

Submit manufacturer's instructions for [fuse cutouts](#), including special

provisions required to install equipment components and system packages. Include special notices detailing impedances, hazards, and safety precautions.

Ensure that distribution fuse cutouts are self-contained, enclosed, dropout type, or open type when required for higher voltage or interrupting rating. Install loadbreak cutouts only if specifically indicated.

Ensure the interrupting capacity is sufficient to break the maximum system fault current to which the cutout will be subjected. The minimum interrupting capacity is 16,000 amperes (A) root mean square (rms) asymmetric.

Provide that heavy-duty or extra-heavy-duty classification cutouts. Ensure cutouts installed on three-phase, 13.2 kilovolt (kV) or 13.8 kV systems that are rated at 15 kV. The installation of cutouts rated at 7.8 kV on these systems is not allowed.

Provide fuse links with a continuous rating equal to approximately 150 percent of the full-load line current when used for transformer protection, and approximately [100][110][\_\_\_\_\_] percent of the conductor-rated capacity when used for circuit protection. Ensure that the 15 kV cutout has a wet withstand, 10-second voltage rating of 37 kV, with a 95 kV basic impulse level (BIL). Provide a continuous current rating of 100 A unless otherwise indicated. Provide fuse disconnects rated not less than 100 amperes, having attachments to permit manual operation of the disconnect under load without external arcing.

Where indicated, combine lightning arresters and fuse cutouts.

## PART 3 EXECUTION

### 3.1 INSTALLATION

Install distribution fuse cutouts in accordance with [installation drawings](#) and with the [manufacturer's installation instructions](#).

-- End of Section --