

\*\*\*\*\*  
USACE / NAVFAC / AFCEA / NASA UFGS-43 13 13.13 (April 2006)  
-----  
Preparing Activity: USACE Replacing without change  
UFGS-11226 (August 2004)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2007

Latest change indicated by CHG tags

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

DIVISION 43 - PROCESS GAS AND LIQUID HANDLING, PURIFICATION, AND STORAGE  
EQUIPMENT

SECTION 43 13 13.13

VAPOR PHASE ACTIVATED CARBON ADSORPTION UNITS

04/06

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 UNIT PRICES
- 1.3 SYSTEM DESCRIPTION
  - 1.3.1 Design Requirements
  - 1.3.2 Influent Air/Gas Conditions
  - 1.3.3 Performance Requirements
    - 1.3.3.1 Physical Requirements
    - 1.3.3.2 Chemical Requirements
    - 1.3.3.3 Carbon Replacement
- 1.4 SUBMITTALS
- 1.5 QUALIFICATIONS
  - 1.5.1 Contractor
  - 1.5.2 Single Source Supplier
  - 1.5.3 Carbon Vessel Fabricator
- 1.6 PARTNERING AND/OR PRE-SUBMITTAL CONFERENCE
- 1.7 GENERAL REQUIREMENTS
  - 1.7.1 Standard Products
  - 1.7.2 Nameplates
  - 1.7.3 Verification of Dimensions
  - 1.7.4 Operation
- 1.8 DELIVERY, STORAGE AND HANDLING
- 1.9 SPARE PARTS
- 1.10 DESIGN CALCULATIONS

#### PART 2 PRODUCTS

- 2.1 VAPOR PHASE ACTIVATED CARBON
- 2.2 VAPOR PHASE ACTIVATED CARBON ADSORPTION UNITS
  - 2.2.1 Velocity
  - 2.2.2 Vapor Distribution/Collection Systems
  - 2.2.3 Shell Design

- 2.2.3.1 Corrosion Prevention
- 2.2.3.2 Manways
- 2.2.3.3 Insulation
- 2.2.3.4 Vessel
- 2.2.3.5 Fire Sprinklers
- 2.2.3.6 Seismic Requirements
- 2.2.4 Description
- 2.3 ACCESSORIES
  - 2.3.1 Blowers
  - 2.3.2 Preconditioning Equipment for Inlet Air/Gas Stream
  - 2.3.3 Carbon Storage and Transfer System
    - 2.3.3.1 Fresh Carbon Storage Tanks
    - 2.3.3.2 Exhausted Carbon Storage Tanks
    - 2.3.3.3 Sampling Valves
    - 2.3.3.4 Piping
- 2.4 VAPOR PHASE ACTIVATED CARBON INSTRUMENTATION AND CONTROLS
  - 2.4.1 Sensors and Transmitters
    - 2.4.1.1 Relative Humidity Sensors
    - 2.4.1.2 Airflow Measuring
    - 2.4.1.3 Pressure Gauges
    - 2.4.1.4 Thermometers
  - 2.4.2 Controllers
    - 2.4.2.1 Relative Humidity Controllers
    - 2.4.2.2 Alarms
    - 2.4.2.3 Relative Humidity Alarms
    - 2.4.2.4 Pressure Alarms
    - 2.4.2.5 Temperature Alarms
    - 2.4.2.6 Carbon Monoxide Alarms
    - 2.4.2.7 Timing Interlock

## PART 3 EXECUTION

- 3.1 EQUIPMENT INSTALLATION
- 3.2 PAINTING FOR CORROSION PREVENTION
- 3.3 FIELD QUALITY CONTROL
  - 3.3.1 Equipment Tests
  - 3.3.2 Performance Tests
  - 3.3.3 Spent Activated Carbon Sampling and Analyses
  - 3.3.4 Carbon Testing
  - 3.3.5 Breakthrough Monitoring
  - 3.3.6 Noncompliance with Performance Requirements
- 3.4 MANUFACTURER'S FIELD SERVICE
  - 3.4.1 Manufacturer's Representative
  - 3.4.2 Field Training
- 3.5 POSTED FRAMED INSTRUCTIONS

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEA / NASA UFGS-43 13 13.13 (April 2006)  
-----  
Preparing Activity: USACE Replacing without change  
UFGS-11226 (August 2004)

#### UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2007

Latest change indicated by CHG tags

\*\*\*\*\*

#### SECTION 43 13 13.13

#### VAPOR PHASE ACTIVATED CARBON ADSORPTION UNITS 04/06

\*\*\*\*\*

NOTE: This guide specification covers the requirements for systems to transfer organic contaminants from a contaminated air/gas stream (e.g. landfill off gas, soil vapor extraction, air stripping, process tank vapors, thermal desorption) to activated carbon adsorption media. This specification only covers offsite disposal or regeneration of activated carbon; it does not cover onsite regeneration.

Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

\*\*\*\*\*

#### PART 1 GENERAL

#### 1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in

this paragraph by organization, designation, date,  
and title.

Use the Reference Wizard's Check Reference feature  
when you add a RID outside of the Section's  
Reference Article to automatically place the  
reference in the Reference Article. Also use the  
Reference Wizard's Check Reference feature to update  
the issue dates.

References not used in the text will automatically  
be deleted from this section of the project  
specification when you choose to reconcile  
references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the  
extent referenced. The publications are referred to within the text by the  
basic designation only.

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING  
ENGINEERS (ASHRAE)

ASHRAE FUN IP (2005) Fundamentals Handbook, I-P Edition

ASHRAE FUN SI (2005) Fundamentals Handbook, SI Edition

ASME INTERNATIONAL (ASME)

ASME B40.100 (2006) Pressure Gauges and Gauge  
Attachments

ASTM INTERNATIONAL (ASTM)

ASTM D 2652 (2005a) Activated Carbon

ASTM D 2854 (1996; R 2004) Apparent Density of  
Activated Carbon

ASTM D 2862 (1997; R 2004) Particle Size Distribution  
of Granular Activated Carbon

ASTM D 2866 (1994; R 2004) Total Ash Content of  
Activated Carbon

ASTM D 2867 (2004) Moisture in Activated Carbon

ASTM D 3802 (1979; R 2005) Ball-Pan Hardness of  
Activated Carbon

ASTM D 4607 (1994; R 2006) Standard Test Method for  
Determination of Iodine Number of  
Activated Carbon

ASTM D 5228 (1992; R 2000) Determination of the Butane  
Working Capacity of Activated Carbon

SHEET METAL AND AIR CONDITIONING CONTRACTORS' NATIONAL ASSOCIATION  
(SMACNA)

SMACNA HVACTAB

(2002, 3rd Ed) HVAC Systems - Testing,  
Adjusting and Balancing

1.2 UNIT PRICES

\*\*\*\*\*

NOTE: On many hazardous, toxic and radioactive waste (HTRW) projects, the Contractor is required to treat contaminated air/gas, as well as furnish the equipment. Measurement and payment and unit pricing may be necessary to cover treatment costs. Write the contract to provide an incentive for the Contractor to do the job efficiently. It may be preferable to base payment on the kg (lbs) of contaminants removed from the air/gas stream entering the carbon vessel. However, if carbon is being used to treat the air from an air stripper, the basis would be the volume of water treated in the air stripper or kg (lbs) of volatile organic chemicals in the water stream entering the air stripper. Or, if the mass of contaminant decreases during the long term operation of the unit, while at the same time the O&M expenses stay approximately constant, it may be preferable to base the payment on the volume of air/gas treated.

\*\*\*\*\*

Payment for contaminated air/gas treated will be as described in the Payment Schedule of the Bid Form.

1.3 SYSTEM DESCRIPTION

\*\*\*\*\*

NOTE: Provide additional information about equipment preceding and following the carbon vessel. This is to provide the vendor with a complete picture of the unit's purpose and operation. Some paragraphs may be eliminated or modified if this Section is to be issued as a performance specification. Others will be eliminated or modified if it is to be issued as a design specification.

Laboratory adsorption studies are seldom done for air/gas adsorption. Estimates are obtained from isothermal data or from vendor computer programs. The ASTM Standards do not provide information on the minimum and maximum values that are acceptable for specifying carbon. Manufacturers may need to be contacted to determine the acceptable values. The characteristics for virgin and regenerated carbon will be different. Verify that the requirements are correct for the type of carbon specified.

\*\*\*\*\*

The vapor phase activated carbon adsorption system shall be a complete

once-through forced flow system. The system shall be capable of reducing the levels of the listed organic contaminants to the values shown in paragraph Performance Requirements. The unit shall be filled with granular activated carbon for removal of organic contaminants from [landfill gas] [soil vapor extraction air/gas] [air stripping air/gas] [process tank vapor emissions] [low temperature thermal desorption air/gas] [\_\_\_\_\_]. Equipment shall include, but shall not be limited to, vessels containing activated carbon, supporting equipment and accessories. Terminology is in conformance with **ASTM D 2652**. The system shall be complete with [[2] [\_\_\_\_\_] parallel trains of [2] [\_\_\_\_\_] carbon vessels in [series] [parallel]] [[2] [\_\_\_\_\_] carbon vessels [in series] [parallel]], activated carbon, [blowers], instruments, controls, valves, piping, pre-heater/cooler and other specified appurtenances. The piping shall be arranged [as shown on the drawings] [\_\_\_\_\_] to allow any of the [2] [\_\_\_\_\_] units to serve as the primary unit and shall also allow any unit to operate alone while the other units are being emptied and refilled with fresh carbon.

### 1.3.1 Design Requirements

\*\*\*\*\*

**NOTE:** The most difficult part of designing an activated carbon adsorption system may be determining the contaminant concentration in the air/gas stream to be treated. Many times design estimates are based on limited data. The actual rate, particularly after the unit has operated for a while, may be much different. An approach may be to design the process for easy addition or removal of carbon units as determined after startup.

Determine seismic parameters from paragraph Seismic Requirements, and wind speed from ASCE 7, Chapter 1, or UFC-3-310-01. Specify whether the unit will be installed inside or outside and any other conditions that will affect the operation of the unit. Coordinate this Section with other pertinent Sections to ensure that information is presented only once. Verify that the floor and footings are designed to support the equipment.

\*\*\*\*\*

The following requirements shall be met:

- a. Minimum equipment design life: [\_\_\_\_\_] years.
- b. Vessel type: [permanent with carbon] [replacement] [interchangeable canisters].
- c. Adsorption system design requirements:
  - 1) Maximum vertical projection: [\_\_\_\_\_] m ft.
  - 2) Maximum ground surface coverage: [\_\_\_\_\_] by [\_\_\_\_\_] m ft.
- d. Seismic parameters: [\_\_\_\_\_].
- e. Wind speed (maximum): [\_\_\_\_\_] km/h mph.
- f. Ground snow load: [\_\_\_\_\_] kPa psf.

g. Ambient air temperature:

1) Maximum: [\_\_\_\_\_] degrees C degrees F.

2) Minimum: [\_\_\_\_\_] degrees C degrees F.

### 1.3.2 Influent Air/Gas Conditions

\*\*\*\*\*

NOTE: Remove this paragraph if the specification is to be issued as a design specification. Obtain an analysis of the air/gas to be treated giving appropriate information to be inserted in the blank spaces. The inlet air/gas composition may be difficult to obtain. If the specification is to be issued as a performance specification the inlet composition will need to be estimated.

Oxygen and methane data are useful if the methane concentration is high enough to have a potential to be in the explosive range. If the concentration is well below this range, remove the methane and oxygen concentration lines. Provide all available information. All available pertinent site characterization data should be placed in an appendix of the technical specifications or on the drawings, and referenced here. Indicate the detail to which site characterization has been performed and indicate where data gaps exist. The information should also include soil gas data, chemical data, geotechnical data, sampling locations, and boring logs. Table must be edited to add contaminants not listed and delete those that are not applicable. Verify that carbon will adsorb the organic chemicals since many organic chemicals do not adsorb well on carbon.

\*\*\*\*\*

	Minimum	Average	Maximum
Oxygen			[_____] percent
Methane			[_____] percent
Relative Humidity	[_____] [_____] [_____] 50 percent		
Carbon Tetrachloride	[_____] [_____] [_____] ppmv		
Trichloroethene	[_____] [_____] [_____] ppmv		
Benzene	[_____] [_____] [_____] ppmv		
Toluene	[_____] [_____] [_____] ppmv		
Xylene	[_____] [_____] [_____] ppmv		

	Minimum	Average	Maximum
Carbon Monoxide	[_____]	[_____]	[_____] ppmv
Ozone	[_____]	[_____]	[_____] ppmv
[_____]	[_____]	[_____]	[_____] ppmv

### 1.3.3 Performance Requirements

\*\*\*\*\*  
**NOTE: Remove these paragraphs if the specification is to be issued as a design specification. Removal expressed as a percent is dependent on inlet concentrations which can vary. Ensure that the desired emission rates can be met before using percent removal.**  
 \*\*\*\*\*

#### 1.3.3.1 Physical Requirements

	Minimum	Maximum	Unit
Air/gas flow rate	0.0005		cu m/s
Air/gas temperature		60	degrees C
Inlet Pressure		70	kPa
	Minimum	Maximum	Unit
Air/gas flow rate	1		scfm
Air/gas temperature		140	degrees F
Inlet Pressure		10	psig

#### 1.3.3.2 Chemical Requirements

	Maximum Emission	Per Cent Removal
Carbon Tetrachloride	[_____] ppmv	[_____]
Trichloroethene	[_____] ppmv	[_____]
Benzene	[_____] ppmv	[_____]
Toluene	[_____] ppmv	[_____]
Xylene	[_____] ppmv	[_____]
[_____]	[_____] ppmv	[_____]



1.3.3.3 Carbon Replacement

Intervals between carbon replacements shall not be less than [\_\_\_\_\_] days.

1.4 SUBMITTALS

\*\*\*\*\*

NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for [Contractor Quality Control approval.][information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] The following shall be submitted in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Vapor Phase Activated Carbon Adsorption Units[; G][; G, [\_\_\_\_\_]]

Drawings showing complete equipment layout, piping, wiring and schematic diagrams, manufacturer's description and technical literature, performance charts, catalog cuts and installation instructions and any other details required to show equipment

relationships, clearances for maintenance and operation and to demonstrate that the system has been coordinated and will properly function as a unit. Process flow diagrams and instrumentation diagrams showing all major pieces of process equipment with controls. Details on the carbon adsorber shell including information on vapor diffusion, carbon contact shell dimensions, construction materials and structural and supporting design calculations.

### SD-03 Product Data

#### Emissions

Reports for emissions permit compliance.

#### Vapor Phase Activated Carbon Adsorption Units[; G][; G, [\_\_\_\_\_]]

Instrumentation and controls; capacities and pressure drop; make and model; complete list of equipment and materials, including manufacturer's descriptive and technical literature; spare parts data; performance charts and curves; catalog cuts; and installation instructions. Design calculations or computer modeling results for vapor phase carbon adsorption system indicating removals of each of the organic compounds listed. Demonstration of, or design calculations for, the total head loss through the carbon unit. Isotherm and design calculations or manufacturer's computer models shall be provided to estimate the mass of carbon required and the breakthrough curves. Calculations showing how the vapor phase carbon adsorption system functions with the entire air/gas system including carbon vessel, [regeneration equipment], preheater, instrumentation and controls, dimensions, capacities, make and model, materials of construction, coating systems, pressure drop through each component of the system, including line sizing, valving, pressure and temperature gauges. Structural calculations for fabrication and erection drawings if requested (not needed for drum/canister applications).

A complete list of parts, supplies, special tools, instruments and accessories and special lifting and handling devices required for periodic maintenance, repair, adjustment and calibration and recommended spare parts for each different item of material and equipment specified, with current unit prices and source of supply, and a list of the parts recommended by the manufacturer to be replaced after [one] [\_\_\_\_\_] and [three] [\_\_\_\_\_] years of service.

#### Vapor Phase Activated Carbon[; G][; G, [\_\_\_\_\_]]

Type of activated carbon, with isotherms for the selected carbon, with each of the volatile organic compounds listed in the effluent requirements for the anticipated temperature range at 50 percent relative humidity. Design calculations or vendor computer models shall be used to estimate the mass of carbon required and the breakthrough curves for the listed organic compounds in the carbon bed.

#### Posted Framed Instructions[; G][; G, [\_\_\_\_\_]]

Framed and other instructions, containing wiring and control

diagrams and condensed operating instructions.

#### SD-06 Test Reports

##### Field Quality Control

Reports on tests performed to show compliance with instructions. Test reports shall include all field tests performed to adjust each component and all field tests performed to prove compliance with the specified performance criteria. Each test report shall indicate the final position of all controls. Performance test data shall be reflected in the operating instructions.

#### SD-07 Certificates

##### Vapor Phase Activated Carbon

Manufacturer's certificates attesting that the activated carbon furnished meets the specified requirements. Copies of certificate from system supplier showing that the equipment has been tested and has passed all quality control criteria. Certification of the activated carbon [supplier] [transporter] [regeneration facility]. [Copies of the Department of Transportation licenses of carbon transporter service.]

##### Vapor Phase Activated Carbon Adsorption Units

Verification from a Registered Professional Engineer, licensed to practice mechanical or structural engineering, as appropriate, in the State in which the system is to be installed/fabricated stating that: 1) The fabrication drawings and pressure calculations for the vessels were done for the site conditions in accordance with the appropriate codes and standards. 2) The erection drawings for the shells and tank foundations and supports were done for the site conditions in accordance with the appropriate codes and standards.

#### SD-10 Operation and Maintenance Data

##### Operating and Maintenance Manuals[; G][; G, [\_\_\_\_]]

[Six] [\_\_\_\_] complete copies of operating instructions outlining the step-by-step procedures required for system startup, operation and shutdown. The instructions shall include layout, wiring, and control diagrams of the system as installed. The manufacturer's name, model number, service manual, parts list, brief description of all equipment and their basic operation features, and operating instructions for each piece of equipment and bulletins, cut sheets and descriptive data. [Six] [\_\_\_\_] complete copies of maintenance instructions listing routine preventative maintenance procedures, possible breakdowns and repairs, and trouble shooting guides list showing lubricants for each item of mechanical equipment, approximate quantities needed per year and recommended lubrication intervals.

## 1.5 QUALIFICATIONS

### 1.5.1 Contractor

The Contractor shall have [had a minimum of [2] [\_\_\_\_\_] years experience in the construction, startup and operation of industrial air pollution control devices] [installed a minimum of [2] [\_\_\_\_\_] vapor phase carbon adsorption units in the past [5] [\_\_\_\_\_] years].

### 1.5.2 Single Source Supplier

The Contractor shall assign to a single supplier full responsibility for furnishing of the activated carbon system. The designated single supplier, however, need not manufacture the system but shall coordinate the selection, assembly, installation, and testing of the entire adsorption system, including preheater, the blower and ductwork specified in other Sections. The supplier shall have [been in the business of manufacturing, fabricating or installing these systems for a minimum of [2] [\_\_\_\_\_] years] [manufactured and supplied a minimum of [5] [\_\_\_\_\_] vapor phase carbon adsorption units].

### 1.5.3 Carbon Vessel Fabricator

\*\*\*\*\*  
**NOTE: Verification from a registered professional engineer should only be required for large systems which have to be bolted to the foundation. Delete this paragraph for small units which are on forktubes or a flat base and not fastened to the foundation.**  
\*\*\*\*\*

The Contractor shall have a Registered Professional Engineer, licensed to practice mechanical or structural engineering, as appropriate, in the State in which the system is to be installed verify that: 1) The fabrication drawings and pressure calculations for the vessels and appurtenances were done for the site conditions in accordance with the appropriate codes and standards. 2) The erection drawings for the shells and tank foundations and supports were done for the site conditions in accordance with the appropriate codes and standards.

## 1.6 PARTNERING AND/OR PRE-SUBMITTAL CONFERENCE

\*\*\*\*\*  
**NOTE: Remove this paragraph when a conference is not required.**  
\*\*\*\*\*

A [partnering] [and] [Pre-submittal] conference will be required. The Contractor shall ensure that involved subContractors, suppliers, and manufacturers are notified. The date and time of the conference shall be furnished to the Contracting Officer for approval.

## 1.7 GENERAL REQUIREMENTS

### 1.7.1 Standard Products

Material and equipment shall be the standard products of a manufacturer regularly engaged in the manufacture of the products and shall essentially

duplicate items that have been in satisfactory use for at least [2] [\_\_\_\_\_] years prior to bid opening. Materials and equipment shall be supported by a service organization that is located within [\_\_\_\_\_] km miles of the site.

#### 1.7.2 Nameplates

Major equipment items such as adsorption vessels, blowers and motors shall have the manufacturer's name, address, type or style, model or serial number, and catalog number on a plate secured to the item of equipment.

#### 1.7.3 Verification of Dimensions

The Contractor shall, after becoming familiar with the details of the work, verify all dimensions in the field, and shall advise the Contracting Officer of any discrepancies before performing the work.

#### 1.7.4 Operation

The system shall be designed to operate continuously, 24 hours per day, 7 days per week.

### 1.8 DELIVERY, STORAGE AND HANDLING

Parts shall be preassembled to the largest extent possible, compatible with transportation limitations and equipment protection considerations. Field assembly, if any, shall require merely bolting together of match-marked components. Equipment shall be crated and delivered to protect against damage during shipping. Flange faces shall be protected from damage. All openings shall be covered to prevent entrance of dirt, water and debris. All parts shall be properly protected so that no damage or deterioration will occur during a prolonged delay from the time of shipment until installation is completed and until the units and equipment are ready for operation. Finished iron or steel surfaces shall be properly protected to prevent rust and corrosion. All equipment delivered and placed in storage shall be stored with protection from the weather (humidity and temperature), dirt and dust, and other contaminants.

### 1.9 SPARE PARTS

Within 30 days of approval, the Contractor shall furnish a spare parts list for each different item of material and equipment specified with the shop drawings submitted. The list shall include parts, supplies, prices and sources schedule. The Contractor shall furnish those spare parts and special tools which are recommended by the manufacturer. The Contractor shall also provide 12 months supply of any expendable items and frequently replaced parts, except for carbon, as identified by the manufacturer. Following completion of the startup and operating period the Contractor shall [replenish the spare parts inventory and provide a twelve month supply] [supply the [carbon regeneration] [carbon disposal] facility name, address and price schedule].

### 1.10 DESIGN CALCULATIONS

\*\*\*\*\*  
NOTE: Delete this paragraph when design is done by  
the Government.  
\*\*\*\*\*

Before initiation of construction the Contractor shall supply a copy of all

the design calculations to the Contracting Officer.

## PART 2 PRODUCTS

### 2.1 VAPOR PHASE ACTIVATED CARBON

\*\*\*\*\*  
NOTE: Performance specifications are recommended to allow the Contractor to install proven "off-the-shelf" units supplied by two or three reputable manufacturers. Determine if the first charge of carbon needs to be virgin carbon for liability requirements. Remove items not required below.  
\*\*\*\*\*

Material shall conform to the following:

- a. The initial charge of carbon shall be [virgin] [regenerated] [virgin or regenerated] carbon. Subsequent charges shall be [virgin] [regenerated] [virgin or regenerated] carbon.
- b. The carbon adsorption system shall be capable of reducing emissions for individual compounds to below the limits specified in SYSTEM DESCRIPTION.
- c. Approximate average volatile organic composition of the vapor stream shall be based on estimated influent component levels as specified in SYSTEM DESCRIPTION.
- d. Minimum butane working capacity of new activated carbon of [23.8] [\_\_\_\_\_] percent by weight shall be as determined by ASTM D 5228.
- e. Minimum iodine number of virgin or reactivated carbon of [1000] [\_\_\_\_\_] shall be as determined by ASTM D 4607.
- f. Maximum moisture content of [2] [\_\_\_\_\_] percent by weight shall be as determined by ASTM D 2867.
- g. Maximum total ash content of [10] [\_\_\_\_\_] percent by weight shall be as determined by ASTM D 2866.
- h. Minimum hardness number of [90] [\_\_\_\_\_] necessary for the required life in vapor phase applications shall be as determined by ASTM D 3802.
- i. Activated carbon particle size shall be uniform for consistent pressure drop characteristics. Maximum particle size shall be 4.6 mm 0.2 inch diameter as determined by ASTM D 2862.
- j. The granular activated carbon shall be of the type that can be accepted for offsite regeneration of the spent activated carbon by an approved carbon regeneration facility.
- k. Minimum apparent density of [0.45] [\_\_\_\_\_] g/cc shall be as determined by ASTM D 2854.
- l. Maximum pressure drop shall be [\_\_\_\_\_] kPa/m inches of water per foot of bed depth, measured in air at 21 degrees C 70 degrees F.

- m. US Sieve size shall be [4 x 8] [\_\_\_\_].
- n. Material shall be free from impurities that affect the serviceability and appearance of the finished product.

## 2.2 VAPOR PHASE ACTIVATED CARBON ADSORPTION UNITS

\*\*\*\*\*

NOTE: General rules to the system designer for configuration of a vapor phase activated carbon system are as follows:

- a. Two stage series operation to provide longer contact and more complete exhaustion of the carbon is preferred. In series operation, the unit with the freshest carbon at any given time should be in the lag position. For critical operations, lead, lag and standby units should be provided as specified in paragraph SYSTEM DESCRIPTION.
- b. Multiple units in parallel operation are frequently used for high flows with low contamination levels when short contact times are adequate. Single units should be used only in installations in which the system can be shut down for change out of the activated carbon adsorption media. Multiple smaller units containing the same amount of carbon and providing equal contact are usually preferable to single large unit.
- c. An appropriate piping configuration which can adapt the units for series or parallel operation should be considered. Arrangements that allow conversion from parallel to series and the reverse allow the flexibility to respond to differing conditions.
- d. Surface loading ranges between 12 and 24 cu m/min/sq m (40 and 80 cfm/min/sq ft) are often used.
- e. Minimum bed depth at a given velocity is based on the minimum contact time required to achieve the required removal. Additional bed volume allows more time between carbon changes.
- f. The relative humidity of the air/gas entering the carbon unit should be 50 percent or less. If the air/gas entering the unit has entrained water an air/gas-water separator should be used. Without this, the temperature of the air/gas will have to be elevated enough to vaporize the mist and lower the relative humidity to about 50 per cent. At this higher temperature the organic chemical may not adsorb well.

\*\*\*\*\*

### 2.2.1 Velocity

\*\*\*\*\*  
NOTE: In an up-flow system the velocity should generally be in the range of 12 to 24 m/sec (40 to 80 feet per minute); this depends on the particle size. In a down-flow system, the flow velocity is only limited by the allowable pressure drop.  
\*\*\*\*\*

The minimum and maximum acceptable flow velocities shall be as follows:  
0.25 m/sec at [ ] cu m/sec minimum; and 0.375 m/sec at [ ] cu m/sec maximum  
40 ft/min at [ ] scfm minimum; and 80 ft/min at [ ] scfm maximum.

### 2.2.2 Vapor Distribution/Collection Systems

Vapor distribution/collection systems shall provide effective distribution across the bed throughout the stated capacity range. A system shall be provided to minimize short circuiting or channeling of contaminated air/gas through the carbon vessel. The system shall be designed to evenly distribute the controlled contaminated air/gas flow across the cross section, with the nominal velocity under design conditions not exceeding 0.41 m/sec 80 fpm for up-flow systems. Design of the inlet and outlet shall be adequate to prevent local pressurization in excess of the vessel rating or design.

### 2.2.3 Shell Design

\*\*\*\*\*  
NOTE: Most carbon vessels are not designed for vacuum. Verify that a vacuum cannot be drawn on the vessel exceeding the manufacturer's recommendation. If the vessel will have internal pressure greater than 103 kPa (15 psig), it may need to be ASME rated. Vessels with less than this pressure may or may not need to be pressure rated depending on special ASME or State/local codes.  
\*\*\*\*\*

#### 2.2.3.1 Corrosion Prevention

Corrosion resistant steel, fiberglass, or other plastic shall be used for shell construction or a steel shell with a corrosion resistant [enamel] [ ] coating. The lining system shall have a corrosion resistant [epoxy or phenolic resin] [ ] coating. Paint kits shall be furnished for use after assembly and finishing.

#### 2.2.3.2 Manways

Minimum manway requirements, for access, addition and removal of carbon shall be [1] [ ] per adsorber and 610 mm 24 in minimum nominal diameter.

#### 2.2.3.3 Insulation

\*\*\*\*\*  
NOTE: Insulation is optional. It may be needed if the carbon units are installed outside in cold climates. A high differential pressure across a fan



or blower that precedes the carbon unit may result in a high air/gas discharge temperature. Pipes and fittings down stream may not need insulation. Plastic or fiberglass pipes and fittings should not be used if the discharge temperature can exceed that recommended for the material.

\*\*\*\*\*

Insulation [and heat tape] to prevent cooling of the air/gas in the system shall be installed as specified in Section 23 07 00 THERMAL INSULATION FOR MECHANICAL SYSTEMS. All outside surfaces of the following equipment shall be insulated: [adsorbers] [pipes] [fittings] [stacks] [\_\_\_\_\_].

#### 2.2.3.4 Vessel

\*\*\*\*\*

NOTE: If the specification is to be issued as a performance specification, remove adsorber diameter and carbon quality in this paragraph. Delete the minimum bed depth for a performance specification. Small units do not need inlet air/gas distributors. Add a paragraph requiring an outside access ladder if the top of the vessel must be accessed frequently. The number of carbon vessels should conform to those specified in SYSTEM DESCRIPTION.

\*\*\*\*\*

The following requirements shall be met:

- a. Minimum Number of Vessels: [2] [\_\_\_\_\_].
- b. Minimum Adsorber Diameter: [\_\_\_\_\_] m ft.
- c. Material of Construction: [carbon steel] [\_\_\_\_\_].
- d. Maximum Allowable Working Pressure: [\_\_\_\_\_] kPa psig.
- e. Minimum Carbon Quantity per Vessel: [\_\_\_\_\_] kg lbs.
- f. Minimum Carbon Bed Depth: 922 mm 36 inches.
- g. Flow Direction: [upflow] [downflow].
- h. Outlet Collector: [\_\_\_\_\_].
- i. Inlet Distributor: Integral
- j. Min. Allowable Temperature: [\_\_\_\_\_] degrees C degrees F.

Each unit shall be [skid-mounted. Skids shall be fabricated of [cast iron] [steel] channels and shall be designed to support the equipment and to distribute the weight in transit and in service without loading on the tank or concrete slab;] [equipped with lifting lugs] and pre-piped internally. Each vessel shall be secured to a structural steel frame suitable for shipment or transport with a forklift or crane and set on a level area for operation. Exterior structural steel surfaces shall be coated with a suitable primer and top coat to resist corrosion due to water spray. Each unit shall have a minimum of one ground connection. Each unit shall be provided with an inlet air/gas distributor, if required. Sampling ports

shall be provided on the inlet and outlet pipes of each vessel to allow independent sampling and measurement of breakthrough for each unit.

#### 2.2.3.5 Fire Sprinklers

\*\*\*\*\*  
NOTE: A fire suppression system is needed if the carbon manufacturer believes the adsorbed contaminant can react and cause a fire.  
\*\*\*\*\*

The carbon vessels shall be equipped with an internal water sprinkler to suppress carbon fires.

#### 2.2.3.6 Seismic Requirements

\*\*\*\*\*  
NOTE: Provide seismic requirements, if a government designer (either Corps office or A/E) is the Engineer of Record, and show on the drawings. Remove the bracketed phrase if seismic details are not provided. Sections 13 48 00 SEISMIC PROTECTION FOR MISCELLANEOUS EQUIPMENT and 13 48 00.00 10, SEISMIC PROTECTION FOR MECHANICAL EQUIPMENT properly edited, must be included in the contract documents.  
\*\*\*\*\*

Adsorption units shall be supported and braced to resist seismic loads as specified under Sections 13 48 00 SEISMIC PROTECTION FOR MISCELLANEOUS EQUIPMENT and 13 48 00.00 10 SEISMIC PROTECTION FOR MECHANICAL EQUIPMENT [as shown on the drawings].

#### 2.2.4 Description

Calculations, layouts and drawings of the carbon adsorption system shall be provided to clearly show the basis for the design; including isotherms, estimated breakthrough volumes, and calculations to show that the entire system will conform to paragraph Performance Requirements.

### 2.3 ACCESSORIES

#### 2.3.1 Blowers

The blowers shall conform to Section 43 11 00 FANS/BLOWERS/PUMPS; OFF-GAS.

#### 2.3.2 Preconditioning Equipment for Inlet Air/Gas Stream

\*\*\*\*\*  
NOTE: An air/gas preheater may not be needed if the carbon unit is preceded with a blower. Blowers heat the air/gas which reduces the relative humidity. A blower may raise the temperature of the air/gas more than needed. If this occurs, cooling will be required before entering the carbon unit. If a specific type of preheater is needed, specific information on the type of heater, materials of construction and type of energy source (electricity, steam, natural gas) should be indicated on the drawings or added to the specifications. Either the

paragraph on the air/gas preheater or the air/gas cooler or both should be deleted.

\*\*\*\*\*

[A preheater shall be required if the relative humidity is greater than [50] [\_\_\_\_\_] per cent. The preheater shall be [of the type and size as shown on the schedule on the drawings] [\_\_\_\_\_] . The preheater shall lower the relative humidity of the influent to [50] [\_\_\_\_\_] percent. Materials of construction and controls and cutoffs shall be provided. The heating element shall be [directly] [indirectly] heated.] [The vapor stream leaving a forced draft blower that precedes the carbon vessel shall pass through a heat exchanger that cools the air/gas stream. The heat exchanger shall be of the type and size as shown on the schedule on the drawings. The heat exchanger shall lower the temperature enough to raise the relative humidity to no more than 50 percent.]

### 2.3.3 Carbon Storage and Transfer System

\*\*\*\*\*

NOTE: Fresh carbon storage vessels and exhausted carbon storage vessels are not usually used in vapor phase systems. In large systems, the carbon is vacuumed or removed by eductor (water) and put into a truck. In smaller systems the carbon is usually removed by vacuum.

If there is no onsite storage, two trucks are needed, one empty to receive the used carbon and one with fresh carbon. Economics should dictate whether to install extra vessels at the site or to have an empty truck accompany the truck with the fresh carbon. It is often desirable to size the vessels to hold a full truck load of activated carbon to reduce shipping costs. On many small systems, the entire vessel containing the used carbon is replaced with a vessel containing fresh carbon. Vessels are sometimes filled from 400 to 450 kg (900 to 1000 pound) sacks or 90 kg (200 pound) drums. In this situation, no storage tanks are needed. Remove the paragraph on fresh Carbon Storage Tank and Exhausted Carbon Storage Tanks if these will not be required.

\*\*\*\*\*

#### 2.3.3.1 Fresh Carbon Storage Tanks

A fresh carbon storage system shall be provided. Minimum capacity of the system shall provide storage of [\_\_\_\_\_] kg pounds of dry carbon at a bulk density of [\_\_\_\_\_] kg/cubic meter pcf.

#### 2.3.3.2 Exhausted Carbon Storage Tanks

An exhausted carbon storage supply system shall be provided. Minimum capacity of the system shall provide storage of [\_\_\_\_\_] kg pounds of wet carbon saturated with organic chemicals.

#### 2.3.3.3 Sampling Valves

Sampling valves shall be provided at the inlet and outlet of each carbon unit.

#### 2.3.3.4 Piping

Piping shall be in accordance with Section 31 21 00 PIPING; OFF-GAS.

#### 2.4 VAPOR PHASE ACTIVATED CARBON INSTRUMENTATION AND CONTROLS

\*\*\*\*\*  
NOTE: These paragraphs can be used in conjunction with Sections 25 10 10 UTILITY MONITORING AND CONTROL SYSTEM (UMCS) and 23 09 23 DIRECT DIGITAL CONTROL FOR HVAC AND OTHER LOCAL BUILDING SYSTEMS modified as required for this application. An instrumentation and control Guide Specification for hazardous waste systems is being written.  
\*\*\*\*\*

##### 2.4.1 Sensors and Transmitters

\*\*\*\*\*  
NOTE: The humidity interlock will prevent condensation of water vapor in the carbon during startup if conditions exist that could allow high humidity air to the carbon unit.  
\*\*\*\*\*

Sensors and transmitters shall have a range selected for the application, using the smallest range available from the controls manufacturer that will meet all expected sensed conditions in the sequence of control. Sensors and transmitters shall consist of the following:

##### 2.4.1.1 Relative Humidity Sensors

Relative humidity sensing element shall have a relative humidity sending range from 0 to 100 percent (condensing). The sensor shall be capable of sensing a condensing air stream (100 percent RH) without affecting the sensors calibration or harming the sensor. Sensing elements shall have an accuracy of plus or minus 5 percent of full scale within the range of 20 to 80 percent relative humidity. All sensors shall be mounted in locations that are accessible for calibration and shall be fitted for ease of calibration and re-calibration.

##### 2.4.1.2 Airflow Measuring

\*\*\*\*\*  
NOTE: Pitot-tube type flow measuring devices can malfunction if the air/gas contains water droplets.  
\*\*\*\*\*

The velocity sensing elements shall be of the [RTD or thermistor type, with linearizing means. The sensing elements shall be distributed across the pipe in the quantity and pattern set forth for measurements and instructions in ASHRAE FUN SIASHRAE FUN IP and SMACNA HVACTAB for traversing of ducted airflows. The resistance to airflow through the airflow measurement station shall not exceed 2 mm 0.08 inch water gauge at an airflow of 600 m/min 2,000 fpm. Station construction shall be suitable for operation at airflows of up to 1500 m/min 5,000 fpm over a temperature range of 4 to 60 degrees C 40 to 140 degrees F, and accuracy shall be plus or minus 3 percent over a range of 40 to 760 m/min 125 to 2,500 fpm scaled

to air volume.] [multiple pitot tube type with averaging manifolds. The sensing elements shall be distributed across the pipe in the quantity and pattern set forth for measurements and instruments in ASHRAE FUN SI ASHRAE FUN IP or SMACNA HVACTAB for the traversing of ducted airflows. The resistance to airflow through the airflow measurement station shall not exceed 2 mm 0.08 inch water gauge at an airflow of 600 m/min 2,000 fpm. Station construction shall be suitable for operation at airflows of up to 1500 m/min 5,000 fpm over a temperature range of 4 to 60 degrees C 40 to 140 degrees F, and accuracy shall be plus or minus 3 percent over a range of 150 to 760 m/min 500 to 2,500 fpm scaled to air volume. This device shall not be used if the required velocity measurement is below 210 m/min 700 fpm.]

#### 2.4.1.3 Pressure Gauges

Pressure gauges shall conform to ASME B40.100.

#### 2.4.1.4 Thermometers

Thermometers shall be dial type, 88 mm 3-1/2 inch diameter, chromium plated case; remote or direct-type bulb as required; plus or minus 0.5 degree C 1 degree F accuracy; white face with black digits graduated in 1 degree C 2 degree F increments. Thermometer wells of the separable socket type shall be provided for each thermometer with direct-type bulb. Range of thermometers shall be [\_\_\_\_\_] to [\_\_\_\_\_] degrees C degrees F.

#### 2.4.2 Controllers

Controllers shall have set point, action, proportional band, authority throttling range, ratio, and remote set point adjustment as required to meet requirements of the sequence of control. Controllers shall be mounted on a unit control panel located [in the same room as the system being controlled] [near the carbon vessels].

##### 2.4.2.1 Relative Humidity Controllers

Humidity controllers shall be space-type and shall take full control action for a relative humidity change of plus or minus 5 percent of the setting of the controller. Set point adjustment range shall be approximately [20] [\_\_\_\_\_] percent to [80] [\_\_\_\_\_] percent relative humidity. Controllers shall have adjustable throttling ranges. Controllers to be mounted in the interior of piping shall be of the insertion type, fitted with air shields where so recommended by the manufacturer.

##### 2.4.2.2 Alarms

Alarm annunciation shall be by [visual] [and] [audible] indication. Alarm signals shall be locked in and require manual reset. [An auto dialer shall be furnished] [Alarms shall be telemetered to the master control panel in the control room].

##### 2.4.2.3 Relative Humidity Alarms

Relative humidity alarms shall be installed immediately upstream from the carbon vessels to alert the operator of relative humidity exceeding [50] [\_\_\_\_\_] percent.

##### 2.4.2.4 Pressure Alarms

Pressure [alarms] [indicators] shall be installed on each side of the

carbon vessels to alert the operator of excessive pressure drop.

#### 2.4.2.5 Temperature Alarms

\*\*\*\*\*  
NOTE: Temperature or carbon monoxide alarms can be  
used to monitor for fire in the carbon bed.  
\*\*\*\*\*

Temperature alarms shall be provided on excursions (drop or rise) of [10] [\_\_\_\_\_] degrees C [18] [\_\_\_\_\_] degrees F outside the control range in the duct leaving the carbon vessel.

#### 2.4.2.6 Carbon Monoxide Alarms

Carbon monoxide alarms shall be provided to alert the operator of concentrations in excess of [100] [\_\_\_\_\_] ppm in the exit gas.

#### 2.4.2.7 Timing Interlock

A timing interlock shall be provided to delay starting the blower until the preheater has been turned on for [15] [\_\_\_\_\_] seconds. This interlock shall prevent saturation of the carbon during startup procedures and shall delay blower stops after every shut performed.

### PART 3 EXECUTION

#### 3.1 EQUIPMENT INSTALLATION

Equipment shall be installed as shown and in accordance with written instructions of the manufacturer. Each vessel shall be [anchored to a footing isolated from the floor slab] [mounted on a skid base]. Anchor brackets, anchor rods or straps shall be provided to hold the shell to anchors in the footing. Reinforced concrete foundations for each carbon unit shall be designed to support the unit and shall be in accordance with Section 03 31 00.00 10 CAST-IN-PLACE STRUCTURAL CONCRETE.

#### 3.2 PAINTING FOR CORROSION PREVENTION

Equipment which did not receive a factory finish shall be painted, unless specified otherwise. The paint system applied to the outside of the tank shall be in accordance with Section 09 90 00 PAINTS AND COATINGS. Surfaces that have not been factory primed shall be primed and top coated with the manufacturer's standard factory finish. Factory painting shall conform to manufacturer's standard factory finish. All defects in the finish prior to or during installation of the equipment shall be repaired by the Contractor as specified in Section 09 90 00 PAINTS AND COATINGS. All exposed ferrous surfaces not painted in the factory shall be painted in accordance with Section 09 90 00 PAINTS AND COATINGS. Painting of corrosion resistant materials such as copper, brass, bronze, copper-nickel, and stainless steel is not required, unless otherwise specified. All ferrous surfaces shall be coated or painted. Color shall be as indicated on the paint schedule or as otherwise approved.

#### 3.3 FIELD QUALITY CONTROL

##### 3.3.1 Equipment Tests

After installation of the carbon adsorption system is complete, operating

tests shall be carried out to ensure that the unit installed operates properly. All products shall be carefully inspected for defects in workmanship and material; debris and foreign matter shall be cleaned out of all equipment; all operating mechanisms shall be tested to check their proper functioning; and all nuts and bolts shall be checked for tightness. Valves and other equipment which do not operate easily or are otherwise defective shall be repaired or replaced. Tests shall assure that there is no vibration, or noise from any parts. If deficiencies are revealed during tests, such deficiencies shall be corrected and the tests shall be reconducted at the Contractor's expense.

### 3.3.2 Performance Tests

\*\*\*\*\*

NOTE: Running the unit to exhaustion should only be required if this is expected to occur within the test period. Some vessels may not get to exhaustion for a long period of time. Verify that the sample ports are addressed in Section 31 21 00 PIPING; OFF-GAS. Coordinate sampling requirements of this paragraph with the sampling requirements of other units/processes in the entire treatment train.

\*\*\*\*\*

After installation of the activated carbon adsorption system, operating tests shall be carried out to ensure that the system operates properly. This shall include the adsorption units, all accessories and instruments and controls. If any deficiencies are revealed during any tests, such deficiencies shall be corrected and the tests repeated. [Each] [A typical] adsorber shall be run at a constant flow rate of approximately [\_\_\_\_\_] cubic meters/second scfm [until the maximum emissions as listed in paragraph Chemical Requirements occur] [for [24] [\_\_\_\_\_] hours]. A complete log of each test run shall be made, giving the following data: date, time of readings and sampling. Total chemicals removed shall be determined by analyses of the inlet and outlet for the chemical requirements listed in paragraph Performance Requirements. Samples shall be taken of the emissions for analysis after [each [\_\_\_\_\_] cubic meters feet have been run through the adsorber] [[\_\_\_\_\_] hours of operation]. Results of the tests shall be used in determining the capacity and performance of the adsorption unit. Sampling and analyses shall be performed in accordance with Section 01 35 45.00 10 CHEMICAL DATA QUALITY CONTROL.

### 3.3.3 Spent Activated Carbon Sampling and Analyses

Sampling and analyses of the spent activated carbon media shall be performed in accordance with requirements [for spent carbon transport and requirements of the regeneration facility] [of the RCRA permitted treatment, storage and disposal facility] and Section 01 35 45.00 10 CHEMICAL DATA QUALITY CONTROL.

### 3.3.4 Carbon Testing

The carbon to be used during the performance testing shall be tested by the Contractor to ensure it meets the requirements of Section 01 35 45.00 10 CHEMICAL DATA QUALITY CONTROL and paragraph VAPOR PHASE ACTIVATED CARBON.

### 3.3.5 Breakthrough Monitoring

\*\*\*\*\*

**NOTE: Continuous emission monitors are not addressed in this Section. If continuous emission monitors are required, verify that the detector used is specific for the chemicals to be monitored.**

\*\*\*\*\*

Monitoring the emissions for the chemicals in paragraph Chemical Requirements shall be done once every [7] [\_\_\_\_\_] days to determine when to replace the granular activated carbon. The volume of air/gas that was treated, from the time that the vessel was placed in the upstream position until breakthrough was consistently determined, shall be recorded as the breakthrough volume. Breakthrough volume is the volume of air/gas that was treated before the concentration of any one of the chemicals in paragraph Chemical Requirements was exceeded. The criteria for determining when to replace granular activated carbon may be modified as more data are generated.

### 3.3.6 Noncompliance with Performance Requirements

Removals shall meet or exceed those specified in the performance requirements of this specification. If at any time during the first [12] [\_\_\_\_\_] months of operation the results of the organic analyses of the air/gas emissions are not in compliance with paragraph Chemical Requirements, except for periods when the carbon is saturated, flow through the unit shall be stopped and the system shall be said to be inoperable. If at any time the operation of the system does not meet the flow rate requirements, instrumentation or control requirements set forth in this contract, flow through the system shall be stopped. The Contractor shall immediately proceed to repair or modify the system for compliance with the contract documents. Repairs or modifications shall be made entirely at the Contractor's expense. The Contractor shall notify the Contracting Officer one day before the system is to be restarted and retested.

## 3.4 MANUFACTURER'S FIELD SERVICE

### 3.4.1 Manufacturer's Representative

Services of the manufacturer's representative, who is experienced in the installation, adjustment and operation of the equipment specified, shall be provided for a minimum of [16] [\_\_\_\_\_] hours at the site. The representative shall supervise the installation, adjustment, and testing of the equipment. Prior to startup, the equipment shall be inspected for alignment and connections by a factory representative. The manufacturer's representative shall inspect the final installation and supervise the adjustment and testing of the equipment. The Contractor shall schedule and coordinate the testing to coincide with the later phases of the carbon column testing, to prove out the complete installation in the presence of a Government representative. After completion of all testing, the manufacturer's representative shall assist the plant operators in plant startup.

### 3.4.2 Field Training

The Contractor shall conduct a training course of operating staff as designated by the Contracting Officer. The training period, for a total of [24] [36] hours of normal working time, shall start after the system is functionally complete but prior to final acceptance tests. The field instructions shall cover the topics included in the [Operating and Maintenance Manuals](#). The Contractor shall also provide [16] [\_\_\_\_\_] hours



of training, as directed by the Contracting Officer, following completion of the [one year] [\_\_\_\_\_] operating period for the follow-in Contractor.

### 3.5 POSTED FRAMED INSTRUCTIONS

Installation instructions, sequences, and precautions, including tolerances for level, horizontal, and vertical alignment shall be posted as specified.

Grouting requirements, including grout spaces and materials; wiring and control diagrams; system layouts and isometrics; instructions and other sheets; operating instructions explaining preventive maintenance procedures and checks to assure the system is operating normally and safely shall be submitted for approval prior to posting. Methods of checking the system for normal safe operation; procedures for operating the system; and procedures for safely starting and stopping the system shall be prepared in typed form, framed and posted beside the diagrams. Instructions shall be written for any required sampling, carbon transfer and shipping of activated carbon to regeneration or disposal facility. Catalog cuts are not acceptable.

-- End of Section --