
USACE / NAVFAC / AFCEA / NASA UFGS-05 21 13 (July 2007)

Preparing Activity: USACE Superseding
UFGS-05 21 02.00 10 (April 2006)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2008

SECTION TABLE OF CONTENTS

DIVISION 05 - METALS

SECTION 05 21 13

DEEP LONGSPAN STEEL JOIST FRAMING

07/07

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 SUBMITTALS
- 1.3 GENERAL REQUIREMENTS
- 1.4 REGULATORY REQUIREMENT
- 1.5 DELIVERY AND STORAGE
- 1.6 QUALITY ASSURANCE
 - 1.6.1 Drawing Requirements
 - 1.6.2 Certification of Compliance

PART 2 PRODUCTS

- 2.1 DEEP LONGSPAN STEEL JOISTS
- 2.2 ACCESSORIES AND FITTINGS
- 2.3 SHOP PAINTING

PART 3 EXECUTION

- 3.1 ERECTION
- 3.2 BEARING PLATES
- 3.3 PAINTING
 - 3.3.1 Touch-Up Painting
 - 3.3.2 Field Painting
- 3.4 VISUAL INSPECTIONS
- 3.5 SCHEDULE

-- End of Section Table of Contents --

USACE / NAVFAC / AFCEA / NASA UFGS-05 21 13 (July 2007)

Preparing Activity: USACE Superseding
UFGS-05 21 02.00 10 (April 2006)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2008

SECTION 05 21 13

DEEP LONGSPAN STEEL JOIST FRAMING
07/07

NOTE: This guide specification covers the requirements for deep longspan steel joist framing and accessories.

Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable item(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

PART 1 GENERAL

NOTE: Use Section 05 21 23 for STEEL JOIST GIRDER FRAMING. Use Section 05 21 19 for OPEN WEB STEEL JOIST FRAMING. Use Section 05 21 16 for LONGSPAN STEEL JOIST FRAMING.

Show the following information on the project drawings:

1. Joist series and size, joist spacing, and kg (kip) load on each panel point, span, and slope.
2. Design loads, including uplift and lateral forces in addition to gravity (dead and live) loads.

3. Method of anchoring, framing at openings,
spacing and type of bridging.

4. Accessory details as applicable.

1.1 REFERENCES

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN WELDING SOCIETY (AWS)

AWS B2.1 (2005; Errata 2006; Errata 2006) Welding Procedure and Performance Qualification

AWS D1.1/D1.1M (2006; Errata 2006) Structural Welding Code - Steel

STEEL JOIST INSTITUTE (SJI)

SJI 279167 SPECS/LOADS (2006) 42nd Edition Standard Specifications and Load Tables for Steel Joists and Joist Girders

SJI MANUAL (2003) 75 Year Manual, 1928-2003

SJI TD 10 (2003) Technical Digest for the Design of Fire Resistive Assemblies with Steel Joists

SJI TD 8 (1983) Technical Digest for the Welding of Open Web Steel Joists

SJI TD 9 (2006) Technical Digest for the Handling and Erection of Steel Joists and Joist Girders

THE SOCIETY FOR PROTECTIVE COATINGS (SSPC)

SSPC PS 14.01 (1982; E 2004) Steel Joist Shop Painting System

SSPC Paint 15 (1999; E 2004) Steel Joist Shop Primer/Metal Building Primer

U.S. NATIONAL ARCHIVES AND RECORDS ADMINISTRATION (NARA)

29 CFR 1910.1200 Hazard Communication

29 CFR 1926 Safety and Health Regulations for Construction

29 CFR 1926.757 Steel Erection; Open Web Steel Joists

1.2 SUBMITTALS

NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for [Contractor Quality Control approval][information only]. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government]. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-01 Preconstruction Submittals

Welder qualification
Material Safety Data Sheet (MSDS) per OSHA 1910.1200

SD-02 Shop Drawings

Deep Longspan Steel Joist Framing; G

Detailed drawings including fabrication and erection details, specifications for shop painting, and identification markings of joists [and joist girders].

SD-06 Test Reports

Erection inspection
Welding inspections

SD-07 Certificates

Accessories
Certification of Compliance

1.3 GENERAL REQUIREMENTS

NOTE: The structural steel design must meet the requirements of OSHA Steel Erection Standard, 29 CFR Part 1926, Subpart R-Steel Erection, Effective Date January 18, 2002, and 29 CFR 1926.757.

Drawings must show size, spacing and method of anchoring. Indicate size by reference to appropriate SJI designations. Mechanical and electrical layout drawings and specifications for ceiling suspensions must contain notes indicating that hanger loads between panel points in excess of 222 N (50 pounds) must have the excess hanger loads suspended from panel points.

When joists or girders are to be designed to resist uplift and/or lateral forces, such joists and girders and the forces they must resist must be indicated on the drawings. Also, indicate all proper anchorages and bracing designed to resist those forces, as required.

The standard joist tables cannot be used verbatim when the depth of the joist is reduced near the ends to accommodate two-way top chord slopes in excess of 10 mm per meter (1/8 inch per foot). Before using standard designations for these joists, the designer must verify the adequacy of the joist members.

Designate Deep Longspan Steel Joists on the drawings in accordance with the standard designations of the Steel Joist Institute. Joists of other standard designations or joists with properties other than those shown may

be substituted for the joists designated provided the structural properties are equal to or greater than those of the joists shown and provided all other specified requirements are met.

1.4 REGULATORY REQUIREMENT

All deep longspan joist framing must conform to 29 CFR 1926.757. Secure all joist bridging and anchoring in place prior to the application of any construction loads. Distribute temporary loads so that joist capacity is not exceeded. Do not apply loads to bridging.

1.5 DELIVERY AND STORAGE

Handle, transport, and store joists [and joist girders] in a manner to prevent damage affecting their structural integrity. Store all items off the ground in a well drained location protected from the weather and easily accessible for inspection and handling.

1.6 QUALITY ASSURANCE

All work must comply with the requirements set forth in 29 CFR 1926.

1.6.1 Drawing Requirements

Submit drawings of deep longspan steel joist framing. Show joist type and size, layout in plan, and erection details including methods of anchoring, framing at openings, type and spacing of bridging, [requirements for field welding,] and details of accessories as applicable.

1.6.2 Certification of Compliance

NOTE: Use the SJI MANUAL reference for projects
involving existing joist girder and joist systems.

Prior to construction commencement, submit Material Safety Data Sheet per 29 CFR 1910.1200 for deep longspan steel joists, and certification for welder qualification, compliance with AWS B2.1, welding operation, and tacker, stating the type of welding and positions qualified for, the code and procedure qualified under, date qualified, and the firm and individual certifying the qualification tests. Submit certification of compliance for the following:

[SJI MANUAL]
SJI TD 8
SJI TD 9
SJI TD 10
29 CFR 1926
29 CFR 1926.757

PART 2 PRODUCTS

2.1 DEEP LONGSPAN STEEL JOISTS

Deep longspan steel joists must conform to SJI 279167 SPECS/LOADS, DLH-Series. Joists designated DLH must be designed to support the loads given in the applicable standard load tables of SJI 279167 SPECS/LOADS.

2.2 ACCESSORIES AND FITTINGS

Accessories and fittings, including end supports and bridging, must be in accordance with the standard specifications under which the members were designed.

2.3 SHOP PAINTING

NOTE: The requirements of the paragraph will be coordinated with the requirements of Section 09 90 00 PAINTS AND COATINGS. In crawl spaces and other high humidity areas where greater protection than that provided by a primer paint is required and the joists or girders will not be finish painted, the paragraph will be revised to require that the joists or girders be shop painted with a corrosion resistant type paint as recommended by SSPC.

Deep longspan joists [, joist girders] and accessories must be shop painted with a rust-inhibiting primer paint. For joists [and joist girders] which require finish painting under Section 09 90 00 PAINTS AND COATINGS, the primer paint must conform to SSPC Paint 15 and SSPC PS 14.01.

PART 3 EXECUTION

3.1 ERECTION

Installation of deep longspan joists [and joist girders] must conform to SJI 279167 SPECS/LOADS for the joist series indicated, and the requirements of 29 CFR 1926 and 29 CFR 1926.757. Handling and setting of joists [and joist girders] must avoid damage to the members. Damaged joists [and joist girders] must be removed from the site, except when field repair is approved and such repairs are satisfactorily made in accordance with the manufacturer's recommendations. All welding must conform to AWS B2.1 and AWS D1.1/D1.1M.

[3.2 BEARING PLATES

NOTE: Use this paragraph for masonry or cast-in-place concrete applications only.

Provide bearing plates to accept full bearing after the supporting members have been plumbed and properly positioned, but prior to placing superimposed loads. The area under the plate must be damp-packed solidly with bedding mortar, except where nonshrink grout is indicated on the drawings. Bedding mortar and grout must be as specified in Section 03 31 00.00 10 CAST-IN-PLACE STRUCTURAL CONCRETE.

] 3.3 PAINTING

3.3.1 Touch-Up Painting

After erection of joists [and joist girders], touch-up connections and areas of abraded shop coat with paint of the same type used for the shop coat.

[3.3.2 Field Painting

NOTE: Omit bracketed text when field painting is
not required.

Paint joists [and joist girders] requiring a finish coat in conformance
with the requirements of Section 09 90 00 PAINTS AND COATINGS.

]3.4 VISUAL INSPECTIONS

AWS D1.1/D1.1M, Section 6. Perform erection inspection and field welding
inspections with AWS certified welding inspectors. Welding inspectors must
visually inspect and mark welds.

[3.5 SCHEDULE

NOTE: Delete this paragraph for non-metric projects.

SI dimensioning in this paragraph is based on a mathematical conversion of
inch-pound dimensions following the SJI specification SJI 279167 SPECS/LOADS.
The SI and I-P units for the dimensions shown are as follows.

<u>Inch-Pound Units</u>	<u>SI Units</u>
20 feet	6096 mm
30 ksi	207 MPa

]

-- End of Section --