

\*\*\*\*\*  
USACE / NAVFAC / AFCEA / NASA UFGS-11 24 27 (October 2007)  
-----  
Preparing Activity: USACE Superseding  
UFGS-11 24 27 (April 2006)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2008

\*\*\*\*\*

### SECTION TABLE OF CONTENTS

#### DIVISION 11 - EQUIPMENT

#### SECTION 11 24 27

#### AIR STRIPPER

10/07

#### PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 UNIT PRICES
- 1.3 SYSTEM DESCRIPTION
  - 1.3.1 Design Requirements
  - 1.3.2 Influent Inorganic Chemical Conditions
  - 1.3.3 System Performance Requirements
    - 1.3.3.1 Air to Water Ratio
    - 1.3.3.2 Influent and Effluent Organic Contaminant Concentrations
    - 1.3.3.3 Operating Schedule
  - 1.3.4 Seismic Protection
  - 1.3.5 Design Loads
- 1.4 SUBMITTALS
- 1.5 QUALIFICATIONS
  - 1.5.1 Contractor
  - 1.5.2 Single Source Supplier
  - 1.5.3 Manufacturer's Representative
  - 1.5.4 Welding
- 1.6 [PRE-INSTALLATION CONFERENCE OR] [PARTNERING CONFERENCE]
- 1.7 DELIVERY, STORAGE, AND HANDLING
- 1.8 GENERAL REQUIREMENTS
  - 1.8.1 Standard Products
  - 1.8.2 Nameplates
  - 1.8.3 Field Measurements

#### PART 2 PRODUCTS

- 2.1 SYSTEM COMPONENTS
  - 2.1.1 Pump
  - 2.1.2 Blower
  - 2.1.3 Pipe Connections
  - 2.1.4 Mist Eliminator
  - 2.1.5 Exhaust Stack
  - 2.1.6 Off-Gas Control
  - 2.1.7 Instrumentation and Controls

- 2.1.8 Chemical Feed Systems
- 2.1.9 Cleaning Provisions
- 2.1.10 Assembly
- 2.1.11 Lifting Lugs
- 2.1.12 Guy Wires
- 2.1.13 Freeze Protection
- 2.1.14 Sump
- 2.1.15 Electrical Work
- 2.1.16 Spare Parts
- 2.1.17 Framed Instructions
- 2.2 STRIPPER
  - 2.2.1 Materials
    - 2.2.1.1 Shell
    - 2.2.1.2 Internals
  - 2.2.2 Perforated Plate (Sieve Tray) Stripper
    - 2.2.2.1 Perforated Plates (Sieve Trays)
    - 2.2.2.2 Gaskets
    - 2.2.2.3 Disassembly
  - 2.2.3 Enclosed Low Profile Mass Transfer Mechanisms
  - 2.2.4 Packed Column
    - 2.2.4.1 Packing
    - 2.2.4.2 Water Distribution and Re-distribution System
    - 2.2.4.3 Packing Support
    - 2.2.4.4 Access
    - 2.2.4.5 Manholes and Pipe Connections
    - 2.2.4.6 View Ports
    - 2.2.4.7 Ladders, Platforms and Cages

## PART 3 EXECUTION

- 3.1 FOUNDATIONS
- 3.2 ANCHORS
  - 3.2.1 Number of Anchors
  - 3.2.2 Anchor Bolts and Straps
  - 3.2.3 Attachment
  - 3.2.4 Seismic Requirements
- 3.3 EXCAVATING, FILLING, AND GRADING
- 3.4 EQUIPMENT INSTALLATION
- 3.5 PAINTING FOR CORROSION PREVENTION
  - 3.5.1 Welded Tanks
    - 3.5.1.1 Exterior Surfaces
    - 3.5.1.2 Interior Surfaces
  - 3.5.2 Touch-up Painting
  - 3.5.3 Field Painting
  - 3.5.4 Corrosion Resistant Metals
- 3.6 MANUFACTURER'S FIELD SERVICE
- 3.7 TESTS
  - 3.7.1 Hydrostatic Tests
  - 3.7.2 Performance Testing
  - 3.7.3 Influent and Effluent Sampling
  - 3.7.4 Influent and Effluent Analyses
  - 3.7.5 Discharge
  - 3.7.6 Noncompliance
- 3.8 STARTUP
- 3.9 ADJUSTING, CLEANING, AND DISINFECTING
- 3.10 DEMONSTRATION
- 3.11 FIELD TRAINING
- 3.12 MAINTENANCE

-- End of Section Table of Contents --

\*\*\*\*\*  
USACE / NAVFAC / AFCEA / NASA UFGS-11 24 27 (October 2007)  
-----  
Preparing Activity: USACE Superseding  
UFGS-11 24 27 (April 2006)

## UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2008

\*\*\*\*\*

### SECTION 11 24 27

#### AIR STRIPPER 10/07

\*\*\*\*\*

NOTE: This guide specification covers the requirements for systems to transfer volatile compounds from a water stream to an air stream.

Edit this guide specification for project specific requirements by adding, deleting, or revising text. For bracketed items, choose applicable items(s) or insert appropriate information.

Remove information and requirements not required in respective project, whether or not brackets are present.

Comments and suggestions on this guide specification are welcome and should be directed to the technical proponent of the specification. A listing of technical proponents, including their organization designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as a Criteria Change Request (CCR).

\*\*\*\*\*

#### PART 1 GENERAL

\*\*\*\*\*

NOTE: This guide specification covers air strippers for removal of volatile substances from water. Refer to Design Guide (DG) 1110-1-2 Air Stripping.

\*\*\*\*\*

#### 1.1 REFERENCES

\*\*\*\*\*

NOTE: This paragraph is used to list the publications cited in the text of the guide specification. The publications are referred to in the text by basic designation only and listed in this paragraph by organization, designation, date, and title.

Use the Reference Wizard's Check Reference feature when you add a RID outside of the Section's Reference Article to automatically place the reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

\*\*\*\*\*

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN WATER WORKS ASSOCIATION (AWWA)

- |           |  |
|-----------|--|
| AWWA C653 | (2003) Disinfection of Water Treatment Plants              |
| AWWA D100 | (2005; Errata 2007) Welded Steel Tanks for Water Storage   |
| AWWA D102 | (2006) Coating Steel Water-Storage Tanks                   |
| AWWA D103 | (1997) Factory-Coated Bolted Steel Tanks for Water Storage |
| AWWA D120 | (2002) Thermosetting Fiberglass-Reinforced Plastic Tanks   |

ASME INTERNATIONAL (ASME)

- |              |  |
|--------------|--|
| ASME B40.100 | (2006) Pressure Gauges and Gauge Attachments |
|--------------|--|

MANUFACTURERS STANDARDIZATION SOCIETY OF THE VALVE AND FITTINGS INDUSTRY (MSS)

- |           |   |
|-----------|---|
| MSS SP-25 | (1998) Standard Marking System for Valves, Fittings, Flanges and Unions |
|-----------|---|

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

- |         |  |
|---------|--|
| NFPA 70 | (2007) National Electrical Code - 2008 Edition |
|---------|--|

1.2 UNIT PRICES

\*\*\*\*\*

NOTE: If the Contractor is required to treat water, as well as to furnish the equipment, measurement and payment and unit pricing may be necessary to cover treatment costs.

\*\*\*\*\*

Measurement and payment and unit prices for quantities of water treated will be determined in accordance with the Bid Schedule.

### 1.3 SYSTEM DESCRIPTION

The air stripping equipment shall be as specified in PART 2 of this section.

#### 1.3.1 Design Requirements

\*\*\*\*\*

NOTE: The contaminant concentration and flow rate to be used in the design are critical to this specification. Install multiple strippers to accommodate extreme variations from the design flow rate and contaminant concentrations or to maintain the groundwater gradient.

Determine design wind speed from ASCE 7; use 161 km/h (100 mph) minimum. Use 1.2 kPa (25 psf) snow load for most heavy snow climates; delete snow load where maximum snow is insignificant. Local climates and topography may dictate that a value greater than 1.2 kPa (25 psf) be used for snow loading. Consult ANSI A58 and local codes. Wind speed and snow load can be deleted if the air stripper is installed inside.

Seismic criteria are given in paragraph Seismic Protection. Consult NFPA 780 to determine if lightning protection is needed.

\*\*\*\*\*

The following requirements shall be met:

- a. Water/wastewater flow rate
  - Maximum [ ] L/s gpm
  - Minimum [ ] L/s gpm
- b. Water/wastewater temperature
  - Maximum [ ] degrees C F
  - Minimum [ ] degrees C F
- c. Ambient air temperature
  - Maximum [ ] degrees C F
  - Minimum [ ] degrees C F
- d. Air Stripper system dimensions
  - Maximum vertical projection [ ] mm ft
- e. Maximum ground surface coverage including blower, motor and other appurtenances
  - [ ] by [ ] mm
  - [ ] by [ ] ft
- f. Soil bearing capacity [ ] MPa psf
- g. Seismic parameters [ ]
- h. Wind speed
  - Maximum [ ] km/h mph

i. Ground snow load [\_\_\_\_\_] kPa psf

j. Design Life  
Minimum [\_\_\_\_\_] years

### 1.3.2 Influent Inorganic Chemical Conditions

Measured influent inorganic chemical concentrations of [waste water] [water from surface impoundment] [ground water] [total] [filtered] have been [as listed in C:\SPECSINTACT\JOBS\STRIP\pulldata\N.secN 11220 PRECIPITATION/COAGULATION/FLOCCULATION WATER TREATMENT] [:

pH	[_____] Minimum
[_____] Average	
[_____] Maximum	
Total Hardness as CaCO3	[_____] mg/L Maximum
[_____] mg/L Average	
Total alkalinity as CaCO3	[_____] mg/L Maximum
[_____] mg/L Average	
Hydroxide alkalinity as CaCO3	[_____] mg/L Maximum
[_____] mg/L Average	
Carbonate	[_____] mg/L Maximum
[_____] mg/L Average	
Bicarbonate	[_____] mg/L Maximum
[_____] mg/L Average	
Total Dissolved Solids	[_____] mg/L Maximum
[_____] mg/L Average	
Langelier Index	[_____] Maximum
[_____] Average	
Total Suspended Solids	[_____] mg/L Maximum
[_____] mg/L Average	
Total Iron	[_____] mg/L Maximum
[_____] mg/L Average	
Dissolved Iron	[_____] mg/L Maximum
[_____] mg/L Average	
Total Manganese	[_____] mg/L Maximum
[_____] mg/L Average	
Dissolved Manganese	[_____] mg/L Maximum
[_____] mg/L Average	
Calcium	[_____] mg/L Maximum
[_____] mg/L Average	
Magnesium	[_____] mg/L Maximum
[_____] mg/L Average	

Sodium	[_____] mg/L Maximum
[_____] mg/L Average	
Potassium	[_____] mg/L Maximum
[_____] mg/L Average	
Sulfate	[_____] mg/L Maximum
[_____] mg/L Average	
Nitrate	[_____] mg/L Maximum
[_____] mg/L Average	
Chloride	[_____] mg/L Maximum
[_____] mg/L Average	
Fluoride	[_____] mg/L Maximum
[_____] mg/L Average]	

### 1.3.3 System Performance Requirements

#### 1.3.3.1 Air to Water Ratio

Air to water ratio

Maximum at maximum flow	[_____] volume/volume
Minimum at minimum flow	[_____] volume/volume

#### 1.3.3.2 Influent and Effluent Organic Contaminant Concentrations

\*\*\*\*\*  
**NOTE: Either specify maximum effluent concentrations or percent removal requirements.**  
 \*\*\*\*\*

Maximum Influent	[_____] ug/L
Average Influent	[_____] ug/L
Minimum Influent	[_____] ug/L
Maximum Effluent	[_____] ug/L
Removal Required	[_____] percent

Removal percentage shall be determined as follows:

((Influent concentration - Effluent concentration)/Influent concentration)  
 times 100 percent

#### 1.3.3.3 Operating Schedule

Capacity and design of the air stripper and accessories shall allow the system to operate continuously for [24 hours per day, 7 days per week] [\_\_\_\_\_].

#### 1.3.4 Seismic Protection

\*\*\*\*\*  
**NOTE: Provide seismic details on the drawings or remove the second bracketed sentence.**  
 \*\*\*\*\*

The air stripper shell and components shall be structurally designed for seismic forces [in accordance with UFC 3-310-04 and Sections 13 48 00



SEISMIC PROTECTION FOR MISCELLANEOUS EQUIPMENT and 13 48 00.00 10 SEISMIC PROTECTION FOR MECHANICAL EQUIPMENT] [as shown on the drawings]. [The calculations and drawings shall be stamped by a professional engineer qualified to practice at the site.]

#### 1.3.5 Desing Loads

The air stripper and appurtenances shall be structurally designed for the wind loads listed in the system performance requirements, plus live and dead loads resulting from internally supported parts, weight of operating liquid when the shell is completely full of water, piping structural supports, and internal or external pressures with an appropriate safety factor. The concrete base shall be designed in accordance with Section 03 31 00.00 10 CAST-IN-PLACE STRUCTURAL CONCRETE.

#### 1.4 SUBMITTALS

\*\*\*\*\*

NOTE: Review submittal description (SD) definitions in Section 01 33 00 SUBMITTAL PROCEDURES and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

\*\*\*\*\*

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for [Contractor Quality Control approval.] [information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] The following shall be submitted in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

### Process Flow Diagrams

Process flow diagrams showing all major pieces of process equipment with flow rates and material balances.

### Process and Instrumentation Diagram (P&ID)

Process and instrumentation diagram (P&ID) showing all instrumentation and control locations functions and settings.

### Equipment Installation

Drawings containing complete wiring and schematic diagrams and any other details required to demonstrate that the system has been coordinated and will properly function as a unit. Drawings shall show proposed layout and anchorage of equipment and appurtenances, and equipment relationship to other parts of the work including clearances for maintenance and operation.

## SD-03 Product Data

### Air Stripping System

A complete list of material, including manufacturer's descriptive and technical literature, catalog cuts, drawings, and installation instructions, performance charts, technical literature, catalog cuts for [packing,] [mist eliminator,] [perforated trays and number,] [perforated bubbler tubes,] [venturi design] stripper, instrumentation and controls, including capacities, make and model, materials of construction, valving, and pressure gauges.

### Foundations

Calculations for the shell and concrete foundations, mounting and support details including the seismic analysis, where appropriate.

### Qualifications

Qualifications of the installer, and the manufacturer's and supplier's representatives.

### Field Training

Training course curriculum and training instructions, [14] [\_\_\_\_\_] days prior to the start of training.

### Framed Instructions

Installation instruction procedures, sequences, and precautions, including tolerances for level, horizontal, and vertical alignment. Grouting requirements including grout spaces and materials.

### Spare Parts

Spare parts data for each different item of material and

equipment specified, after approval of the related submittals, and not later than [\_\_\_\_\_] months prior to the date of beneficial occupancy. The data shall include a complete list of parts and supplies, with current unit prices and source of supply. List of all special tools, instruments, accessories, and special lifting and handling devices required for periodic maintenance, repair, adjustment, and calibration.

#### SD-05 Design Data

##### Calculations

Design calculations for air stripping system indicating removals of each of the listed volatile compounds. Air and water pressure drops through each component of the system, including line sizing, hydraulic loading (L/sq. m gal/sq. ft), air volume (cubic m/second CFM, air to water ratio (dimensionless and with appropriate units).

#### SD-06 Test Reports

##### Tests

Performance reports in booklet form, upon completion of testing of the installed system. Test reports shall include all field tests performed to adjust each component and all field tests performed to prove compliance with the specified performance criteria. Each test report shall indicate the final position of all controls. Performance test data shall be reflected in the operating instructions.

#### SD-07 Certificates

##### Manufacturer's Representative

Names and qualifications of each manufacturer's field representative and training engineer with written certification from the manufacturer that each representative and trainer is technically qualified.

##### Materials and Equipment

Verification from a Registered Professional Engineer, registered in the state in which the system is to be installed, that the stack, [the shell, ladder, platform and cage calculations for the air stripper,] the foundation and lifting lugs were designed for the listed conditions in accordance with the appropriate requirements, codes and standards.

#### SD-08 Manufacturer's Instructions

##### Air Stripping System

Installation, operating and maintenance instructions as provided by the manufacturer, [\_\_\_\_\_] days prior to notice to proceed.

#### SD-09 Manufacturer's Field Reports

##### Air Stripping System

Field reports on completed installation as provided by the manufacturer's representative.

## SD-10 Operation and Maintenance Data

### Air Stripping System Maintenance

The following information can either be included in the manual or manufacturer literature that contains the information and is furnished with the O&M Manuals. Each manual shall have an index listing the contents. Manuals shall be bound in sturdy three-ring, loose-leaf binders.

[Six] [\_\_\_\_\_] complete copies of operating instructions outlining the step-by-step procedures required for system startup, normal operation, short- and long-term deactivation, and shutdown. An introduction and overall equipment description, purpose, functions, and simplified theory of operation shall be included in the beginning of the instructions. The instructions shall include the manufacturer's name, model number, service manual, parts list and brief description of each piece of equipment and its basic theory and operating features. The instructions shall include piping and component layouts and wiring and control diagrams for the systems as installed. Performance test data shall be reflected in the operating instructions.

[Six] [\_\_\_\_\_] complete copies of maintenance instructions listing routine maintenance procedures, calibration procedures, possible breakdowns and repairs and trouble shooting guides. Procedures for cleaning and removal of scale shall be included.

## 1.5 QUALIFICATIONS

### 1.5.1 Contractor

Contractor shall have a minimum of [2] [3] [5] [\_\_\_\_\_] years experience in the construction of water treatment, wastewater treatment, and/or industrial wastewater treatment and/or industrial wastewater pretreatment plants.

### 1.5.2 Single Source Supplier

The Contractor shall assign to a single supplier full responsibility for the furnishing of the [air stripping system](#). The designated single supplier, however, need not manufacture the system but shall coordinate the design, assembly, installation, and testing of the entire system as specified herein.

### 1.5.3 Manufacturer's Representative

Services of a manufacturer's field service representative who is experienced in the installation, adjustment, and operation of the equipment furnished and who has complete knowledge of the proper operation and maintenance of the system shall be provided.

### 1.5.4 Welding

\*\*\*\*\*

**NOTE: Use wording in second set of brackets when critical pipe welding is required.**

\*\*\*\*\*

[Piping shall be welded in accordance with qualified procedures using performance qualified welders and welding operators. Procedures and welders shall be qualified in accordance with [\_\_\_\_\_]. Welding procedures qualified by others, and welders and welding operators qualified by another employer may be accepted as permitted by [\_\_\_\_\_]. The Contracting Officer shall be notified 24 hours in advance of tests. Structural members shall be welded in accordance with Section 05 05 23 WELDING, STRUCTURAL.]

[Welding and nondestructive testing procedures for piping shall be as specified in Section 43 02 00 WELDING PRESSURE PIPING.] [Welding qualifications for welding procedures, welders, and welding operators shall be in accordance with Sections 8.2 and 8.8 of AWWA D100 and Section 43 02 00 WELDING PRESSURE PIPING.] [Procedures and welders shall be qualified in accordance with the code under which the welding is specified to be accomplished.]

#### 1.6 [PRE-INSTALLATION CONFERENCE OR] [PARTNERING CONFERENCE]

[Pre-installation] [Partnering] conference [may] [will] be [requested] [be required] by the Contracting Officer. The Contractor shall ensure that all of the involved subContractors, suppliers, and manufacturers are represented. The date and time of the conference shall be furnished to the Contracting Officer for approval.

#### 1.7 DELIVERY, STORAGE, AND HANDLING

Parts shall be preassembled to the extent practical, compatible with transportation limitations and equipment protection considerations. Field assembly, if any, shall require merely bolting together of match-marked components. Equipment shall be crated and protected against damage during shipping and delivery. Flange faces shall be protected from damage. Openings shall be covered to prevent entrance of dirt, water and debris. Parts shall be properly protected so that no damage or deterioration will occur during a prolonged delay from the time of shipment until installation is completed and the units and equipment are ready for operation. Finished iron or steel surfaces shall be properly protected to prevent rust and corrosion. All equipment delivered and placed in storage shall be stored with protection from the weather, humidity and temperature variation, dirt and dust, and other contaminants.

#### 1.8 GENERAL REQUIREMENTS

##### 1.8.1 Standard Products

Materials and equipment shall be the standard products of a manufacturer regularly engaged in the manufacture of the products and shall essentially duplicate equipment that has been in satisfactory operation for at least [2] [\_\_\_\_\_] years prior to bid opening. Equipment shall be supported by a service organization that is, in the opinion of the Contracting Officer, reasonably convenient to the site.

##### 1.8.2 Nameplates

Major equipment items shall have the manufacturer's name, address, type or style, model or serial number, and catalog number on a plate secured to the item of equipment. Each piece of equipment shall bear the approval

designation and the markings required for that designation. Valves shall be marked in accordance with MSS SP-25 and shall bear a securely attached tag with the manufacturer's name, catalog number and valve identification permanently displayed.

#### 1.8.3 Field Measurements

The Contractor shall become familiar with all details of the work, verify all dimensions in the field, and shall advise the Contracting Officer of any discrepancy before performing the work.

### PART 2 PRODUCTS

\*\*\*\*\*  
NOTE: Consider if the influent or the stripper must be acid cleaned or chlorine-treated in selection of materials. Stainless steel may not be appropriate if a chlorine solution will be used for extended periods of time. Galvanized steel or corrodible metal internals should not be used.  
\*\*\*\*\*

#### 2.1 SYSTEM COMPONENTS

##### 2.1.1 Pump

Pumps shall be in accordance with Section [43 21 39 PUMPS: WATER, VERTICAL TURBINE] [43 21 13 PUMPS: WATER, CENTRIFUGAL].

##### 2.1.2 Blower

Fans, blowers and or vacuum pumps shall be in accordance with Section 43 11 00 FANS/BLOWERS/PUMPS; OFF-GAS

##### 2.1.3 Pipe Connections

Influent pipe connections shall be full line diameter of the connecting pipe. Effluent pipe connections shall be made with standard reducing fittings only if there is adequate vertical run to avoid back-up. Air and off-gas piping shall be as specified in Section 31 21 00 PIPING; OFF-GAS. Liquid piping shall be as specified in Section 40 05 13 PIPELINES, LIQUID PROCESS PIPING.

##### 2.1.4 Mist Eliminator

The mist eliminator shall have the minimum separation efficiency stated in the performance requirements. Materials shall be as specified for the stripper internals.

##### 2.1.5 Exhaust Stack

\*\*\*\*\*  
NOTE: Maintain velocities within limits to reduce condensation/freezing on the stack surface.  
\*\*\*\*\*

Exhaust stack shall be sized for gas velocity between 3 and 7.5 m/sec 10 and 25 feet/second. Materials shall be as specified for the stripper.

#### 2.1.6 Off-Gas Control

\*\*\*\*\*  
NOTE: An air pollution control device may not be required depending on state and local regulations. The air pollution control system is a separate unit process, with different design requirements.  
\*\*\*\*\*

Off gas from the air stripper column shall be conveyed to an air pollution control unit for treatment as specified in Section [43 13 13.13 VAPOR PHASE ACTIVATED CARBON ADSORPTION UNITS] [44 11 33 THERMAL (CATALYTIC) OXIDATION SYSTEMS] [\_\_\_\_].

#### 2.1.7 Instrumentation and Controls

\*\*\*\*\*  
NOTE: Specify the instrumentation and controls as either direct-reading instruments at the column or remote-reading at some other location.  
\*\*\*\*\*

Instrumentation and controls shall conform to the requirements of Section 40 95 00 PROCESS CONTROL and the requirements specified for each piece of the equipment with the interlocks and control devices specified herein.

- a. Gauges shall have 150 mm 6 inch dials, shall be stem mounted, and shall conform to ASME B40.100. Accuracy of gauges shall be Grade A or better. Gauges shall be calibrated in kPa and psi psi in not more than 10 kPa and 2 psi 2 psi increments from 0 to 350 kPa and 0 to 50 psi 0 to 50 psi in excess of the normal operating pressure at the tank.
- b. Control to shut down the system and activate an alarm if the blower fails.
- c. Interlock for concurrent operation of blowers and influent [pumps] [control valves].
- d. Water flow indicators [\_\_\_\_] to [\_\_\_\_] L/second [\_\_\_\_] to [\_\_\_\_] gpm.
- e. Effluent water temperature gauge [\_\_\_\_] to [\_\_\_\_] degrees C [\_\_\_\_] to [\_\_\_\_] degrees F.
- f. Pressure drop instrument [\_\_\_\_] to [\_\_\_\_] mm [\_\_\_\_] to [\_\_\_\_] inch water.
- g. Direct reading pressure gauges in the air inlet and outlet throats.

#### 2.1.8 Chemical Feed Systems

\*\*\*\*\*  
NOTE: Determine if there is an environmentally preferred alternative and evaluate the options for cleaning compounds. The potential for reuse of cleaning chemicals will depend on the fouling material composition and if the suspended biomass or chemicals can be easily removed by settling and/or filtration. Consider conventional acids (HCl,

H2SO4) with environmentally safer products such as acetic and citric acids for chemical fouling. NaOCl may be needed for biological fouling.

Perform a cost/benefit study to select between alternative cleaning solutions, reusing the cleaning solution and disposal options. This specification does not include the disposal of sludge generated during the cleaning.

\*\*\*\*\*

Chemical feed requirements shall be as specified in Section 43 32 69  
CHEMICAL FEED SYSTEMS and/or Section 43 32 76 CHLORINE-FEEDING MACHINES  
(AUTOMATIC, SEMIAUTOMATIC AND MANUAL).

#### 2.1.9 Cleaning Provisions

\*\*\*\*\*

NOTE: The type of cleaning chemicals used to remove mineral deposits and/or biological growth which may foul the air stripper interior and adversely affect the unit's performance will be unique to each site and depends on whether the fouling is from biological growth or chemical deposition and on the materials of construction. Tests may be needed before or after the system is started to determine the best cleaning solution.

\*\*\*\*\*

[The air stripper shall be furnished with a cleaning package that can be operated periodically. The system shall include tanks, pipes and valves to allow flushing with chemical cleaners, biocides or disinfectants. The package shall include a corrosion resistant pump, chemical addition port, [cleaning solution storage tank] and plumbing accessories to allow the re-circulation of cleaning solutions through the stripper.] [The air stripper shall be designed for a cleaning procedure during which the air stripper will be isolated and filled or flooded with a [[10] [\_\_\_\_\_] percent maximum [sulfuric] [hydrochloric] [\_\_\_\_\_] acid solution] [\_\_\_\_\_] cleaning solution.]

#### 2.1.10 Assembly

The system shall be factory pre-assembled into reasonably sized modules for easy field assembly and mounted on a skid. The skid shall have a welded steel frame with [2.4] [6.4] mm [3/32] [1/4] inch thick steel plate or fiberglass reinforced plastic (FRP) grating with ultraviolet (UV) inhibitors decking.

#### 2.1.11 Lifting Lugs

[Trays] [Columns] [Stacks] and other major components shall be provided with lifting lugs, as necessary for easy handling with a crane or similar device during installation, maintenance and replacement of column internals.

#### 2.1.12 Guy Wires

\*\*\*\*\*

NOTE: Size of the columns should be taken into account. In temporary installations, or in areas of



high seismic activity, guy wires may be acceptable.

\*\*\*\*\*

Air strippers and air stripper stacks shall be free standing and supported entirely by anchoring in a concrete base and shall be compatible with the dimensional constraints indicated. Each column air stripper [and stack] shall be self supporting. A superstructure or frame not extending beyond the foundation will be permitted. No guy wires shall be used except as directed by the Contracting Officer.

#### 2.1.13 Freeze Protection

\*\*\*\*\*

NOTE: When cold dry air is used for stripping, the evaporative cooling may chill the water more than the conduction of heat through the shell of the stripping column. If evaporative calculations show that this will significantly lower the rate at which the volatiles are removed from the water, the problem can be eliminated by stripping with re-circulated air.

\*\*\*\*\*

[Insulation shall be provided in accordance with Section 23 07 00 THERMAL INSULATION FOR MECHANICAL SYSTEMS. The system shall be insulated and jacketed to prevent freezing under the most severe conditions stated in the performance requirements with a water temperature drop of less than 3 degrees C 5 degrees F.] [Air from the stripper that had the volatilized contaminants removed by the subsequent air pollution control device may be re-circulated into the bottom of the column].

#### 2.1.14 Sump

Each air stripper shall have a sump to receive and store the treated effluent. Sump shall be sized to provide a minimum residence time of [2] [5] [10] minutes when the stripper is operating at the specified capacity. [An inspection port] [and] [A 13 mm 1/2 inch diameter (minimum) drain/sample port with manually operated valve] shall be provided at the bottom of the sump to completely drain the air stripper.

#### 2.1.15 Electrical Work

\*\*\*\*\*

NOTE: Show NFPA 70 hazardous area classification on the drawings. If the potential for an explosive atmosphere exists, the wiring, blower, motor and other electrical equipment must meet the applicable explosive prevention standards.

\*\*\*\*\*

Electrical equipment shall conform to Section 26 20 00 INTERIOR DISTRIBUTION SYSTEM. Equipment and wiring shall be in accordance with NFPA 70, with proper consideration given to environmental conditions such as moisture, dirt, corrosive agents, and hazardous area classification. Equipment located outdoors, not provided with climate controlled enclosure, shall be capable of operating in the ambient temperature range indicated in paragraph Design Requirements unless otherwise specified. Electrical motor-driven equipment specified herein shall be provided complete with motor control centers, panels, motor starters, etc.

#### 2.1.16 Spare Parts

Spare parts shall be provided for each different item of material and equipment specified, including all parts recommended by the manufacturer to be replaced after [1 year] [and] [3 years] service.

#### 2.1.17 Framed Instructions

Framed instructions under glass or in laminated plastic, including [process flow diagrams](#) and wiring and control diagrams showing the complete layout of the entire system, shall be posted where directed. Condensed operating instructions explaining preventive maintenance procedures, methods of checking the system for normal safe operation, and procedures for safely starting and stopping the system shall be prepared in typed form, framed as specified above for the wiring and control diagrams and posted beside the diagrams. Posted diagrams, instructions, and other sheets shall be submitted prior to posting. [One] [\_\_\_\_\_] framed [process and instrumentation diagram \(P&ID\)](#) showing all major process equipment, pumps, pipes, valves, instruments direction of flow, flow rates pressures and temperatures shall be provided.

### 2.2 STRIPPER

\*\*\*\*\*  
**NOTE: See DG 1110-1-3 Air Stripping for recommendations.**  
\*\*\*\*\*

The stripper system shall consist of [1] [2] [\_\_\_\_\_] [packed column] [perforated plate (sieve tray)] or [enclosed low profile mass transfer mechanism] air stripper to transfer volatile organic compounds from the water phase to the air base. The Contractor shall use manufacturer's standard size units whenever possible.

#### 2.2.1 Materials

\*\*\*\*\*  
**NOTE: Limit the materials of construction to those that will not be corroded or dissolved by the contaminants in the water or cleaning solutions (acids).**  
\*\*\*\*\*

##### 2.2.1.1 Shell

\*\*\*\*\*  
**NOTE: Use coated steel for short term applications only, since cracking of the coating could allow the column to corrode.**  
\*\*\*\*\*

The air stripper shall be constructed of [polyethylene (HDPE) seamless one piece molded modular sections,] [polyvinylchloride (PVC) with ultraviolet (UV) inhibitors,] [fiberglass reinforced plastic (FRP) with ultraviolet (UV) inhibitors,] [structural grade aluminum,] [304 stainless steel,] [316 stainless steel,] or [steel with internal and external coating as specified,] of suitable thickness to prevent deformation. Steel tank materials shall conform to the applicable provisions of Section 2 of

AWWA D100 or Section 2 of AWWA D103 or AWWA D120. Design, fabrication, and erection shall be in accordance with the applicable requirements of AWWA D100 or AWWA D103 except as modified herein and in the design requirements of this specification. Shop Fabrication shall conform [to Section 9 of AWWA D100 or Section 7 of AWWA D103 or AWWA D120] [the manufacturer's recommended fabrication procedures].

#### 2.2.1.2 Internals

The air stripper internals shall be constructed or [polyethylene (HDPE)] [polyvinylchloride (PVC)] [fiberglass reinforced plastic (FRP)] [aluminum] [304 stainless steel] [316 stainless steel] or copper.

#### 2.2.2 Perforated Plate (Sieve Tray) Stripper

\*\*\*\*\*

NOTE: Determining the number of trays needed in a perforated plate air stripper is more difficult than determining the height of packing in a packed column air stripper. The efficiency of each tray must be known or estimated to determine the number of trays required. The designer may have to rely on the manufacturer's test data or other estimation methods. These methods may be empirical, scale up from smaller units or more theoretical mass transfer calculation methods.

\*\*\*\*\*

The stripper shall have the following features: Vertically stacked trays with horizontal perforated plate (sieve trays) bottoms that are enclosed in a shell and are separated vertically. Contaminated water is introduced at the top, flows across a perforated plate, over a weir and down to the next lower plate. The process is repeated for each tray until the water reaches the bottom of the unit and enters the sump. Air is introduced at the bottom of the unit and is forced up through the perforations in the trays to form bubbles. Volatile organic chemicals in the water phase transfer to the bubbles in the air phase. The air phase containing the volatile chemicals then leaves the top of the column. Calculations shall be provided to clearly show the basis for the selected number of trays (each tray contains one perforated plate), size and number of the perforations on each plate, tray spacing, size of trays and tray efficiency. The data may be actual performance data from the manufacturer or calculation methods.

##### 2.2.2.1 Perforated Plates (Sieve Trays)

\*\*\*\*\*

NOTE: Stainless steel is recommended on large units. Plastic materials are acceptable for small low profile air strippers; plastic materials on large air strippers may warp and then leak between the trays.

If frequent fouling is anticipated, stainless steel should be used as it is easier to clean. Plastic can be damaged by scraping and steam or high pressure water cleaning.

\*\*\*\*\*

Materials for perforated plates, downcomers, downcomer seals, baffles and

other components shall be constructed of materials allowed by paragraph Internals of suitable thickness to prevent deformation. Tray design shall prevent short-circuiting of air or water. The number and size of perforations shall provide for maximum mass transfer.

#### 2.2.2.2 Gaskets

The trays shall have gaskets that prevent air and water leakage in and out of the shell and between trays. Gaskets shall be of a material compatible with the influent and with the cleaning methods.

#### 2.2.2.3 Disassembly

\*\*\*\*\*  
NOTE: Once disassembled, high pressure water, steam  
or physical scraping can be used to clean the trays.  
\*\*\*\*\*

The strippers must be easily disassembled for cleaning or shall have hatches for access to the individual trays or other internal components for inspection and cleaning.

#### 2.2.3 Enclosed Low Profile Mass Transfer Mechanisms

\*\*\*\*\*  
NOTE: Enclosed low profile mass transfer mechanism  
air strippers employ a variety of methods to  
facilitate the mass transfer of volatile chemicals  
from the water phase to the air phase. Calculation  
methods for these air strippers are unique to each  
design and may not be readily available. Designers  
may have to rely heavily on manufacturer supplied  
performance data, or use mass transfer calculation  
methods developed for other processes, such as  
distillation or waste water aeration, to verify the  
performance. If manufacturer supplied performance  
data are relied on, the designer should determine  
whether the computer models use theoretical  
equations calibrated to actual test data, or whether  
they are based only on theoretical equations or  
empirical data.  
\*\*\*\*\*

The Contractor shall furnish a low profile (such as perforated bubbler tubes or the venturi design principle), non-perforated plate, air stripper that is enclosed, uses mass transfer mechanisms which include, but are not limited to, perforated bubble tubes or the venturi design to transfer (volatilize) contaminants from the water phase to the air phase.

#### 2.2.4 Packed Column

\*\*\*\*\*  
NOTE: Calculations must be provided to clearly show  
the basis for the diameter and packing height.  
Base the diameter of the column on a maximum liquid  
loading rate of 60 to 80 per cent of the flooding  
loading rate. Data for the mass transfer  
coefficient (K<sub>La</sub>) and pressure drop/flooding  
calculations must be obtained from a pilot plant run  
\*\*\*\*\*

with this packing on the same or similar pollutants  
or vendor supplied data run with this packing on the  
same or similar pollutants.

These data and the requirement that the Contractor  
must meet the removal efficiencies or effluent  
criteria specified in the system performance  
requirements should assure that the column is sized  
properly.

\*\*\*\*\*

The Contractor shall furnish a packed column air stripper with the following features: A column filled with packing material that has a large surface area to volume ratio. The contaminated water is pumped to the top of the column above the packing and is distributed uniformly over the packing. Air is forced up through the bed of packing at the same time the water is "trickling" down through the packing (i.e. countercurrent flow). As the water and air pass each other, the volatile chemicals in the water leave the water (volatilize) and enter the air stream. The air stream then carries the volatile chemicals up and out of the top of the column.

#### 2.2.4.1 Packing

The column shall be filled with high efficiency open packing, either structured "arranged" or random "dumped" polypropylene, PVC, stainless steel, ceramic or other media that is durable under the service conditions. Packing diameter shall not exceed 20 percent of the column diameter and shall be as near 9 percent of the column diameter as is feasible with the type of media supplied. Packed section of the column shall be between [ ] and [ ] mm [ ] and [ ] feet in diameter and the height of the packing shall be between [ ] and [ ] mm [ ] and [ ] feet.

#### 2.2.4.2 Water Distribution and Re-distribution System

\*\*\*\*\*

NOTE: Columns that are wider relative to their  
depth need more distributor and re-distributors than  
are considered in the manufacturer literature

\*\*\*\*\*

Water distribution system shall be [PVC] [[304] [316] stainless steel] [aluminum] full solid cone spray nozzle or distributor tray that distributes the water over the fill area of the packing. Water distribution system shall produce a minimum of [125] [50] [ ] streams/sq. m [12] [4.8] [ ] streams/sq. ft at the normal pumping rate. The distribution system shall be designed for easy removal and replacement. If a full solid cone spray nozzle is used, it shall be placed at the correct distance from the top of the packing to distribute the spray uniformly over the top of the packing. Water re-distribution systems shall be as recommended by the manufacturer. Distance between re-distributors shall not exceed [ ] mm ft and shall be less if recommended by the packing manufacturer.

#### 2.2.4.3 Packing Support

Packing support shall be [PVC] [HDPE] [fiberglass reinforced plastic] [aluminum] [[304] [316] stainless steel]. If the bed depth exceeds the packing manufacturer's recommended maximum vertical depth of packing, an

intermediate support shall be installed. The support shall be of suitable thickness to prevent deformation when the packing becomes plugged and the entire shell above the packing support fills with water.

#### 2.2.4.4 Access

\*\*\*\*\*  
NOTE: View ports should be considered if the column  
is tall and the water can become poorly distributed  
or if biological, iron, manganese, or calcium  
fouling is likely to occur.  
\*\*\*\*\*

The top of each column shall be bolted to provide access to tower internals from above. View ports shall be installed at the [top] [and bottom] of the column to check the water distribution and to check for fouling. The stripper shall be designed for easy removal of the packing.

#### 2.2.4.5 Manholes and Pipe Connections

\*\*\*\*\*  
NOTE: Additional ports should be provided if  
packing fouling is expected to be a problem.  
\*\*\*\*\*

Number, type, location, and size of manholes and pipe connections shall be as shown on the drawings and as specified herein. Section 7 of AWWA D100 and Section 5 of AWWA D103 contain the minimum requirements for manholes and pipe connections. Flanged access ports, [460] [525] [600] mm [18] [21] [24] inch in diameter, shall be provided, shall be water and vapor tight, and able to withstand all loads and internal pressures during construction, operation, and cleaning. One or two access ports shall be at the top of the column for access to the mist eliminator and liquid distributor, and one shall be located near the bottom of the column to provide removal of the packing and packing support; and one shall provide access to the sump.

#### 2.2.4.6 View Ports

\*\*\*\*\*  
NOTE: View ports may not be necessary if the  
concentration of minerals in the water is low and  
iron, calcium or biological fouling is not expected  
to be a problem.  
\*\*\*\*\*

View ports shall be at the top and bottom of the packing to allow checks of the distribution and check for fouling.

#### 2.2.4.7 Ladders, Platforms and Cages

\*\*\*\*\*  
NOTE: Ladder should start 2.5 m (8 feet) above the  
ground, if the area is not secured. Ladders,  
platforms and cages may not be appropriate for small  
units.  
\*\*\*\*\*

The air stripper shall be provided with a platform at the top of the column, and an access ladder. A platform shall provide access to each

access port. Catwalks, ladders, cages, and guardrails shall be provided where indicated or required for safe operation and maintenance of equipment and in accordance with Sections 7.4 and 7.5 of AWWA D100 or Sections 5.4 and 5.5 of AWWA D103. Provision shall be made for the attachment of a scaffold cable support at the top of the roof on welded tanks. Ladders shall have side rails and have non-slip rungs that are a minimum of 20 mm 3/4 inches in diameter and 406 mm 16 inches long. The access ladder shall start at [ground level] [2.5 m 8 feet] above the ground. The distance between rungs shall not exceed 305 mm 12 inches. The ladder and platform shall bolt onto brackets that are welded to the columns, or shall be welded directly to the column. Platforms shall be designed to support a uniform live load of 3.6 kPa 75 psf plus the dead load of the structure. The platform shall be a minimum of 915 mm 3 feet wide and fabricated from steel, aluminum, or fiberglass reinforced plastic. Grating openings shall have no dimension greater than 25 mm 1 inch.

### PART 3 EXECUTION

\*\*\*\*\*  
NOTE: Coordinate with paragraph System Design Requirements.  
\*\*\*\*\*

#### 3.1 FOUNDATIONS

\*\*\*\*\*  
NOTE: The footprint and the piping connections for the air stripper on the floor plan, and height required may vary considerably depending on the type of air stripper. The designer should allow enough space for any of the three types of air stripper that the Contractor can select.  
\*\*\*\*\*

Reinforced concrete foundation for air stripper system equipment shall be designed to support the stripper full of water and shall be in accordance with Sections 03 31 00.00 10 CAST-IN-PLACE STRUCTURAL CONCRETE and 03 20 01.00 10 CONCRETE REINFORCEMENT. Foundations for stripper shall be designed in accordance with Section 12 of AWWA D100 or Sections 11 and 8.5 of AWWA D103 for earth, with the bearing value stated in the design requirements. An AWWA D100 Type 1 or an AWWA D103 Type 1 or Type 2 foundation shall be provided for the stripper. Factor of safety on overturning under design wind load shall be 1.5 minimum. When a footing is required, an inverted truncated pyramid of earth with 2 on 1 side slopes above top of footing may be used in determining overturning stability. The elevation at the top of the foundations shall be not less than 200 mm 8 inches above the finished grade.

#### 3.2 ANCHORS

##### 3.2.1 Number of Anchors

An adequate number of anchors designed to prevent overturning of the [stripper] [shell] when empty shall be installed. If anchor bolts are used, the nominal diameter shall be not less than 25 mm, 1 inch, plus a corrosion allowance of at least 6 mm 1/4 inch on the diameter. If anchor straps are used, they shall be pre-tensioned before welding to the shell.

### 3.2.2 Anchor Bolts and Straps

Bolts shall be a right angle bend, hook, or plate washer, while anchor straps shall have only a plate welded to the bottom. The anchors shall be inserted into the foundation to resist the computed uplift.

### 3.2.3 Attachment

Attachment of anchors to the shell shall not add localized stresses to the shell in excess of the material tolerance. The method of attachment shall consider the effects of deflection and rotation of the shell. Anchors shall not be attached to the shell bottom. Attachment of the anchor bolts to the shell shall be through stiffened chair-type assemblies or anchor rings of adequate size and height.

### 3.2.4 Seismic Requirements

Anchors shall be in accordance with UFC 3-310-04 and Section 13 48 00 SEISMIC PROTECTION FOR MISCELLANEOUS EQUIPMENT.

## 3.3 EXCAVATING, FILLING, AND GRADING

Excavating, filling, and grading shall conform to the applicable requirements of Section 31 00 00 EARTHWORK.

## 3.4 EQUIPMENT INSTALLATION

Equipment shall be installed as shown and in accordance with the written instructions of the manufacturer, under the direct supervision of the manufacturer's representative, and in accordance with the applicable provisions of Section 10 of AWWA D100 or Section 8 of AWWA D103 or Section 7 of AWWA D120.

## 3.5 PAINTING FOR CORROSION PREVENTION

\*\*\*\*\*  
NOTE: Some state and local health agencies have listings of acceptable paint materials for the interior of potable water tanks; they will also apply to the interior of the air stripper. The designer must contact the appropriate state and local authorities to determine if the proposed paint systems are acceptable. If these systems are not acceptable, the designer must determine the best acceptable system and revise this specification accordingly. Any deviation from this specification and AWWA Standards must be submitted with justification to CEMP-RT for approval.  
\*\*\*\*\*

### 3.5.1 Welded Tanks

#### 3.5.1.1 Exterior Surfaces

The paint system applied to the outside of the tank air stripper shall be in accordance with Section 09 90 00 PAINTS AND COATINGS. Factory primed surfaces shall be solvent-cleaned before painting. Surfaces that have not been factory primed shall be prepared and primed in accordance with the paint manufacturer's recommendations.



#### 3.5.1.2 Interior Surfaces

Tank interior surfaces shall be coated in accordance with Sections 3.2, 3.3, 3.4, 3.5, 3.6 or 3.7 of AWWA D102.

#### 3.5.2 Touch-up Painting

Factory painted items shall be touched up as needed. These items shall be cleaned of all foreign material and shall be primed and top coated with the manufacturer's standard factory finish.

#### 3.5.3 Field Painting

Equipment which did not receive a factory finish shall be painted as specified in Section 09 90 00 PAINTS AND COATINGS.

#### 3.5.4 Corrosion Resistant Metals

Painting of corrosion resistant materials such as copper, brass, bronze, copper-nickel, and stainless steel shall not be performed unless otherwise specified.

### 3.6 MANUFACTURER'S FIELD SERVICE

Prior to startup, the equipment shall be inspected for alignment and connections by a factory representative. The manufacturer's representative shall inspect the final installation and supervise the adjustment and testing of the equipment.

### 3.7 TESTS

\*\*\*\*\*  
NOTE: Avoid further mention of sampling or  
analytical methods in this section. Always refer to  
the chemistry section to avoid conflicts.  
\*\*\*\*\*

#### 3.7.1 Hydrostatic Tests

Each unit shall be hydrostatically tested by completely filling the shell with water and inspecting for leaks. Leaks shall be repaired and the column retested. Equipment shall be checked for leaks after it has been filled for at least one hour. Shell inspections and testing shall be in accordance with Section 11 of AWWA D100 or Section 9 of AWWA D103. [Mill and shop inspections shall be performed by an approved commercial inspection agency.] [Radiographic inspections of the welded shell shall be performed by the Contractor.] The Contractor shall perform the hydrostatic test and the vacuum box leak test of the tank bottom, Final leak test and hydrostatic test shall be performed before painting.

#### 3.7.2 Performance Testing

Each unit shall be operated at the maximum flow specified in the performance requirements for at least one hour prior to sampling.

#### 3.7.3 Influent and Effluent Sampling

The Contractor shall collect samples in the presence of the Contracting

Officer and transport the samples to the laboratory for analysis in accordance with Section 01 35 45.00 10 CHEMICAL DATA QUALITY CONTROL.

#### 3.7.4 Influent and Effluent Analyses

All equipment shall be inspected and tested under operating conditions after installation. The unit must be demonstrated to run without operator intervention for 72 contiguous hours. If inspection or test shows defects, such defects shall be corrected, and inspection and test shall be repeated. Performance shall be tested in accordance with [Section 01 35 45.00 10 CHEMICAL DATA QUALITY CONTROL] [\_\_\_\_\_].

#### 3.7.5 Discharge

\*\*\*\*\*  
NOTE: A holding/mixing tank requirement can be  
deleted if an NPDES or sewer discharge permit has  
been secured.  
\*\*\*\*\*

During the performance testing, the effluent from the air stripper system shall be contained within the holding/mixing tank with no flow discharged to the [system] [stream] [sewer].

#### 3.7.6 Noncompliance

Removals shall meet or exceed the specified system performance requirements. If at any time the result of the organic analyses of the influent and effluent water indicate that the air stripping system is not in compliance with Contract Documents, flow through the air stripper shall be stopped and the system shall be declared inoperable. If at any time the operation of the air stripping system does not meet the hydraulic, instrumentation, or control requirements set forth in this contract, flow through the air stripping system shall be stopped and the system shall be declared inoperable. The Contractor, upon notification of the air stripping system non-compliance, shall immediately proceed to repair or modify the system to meet compliance. Repairs or modifications shall be made entirely at the Contractor's expense. The Contractor shall notify the Contracting Officer one day before the air stripping system is to be restarted and retested.

#### 3.8 STARTUP

\*\*\*\*\*  
NOTE: Modify this paragraph for Contractor  
operation.  
\*\*\*\*\*

After completion of all testing, the manufacturer's representative shall assist the plant operators in plant startup.

#### 3.9 ADJUSTING, CLEANING, AND DISINFECTING

Adjustments within the control range shall be made to obtain optimum performance under actual field conditions. For potable water systems, cleaning [is] [and disinfection in accordance with AWWA C653 are] required prior to placing the unit in service.

### 3.10 DEMONSTRATION

The manufacturer's representative shall demonstrate that the system meets the performance requirements.

### 3.11 FIELD TRAINING

The Contractor shall conduct a training course of operating staff as designated by the Contracting Officer. The training period, for a total of [24] [36] [\_\_\_\_\_] hours of normal working time, shall start after the system is functionally complete but prior to final acceptance tests. The field instructions shall cover the topics included in the Operating and Maintenance Manuals.

### 3.12 MAINTENANCE

\*\*\*\*\*  
**NOTE: Select the option that is compatible with the**  
**Bid Schedule.**  
\*\*\*\*\*

The Contractor shall manage, operate, maintain, and monitor the off-gas control system [until contract close out] [for at least [one year] [\_\_\_\_\_] after construction, startup and performance testing are complete]. At a minimum, an operator shall be on site [eight] [\_\_\_\_\_] hours per week to operate, maintain, and calibrate the equipment and instruments, and to collect samples for analyses. A qualified person shall be on call to respond to emergencies and alarm conditions at the off-gas system within two hours of alarm conditions. Compliance and monitoring records and reports shall be prepared and maintained for the Contracting Officer and regulatory agencies. The operator shall maintain a log of the actions taken.

-- End of Section --