
USACE / NAVFAC / AFCEA / NASA UFGS-42 23 13 (August 2008)

Preparing Activity: NASA Superseding
UFGS-42 23 13.00 40 (July 2007)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2009

SECTION TABLE OF CONTENTS

DIVISION 42 - PROCESS HEATING, COOLING, AND DRYING EQUIPMENT

SECTION 42 23 13

PROCESSED CONDENSERS

08/08

PART 1 GENERAL

- 1.1 REFERENCES
- 1.2 GENERAL REQUIREMENTS
- 1.3 SUBMITTALS

PART 2 PRODUCTS

- 2.1 AIR-COOLED CONDENSER PACKAGE
- 2.2 FANS AND DRIVES
- 2.3 MOTORS
- 2.4 REFRIGERANT-CONTAINING COMPONENTS
- 2.5 CONDENSING PRESSURE CONTROL
- 2.6 CASING
- 2.7 CONTROL PANEL
- 2.8 VIBRATION ISOLATION

PART 3 EXECUTION

- 3.1 INSTALLATION
- 3.2 OPERATION AND MAINTENANCE

-- End of Section Table of Contents --

USACE / NAVFAC / AFCESA / NASA UFGS-42 23 13 (August 2008)

Preparing Activity: NASA Superseding
UFGS-42 23 13.00 40 (July 2007)

UNIFIED FACILITIES GUIDE SPECIFICATIONS

References are in agreement with UMRL dated July 2009

SECTION 42 23 13

PROCESSED CONDENSERS

08/08

NOTE: This specification covers the requirements
for remote air-cooled condensers for processes.

Include in drawings or schedule total heat rejection
capacity, capacity conditions, coil circuits, and
control diagrams.

Edit this guide specification for project specific
requirements by adding, deleting, or revising text.
For bracketed items, choose applicable items(s) or
insert appropriate information.

Remove information and requirements not required in
respective project, whether or not brackets are
present.

Comments and suggestions on this guide specification
are welcome and should be directed to the technical
proponent of the specification. A listing of
technical proponents, including their organization
designation and telephone number, is on the Internet.

Recommended changes to a UFGS should be submitted as
a Criteria Change Request (CCR).

PART 1 GENERAL

1.1 REFERENCES

NOTE: This paragraph is used to list the
publications cited in the text of the guide
specification. The publications are referred to in
the text by basic designation only and listed in
this paragraph by organization, designation, date,
and title.

Use the Reference Wizard's Check Reference feature
when you add a RID outside of the Section's
Reference Article to automatically place the

reference in the Reference Article. Also use the Reference Wizard's Check Reference feature to update the issue dates.

References not used in the text will automatically be deleted from this section of the project specification when you choose to reconcile references in the publish print process.

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AIR-CONDITIONING, HEATING AND REFRIGERATION INSTITUTE (AHRI)

AHRI 460 (2005) Performance Rating of Remote Mechanical-Draft Air-Cooled Refrigerant Condensers

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS (ASHRAE)

ASHRAE 15 & 34 (2007; Std 15 Errata 2007, 2009, & Addenda a-e; Std 34 Errata 2007, 2008, Addenda a-y, aa-ae) ANSI/ASHRAE Standard 15-Safety Standard for Refrigeration Systems and ANSI/ASHRAE Standard 34-Designation and Safety Classification of Refrigerants

ASHRAE 23 (2005) Methods of Testing for Rating Positive Displacement Refrigerant Compressors and Condensing Units

ASHRAE EQUIP IP HDBK (2004) Handbook, HVAC Systems and Equipment (IP Edition)

ASHRAE EQUIP SI HDBK (2004) Handbook, HVAC Systems and Equipment (SI Edition)

ASTM INTERNATIONAL (ASTM)

ASTM A 653/A 653M (2009) Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process

ASTM A 90/A 90M (2009) Standard Test Method for Weight [Mass] of Coating on Iron and Steel Articles with Zinc or Zinc-Alloy Coatings

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION (ISO)

ISO 1940-1 (2003; Corrigendum 2005) Mechanical Vibration - Balance Quality Requirements for Rotors in a Constant (Rigid) State - Part 1: Specification and Verification of Balance Tolerance - International Restrictions

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA 250 (2008) Enclosures for Electrical Equipment
(1000 Volts Maximum)

NEMA MG 1 (2007; Errata 2008) Standard for Motors
and Generators

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 (2008; AMD 1 2008) National Electrical
Code - 2008 Edition

SOCIETY OF AUTOMOTIVE ENGINEERS INTERNATIONAL (SAE)

SAE J636 (1992; R 2001) V-Belts and Pulleys

UNDERWRITERS LABORATORIES (UL)

UL 1995 (2005) Standard for Heating and Cooling
Equipment

UL 207 (2009) Standard for Refrigerant-Containing
Components and Accessories, Nonelectrical

1.2 GENERAL REQUIREMENTS

**NOTE: If Section 23 00 00 AIR SUPPLY, DISTRIBUTION,
AND EXHAUST SYSTEMS is not included in the project
specification, applicable requirements therefrom
should be inserted and the following paragraph
deleted.**

Section 23 00 00 AIR SUPPLY, DISTRIBUTION, AND EXHAUST SYSTEMS applies to
work specified in this section.

Indicate the manufacturer's standard color selections and finishes for
condensers within [Manufacturer's Standard Color Chart](#).

Submit [Record Drawings](#) for air-cooled condenser units and provide current
factual information including deviations from, and amendments to, the
drawings and concealed and visible changes in the work.

Ensure results of Contractors survey of [Existing Conditions](#) include
features of existing structures and facilities within and adjacent to the
jobsite. Commencement of work constitutes acceptance of existing
conditions.

Submit [Material, Equipment, and Fixture Lists](#) or air-cooled condenser units
including manufacturer's style or catalog numbers, specification and
drawing reference numbers, warranty information, and fabrication site
information.

Submit [Control Diagrams](#) for air-cooled condenser units showing the physical
and functional relationship of equipment. Show size, type, and capacity of
the system on electrical diagrams.

Submit **Design Analysis and Calculations** for air-cooled condensers indicating the manufacturer's recommended **wattage horsepower** ratings, rotational speeds, and piston speeds.

Submit **Equipment and Performance Data** for air-cooled condensers indicating use life, system functional flows, safety features, and other features such as electrical system protective device ratings.

Submit **Equipment Foundation Data** including equipment weight and operation loads, location and projection of anchor bolts, and horizontal and vertical clearances for installation, operation, and maintenance. Include dimensions of foundations and relative elevations, and installation requirements such as noise abatement, vibration isolation, and utility services.

1.3 SUBMITTALS

NOTE: Review Submittal Description (SD) definitions in Section **01 33 00 SUBMITTAL PROCEDURES** and edit the following list to reflect only the submittals required for the project. Submittals should be kept to the minimum required for adequate quality control.

A "G" following a submittal item indicates that the submittal requires Government approval. Some submittals are already marked with a "G". Only delete an existing "G" if the submittal item is not complex and can be reviewed through the Contractor's Quality Control system. Only add a "G" if the submittal is sufficiently important or complex in context of the project.

For submittals requiring Government approval on Army projects, a code of up to three characters within the submittal tags may be used following the "G" designation to indicate the approving authority. Codes for Army projects using the Resident Management System (RMS) are: "AE" for Architect-Engineer; "DO" for District Office (Engineering Division or other organization in the District Office); "AO" for Area Office; "RO" for Resident Office; and "PO" for Project Office. Codes following the "G" typically are not used for Navy, Air Force, and NASA projects.

Choose the first bracketed item for Navy, Air Force and NASA projects, or choose the second bracketed item for Army projects.

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are [for Contractor Quality Control approval.][for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section **01 33 00 SUBMITTAL PROCEDURES**:

SD-01 Preconstruction Submittals

Submit [Material, Equipment, and Fixture Lists](#) for air-cooled condenser units in accordance with paragraph entitled, "General Requirements," of this section.

Submit results of [Existing Conditions](#) in accordance with paragraph entitled, "General Requirements," of this section.

SD-02 Shop Drawings

Submit connection diagrams indicating the relations and connections of the following items. Indicate on drawings the general physical layout of all controls, and internal tubing and wiring details.

[Motors](#)
[Control Panel](#)
[Air-Cooled Condenser](#)
[Refrigerant-Containing Components](#)

Submit the following for air-cooled condenser units showing in accordance with the paragraph entitled, "General Requirements," of this section.

[Control Diagrams](#)
[Installation Drawings](#)
[Record Drawings](#)

SD-03 Product Data

Submit [Equipment Foundation Data](#) for the following items in accordance with the paragraph entitled, "General Requirements," of this section.

[Air-Cooled Condenser](#)
[Fans and Drives](#)
[Motors](#)
[Vibration Isolation](#)

Submit [Equipment and Performance Data](#) for air-cooled condensers in accordance with paragraph entitled, "General Requirements," of this section.

Submit manufacturer's catalog data for the following items:

[Air-Cooled Condenser](#)
[Motors](#)
[Control Panel](#)
[Refrigerant-Containing Components](#)
[Fans and Drives](#)
[Condensing Pressure Control](#)
[Casing](#)
[Vibration Isolation](#)
[Spare Parts](#)

SD-04 Samples

Submit [Manufacturer's Standard Color Chart](#) in accordance with

paragraph entitled, "General Requirements," of this section.

SD-05 Design Data

Submit [Design Analysis and Calculations](#) for air-cooled condensers in accordance with paragraph entitled, "General Requirements," of this section.

SD-07 Certificates

Submit [Listing of Product Installation](#) for air-cooled condenser units in accordance with paragraph entitled, "Installation," of this section.

Submit certificates of compliance for following items showing conformance with the referenced standards contained in this section.

[Motors](#)
[Control Panel](#)
[Air-Cooled Condenser](#)
[Refrigerant-Containing Components](#)
[Fans and Drives](#)
[Condensing Pressure Control](#)
[Casing](#)
[Vibration Isolation](#)

SD-10 Operation and Maintenance Data

Submit [Operation and Maintenance Manuals](#) in accordance with paragraph entitled, "Operation and Maintenance," of this section.

PART 2 PRODUCTS

NOTE: Ensure fan and motor balancing conform to ISO Std.1940/1 - (1986) Balance Quality Requirements of Rigid Rotors - Determination of Permissible Residual Unbalance unless otherwise noted. For motor vibration levels conform to NEMA Specification MG-1, Motors and Generators, Part 7 unless otherwise noted.

2.1 [AIR-COOLED CONDENSER](#) PACKAGE

Provide a packaged, self-contained air-cooled condenser assembly that includes fans, motors, drives, refrigerant condensing coils, controls, intercomponent piping and wiring, totally enclosed weatherproof casing, and frame mounting; ready for terminal field connections with fully automatic operation.

Ensure condenser and [spare parts](#) conform to the applicable requirements of [UL 1995](#), [UL 207](#), [ASHRAE 15 & 34](#), [ASHRAE 23](#), [AHRI 460](#).

NOTE: Revise the following paragraphs as required to suit project conditions. A lower ambient temperature suitability will require a more expensive low-ambient control.

Provide a unit suitable for startup and operation in ambient temperatures as low as 7 degrees C 45 degrees F.

2.2 FANS AND DRIVES

NOTE: Select the first paragraph for on-the-roof and other applications where noise is not a factor. Select the second paragraph for on-grade locations adjacent to offices, situations requiring ducting, and generally for low-noise-level areas.

Where noise is a factor, drawings should show limiting speeds, outlet velocities, or noise criteria to suit project conditions.

[Provide propeller type fans, of corrosion-resistant construction, and statically and dynamically balanced to ISO 1940-1-1986, [G6.3] [G2.5] [_____] with vertical discharge and a maximum fan-tip speed of 51 meter per second 10,000 feet per minute.]

[Provide double-width, double-inlet, centrifugal-scroll type fan with forward curved or airfoil section bladed wheels of corrosion-resistant construction and statically and dynamically balanced to ISO 1940-1-1986, [G6.3] [G2.5] [_____]. Fan shaft first-critical speed shall be at 20 percent above fan operating speed.]

NOTE: Select the first paragraph only for propeller fan units smaller than 5 horsepower with ratings less than 3730 watt. If the second paragraph is selected, not less than two belts should be specified for critical operations.

[Provide direct drive.]

[Provide V-belt with corrosion-protected shaft and antifriction type bearings drive that conforms to ASHRAE EQUIP SI HDBK ASHRAE EQUIP IP HDBK, Chapter 41; and rated at not less than 1.5 times the identification plate motor wattage horsepower, SAE J636. Provide bearings [sealed against moisture and dirt, prelubricated, and suitable for not less than 10,000 operating hours without need for relubrication] [of lubricable type with grease supply and relief fittings together with extension tubing for accessibility where necessary][permanently lubricated and sealed]. Completely pack bearing cavity with a grease suitable for the service.]

NOTE: Modify or delete the following two paragraphs as required.

[Equip fan drive with an adjustable sheave sized for installation at its midpoint setting and able to provide 20-percent speed adjustment.

Mount motors on an adjustable base; mount motors with ratings larger than

7460 watt larger than 10 horsepower on a pivoted motor base.]

Provide weather-protected drive. Guard drive and fan discharge and inlet in accordance with the recommendations of the Occupational Safety and Health Act (OSHA). Provide fan guard that are hot-dip galvanized after fabrication and suitable for salt-air atmosphere; electrogalvanizing is not acceptable.

2.3 MOTORS

Conform to NEMA MG 1 for motors and be totally enclosed type.

NOTE: Retain the following paragraph for direct
drive units.

[Resiliently mount motors.]

2.4 REFRIGERANT-CONTAINING COMPONENTS

NOTE: Modify the following paragraphs as required
to suit project. Check subcooling requirements for
project.

Design and size condensing coils specifically for air-cooled condenser service. Construct with seamless copper tubing, with copper extended surface integral with or mechanically attached to the tube. Provide a coil frame not less than 2.8 millimeter 12-gage galvanized steel. [Factory test coils, pneumatically under water at not less than 2758 kilopascal 400 pounds per square inch gage.] Provide a purging vent at the highest point of the entering refrigerant header of each coil circuit. Provide coil subcooling when a differential not greater than 7 degrees C below zero degrees C 20 degrees F exists between condensing and ambient temperatures.

Provide condenser coil and receiver with an excess capacity of not less than 20 percent for storage of pumped-down refrigerant.

Condensing coil and remainder of refrigerant circuit shall be cleaned and factory charged with dry nitrogen or refrigerant.

Protect coil from physical damage.

2.5 CONDENSING PRESSURE CONTROL

NOTE: Retain the following paragraph only for
single-phase powered units.

Accomplish condensing pressure control by an electronic solid-state control system that will modulate speed of a motor conforming to requirements specified herein from 0 to 100 percent by fan cycling or by a combination of these methods.

NOTE: Retain one of the following two paragraphs

for single- or three-phase powered units.

[Accomplish condensing pressure control by [condenser-coil flooding system]
[modulation of dampers located in the discharge airstream].]

[Accomplish condensing pressure control by [fan cycling] [modulation of
dampers located in the discharge airstream] [combination of fan cycling and
discharge damper modulation].]

Where condenser is being used as a combination receiver, the pump-down
capacity shall be not less than 80 percent of the available refrigerant
volume.

2.6 CASING

Construct casing of minimum 1.3 millimeter 18-gage mill-galvanized steel
that has been phosphatized, primed, and finished with the manufacturer's
standard enamel. [Specially treat casing for use in a coastal environment.]

NOTE: Specify 2.5 ounces 71 gram of zinc
specifications for "heavy-duty" heavier steel.

Mill galvanized steel shall conform to ASTM A 653/A 653M and shall be
coated with not less than 380 gram 1.25 ounces of zinc per square meter foot
of two-sided surface when tested in accordance with ASTM A 90/A 90M.

Construct casing frame of mill galvanized steel or hot-dip galvanized after
fabrication to equal or exceed mill galvanizing requirements.

Include access doors and coil end enclosure. Control panel may be located
within or external to casing.

2.7 CONTROL PANEL

NOTE: Modify the following paragraphs for remote
location.

Provide condenser-mounted control panel and intercomponent piping and
wiring. For control panels exposed to the weather provide NEMA 250, Type 3
enclosures and NEMA 250, Type 1 enclosures if protected by casing. Conform
to NFPA 70 requirements for electrical work and incorporate UL-listed
components.

NOTE: Modify the following paragraph to suit
project requirements.

Provide control panel with the following factory-mounted controls:
115-volt control power transformer, fan contactors, fan controls for low
ambient operation, and compressor interlock.

2.8 VIBRATION ISOLATION

Ensure vibration isolation provisions conform to requirements specified under Section 23 05 48 VIBRATION AND SEISMIC CONTROLS FOR HVAC PIPING AND EQUIPMENT.

PART 3 EXECUTION

3.1 INSTALLATION

Submit [Listing of Product Installation](#) for air-cooled condenser units showing at least 5 installed units, similar to those proposed for use, that have been in successful service for a minimum period of 5 years. Include purchaser, address of installation, service organization, and date of installation.

Install equipment in accordance with manufacturer's recommendations.

Submit [Installation Drawings](#) for air-cooled condenser units. Indicate on drawings overall physical features, dimensions, ratings, service requirements, weights of equipment, and details of equipment room layout and arrangement.

3.2 OPERATION AND MAINTENANCE

Submit [6] [_____] copies of the [Operation and Maintenance Manuals](#) 30 calendar days prior to testing the air-cooled condenser units. Update and resubmit data for final approval no later than 30 calendar days prior to contract completion.

-- End of Section --